



FAX n° 103465

Tot. PAG. 1

TO: LEMMENS

Att.: Mr. Stephan Lemmens

Ref. Vs. E-mail del 07/07/2004

**RE: EUROPEAN DIRECTIVE 97/23/EC**

As known the European Directive 97/23/EC considers Finned Block Heat Exchangers as a Piping, and therefore the most critical component is the header tube of the Heat Exchanger.

As all Yr. Finned Pack Heat Exchanger have headers of a diameters not greather than DN 32, they cannot be marked EC, beeing sufficient a good quality of construction according to Art 3, Par 3 of the Directive.

We remain at Yr. disposal for anything else you might need,

Ronchi dei Legionari, 07/07/2004

Best Regards  
ROEN EST

