

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

EDMS 02-103-1

Technical specification for 12 kV Non-Motorized Ring Main Unit (GIS / AIS)

Indoor/Outdoor Installation

Issue: Jan -2023 / Rev- 1

- This revision contains option items that must be selected by EDC before bidding.
- EDMS 19-400 for HRC Fuses shall be attached if applicable.
- EDMS 17-400 for MV CTs shall be attached if applicable.
- EDMS 17-401 for MV VTs shall be attached if applicable.
- EDMS 20-305 for Indirect Smart Meters shall be attached if applicable.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

CONTENTS

<u>Clause</u>	<u>Description</u>	<u>Page</u>
1	SCOPE	7
2	REFERENCE	7
3	APPLICABLE STANDARDS	7
4	GENERAL REQUIREMENTS	9
4.1	GENERAL	9
4.2	ENVIRONMENTAL CONDITIONS	9
4.3	GENERAL TECHNICAL DATA	9
4.4	DESIGN CRITERIA (Indoor Use)	10
4.5	SWITCH DISCONNECTOR (LOAD BREAK SWITCH)	11
4.6	SWITCH FUSE DISCONNECTOR	12
4.7	CIRCUIT BREAKER	13
4.8	INSTRUMENTAL TRANSFORMERS/SENSORS	15
4.9	INTERLOCKS	18
4.10	SF6 GAS PRESSURE INDICATOR & REFILLING PROVISION	18
4.11	ENCLOSURE	19
4.12	EARTH FAULT INDICATOR	20
4.13	PROTECTION RELAY FOR [Y1] MODULE	21
4.14	GIS	25
4.15	AIS	26
5	TESTING AND INSPECTION	27
6	TRAINING	28

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

7	AFTER SALE SERVICE	29
8	WARRANTEE	29
9	MARKING	29
10	SUBMITALS	30
11	OPTION LIST	31
12	GURANTEE TABLE	32
13	APPENDIX	39

GLOSSARY:

EEHC: Egyptian Electricity Holding Company.

EDMS: Egyptian Distribution Material Specifications.

MV: Medium Voltage.

RMU: Ring Main Unit.

GIS: Gas Insulated System.

AIS: Air Insulated System.

A.C.: Alternating Current.

D.C.: Direct Current.

IEC: International Electro technical Commission.

NO: Normal Open.

NC: Normal Close.

VDS: Voltage Detecting Systems.

VPIS: Voltage Presence Indicator

EMS: Energy Management System.

DMS: Distribution Management System.

DA: Distribution Automation.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

SA: Substation Automation.

RTU: Remote Terminal Unit.

ADMS: Advanced Distribution Management System.

SCADA: Supervisory Control and Data Acquisition.

C.T.: Current Transformer.

V.T.: Voltage Transformer.

SF6: Sulfur Hexafluoride

IP: Ingress Protection.

IK: Degree of Protection against Mechanical Impact.

C.B.: Circuit Breaker.

L.B.S.: Load Breaker Switch.

H.R.C.: High Rupture Capacity.

...EDC: Electricity Distribution Company.

LSC: Loss of Service Continuity.

IAC: Internal Arc Classification.

AFLR: Access Front Lateral Rear.

LPCT: Low Power Current Transformer

FPI: Fault Passage Indicator.

TCP: Transmission Control Protocol.

O.C.: Over Current.

E.F.: Earth Fault.

S.C.: Short Circuit.

IDMT: Inverse Definite Minimum Time.

DT: Definite Time.

XLPE: Cross-linked polyethylene.

HMI: Human Machine Interface.

RTC: Real time Clock.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

1. SCOPE

This specification specifies the minimum technical requirements for design, supply, engineering, manufacturing, testing, inspection, packing, and performance of non-motorized indoor/outdoor gas-insulated (AIS/GIS) ring main unit (RMU) intended to be used in a 12 kV medium-voltage system. The RMU shall be ready to be motorized and remotely controlled by using integrated automation solution via the SCADA in the future. All required modifications and retrofit must be deployed on the site.

2. REFERENCE

The RMU equipment should comply with IEC listed hereafter. In no way does this specification supersede the relevant codes except when the requirements herein are more stringent. All cases of conflicts should be immediately brought to the tenderer's attention.

3. APPLICABLE STANDARDS

Unless otherwise specified, the RMU should comply with the latest edition of IEC publications:

- | | | |
|------|---------------|---|
| 3.1. | IEC 62271-1 | Common Specification for alternating current switchgear and control gear |
| 3.2. | IEC 62271-200 | AC metal-enclosed switchgear and control gear for rated voltage above 1 kV and up to and including 52 kV. |
| 3.3. | IEC 62271-100 | High-voltage alternating-current circuit breakers |
| 3.4. | IEC 62271-102 | Alternating current disconnectors (isolators) and earthing switch. |
| 3.5. | IEC 62271-103 | Switches for rated voltages above 1 kV up to and including 52 kV |
| 3.6. | IEC 62271-105 | Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV. |
| 3.7. | IEC 62271-213 | High-voltage switchgear and controlgear - Part 213: Voltage detecting and indicating system |
| 3.8. | IEC 61131-5 | Programmable controllers – communication. |

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- | | | |
|--------------|------------------|--|
| 3.9. | IEC 6100-4 | Electromagnetic compatibility measurements and testing. |
| 3.10. | IEC 61508 | Functional safety of electrical/electronic/programmable electronic safety-related system. |
| 3.11. | IEC 60255 | Electrical relays |
| 3.12. | IEC 60694-2.2 | Common specifications for HV switchgear & control gear) |
| 3.13. | IEC 61869-1 | Instrument transformers - General requirements) |
| 3.14. | IEC 61869-2 | Instrument transformers - Additional requirements for CTs) |
| 3.15. | IEC 61869-3 | Instrument transformers - Additional requirements for inductive VTs) |
| 3.16. | IEC 62271-206 | HV switchgear and control gear - Voltage presence indicating systems for rated voltages above 1 kV and up to and including 52 kV. |
| 3.17. | IEC 60947-5-1 | Control switches (low-voltage switching devices for control an auxiliary circuits, including contactor relays). - Part 1: General requirements |
| 3.18. | IEC 60376 | Specification of technical grade sulfur hexafluoride (SF6) for use in electrical equipment. |
| 3.19. | IEC 60529 | Degrees of protection provided by enclosures (1P Code). |
| 3.20. | ISO 2063 | Metallic coatings, protection of iron and steel against corrosion- metal spraying of zinc and aluminum. |
| 3.21. | CENELEC EN 50180 | Bushings above 1 kV up to 52 kV |
| 3.22. | CENELEC EN 50181 | Plug-in type bushings above 1 kV up to 52 kV |
| 3.23. | IEC 60282-1 | High-voltage fuses - Part 1: Current-limiting fuses |
| 3.24. | IEC 60086-2 | Primary batteries - Part 2: Physical and electrical specifications |

In case of any deviation from the listed standard, it should be indicated in the list of deviations list submitted by the tenderer.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

4. General Requirements :

4.1. General

The Ring Main Unit should have different configurations that consisting of a combination of various modules to meet the electricity distribution company requirements. Some of these modules are listed below and not limited to:

- [X] Switch disconnecter with Earthing switch module.
- [Y1] Circuit breaker with Earthing switch module.
- [Y2] Switch-fuse disconnecter with H.R.C fuses with Earthing switch module.
- [M1] Metering tariff Module may have different configurations:
 - It includes the 3 CTs and 3 VTs in the same separate cubicle.
 - It includes the 3 VTs only in a separate cubicle and the 3 CTs included in cubicle [Y].
 - 3 metal enclosed / metal coated plug-in VTs on the main busbar without cubicle and the 3 CTs included in cubicle [Y].
- [M2] Auxiliary supply module consists of Voltage transformer: Single / double pole.in case of no low voltage feeding.

Note: [X], [Y1 or Y2], and [M1 or M2] should be defined according toEDC requirements.
: The SRMU may be extendable (as option according toEDC requirements).

4.2. ENVIRONMENTAL CONDITIONS

The electrical and mechanical properties of the required RMU should be guaranteed under the following environmental conditions:

Ambient temperature	-5°C to +45°C (50°C as option according toEDC)
Average relative humidity	95 % over a period of 24 h and 90 % over a period of one month.
Altitude	Up to 1000 m above sea-level

4.3. GENERAL TECHNICAL DATA

The required RMU should have a safe behavior and meet all requirements given below:

Rated (Maximum operating) voltage	12 kV
Nominal operating (Service) voltage	11 kV
Power frequency R.M.S. withstand voltage (1 min)	28 kV

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

Impulse withstand voltage (1.2/50) μ s peak	75 kV.
Rated frequency	50 Hz.
Color	Light grey (Preferred)
IP Class (Gas Tank)	IP67
Electrolytic Copper purity	$\geq 99.9 \%$
Copper Conductivity	not less than 57 MS/ m

4.4. **DESIGN CRITERIA (Indoor Use)**

- It is not the intent to specify herein complete details of design and construction. The offered equipment shall conform to the relevant standards and be of high quality, sturdy, robust and of good design and workmanship complete in all respects and capable to perform continuous and satisfactory operations in the actual service conditions at site and shall have sufficiently long life in service as per requirements.
- A 12kV RMU for indoor use. And shall be installed inside a building/a kiosk on the ground. It consists of a feeder switch, cable compartment, and base frame.
- Each part of RMU completed with all fittings is capable of withstanding the mechanical stress in case of operation, electromagnetic force in case of short circuit. It will not open or close by gravitation, vibration, and so on.
- The RMU structure of the switchboard should consist of a heavy-duty structural steel framework of substantial sections and dimensions to carry safely the mounted items.
- The RMU structure should be from rolled steel sheets not less than 2 mm thickness before any coating or painting for indoor use or with a mechanical impact class not less than (IK 07) and should certifies by type test.
- The RMU should be of electrostatic powder with thickness of 60:80 microns everywhere.
- For GIS: The switchgear shall be metallic partitioning classification (PM), except for fuse module may be (PI).
- The switchgear loss of service continuity category is LSC2 for [x] and [y] modules.
- The load break switch, as well as earthing switch, should be operated using a handle at the front (one handle must be provided with each switchboard)
- The positions of the load break switch and earthing switch should be indicated by a movable obvious color with suitable clear current mimic position indicator gives the position of the switches and breaker at the front of the switchboard.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

- The incoming / outgoing cables shall enter the switchgear from the bottom; where these cables are XLPE insulated, 12/20KV and having aluminum conductors up to $3 \times 400 \text{ mm}^2$ (or as EDC requirement).
- The RMU should withstand the internal arc test:
 - For GIS: The tank should withstand the internal arc and should relieve arc safely.
 - For AIS: The RMU should withstand the internal arc test (IAC AFL 16 kA for 1 Sec) to verify the effectiveness of the design in protecting persons as option asEDC requirement.
- The gas tank should have a pressure relief.
- A suitable base for RMU shall be provided (as optional according to ...EDC requirements).
- The RMU shall be designed such that the position of the different devices shall be visible to the operator on the front of the switchboard and easy to operate & prevent access to all live parts during operation without the use of the RMU special tools.
- Each module shall have a facility to carry out high voltage tests and current injection tests for the cables terminated on them via T-elbow. Disconnection of cables for testing purposes is not accepted.
- The RMU should have suitable support facilities to be lifted from the top and wooden pallet to be lifted from bottom for safe transport.

4.5. Switch disconnecter (Load break switch)

- Switch disconnecter shall be gas load break switch, 12kV - 630A, manual drive with its spring mechanism, used for the cable feeders.
- Switch disconnecter shall have three positions; 'ON', 'OFF', and 'Earth'. The main switch and earth switch should have two independent manual operating mechanisms to prevent simultaneous closing of the main switch and earth switch.
- The manual switching operation shall be using an operating handle. Switching speed shall be independent of the handle speed.
- The switch disconnecter shall have the retrofitting capability on the site for the operating mechanism and associated equipment.
- Switch disconnecter shall be designed for interrupting the full rated current, interrupting small inductive current for unloaded transformer or capacitive current for cable or overhead lines load breaking, and fault-making.
- The earth switch contacts shall be designed to close into a fault and shall have the same short circuit capacity as the main contacts.
- The operating handle shall be designed to prevent the opening of the switch-disconnector or the earth switch after closing

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

Switch disconnector	Rated Voltage	12 kV
	Rated normal current at 40 C°	630 A
	Short-time withstand current (I_K)	25 kA for 1 second
	Making capacity	62.5 kA
	Mechanical endurance	M1: (1000 operating cycles)
	Electrical endurance	E3, C1
Earth switch	Short-time withstand current	25 kA for 1 S
	Making capacity	62.5 kA
	Mechanical endurance	M0: (1000 operating cycles)
	Electrical endurance	E2

4.6. Switch-Fuse disconnector:

- The LBS shall be gas insulated - load break switch, 12kV - 200A, manual drive with its spring mechanism
- It used for the transformer protection and complete with three high rupture capacity (H.R.C) fuses and the rating of fuse should be according to transformer rating and should be specified byEDC on every tender.
- The high rupture capacity (H.R.C) fuses shall be designed according to the latest revision of EDMS 19-400.
- The LBS shall have a 3-position 'ON', 'OFF', and 'Earth' the main switch, and the earth switch should have two independent manual operating mechanisms to prevent simultaneous closing of the main switch and earth switch.
- The manual switching operation shall be using an operating handle. Switching speed shall

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

be independent of the handle speed.

- The switch fuse disconnecter shall have the retrofitting capability on the site for the operating mechanism and associated equipment.
- The operating handle shall be designed to prevent the opening of the switch-disconnector after closing.
- The fuse holder frames should fit with an automatic opening device that functions even if only a single fuse blows.
- The fuse striker mechanism should trip the switch in case of any failure (The automatic fuse contact shall be designed to open into a fault) and shall have visual and signal indications.
- The switch shall have the capability to open electrically by Buchholz relay via trip coil.

Switch fuse disconnecter	Rated Voltage	12 kV
	Rated normal current at 40 C°	200 A
	Short-time withstand current (I _K)	25 kA for 1 second
	Making capacity	62.5 kA
	Mechanical endurance	M1:(1000 operating cycles)
	Electrical endurance	E3, C1
Earth switch	Short-time withstand current	25 kA for 1 S
	Making capacity	62.5 kA
	Mechanical endurance	M0: (1000 operating cycles)
	Electrical endurance	E2

4.7. Circuit Breaker

- The Circuit breaker shall be of fixed type.
- The interruption medium can be either gas insulated or vacuum.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- The circuit breaker shall have three positions; 'ON', 'OFF', and 'Earth' or The circuit breaker shall have two positions; 'ON', 'OFF', and should be connected with disconnector switch to be able to safe isolation for feeder, and the feeder can be earthed.
- The circuit breaker and earth switch should have two independent manual operating mechanisms to prevent simultaneous closing of the circuit breaker and earth switch.
- The circuit breaker, disconnector, and earth switch should have independent manual operating mechanisms to prevent simultaneous closing of the circuit breaker, disconnector, and earth switch in case of having isolator in the CB compartment.
- The manual switching operation shall be using an operating handle or push buttons. Switching speed shall be independent of the handle speed.
- The opening process of the circuit breaker shall be mechanically by trip button, electrically by protection relay via low power trip coil, and electrically by Buchholz relay via trip coil.
- The circuit breaker shall be ready for opening in the closed position without needing any charging process.
- The circuit breaker shall have the retrofitting capability on the site for the operating mechanism and associated equipment.
- The circuit breakers should be mechanically and electrically trip free and with provision for manual operation.
- The operating handle shall be designed to prevent the opening of the switch-disconnector or the earthing switch after closing.
- The CB shall be tripped if Buchholz relay trip via trip coil in case of oil transformer or temperature high for Dry transformer.

Circuit Breaker	Rated Voltage	12 kV
	Rated normal current at 40 C°	200/400/630 A - As required
	Short-time withstand current (I_K)	25 kA for 1 second
	Short circuit breaking capacity (I_{sc})	25 kA
	Making capacity	62.5 kA
	Mechanical endurance	M1: (2000 operating cycles)

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

	Electrical endurance	E2,S1, C1
	Opening time	Up to 75 ms.
Earth switch	Short-time withstand current	25 kA for 1 S
	Making capacity	62.5 kA
	Mechanical endurance	M0: (1000 operating cycles)
	Electrical endurance	E2

4.8. Instrumental Transformers/Sensors

4.8.1. For metering tariff Module [M1]

- Metering Module may have different configurations:
 - It includes the CTs and VTs in the same cubic.
 - It includes the VTs only and the CTs included in cubic [Y].
 - 3 metal enclosed plug-in VTs on the busbar and the 3 CTs included in cubic [Y] without cubic.
- Three single phase dry type (conventional/ring) current transformers according to EDMS17-400 specification.
- The Current transformer shall comply with IEC 61869.
- The current transformers should be interchangeable from lower ratio to higher ratio from the secondary side of the current transformer only.
- The current transformers ratio should be specified byEDC on every tender.
- The winding of the current transformers should be made of copper.
- Suitable current transformer shall be a part of RMU compartment along with its complete sizing calculations feed from bus-bar or outgoing feeder.
- For ring CT:
 - Highest voltage for equipment Um (R.M.S) 0.72 kV
 - Rated power frequency withstand voltage 3 kV
- Three single phase (conventional/screened) voltage transformers dry type according to EDMS17-401.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- The VT shall comply with IEC 61869.
- The voltage transformer shall be (11000/ $\sqrt{3}$ /110/ $\sqrt{3}$ V/110/3 V) 50 VA, CL0.5 Voltage factor 1.9 for 8 hrs. & 1.2 continuous feed from bus-bar/outgoing feeder.
- Conventional voltage transformers should be protected by suitable H.R.C fuses on the Primary side. No need for fuses in case of using screened VTs without life parts in the compartment.
- VTs shall be protected by suitable MCBs on the secondary side. Suitable protection system shall be provided to protect the voltage transformer against Ferro-resonance phenomena.
- For conventional CTs and VTs, the leakage path should not be less than 2 cm/kV of the nominal operating voltage.
- Separate box of IP 42 for installing smart energy meter and its connections. The meter dimension (L×W×D) is not less than (293×178×95) mm. Door-open signals for both meter box, VT and CT compartment shall be wired to the terminal block inside the meter box. The front door of the meter box shall be transparent.

4.8.2. For auxiliary supply module [M2] in case of no low voltage feeding for supplying EFI

- Single /double pole dry type (conventional/screened) voltage transformers according to EDMS17-401.
- The voltage transformer shall be (11000/ $\sqrt{3}$ /suitable value), voltage factor 1.9 for 8 hrs. & 1.2 continuous feed from bus-bar.
- The secondary voltage and burden of the voltage transformer should be design according to the manufacture solution and the RMU configuration.
- The rated continuous output power shall be design regarding to the consumption with safety factor not less than 20%.
- Conventional voltage transformers should be protected by suitable H.R.C fuses on the Primary side. No need for fuses in case of using screened or double pole VTs without life parts in the compartment.
- VTs shall be protected by suitable MCBs on the secondary side. Suitable protection system shall be provided to protect the voltage transformer against Ferro-resonance phenomena if applicable.
- For conventional CTs and VTs, the leakage path should not be less than 2 cm/kV of the nominal operating voltage.
- In case ofEDC accepting Battery operated EFI, there is no need for [M2] Module.

4.8.3. Current transformer for [Y1] Module

- The three single phase current transformers may be Block type CTs, or Ring core CTs, or Current sensors.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- The Current transformers (Block type or Ring core) shall comply with IEC61869.
- The Current Sensor shall comply with IEC 60044-8.
- The current transformers ratio should be according to rated normal current of each module.
- The winding of the current transformers should be made of copper.
- The current transformer or current sensor used for protection shall provide both measurement and power output for the protection relay.
- The ring core CT used for protection relay shall be class 5P10 for protection with $\pm 1\%$ at rated primary current with suitable ratio (...../1A).
- The block type CT burden should be 15VA class 5P10 for protection relays (for [Y1] module).
- The current sensor/ Ring core CT should be designed to give a thermal protection to the measuring and protection devices during heavy earth faults and should allow for cable fault currents up to 25kA (r.m.s.) and should operate at cable sheath temperature up to 90°C.
- Suitable current sensor shall be a part of RMU compartment along with its complete sizing calculations.
- The current sensors/ Ring core CT should have current injection facility to perform the primary current injection test (preferred).
- The current sensors/ Ring core CT shall has rated and insulation voltages of 0.72 kV/3 kV - 1min.

4.8.4. Capacitive Voltage Indicator

- Voltage Presence Indicator System (VPIS) or voltage detector system (VDS) should be integrated in all functional modules.
 - VPIS/VDS shall receive the signals through the capacitive sensor installed inside the bushings of RMU which detect the cable side voltage.
 - The indicator shall be flush-mountable.
 - VPIS/VDS shall be according to standard IEC 62271- 213.
 - VPIS/VDS shall have a low voltage hot phasing facility. The lamps / LCD shall be powered by bushing-type capacitive dividers.
 - VPIS/VDS shall detect the voltage presence /absence and be fitted with a 3 LEDs or LCD.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

4.9. Interlocks

- Interlocks between different components of the equipment are provided for reasons of protection and for convenience of operation. Interlocks shall not be damaged by attempted incorrect operations of any associated switching device.
- A mechanical indicator should be provided to show the position of the switches to enable locking at each position separately.
- Arrangements for padlocking should be provided for:
 - Each position of the switches enables locking at each position separately.
 - Mechanical pushbuttons for closing or opening the circuit breaker.
- The switch should be provided with the inter-locks specified in IEC62271-200 but not limited to the following:
 - Operation of the 'ON/OFF' mechanism of switch / CB shall be possible only if the earth switch is in the 'Earth OFF' position.
 - Operation of the 'ON / OFF' mechanism of the earth switch shall be possible only if the mechanism of switch / CB is in the 'OFF' position.
 - In case of using disconnector in series with the CB:
 - Operation of the „ON/OFF“ mechanism of disconnector shall be possible only if the earth switch/ CB are in the 'OFF' position.
 - Operation of the „ON / OFF“ mechanism of the earth switch shall be possible only if the mechanism of disconnector is in the „OFF“ position.
 - The cable box cover cannot be opened unless the earth switch is in the “ON” position.
 - LBS or CB cannot be moved “ON” position when the cable box cover is in the open position.
 - Fuse changing or accessing the fuse chamber cannot be done in any position other than the “Earth” position.
- Additional lock for fuse module:
Fuse Switch cannot be moved “ON” position when:
 - The fuse access cover is not properly closed
 - Fuse switch in 'Earth' position.

4.10. Gas pressure Indicator & Refilling provision

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

- Temperature independent gas pressure gauge shall be provided. The safe operating zone shall correspond to a temperature range of -10°C to 50°C .
- A refilling non-return inlet valve if provided shall be easily accessible for field refilling.
- The vendor shall give a guarantee for the tank for maximum leakage rate of gas will be lower than 0.1%/year.
- A SF6 gauge shall be provided for visual indication of SF6 gas pressure inside the switchgear chamber. The SF6 gauge shall be readily visible from the front of the unit without the necessity to remove any covers and be clear marked to indicate the normal gas pressure and low gas pressure on the gauge face.

4.11. Enclosure (Outdoor Use):

- Outdoor RMU shall have a tamperproof and a weatherproof steel enclosure which cover whole body of the RMU and control box.
- The Enclosure should be of electrostatic powder with thickness of 60:80 microns
- The status of the door of the enclosure shall be monitored.
- The enclosure shall provide with lockable doors, door handles, ventilation louvers and lifting hooks.
- The doors of enclosure should be same design of M.V compartment of kiosk.
- The degree of protection shall be IP54.
- All nuts, bolts and washers shall be hot dipped galvanized.
- The enclosure shall have a pocket or provision inside to store the instruction documents and other relevant information.
- The enclosure should be from rolled steel sheets of 2.5 mm thickness before paint at least or with a mechanical impact class not less than IK10 for outdoor use and should support by certificate.
- The roof of enclosure should be galvanized steel, and finished with electrostatic paint.
- The roof of enclosure should have slope (towards the two sides) by degree not less than 6° .
- The enclosure should be hot-dip galvanized (HDG) to provide distinct corrosion protection, and finished with electrostatic paint (as option according toEDC requirements).
- Natural ventilation shall be provided.
- The enclosure door should be provided with suitable gaskets, and should have locks with a master key.
- The enclosure shall be equipped with a base of iron beam with supports to withstand lifting it from the bottom and suitable for the RMU weight. The iron beam shall be painted by two layers one for iron erosion resistant and the 2nd is black.
- Two large galvanized iron bolts (approved closing means) shall be installed, one on the top and the


EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

other on the bottom of the left leaf for easy closing and opening the door.

- The doors shall be equipped with two eye-bolts (iron hasp) as shown in the figure. In addition one eye-bolt to be supported by locks.



- The means for non-closing the external doors during maintenance is by mean of a rectangular section attached to the body of the panel with a screw at one end and with a hole on the other end that is fixed with a stent welded to the outer door when it is opened.

4.12. Earth Fault Indicator:

The Earth fault indicator shall be comprises of the following components:

- Indicating electronic device.
- Current sensing components.

The current sensing components consists of coil and core balance current transformer, the housing of indicating facility with a fluorescent coated red flag, the indicator shall be mounted above the (R.M.U) in an easily visible position and shall be weather proof.

Features:

- The earth fault indicator power supply:
 - External supply {(220/110/64 V + 10%, - 20 % v), 50 c/s.} or battery operated, buffered by integrated lithium battery (10 years life time) as option as per ...EDC requirement.
- The C.T. will be designed to give thermal protection to the indicator during heavy earth fault, and can allow for cable fault currents up to 25 KA (r.m.s.) and can operate satisfactory at cable sheath temperature up to 85 °C.
- Cable connection C.T. with indicating system will be within the loop resistance recommended.
- Earth fault indicator will have a core balance current transformer and an indicating facility with a flag and auxiliary (N.O) contact, with following specifications:
 1. Normally open aux. contacts free rated current 1 A.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

2. The closing of the aux. (N.O) contacts shall satisfy synchronization with the flag drop. i.e., contacts close when E.F current reaches $25 \pm 10\%$ A, and continue closing whether the E.F current in the power cable still flowing with this value and the aux. A.C {220/110/64 V (+10%, -20%)} still present or the E.F current and the aux. A.C voltage are disconnected by the protection relays in the distribution switchboard. in case of battery the reset will be through normal current.

- Earth fault indicator is equipped with a mean for testing its operation.
- The flag turns to red color in case the earth current occurs and increase of the rated pre-set value (e.g. $25 \pm 10\%$ A).
- Operation a red indication will be clearly visible from a distance 2m at least in day light.
- Indicator will automatically reset by the healthy starting transient current.

Specifications:

- Trip current : 25A
- Accuracy : better than $\pm 10\%$
- Flag response time : ≤ 0.1 sec.
- Response time : ≤ 0.1 sec.
- C.T. is suitable for Cable diameter .
- Allowed earth fault (surge current) : 25 KA (r.m.s.)
- Ambient temperature : - 5 to + 45°C.
- IP 40

4.13. Protection Relay for [Y1] module

The protection relay shall be three phases combined non-directional (over current + earth fault & short circuit) digital protective relay and timer in one unit connected to three current transformers/sensors of the protected object and suitable for resistance earthed neutral system, in solidly grounded system the residual over current protection can be used on feeder of any length and fulfilling the following requirements and specifications:

4.13.1. Technical Specification

Protective relay should select based on the following specifications:

- The protection relay is based on a multiprocessor environment.
- The modern technology should be applied in both hardware and software solution.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- The relay must be designed for protection against (O.C. & E.F & S.C & Thermal) includes the following:
 - Reset factors > 95%
 - Operation temp. From -5°C to +55°C
 - Humidity > 90% non-condensation.
 - It should be able to operate without intended delay.
 - Definite and inverse time characteristics according to IEC standards.
 - Two LEDs for ready of protection, and trip indication with suitable reset pushbutton and can be automatically rested.
 - Self-monitoring and blocking for internal faults with alarm contact and led indication.
 - Support a digital screen for current measurements.
 - The three phases overcurrent unit and the earth fault measure the phase current and the neutral current of the protected object.
 - The relay should be flush mounted.
 - Output contacts (Tripping contacts).
 - Rated voltage: related to the auxiliary supply voltage with ripple content (3-4) %.
 - Continuous carrying capacity 2 ADC.
 - Making and carrying current capacity for 0.5 sec > 6 A.
 - Make and carry for 3.0 sec > 4 A
 - Free contacts at least (1 N.O for O.C & 1 N.O for E.F).
- The actuator shall be a low power tripping coil specifically designed to operate with the sensors and the processing unit with minimum energy.
- Three-phase thermal protection.
- The relay must have the inrush current blocking based on the second order harmonic percentage which can be used in all protection stages, without using multiplayer
- Support a digital screen for current measurements, parameter, setting and events.
- All parameters and events can be set or read by P.C or manually by key pad
- Smaller dimensions preferred
- Tender must supply with offer detailed instruction and catalogue
- The relay must include event recorder and should be read by screen or software.
- Continuous self-supervision and diagnosis of electronics and software
- User-selectable password protection for HMI
- Display of primary/secondary current values
- Housing degree of protection IP 54 according to IEC 60529.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- The output contact functions freely configurable for desired operation.
- The relay should have at least two setting tables.
- Not responsive to mechanical shocks.
- Protected against sun, radiation, humidity and dust.
- RMU manufacturer to provide suitable supplying for protective relay:
 - Self-powered: energized by the CT's
- Complied with MV relay standard IEC-60255.
- The protection relay shall be approved form the protection central sector of EEHC.

4.13.2. Non-volatile memory for the following:

- The digital protective relay should be equipped with a nonvolatile memory for preserving important data during auxiliary supply breaks. The memory does not need batteries, and a lifelong service is guaranteed, and following data is stored:
 - Date and Time.
 - Setting values
 - Recorded last five fault data.

4.13.3. The real-time clock

- The relay must be supported by a real-time clock (RTC) which used for time stamping of events. It is also running during auxiliary power breaks. When the supply is RE-established, the relay sets the right time and new events are stamped accordingly.

4.13.4. The relay must include the following protection:

- $I >$ Three-phase low-set over current stage with definite-time and inverse definite minimum time characteristic (IDMT)
- $I >>$ Three-phase high-set over current stage with the instantaneous or definite time characteristic.
- $I_0 >$ low-set non-directional earth –fault stage with definite-time or inverse definite minimum time characteristic (IDMT).
- $I_0 >>$ High-set non-directional earth-fault stage with instantaneous or definite –time characteristic.
- **Setting values and ranges:**
 - Current stages (over current)
 - Low set over current $I >$ (0.1 – 2.5) In with steps < 0.05 In.
 - High set over current $I >>$ (0.2 - 20) In with steps < 0.05 In

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- Operating time ranges (over current)
 - Operate time in DT mode: (0.05 - 3) sec with step < 0.01 sec
- Current stages (earth fault)
 - Low set earth fault $I_{o>}$: (0.1 – 1) In with steps < 0.01 In.
 - High set earth fault $I_{o>>}$: (0.2 - 10) In with steps < 0.01 In.
 - Sensitive earth fault: (0.005 – 0.5) In (as option by a core balance CT)
- Operating time ranges (earth fault)
 - Operate time in DT mode: (0.05 - 3) sec with step < 0.01 sec.
 - Sensitive earth fault: (0 – 3) sec. (as option by a core balance CT)

4.13.5. Standard tests

■ Insulation tests

- Dielectric tests: according to the (IEC 60255/5 & 60225/5 or equivalent) tests voltage 2 KV 50 Hz, 60 sec.
- Impulse voltage test according to the (IEC 60255/5 & 60225/5 or equivalent) Tests voltage 5 kV, unipolar impulses, waveform 1.2/50 μ s.
- Insulation resistance measurements according to the IEC60255/5.

■ High frequency interference withstands:

- According to class III of IEC 60225

■ Over load

- Current circuit temporary ≥ 25 kA primary for 1.0 sec.

■ Mechanical tests

- Vibration test (sinusoidal) according to the IEC 60255.
- Shock and bump test according to the IEC 60255.

4.13.6. Diagnostic and Supervision

- Supervision functions for energizing current input circuit.
- Self-test diagnostic.

4.13.7. Measurement

- Display primary current values (IR-IS-IT-IN).
- Transient disturbance Events.

4.13.8. Associated current transformer

Suitable current transformer for protective relay shall be a part of RMU compartment along with its

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

complete sizing calculations. It shall be for measurement and powering purposes.

4.14. For GIS

4.14.1. General

- Protection degree IP:
L.V mechanism compartment / cable compartment: IP2X/IP2X respectively. It is necessary to close and cover all openings with the panel front well so as not to allow any dust penetration into the panel or the mechanism.
- All load break switches should be accommodated in one tank and may be accommodated every load break switch to be on a separate tank (as option according toEDC requirement).
- The gas pressure indication for the tank should be through two zones, Safe and insufficient area or one stage in case of completely sealed tank.
- The envelope should be permanently sealed and filled with SF₆ gas at suitable pressure.

4.14.2. Terminal bushing/Cable Box

- Terminal bushing in the RMU shall be suitable for cable termination inside cable box suitable for acceptance single/three core AL/CU XLPE insulated cables up to 400/630 mm².
- Each cable box shall have a bottom plate if applicable and a cable clamp. Bottom plate shall be in two halves with cable entry hole of suitable diameter. Cable clamp shall be detachable semi-circular halves suitable to hold the cable inside the cable box without cable glands. Suitable rubber fitted to each cable entry hole.
- Terminal bushings for RMU shall be interface type C with M16 bolted contact for terminating cables with the use of L elbow type or T elbow type.
- Vertical distance from the top of cable clamp to centerline of cable bushings shall be suitable for all type of terminations
- Removing and installing of cable box cover shall be with minimum number of bolts.

4.14.3. Earthing

- Aground bar of not less than 100 mm² copper shall be provided bolts to the frame. It shall be located so as to facilitate earthing of cable sheaths, elbows and earthing devices. It shall be supported with type test.

4.15. For AIS

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- The gas pressure indication for the SF6 (LBS and CB) should be through two stages (Low for alarming– insufficient for operation blocking) or one stage in case of completely sealed tank.
- Heater of 100-watt, 220v AC with a hygrostat and a M.C.B per each module in cable compartement.
- Additional 200 watt, 220v AC heater shall be installed in the bus bar compartment with its associated MCB and hygrostat.
- Protection degree IP3X.
- The creepage distance of the resin insulator should be not less than 2 cm/KV.
- Main Bus Bar:
 - It should be insulated B.B system and made of high grade of electrolytic copper at least 630A for all RMU panel should not be less than 400 mm².
 - The temperature rise should be according to IEC 60271-103.
 - All main bus bars should be insulated by red anti-track heat shrinkable tubes and the connection points should be covered with a suitable insulated cover.
 - The bus-bar compartments should be placed at the upper part of the switchboard and fitted with using dielectric supports.
 - The entire bus and structure should be constructed to withstand the short circuit effects due to the rated short circuit current of 25 kA for 1 Sec at least.
 - The Bus bar connections should be anti- oxide greased.
 - Main B.B should be extendable and securely mechanically bonded to each unit.
- Earth Bus Bar:
 - An earth copper bar at the bottom of the switchboard extending the entire length of each distribution panel should be provided with a cross section area to withstand the rated short circuit current of the system the bus should be extendable and securely mechanically bonded to each unit.
 - Copper earthing bar 125 mm², each earthing switch should be connected to the earthing bar through copper braid of 25mm²

5. Testing and inspection:

5.1. Type Test:

- All equipment shall be successfully type tested at EEHC approved laboratory in accordance to the latest relevant standard for the following:
 - a) High-voltage switches as per IEC 62271-102/103

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

- b) High-voltages switchgear and controlgear as per IEC 62271-200
- c) High-voltage switch fuse as per IEC 62271-105
- d) Circuit breaker as per IEC 62271-100
- e) Degree of protection as per IEC 60529.

Note: see appendix A for the detailed type tests.

5.2. Routine Test:

Routine tests of the RMU should be carried out according to latest relevant IEC standards by the manufacturer; a representative of Distribution Company will attend these tests before acceptance. The.....EDC have the right to add any test during delivery to check the quality of the product.

5.2.1. High-Voltage switches as per IEC62271-102/103

5.2.2. High-Voltage switch fuse as per IEC62271-105

5.2.3. High-Voltages switchgear and controlgear as per IEC62271-200

5.2.4. Circuit breaker as per IEC62271-100

5.2.5. Measurement unit as per IEC81869-2 and 3

Each and frame equipped with protection relay a primary current injection test shall be conducted

...EDC reserves the right to visit the factory during manufacture of any or all items covered by this specification, for inspection of material or witness of tests.

Accordingly, the manufacturer shall give ...EDC testing schedule.

Panel's Type:		Panel's Name
DESCRIPTION OF TESTS: Pass(P) , Fail (F) , Un-completed (U) , Not available (NA)		
A	Electrical and Mechanical characteristics of RMU	Evaluation
1	Visual inspection tests: ▪ All integrated component is compliant with the drawing ▪ No physical damage ▪ Check the nameplates and general labeling form/to. ▪ Checking SF6 indicator. ▪ Inspect MV cable compartment, earth bar, cable support, cable clamp	

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

2	Dielectric test MV and LV	
3	Voltage drops on Earthing circuit and main circuit	
4	- Manual operating tests MV breaker / switch disconnecter and mechanical interlock. - Electrical operating tests for circuit breaker/ switch disconnecter - Circuit breaker contact resistance and timing test.	
5	Interlocks The purpose of the test is to check that it is not possible to operate the functional unit when there is an interlock	
B	Earth Fault Indicator	
	The purpose of the test is to check the functions of the EFI are matching of the requirements	
C	Protection Relay	
	The purpose of the test is to check the trip of the transformer breaker in case of trip condition: - Phase fault - Earth fault	

6. Training:

....EDC reserves its right to claim a priceless training of its representatives on the vendor's factory, site, and lab.

The training should include and not limited to the following:

1. Installation.
2. Testing & Commissioning.
3. Troubleshooting.
4. Operating and Maintenance

7. After sale Service:

The tenderer should have a licensed service center in Egypt covers all its deliverables.

....EDC reserves its right to claim a free after sale service all over the warranty period guaranteed by the tenderer that covers all its deliverables, after sale services should include and not limited to the following:

1. Technical support.
2. Maintenance.

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

3. Original Spare parts.
4. Submittals.
- All the services, spare parts, materials and accessories will be needed during the after-sale maintenance should be guaranteed by the tenderer immediately and wherever required (Warehouse – Site – Lab.etc.)

8. Warranty

- The supplier guarantees the RMU against all defects arising out of faulty design or workmanship, or of defective material for period of (5) years from date of delivery.
- Warranty period for gas tightness (seal pressure system) shall conform to the relevant IEC and the contractor shall assume full responsibility for no gas leakage during the service life.
- The good quality and manufacturing of the materials should be guaranteed.
- Any parts which on account of poor quality of the materials, manufacturing defects or poor assembly, should be replaced or repaired in the shortest time possible and free of charge.

9. Marking

9.1. The following data should be engraved or laser printed on an aluminum/stainless steel nameplate riveted on the Ring main unit and Enclosure and located in a visible and legible place when the switchboard is installed showing the following information:

- Manufacturer's name
- Type/Model
- Serial Number and year of Manufacturing
- Distribution company name
- order number
- indoor or outdoor application
- Rated voltage and rated insulation level
- Rated frequency
- N1 no. LBS + N2 no. CB/F and the type (GIS/AIS)
- Rated and duration of short-circuits current (KA/sec)
- Making current KA
- degree of protection
- Gross Weight(KG)
- IEC standards

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

➤ IAC type and (KA/time).

9.2. The following data should be cleared per cell (Switch disconnecter, Switch fuse disconnecter/CB) and located in a visible and legible place showing the following information, Entries on the plate should be indelibly marked by etching or engraving:

- Type/Model
- Rated voltage and rated insulation level
- IEC standards
- Rated current (A) and Rated voltage (V).
- Rated and duration of short-circuits current (KA/sec)
- Making current KA
- Electrical and mechanical endurance
- Rated frequency
- Serial Number and year of Manufacturing

10.SUBMITTALS

10.1. Vendor shall provide the following with the quotation:

- Clause by clause compliance with the specification.
- All necessary drawings including the scheme drawing of the RMU, dimensions, single line diagram of (control circuit, tripping circuit, closing circuit, voltage supply circuit, VT and CT connections, Alarms, communication.....etc.)
- Technical catalogues containing the technical data for all offered components of the unit should be submitted.
- Installation and maintenance instructions.
- Copy of type test report.
- A valid approved letter must be submitted from the Egyptian Electricity Holding Company
- A comprehensive list of manufacturer's recommended spare parts. The quantities offered should be adequate for the initial 5 years of operation. Firm price and delivery period shall be quoted for each item andEDC has the right to request the spare part list or not

10.2. Vendor shall provide the following after signing of purchase order:

- Details of manufacturing and testing schedules
- Routine test reports (including tightness test)

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

10.3. Vendor shall provide the following with delivering:

- Operation (user) manual.
- Handles, Master Keys, Locks..... for operation and locking.
- External device to check the phases concordances.
- Testing rods for HIPOT (High Potential) test.
- Testing rods for current injection test.

11.OPTION LIST:

The following table should be filled/attached by ...EDC during tendering.

NO.	Option	Needed	Not Needed
1	Ambient temperature: 50°C		
2	Outdoor RMU		
3	The RMU may be extendable		
4	A suitable base for RMU shall be provided		
5	Internal Arc for AIS		
6	The enclosure should be hot-dip galvanized (HDG)		
7	Sensitive earth fault for protection relay		
8	Every load break switch to be on a separate tank		
9	Power supply of EFI (External supply or Battery operated)		
10	Circuit breaker rated current (200-400-630)A		
11	[X], [Y1 or Y2], and/or [M1 or M2] should be defined according toEDC requirements: NO. of [X...]: , NO. of [Y1...]: NO. of [Y2...]: ,NO. of [M1...]: NO. of [M2...]: H.R.F capacity: ,C.T. Ratio:		

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

12. TECHNICAL DATA SCHEDULE

The guarantee schedules should be submitted and the tenderer should fill in the attached guarantee tables. □....EDC reserves the right to reject any tender not accompanied with clear and complete guarantee tables.

GUARANTEE TABLES

No	Item	Vendor Spcs.
General		
1	Rated (Maximum operating) voltage	KV
2	Nominal operating (Service) voltage	KV
3	Power frequency R.M.S. withstand voltage (1 min)	KV
4	Impulse withstand voltage (1.2/50) μ s peak	KV
5	Rated frequency	HZ
6	Color	
7	Auxiliary voltage	V
8	IP Class (Gas Tank)	
9	Copper purity	%
10	Copper Conductivity	MS/m
Environmental conditions		
1	Ambient temperature	°C
2	Average relative humidity	°C
3	Maximum altitude	m
Design and construction requirements		

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

Indoor RMU		
1	RMU Type	
2	RMU configuration	
3	Thickness of sheet steel/IK protection	mm
4	Thickness of electrostatic paints	 microns
5	Dimensions: Width *Depth *Height	mm*.....mm*.....mm
6	The internal arc: Class: KA: Time: Outlet:	KAsec
7	Load Break Switch:	
8	IEC Standards	
Switch disconnecter		
1	Rated Voltage	KV
2	Rated normal current at 40&45&50 C°	/...../..... A
3	Short-time withstand current	KA
4	Making capacity	KA
5	Mechanical endurance	
6	Electrical endurance	
Earth Switch for Switch disconnecter		
1	Short-time withstand current	KA
2	Making capacity	KA
3	Mechanical endurance	

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

4	Electrical endurance	
Switch fuse disconnecter		
1	Rated Voltage	KV
2	Rated normal current at 40&45&50 C°	/...../..... A
3	Short-time withstand current	KA
4	Making capacity	KA
5	Mechanical endurance	
6	Electrical endurance	
Earth Switch for Switch Fuse disconnecter		
1	Short-time withstand current	KA
2	Making capacity	KA
3	Mechanical endurance	
4	Electrical endurance	
Circuit breaker		
1	Type/Model	/.....
2	Interruption medium	
3	Rated Voltage	KV
4	Rated normal current at 40&45&50 C°	/...../..... A
5	Short-time withstand current	KA
6	Making capacity	KA
7	Mechanical endurance	
8	Electrical endurance	
9	Duty cycle	
10	Opening time	ms
11	Operating mechanism	

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

Earth Switch for Circuit breaker		
1	Short-time withstand current	KA
2	Making capacity	KA
3	Mechanical endurance	
4	Electrical endurance	
CT		
1	Product type	
2	Highest voltage for equipment Um (R.M.S)	KV
3	Rated primary service voltage	KV
4	Rated frequency	HZ
5	Rated primary current	A
6	Rated secondary current	A
7	Current continuous factor	
8	Rated short time "thermal" withstand current (RMS) For 1 sec (KA)	KA
9	Accuracy class	
10	Rated Burden	VA
11	Creepage distance	cm/kV
12	Class of insulation	
VT		
1	Product type	
2	Highest voltage for equipment Um (r.m.s)	KV
3	Rated primary service voltage	KV
4	Rated frequency	HZ

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

5	Rated primary voltage	V
6	Rated secondary voltage	V
7	Voltage factor	
8	Rated impulse withstand voltage for primary windings	KV
9	Short duration withstand (r.m.s) voltage for primary windings (1min)	KV
10	Rated power frequency short duration withstand for secondary winding for 1 minute	KV
11	Accuracy class	
12	Rated Burden	VA
13	Creepage distance	cm/kV
14	Class of insulation	
Current Sensors or Ring core CT		
1	Rated current	A
2	Rated Burden	VA
3	Rated short time "thermal" withstand current (RMS) For 3 sec I_{th}	KA
4	Accuracy class	
5	Accuracy limit factor	
Voltage Presence Indicator System (VPIS)/(VDS)		
1	Product type	
2	IEC standards	
3	It shall have a low voltage hot phasing facility. The lamps / LCD shall be powered by bushing-type capacitive dividers.	Yes/no

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

4	It shall detect the voltage presence /absence and be fitted with a 3 LED/LCD.	Yes/no
Interlocks		
1	Matching all requirements	Yes/no
Enclosure Outdoor Use:		
1	Thickness of sheet steel/IK protection	mm
2	Thickness of electrostatic paints	microns
3	Dimensions: Width *Depth *Height	mm*.....mm*.....mm
4	IP protection	
Earth Fault Indicator (EFI)		
1	Feeding source	
2	IP	
3	Matching all requirements	Yes/no
GIS		
1	Model	
2	IP protection for Cable Box and Mechanism	
3	C.S.A of earthing bar	
4	Interface type of Terminal bushings and size of bolt	
5	Stages No. for the SF6 pressure indication for the tank	
6	Rated short circuit current for 1 Sec	
AIS		
1	Model	
2	IP protection	
3	C.S.A of Bus bar	
4	C.S.A of earthing bar	
5	Creepage distance	cm/kV

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103- 1

Date: 03-01-2023

6	Heater of 100-watt, 220v AC with a hygostat and a M.C.B per each module.	Yes/no
7	Additional 200 watt, 220v AC heater shall be installed in the bus bar compartment with its associated MCB and hygostat.	Yes/no
8	Rated short circuit current for 1 Sec	
Protection Relay for [Y1] module		
1	Maker 's name	
2	Country of manufacture	
3	Type and designation	
4	Standard specification with which relay complies	
5	Relays characteristics	
6	Range of relay setting	I.....(A) / T.....(Sec)
7	Current rating of relay coil	A
8	Voltage rating of relay coil	 V
9	Relay order number	
10	Low power trip coil	Yes / No
11	Standard reconfiguration functionality	
12	The relay should meet the latest revision of IEC publication 60255 standard	Yes / No

We guarantee the data given above for the equipment offered.

Signature:

Date:

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

APPENDIX A

Non-Motorized RMU (AIS / GIS) type tests

1. High-Voltage switches as per IEC62271-103/102 (LBS)

2. Dielectric tests.
3. Temperature-rise tests.
4. Measurement of the resistance circuit.
5. Short-time withstand current and peak withstand current tests.
6. Tightness tests.
7. Making and breaking test.
8. Mechanical test.

2. High-Voltage switch fuse as per IEC62271-105 (fuse-LBS):

1. Dielectric tests
2. Temperature-rise tests.
3. Measurement of the resistance of circuit.
4. Tightness tests.
5. Tests to prove the combination to make and break the specified currents.
6. Mechanical operation test
7. Short-time withstand current and peak withstand current tests.

In case of the switch fuse disconnecter has the same design of switch disconnecter, Type tests no. 5 shall be only applied.

3. Circuit breaker as per IEC62271-100:

1. Dielectric tests
2. Measurement of the resistance of the main circuit
3. Temperature-rise tests
4. Short-time withstand current and peak withstand current tests
5. Mechanical operation test at ambient temperature (class M1)
6. Short-circuit current making and breaking tests
7. Tightness test
8. Electrical endurance tests (only for $U_r \leq 52\text{kV}$). See Note 4.
9. Capacitive current switching tests.

4. High-Voltages switchgear and control gear as per IEC62271-200:

1. Rated Insulation level.
2. Measurement of the resistance of circuits

EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 02-103– 1

Date: 03-01-2023

3. Rated continuous current and measurement of the resistance of circuits
4. Short-time withstand current and peak withstand current tests
5. Making and breaking capacity of the included switching device. See Note 1
6. Mechanical operation of the included switching devices and removable parts. See Note 2
7. IP protection code.
8. IK Protection degree
9. Pressure withstand of gas - filled compartments.
10. Tightness of gas – or liquid- filled compartments. See Note 3
11. Internal Arc Test

Note 1 according to IEC 62271-200:

Switching devices forming part of the main circuit and earthing switches of assemblies shall be tested to verify their rated making and breaking capacities according to the relevant standards and under the proper conditions of installation and use. That is, they shall be tested as normally installed in the assembly with all associated components that may influence the performance, such as connections, supports, provisions for venting. These tests are not necessary if making and breaking tests have been performed on the switching devices installed in assemblies with identical or more onerous conditions.

Note 2 according to IEC 62271-200:

All switching devices not previously tested as mounted in the assembly, shall be operated 50 times C-O, mounted in the assembly. Test conditions and criteria to pass the test are identical to the ones defined on each corresponding switching device standard for mechanical tests.

Note 3 according to IEC 62271-1:

Where possible, the tests should be performed on a complete system. If this is not practical, the test may be performed on parts, components or subassemblies.

Note 4 according to IEC 62271-100:

The electrical endurance capability of circuit-breakers, that are not for auto-reclosing duty, is demonstrated by performing the terminal fault test-duties of 7.107 without intermediate maintenance. Additional tests are not required.