



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 300 - 1

Date: 20-10-2015

EDMS 19-300-1

SPECIFICATION

FOR

LOW VOLTAGE

500 V- H.R.C FUSE LINKS

100 A, 160 A, 250 A, 400 A, 630 A

Issue: oct-2015 / Rev- 1



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 300 - 1

Date: 20-10-2015

CONTENTS

1. SCOPE.....	3
2. RELEVANT STANDARDS.....	3
3. CONSTRUCTION REQUIREMENTS.....	3
4. MARKING.....	4
5. TESTS.....	4
6. SAMPLES.....	4
7. Size / Rated current.....	4
8. GUARABTEE SCHEDULES.....	6



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 300 - 1

Date: 20-10-2015

1- SCOPE

This specification covers the minimum technical requirements for design, engineering, manufacturing, testing L.V. - H.R.C. fuse links with blade contacts for use in the L.V network of ...EDC to protect L.V cables.

2- RELEVANT STANDARDS

IEC 60269-1: Low voltage fuse

IEC 60269-2: Low voltage fuse

IEC 60269-2-1 /2013: Low voltage fuse

3- CONSTRUCTION REQUIREMENTS

- Rated current (IEC 60269-2-1) 100 A , 160 A , 250 A ,400 A, 630 A
- Rated voltage 500 V (AC 50 HZ)
- Rated power dissipation of fuse link IEC 60269-2-1
- Limits of time-current characteristics IEC 60269-1
- Rated breaking capacity (Min.) 50 KA.
- Insulating properties IEC 60269-1
- Cut-off current characteristic IEC 60269-1
- $I^2 t$ characteristics IEC 60269-1 & 60269-2-1
- The main contacts for fuse links shall be electrolytic copper (pure copper 99.9%) heavily silver plated with minimum thickness (4) microns to ensure good contact.
- Each fuse link shall contain an indicating device for signaling.
- The insulation of the fuse link shall carry safely the full rated current permanently and the short circuit current. It shall be of glazed porcelain or glazed steatite.
- The element of each fuse shall not contain any harmful substances such as (as pestos , uria,.....etc).



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 300 - 1

Date: 20-10-2015

- The size and the contact surface area at each contact's face of every fuse link end (2 faces at each end) as indicated in the attached table.

4- MARKING

Each fuse link shall be marked size or reference, rated breaking capacity and Distribution Company badge.

5- TESTS

Tests shall be made in accordance with IEC 60269-1, 60269-2 & 60269-2-1.

6- SAMPLES

Six samples of fuse link shall be supplied with tender (for each size) .

7- Size / Rated current

ملاحظة

- يجب أن يكون الجوانب الفاصل بين جسم المصهر والسطح المعدني من مادة غير قابلة للاشتعال وغير ماصة للرطوبة.

Size / Rated current

oo/ (6, 10 , 16, 20, 25, 32, 40 , 50 , 63, 80, 100 , 125 , 160) A

1 / (80, 100, 125, 160, 200, 250) A

2 / (125, 160, 200, 250, 315, 400) A

3 / (250, 315, 400, 500, 630) A



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 300 - 1

Date: 20-10-2015

	Rated current (A)	Peak current capacity (KA)	Size	Contact surface area mm ²
1	100	≥ 100	00	$150 \times 2 \times 2$
			1	$227 \times 2 \times 2$
2	160	≥ 100	00	$150 \times 2 \times 2$
			1	$227 \times 2 \times 2$
			2	$450 \times 2 \times 2$
3	250	≥ 100	1	$227 \times 2 \times 2$
		≥ 120	2	$450 \times 2 \times 2$
		≥ 120	3	$700 \times 2 \times 2$
4	400	≥ 120	2	$450 \times 2 \times 2$
		≥ 120	3	$700 \times 2 \times 2$
5	630	≥ 120	3	$700 \times 2 \times 2$



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 300 - 1

Date: 20-10-2015

8- GUARANTEE SCHEDULES

Guarantee schedule attached shall be filled and signed.

GUARANTEE SCHEDULE

FOR

FUSES LINKS OF RATED CURRENT

PARTICULARS

1. Maker's name	
2. Standard specifications applied	
3. Rated current	Amp.
4. Rated voltage	Volts
5. Switching voltage limits	Volts
6. Frequency	(HZ)
7. Rated power loss	W
8. Time /Current characteristic attached with the offer	Yes / No
9. Pre-arcing Time /Current characteristic attached with the offer	Yes / No
10. Rated breaking capacity	KA
11. Cut - off characteristics, attached with the offer	Yes / No
12. $I^2 t$ characteristics, attached with the offer	Yes / No



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 300 - 1

Date: 20-10-2015

13. Material and cross-section area of main contacts	mm ²
14. Surface contact area of main contacts with holders at each end	mm ²
15. Material of coating of copper contacts	
16. Material and cross-section of fusing metal	mm ²
17. Material of insulating part	
18. Weight of fuse	Gm
19. Dimensions of fuse / size :	
a) Length	mm
b) Width	mm
c) Height	mm