



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 301 - 1

Date: 20-10-2015

EDMS 19-301-1

SPECIFICATIONS

for

500 v fuse- bases (holders)

100 A, 160 A, 250 A, 400 A, 630 A

Issue: Jul-2019 / Rev- 1



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 301 - 1

Date: 20-10-2015

CONTENTS

1.	SCOPE.....	3
2.	RELEVANT STANDARDS.....	3
3.	CONSTRUCTION REQUIREMENTS.....	3
4.	MARKING.....	4
5.	TESTS.....	4
6.	SAMPLES.....	4
7.	GUARANTEES SCHEDULES	4



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 301 - 1

Date: 20-10-2015

1- SCOPE

This specification covers the minimum technical requirements for design, engineering, manufacturing, testing and packing for L.V. fuse-bases (holders) which are suitable for inserting fuse link with blade contacts of size (00,1,2,3) according to IEC60269 “Network, 400/231 V, 50 HZ, and ambient temperature up to 45°C.

2- RELEVANT STANDARDS

IEC 60269-1: Low voltage fuse

IEC 60269-2: Low voltage fuse

IEC 60269-2-1 /2013: Low voltage fuse

3- CONSTRUCTION REQUIREMENTS

- Rated current (IEC 60269-2-1) 100 A , 160 A , 250 A ,400 A, 630 A
- Rated voltage (A.C.) 500 V. AC 50HZ
- Rated power acceptance of fuse holder IEC 60269-2-1
- Insulating properties IEC 60269-1
- The main contacts for fuse-holders shall be electrolytic copper (pure copper 99.9%) heavily silver plated with thickness not less than (4) microns to ensure good contact .The size , the thickness of contact element and the contact surface area at each contact’s face of every fuse link end (2 faces at each end) , as indicated in the attached table.
- The copper contacts should be fixed by two bolts; each bolt shall be complete with one washer and nut.



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 301 - 1

Date: 20-10-2015

- The insulation of each fuse-base shall be one piece of glazed porcelain or glazed steatite, and shall carry safely the full rated current permanently and the short circuit current recommended for fuse holders of fuse links of rated current 100 A , 160 A , 250 A , 400 A, 630 A min. breaking Capacity 50 KA r.m.s
- With each fuse holder 2 galvanized bolts shall be supplied. Each bolt shall be completed with 2 washers, one spring washer and one nut, all washers and nuts shall be galvanized. The bolts shall be $\frac{3}{8}$ inch or 10 mm.
- The element of each fuse base shall not contain any harmful substances such as (asbestos, uria,.....etc).

4- MARKING

Each fuse-holder shall be marked at least size and rated current or reference and manufacturer's name or trade mark and ...EDC badge.

5- Tests :

Tests shall be made in accordance with IEC 60269-1, 60269-2 & 60269-2-1.

6- SAMPLES :

Six samples of fuse-holders shall be supplied with the tender (for each size).

7- Guarantee schedule :

Guarantee schedule attached shall be duly completed and signed and submitted with the offer.



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 301 - 1

Date: 20-10-2015

Size / Rated current

00/ (6, 10 , 16, 20, 25, 32, 40 , 50 , 63, 80, 100 , 125 , 160) A

1 / (80 , 100 , 125 , 160 , 200 , 250) A

2 / (125 , 160 , 200 , 250 , 315 , 400) A

3 / (250 , 315 , 400 , 500 , 630) A

	Rated current (A)	Peak current capacity (KA)	Size	Thickness of contact element (mm)	Contact surface area mm ²
1	100	≥ 100	00	2	150 × 2 × 2
			1	2	227 × 2 × 2
2	160	≥ 100	00	2	150 × 2 × 2
		≥ 100	1	2	227 × 2 × 2
		≥ 120	2	2.5	450 × 2 × 2
3	250	≥ 100	1	2	227 × 2 × 2
		≥ 120	2	2.5	450 × 2 × 2
		≥ 120	3	3	700 × 2 × 2
4	400	≥ 120	2	2.5	450 × 2 × 2
		≥ 120	3	3	700 × 2 × 2
5	630	≥ 120	3	3	700 × 2 × 2



EEHC DISTRIBUTION MATERIALS SPECIFICATION

EDMS 19- 301 - 1

Date: 20-10-2015

**GUARANTEE SCHEDULE FOR
FUSES-BASE**

PARTICULARS

- 1 - Maker's name
- 2 - Standard specifications applied
- 3 - Rated current amp.
- 4 - Rated voltage volts
- 5 - Frequency..... (HZ)
- 6- Rated breaking capacity KA
- 7 - Material and cross-section area of main contacts (width × thickness) mm x mm
- 8 – Surface contact area of main contacts with fuse link mm²
- 9- Material of coating of copper contacts
- 10- Material of insulating part
- 11- Weight of fuse base..... gm
- 12- Dimensions of fuse base / size :
 - a) Lengthmm
 - b) Widthmm
 - c) Height mm