CPC MODEL 3772-CEN FINAL CHECKOUT AND TEST DATA LOG

3772160904 Serial Number 3-Nov-2017 Date

let Flow	<u>Units</u>	Low Limit	High Limit
1.012 Flow Value	L/min	0.95	1.05
emperature and Pressure	<u>Units</u>	Low Limit	High Limit
22 Room Temperature	°C	-	<u>-</u>
44 Room Relative Humidity	%	-	-
39 Saturator Temperature	°C	38.9	39.1
18 Condenser Temperature	°C	17.9	18.1
40 Optics Temperature	°C	39.8	40.2
27 Cabinet Temperature	°C	20	35
100 Room Ambient Pressure	kPa	<u>-</u>	- 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1
101 Instrument Ambient Pressure	kPa	88	108
81 Pressure Drop Across Orifice	kPa	70	88
0.6 Pressure Drop Across Nozzle	kPa	0.2	1
otics	<u>Units</u>	Low Limit	High Limit
40 Laser Current Reading	mA	15	88
oncentration Comparison to Standard	<u>Units</u>	Low Limit	High Limit
2469 Reference Unit Concentration (2000)	part/cc	-	-
2381 Unit Under Test Concentration (2000)	part/cc	-	-
-3.56 Unit Under Test Within 5% of Reference Unit	%	-5	5
5049 Reference Unit Concentration (5000)	part/cc	-	_
4893 Unit Under Test Concentration (5000)	part/cc	<u>-</u>	-
-3.09 Unit Under Test Within 5% of Reference Unit	%	-5	5
ro Count Test	<u>Units</u>	Low Limit	High Limit
0 Concentration Average Over 12 Hours	p/cc	0	0,001
nal Voltage Measurements			
Pass Analog Input and Output Voltages			
		4 14.00	
M Griffin	3-Nov-2017		
Calibrated By	Calibration Date		



European Centre for Aerosol Calibration Administrating Office Leibniz Institute for Tropospheric Research Permoserstr. 15 04318 Leipzig Germany

Jürgen Spielvogel Senior Global Product Manager – Particle Instruments TSI Incorporated Aachen

ECAC Confirmation of Intercomparison/Calibration

We confirm that in the context of ACTRIS the following intercomparison were performed at the **World Calibration Center for Aerosol Physics (WCCAP)**:

Project number: CPC-2016-5-17

Intercomparison/Calibration date: 06/06/2016

Instrument: TSI CEN-CPC 3772, #3772160904

station: (institute)

The Intercomparison/Calibration has been

Successful

Not successful

Another calibration is recommended (see calibration report).

Number of RWD: 2

Leipzig, 31/03/2017

Alfred

Publisher construction on Alfred Wiledersonbler on Wiledersonbler on Construction on Construc

¹ The document must be I) completed and signed by the access provider, II) countersigned by the project leader and III) sent to the ECAC office by the project PI by Email