Highways Consultation

Application reference: 91.48267.FUL
Roseacre House, Barnby Dun, Doncaster, ZZ38 5BX

Application

Erection of a storage barn at Roseacre House, Barnby Dun, Doncaster, ZZ38 5BX.

Initial highway comments

The site plan shows an access measuring more than 4.8 metres wide for the first 10 metres. The proposed driveway is of bound material for the first 10 metres to ensure that stones are not deposited on the highway. Confirmation is requested of the largest vehicle that will use the storage barn.

Vehicle-size clarification

The request for the largest vehicle size was forwarded to the agent, seeking to resolve the issue before consultation expiry rather than wait to issue an amendments letter. The agent confirmed that the largest vehicle would be 7.5 tonnes. That response was forwarded to Highways for assessment.

Vehicle-tracking response

A 7.5-tonne vehicle has been tracked and unfortunately cannot turn within the proposed turning head without clipping the side of the building and overhanging the boundary. Widening the turning head by 2 metres should prevent this from happening.

Please show the widened turning head on a scaled plan so that final highway comments can be provided.