Yorkshire Water

Developer Services | Sewerage Technical Team

Director of Development and Planning
Doncaster Metropolitan Borough Council
Colonnades House, Duke Street
Doncaster DN1 1ER

Your reference: 94.62735.OUT

74 Market Lane, Bessacarr, Doncaster, ZZ63 7KS

Outline application for the erection of a detached dormer bungalow on approx 0.06ha of land with all matters reserved

Dear Sir/Madam,

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Requested conditions

If planning permission is to be granted, the following conditions should be attached in order to protect the local aquatic environment and Yorkshire Water infrastructure:

1. The site shall be developed with separate systems of drainage for foul and surface water on and off site. The separate systems should extend to the points of discharge to be agreed.

(In the interest of satisfactory and sustainable drainage)

2. There shall be no piped discharge of surface water from the development prior to the completion of surface water drainage works, details of which will have been submitted to and approved by the sewerage undertaker. If discharge to public sewer is proposed, the information shall include, but not be exclusive to:

i) evidence that other means of surface water drainage have been properly considered and why they have been discounted; and

ii) the means of discharging to the public sewer network at a rate not to exceed 3.5 litres per second.

(To ensure that no surface water discharges take place until proper provision has been made for its disposal)

Technical comments

1.) Submitted drawings shows a proposal to connect foul water into the drainage run on adjacent curtilages to the east - this is acceptable.

2.) The developer is proposing to discharge surface water to public sewer however, sustainable development requires appropriate surface water disposal.

a.) Yorkshire Water promote the surface water disposal hierarchy and the developer must provide evidence to demonstrate that surface water disposal via infiltration or watercourse are not reasonably practical before considering disposal to public sewer.

b.) The developer and LPA are strongly advised to seek comments on surface water disposal from other drainage bodies as further restrictions may be imposed.

c.) As the proposal site is currently undeveloped, no positive surface water is known to have previously discharged to the public sewer network. Surface water discharge to the existing public sewer network must only be as a last resort and the developer is required to eliminate other means of surface water disposal.

d.) As a last resort, and upon receipt of satisfactory evidence to confirm the reasons for rejection of other methods of surface water disposal, curtilage surface water may discharge to public surface water sewer at a restricted rate not to exceed 3.5 litres per second.

Yours faithfully,
Town Planning Team