

DELIVERY NOTE

(DUPLICATE FOR TRANSPORTER)

Falcon Acoustics & Passive Fire Solutions Pvt Ltd

Plot No. 60/A,
Kandivali Industrial Estate,
Charkop,
Kandivali (West),
Mumbai - 400067,
Maharashtra, India.
Ph# 022 28699520/ 28672800
GSTIN/UIN: 27AABCF2178C1ZX
State Name: Maharashtra, Code: 27
CIN: U45309MH2008PTC180997
E-Mail: sales@falcontechno.com

Consignee

Oberoi Constructions Limited

Eternia Site
LBS Road Mulund,
Near Johnson & Johnson,
Mulund,
Mumbai- 400080.
Mr. Sumiran Malhotra - 7045544636
GSTIN/UIN : 27AAACO1805E1ZX
State Name : Maharashtra, Code : 27
Buyer (if other than consignee)

Oberoi Constructions Limited

Commerz, 3rd Floor, Int'l Business Park,
Oberoi Garden City, Off. W.E Highway,
Goregaon (E),
Mumbai- 400063.
Ph# 022 66773333
CIN# U45202MH1993PLC074836
GSTIN/UIN : 27AAACO1805E1ZX
State Name : Maharashtra, Code : 27

Delivery Note No.

DC/800/21-22

Dated

12-Jan-2022

Mode/Terms of Payment

50% Against Delivery & 45 on Completion of Work
Other Reference(s)

Supplier's Ref.

Buyer's Order No.

Dated

Despatch Document No.

Despatched through

Destination

Terms of Delivery

Chaudhary Transport (Pick Up)

Transportation Paid

SI No.	Description of Goods	HSN/SAC	Quantity	Rate	per	Disc. %	Amount
1	PRO005 Protecta FR Acrylic-White -310ml	32149090	400 cartg				
2	PRO099 Protecta Pipe Wrap Glass Scrim-SA 50x1.8mm	68151090	75.00 mtrs				
3	Rockwool SALB 64 Kg/M3 x 50mm Thk 1200x600x50mm	68061000	18.00 Boards (10.80 SqrMtr)				
Total							

E & O E

HSN/SAC

Taxable Value

32149090
68151090
68061000

Total

Tax Amount (in words) : NIL



Company's PAN : AABCF2178C

Recd. in Good Condition


for Falcon Acoustics & Passive Fire Solutions Pvt Ltd



This is a Computer Generated Document

Conish
12-01-22

This Is Only For Gate Clearance
Raise MIR in BIM 360.


12/01/22





Falcon Acoustics and Passive Fire
Solutions Pvt Ltd.
Plot No. 60/A
Kandivali Industrial Estate
Charkop
Kandivali (West)
Mumbai-400067

MTC - Certificate of Conformity

Thursday, 24 June 2021

Polyseam Ltd hereby confirms that the products supplied will conform to the agreed specifications.
Certified that the supplies as detailed hereon have been inspected and tested in accordance with the conditions and the requirements of the contract or purchase order and unless otherwise notified conform in all respects to the relevant specification (s), drawing (s) thereto.

Products supplied are listed below.

Sales Order: SO/21335
Sales Invoice: 51/20883
Delivery Note: DN/26260

Our Ref.	Delivery Note	Part No.	Description	Qty	Commodity Code	Line Batch Number	Product Batch Number
SO/21335/001	DN/26260	PRO005-HTP	Protecta FR Acrylic-White-310ml-Cartridge-25-Standard Nozzles HTP	9600	32141010	BN/140866	BN/140168 BN/139406 BN/139928 BN/140744 BN/140751 BN/140759
Packing Information 6 Pallets - 1200 x 1000 x 1100 @ 960kg each							
SO/21335/002	DN/26260	PRO070-HTP	Protecta EX Mortar-20L-Bag-63 HTP	756	38160000	BN/140658	BN/140513 BN/140520 BN/140537 BN/140573 BN/140584 BN/140602
Packing Information 12 Pallets - 1200 x 800 x 1200 @ 960kg each							
SO/21335/003	DN/26260	PRO069	Protecta FR 4 Hour Pipe Wrap-110mm-Bag-25	500	68151090	BN/139855	BN/121770 BN/134569 BN/136457 BN/139854
Packing Information 20 Bags @ 2.3kg each							

Kind Regards,

Laura Nagy
Customer Service
Support

POLYSEAM LTD
15 ST ANDREWS ROAD
HUDDERSFIELD
WEST YORKSHIRE
UNITED KINGDOM
HD1 6SB

Laura Nagy
Customer Service Support

T: +44 (0) 1484 421036
F: +44 (0) 1484 500445
E: post.uk@polyseam.com
www.polyseam.com

Polyseam Ltd.
15 St Andrews Road
Huddersfield
West Yorkshire
HD1 6SB, UK.

Intelligent Chemistry.

Registered in England No: 2839491

with compliments



**ROXUL – ROCKWOOL Insulation India Pvt. Ltd.**

Plot Z/4, Dahej SEZ

Dahej, District Bharuch – 392 130

Phone No.: +91 2641256288

Fax No. +91 26 4222 9981

TEST CERTIFICATE

Date : 20.12.2021

Name of Client	Noble Building Needs LLP	MTC No.	MTC(SNS)- 01147 - 2021
P.O. No.	8694021		
Batch No	48581639		
Material Code	244763		
Description of Material	Safe 'n' Silent Pro 350		
Size (L X W X T)mm	1200 X 600 X 50		

Sl. No.	Description of Test	Standard / Specification	Unit	Specification / Requirement	Result Obtained
A	REQUIREMENTS				
1	Density	EN 1602	kg/m ³	60 ± 15%	61
2	Length	EN 822	mm	-5 +7	1201
3	Width	EN 822	mm	-3 +5	601
4	Thickness	EN 823	mm	-3 +3	51
5	Moisture Content (Ta 2)	IS: 8183 / IS: 3144	%	2 max	0.17
6	Shot Content retained on Sieve - Type test (Ta 2) □ 150 micron □ 300 micron □ 850 micron	ASTM C1335	%	15 max 3 max 1.5 max	8.45 0.65 0.45
7	Alkalinity (Ta-1)	IS: 8183 / IS: 3144	pH	7 to 10	7.59
8	Chloride Content - Type test (Ta-1)	IS: 8183 / IS: 3144	%	0.001 max	0.00080

- Ta-1: Once in a week
- Ta-2: Once in a day's production

Results are based on random tested sample.

For ROXUL – ROCKWOOL Insulation India Pvt. Ltd.



QC Lab

QE-F-19 (Rev No.01 dtd.27.08.2020)