الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.
CR No. 2055011643
س.ت ٢٠٥٥٠١١٦٤٣

UKAS MANAGEMENT SYSTEMS 245 CERTIFIED ISO 9001: 2015

CERTIFICATE OF INSPECTION

Certificate No: UIC/YAN/20174026

Customer	:	**Sudhir Rental Co.**
Address	:	Umluj, Kingdom of Saudi Arabia.
Description	:	**Power Generator**
Make	:	CUMMINS
Model	:	C135D6(S)
Serial No.	:	**1151408862**
ID No	:	**SG – 032 - 150**

This is to certify that the device detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 16-Dec-2023 **Due Date:** 15-Dec-2024

Additional Certification Sticker Number: **110125**

Inspected By:

UIC 10 INSPECTOR

Industrial Inspector

الشركة العالمية لخدمات التفتيش المحدودة ★ UNIVERSAL INSPECTION CO. LTD. ★ QA/QC

Approved By:

QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515
www.ui.com.sa
ص.ب ٢٠٧٢ ، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ٣٤٤ ١٣ ٩٦٦+ / فاكس ٨٨٨١ ٣٤٤ ١٣ ٩٦٦+
هاتف ٠٥١٥ ٣٦٧ ١٣ ٩٦٦+

Certificate No: UIC/ YAN/20174026

Specification:

Frequency	:	*60 Hz*
Set Output	:	*380-480 V*
Rating	:	*150 Kva*
Speed	:	*1800 Rpm*
Mfg Year	:	*2015*
Engine Make	:	*Cummins*

Inspection and Test:

Internal Visual Test : *Satisfactory* - *General Surface* : *Satisfactory*

Compressor Shut-Down : *Satisfactory*

Comments & Recommendations:

The Power Generator was found to be of good working condition and reliable for safe operation.

1. *Inspect the Power Generator regularly for damage before every use.*
2. *Check oil level before operation and moisture at outlet of the Power Generator.*
3. *Check the condition of the nozzles regularly.*
4. *Stop the engine before opening or removing engine covers.*
5. *Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.*
6. *Remember – Safety always comes first!*

Inspected By:

UIC 10 INSPECTOR

Industrial Inspector

الشركة العالمية لخدمات التفتيش المحدودة QA/QC UNIVERSAL INSPECTION CO. LTD.

Approved By:

QA/QC Engineer