

SAH Initial Assessment

Roy Good

10778 Grant Rd, Fairhope, AL 36532

May 15, 2026

12/22 Tasks Completed

10 items need retrofit

Knockout Inspections

9959 Windmill Rd, Fairhope, AL 36532

erica@koinspections.com

12515174558

Roofer Upgrade List

10 items

Items requiring retrofit before FORTIFIED designation

Retrofit work required during re-roof:

- 1 Roof Deck Attachment** Section 4.2
Re-nail deck with 8d ring shank nails at 4" o.c. (12 per 4 ft). Document with 8 photos (4 topside, 4 in attic) per Section 4.2.
- 2 Sealed Roof Deck** Section 4.4
Install sealed roof deck per Section 4.4 using one of 4 approved methods (taped seams, 2-ply, self-adhered, or closed-cell foam).
- 3 Drip Edge** Section 4.5
Install FORTIFIED-compliant drip edge at all eaves and rakes per Section 4.5. Photo each elevation showing nailing pattern.
- 4 Flashing** Section 4.6
Remove and replace ALL existing flashing at: roof perimeters, pitch changes, penetrations, walls, chimneys, valleys, drains per Section 4.6.
- 5 Roof Cover** Sections 4.7 & 4.8
Replace roof cover with FORTIFIED-rated product. Shingles: ASTM D 3161 Class F + ASTM D 7158 Class H. Document slope + cover packaging + starter strip per Sections 4.7-4.8.
- 6 Roof Ventilation** Section 4.9
Replace roof vents with TAS 100(A) compliant products. Photo packaging showing rating per Section 4.9.
- 7 Gable Walls & Vents** Sections 4.9 & 5.5
Install permanent cover hardware (16" o.c. on long sides) for each gable vent. Add bracing per Section 5.5.2 if Silver designation sought.
- 8 Soffits** Section 5.6
Add intermediate bracing per F-S-1 for flexible soffits per Section 5.6. Use corrosion-resistant fasteners if within 3000 ft of saltwater.
- 9 Window & Skylight Protection** Section 5.2
Install impact-rated windows OR impact-rated covers with permanent anchors per Section 5.2. Document with label photos.
- 10 Entry & Garage Doors** Sections 5.3 & 5.4
Install impact-rated entry/garage doors OR impact-rated covers with permanent anchors. Garage doors need design pressure rating per Sections 5.3 & 5.4.

✓ SAH Application Number

What is the SAH ID?

SAH APPLICATION ID	21845
YEAR BUILT	1976
INSPECTOR	John Meeker
PHONE	(251) 709-8979

✓ Site Conditions TB FH 2021-02

Saltwater shoreline distance determines whether corrosion-resistant fasteners are required throughout the project (TB FH 2021-02).

Distance from saltwater shoreline

Within 3000 ft -- corrosion zone

Greater than 3000 ft

Unknown

Wind exposure

Hurricane

High Wind

Inland

✓ Special Eligibility Items TB FH 2022-03 / 2024-01

Roof-mounted PV, HVAC, or elevated decks each require a signed engineer letter. Dry-stack foundation automatically disqualifies the home.

Solar PV system on roof?

Yes -- engineer required

No

Roof-mounted HVAC units?

Yes -- engineer required

No

Elevated rooftop deck?

Yes -- engineer required

No

Dry-stack foundation observed?

Yes -- DISQUALIFIES home

No

✓ Foundation Sections 2.3 & 2.4

Foundations must not be "dry stack" (unrestrained stacked masonry or stone with no foundation). Observation of dry-stack automatically DISQUALIFIES the home.

What is the foundation type?

Slab-on-grade

Pilings

Block

Stem wall

Crawlspace

If block, is mortar present (positive anchorage)?

Yes

No

N/A

Eligibility

Meets Minimum Requirements

Retrofit Required -- Engineer details required

✓ Roof Framing & Rafter Spacing Section 2.5

Min 2x nominal thickness spaced no more than 24" on center for rafters/trusses. Document with at least 3 exposed roof members and tape measure showing spacing.

Framing type

Rafters

Trusses

What is the rafter/truss spacing?

16" on center

24" on center

Greater than 24" -- requires engineering

Eligibility

Meets Minimum Requirements

Retrofit Required -- engineered solution

✓ Roof Deck Thickness Section 4.1

Min 7/16" plywood/OSB OR continuous dimensional lumber boards (gaps less than 1/8") OR T&G decking. 3/8" does not qualify and requires redecking.

What is the deck type?

OSB

Plywood

Tongue and groove

1x planks (boards)

What is the deck thickness?

3/8" -- does not qualify

7/16"

15/32"

1x plank

Eligibility

Meets Minimum Requirements

Retrofit Required -- Redeck

✓ Roof Deck Attachment Section 4.2

When RETROFIT REQUIRED, renail roof decking using 8d ring shank nails no more than 4" on center (12 nails per 4 feet). Document with 4 photos from above deck + 4 photos from attic with tape measure.

Existing fastener type

Staples

Smooth nails

Ring shank

Eligibility

Meets Minimum Requirements

Retrofit Required

✓ Sealed Roof Deck Section 4.4

SRD methods: (1) Taped seams + underlayment, (2) 2-ply underlayment, (3) self-adhered membrane, OR (4) closed-cell spray foam from attic.

Eligibility

Meets Minimum Requirements

Retrofit Required

✓ Drip Edge Section 4.5

When re-roofing, install FORTIFIED-compliant drip edge at all eaves and rakes. Document with 4 photos showing installation and nailing pattern.

Existing drip edge present?

Yes

No

Partial / damaged

Eligibility

Meets Minimum Requirements

Retrofit Required

✓ Flashing Section 4.6

When re-roofing, all existing flashing must be removed and replaced. Flashings required at: perimeters, edges, pitch changes, penetrations, walls, chimneys, expansion joints, valleys, drains.

Eligibility

Meets Minimum Requirements

Retrofit Required

✓ Roof Cover Sections 4.7 & 4.8

Shingles: ASTM D 3161 Class F AND ASTM D 7158 Class H. Metal panels: tested for site-specific design pressures, direct-to-deck. Tile: site-specific test reports required.

Cover type

Asphalt shingle

Metal panel

Metal shingle

Tile

Low slope

Other

Are there multiple roof covers?

Yes

No

Homeowner reported leaks?

Yes

No

Eligibility

Meets Minimum Requirements

Retrofit Required

✓ Roof Ventilation Section 4.9

All roof-mounted vents must be tested to TAS 100(A) for wind-driven rain. Document with 1 photo of packaging per vent type showing manufacturer, model, and TAS 100(A) rating.

Vent type present

Ridge

Off-ridge

Static

Power

Sealed attic

None

Eligibility

Meets Minimum / Sealed

Retrofit Required

✓ Gable Walls & Vents Sections 4.9 & 5.5

Hurricane only: gable vents must have permanent hardware for temporary covers. Gable end wall sheathing + framing/bracing checked at Silver level (Section 5.5).

Gable walls present?

Yes

No

Gables vented?

Yes

No

N/A

Gable bracing visible / adequate?

Yes

No

N/A

Eligibility

Meets Minimum Requirements

Retrofit Required

N/A



Soffits

Section 5.6

Silver designation: flexible (vinyl/aluminum) soffits need intermediate bracing per F-S-1; rigid soffit covers also acceptable. Within 3000 ft saltwater: corrosion-resistant fasteners.

Soffit type

Vinyl / flexible

Aluminum / flexible

Rigid (wood/fiber cement)

None / open eave

Eligibility

Meets Minimum

Retrofit Required

N/A



Chimney

Section 5.7

Silver designation: chimney framing and anchorage to structure must be documented from within attic. 1 exterior photo + 2 attic photos per chimney.

Chimney present?

Yes

No

Eligibility

Meets Minimum

Retrofit Required

N/A

✓ Attached Structures Section 5.8

Load path: roof framing to beam, beam to column top, column base to foundation. All connections must use metal connectors or (2) bolts minimum. Toe-nailed only = DQ for Silver.

Structure type

Porch

Carport

Breezeway

Walkway

None

Eligibility

Meets / Verified

Retrofit Required

N/A

✓ Window & Skylight Protection Section 5.2

Silver designation (Hurricane only): windows + glazed doors + skylights protected with products meeting ASTM E 1886 AND ASTM E 1996 Missile Level D.

Windows / glazed doors protected?

Yes -- Protected

No Protection

Bay windows present?

Yes -- protection required

No

Skylights present?

Yes

No

✓ Entry & Garage Doors Sections 5.3 & 5.4

Silver (Hurricane): entry doors + garage doors require impact rating. Garage door additionally requires design pressure rating. 3 photos per garage door (interior closed, exterior closed, label).

Entry doors impact-rated?

Yes

No

Has impact covers

Garage door present?

None

Non-glazed

Glazed

Eligibility

Meets Minimum

Retrofit Required

N/A

✓ **Roofer Certification** 2025 Standard (new req)

As of Nov 1, 2025, the 2025 FORTIFIED Home Standard requires roofs be installed by IBHS-certified FORTIFIED roofing contractors. Verify cert status before scheduling work.

Selected roofer is FORTIFIED-certified?

Yes

No -- must select certified

TBD

✓ **Notes**

Comments, questions, concerns

Tear off and replace. Cover gable vents (2). Homeowner reported some leaks.