

FSC Safety Manager Parameter Reference Dictionary

for use with the Honeywell FSC System

Release 680

FS09-650

Implementation
FSC Safety Manager

FSC Safety Manager ***Parameter Reference Dictionary***

for use with the Honeywell FSC System

Release 680

FS09-650

10/2011

Copyright, Notices, and Trademarks

© Copyright 2001 – 2007 by Honeywell Sárl.

Revision 09 – October 2011

While this information is presented in good faith and believed to be accurate, Honeywell disclaims the implied warranties of merchantability and fitness for a particular purpose and makes no express warranties except as may be stated in its written agreement with and for its customer.

In no event is Honeywell liable to anyone for any indirect, special or consequential damages. The information and specifications in this document are subject to change without notice.

TotalPlant, TDC 3000 and Universal Control Network are U.S. registered trademarks of Honeywell Inc.

FSC is a trademark of Honeywell Safety Management Systems.

Other brand or product names are trademarks of their respective owners.

Honeywell Process Solutions
1860 W. Rose Garden Lane
Phoenix, AZ 85027 USA

1-800 822-7673


About This Publication

This publication defines the user-visible parameters that exist in the FSC Safety Manager Module used with the Honeywell FSC system Release 680. It also provides a listing of the parameters - and their definitions - which are applicable to various SM point types.

Use this publication as you build data points, and during operation when detailed information about SM parameters is required.

For use in:

- Data Point Configuration
 - This publication provides definitions for each entry that can be made on the *FSC Safety Manager Configuration Forms* in this binder, and in the Parameter Entry Displays at the Universal Station.
- Process Operations
 - This publication provides information about the parameters that appear for the process data points and SM node-specific data points on the displays of Universal Stations that are running with the Operator personality.



REFERENCE – For information on how the parameters are used in SM data points, refer to the *FSC Safety Manager Control Functions* manual in this binder.

The user should be familiar with the FSC Safety Manager system control functions described in the *FSC Safety Manager Control Functions* and the *FSC Safety Manager Implementation Guidelines* before using this publication.

This publication supports TotalPlant Solution (TPS) system network Release 680. TPS is the evolution of TDC 3000^X.

All references in this manual to "FSC Safety Manager" or "FSC Safety Manager Module" pertain only for use with the Honeywell FSC system.

Table of Contents

SECTION 1 – INTRODUCTION.....	1
1.1 Section Overview.....	1
1.2 Parameter Overview.....	2
1.3 Point Type Overview.....	6
1.4 CL Access.....	8
1.5 Parameters Per Point Type	9
SECTION 2 – PARAMETER DEFINITIONS.....	21
2.1 Section Overview.....	21
2.2 \$XXXX—Parameter Definitions	22
2.3 AXXXX—Parameter Definitions	35
2.4 BXXXX—Parameter Definitions	39
2.5 CXXXX—Parameter Definitions	47
2.6 DXXXX—Parameter Definitions	54
2.7 EXXXX—Parameter Definitions	67
2.8 FXXXX—Parameter Definitions.....	71
2.9 GXXXX—Parameter Definitions	77
2.10 HXXXX—Parameter Definitions	78
2.11 IXXXX—Parameter Definitions.....	81
2.12 KXXXX—Parameter Definitions	84
2.13 LXXXX—Parameter Definitions	86
2.14 MXXXX—Parameter Definitions.....	95
2.15 NXXXX—Parameter Definitions	101
2.16 OXXXX—Parameter Definitions	129
2.17 PXXXX—Parameter Definitions	143
2.18 RXXXX—Parameter Definitions	190
2.19 SXXXX—Parameter Definitions	194
2.20 TXXXX—Parameter Definitions.....	209
2.21 UXXXX—Parameter Definitions	210
2.22 WXXXX—Parameter Definitions	212
2.23 YXXXX—Parameter Definitions	213

Figures

Figure 1-1	Parameter Definition Format	2
Figure 2-1	Group and Detail Displays.....	70
Figure 2-2	Digital Input Point Group and Detail Display Examples	84
Figure 2-3	Group and Detail Displays.....	86
Figure 2-4	Group and Detail Displays.....	107
Figure 2-5	Overview Limit	148
Figure 2-6	Group and Detail Displays.....	163

Tables

Table 1-1	Parameter Data Types	3
Table 1-2	Access Level Definitions	4
Table 1-3	Access Lock/Level Relationship.....	4
Table 1-4	Point Names and Related Acronyms	7
Table 1-5	Analog Input Data Point Parameters on the FSC-SMM.....	9
Table 1-6	Analog Input Data Point Parameters on the NIM	9
Table 1-7	Analog Output Data Point Parameters on the FSC-SMM	10
Table 1-8	Analog Output Data Point Parameters on the NIM	10
Table 1-9	Digital Composite Data Point Parameters on the FSC SMM	11
Table 1-10	Digital Composite Data Point Parameters on the NIM.....	12
Table 1-11	Digital Input Data Point Parameters on the FSC-SMM	13
Table 1-12	Digital Input Data Point Parameters on the NIM	13
Table 1-13	The Digital Output Data Point Parameters on the FSC-SMM.....	14
Table 1-14	Digital Output Data Point Parameters on the NIM	14
Table 1-15	Flag Data Point Parameters on the FSC-SMM.....	15
Table 1-16	Flag Data Point Parameters on the NIM	15
Table 1-17	Logic Data Point Parameters on the FSC-SMM	16
Table 1-18	Logic Data Point Parameters on the NIM.....	16
Table 1-19	Node Specific Data Points.....	17
Table 1-20	Numeric Data Point Parameters on the FSC-SMM	18
Table 1-21	Numeric Data Point Parameters on the NIM.....	18
Table 1-22	Timer Data Point Parameters on the FSC-SMM.....	19
Table 1-23	Timer Data Point Parameters on the NIM	19
Table 1-24	UCN Data Points	20
Table 2-1	\$AUXUNIT Definition and Entry Fields	22
Table 2-2	\$REALARM Definition and Entry Fields.....	23
Table 2-3	\$CHKPNT Definition and Entry Fields	24
Table 2-4	\$COMCKPT Definition and Entry Fields	24
Table 2-5	\$OPTOL Definition and Entry Fields	25
Table 2-6	\$PAISLOT(xx) Definition and Entry Fields	26
Table 2-7	\$PAOSLOT(xx) Definition and Entry Fields	26
Table 2-8	\$PDCSLOT(xx) Definition and Entry Fields	27
Table 2-9	\$PDISLOT(xx) Definition and Entry Fields.....	27
Table 2-10	\$PDOSLOT(xx) Definition and Entry Fields	28
Table 2-11	\$PLOGSLT(xx) Definition and Entry Fields.....	28
Table 2-12	\$PTIME(xx) Definition and Entry Fields	29
Table 2-13	\$PTRESID Definition and Entry Fields.....	29
Table 2-14	\$PUANLIN(xx) Definition and Entry Fields.....	30
Table 2-15	\$PUANLOP(xx) Definition and Entry Fields	30
Table 2-16	\$PUDIGCP(xx) Definition and Entry Fields.....	31
Table 2-17	\$PUDIGIN(xx) Definition and Entry Fields	31

Continued on next page

Tables

Table 2-18	\$PUDIGOP(xx) Definition and Entry Fields.....	32
Table 2-19	\$PUFREE(xx) Definition and Entry Fields.....	32
Table 2-20	\$PULOGIC(xx) Definition and Entry Fields.....	33
Table 2-21	\$PUTIME(xx) Definition and Entry Fields.....	33
Table 2-22	\$PVSTREC Definition and Entry Fields	34
Table 2-23	\$RECOVER Definition and Entry Fields	34
Table 2-24	ALENBST Definition and Entry Fields.....	35
Table 2-25	ALMOPT Definition and Entry Fields	36
Table 2-26	ALPRIOR Definition and Entry Fields	37
Table 2-27	ASSOCDSP Definition and Entry Fields	38
Table 2-28	BADCTLFL Definition and Entry Fields.....	39
Table 2-29	BADCTLPR Definition and Entry Fields	40
Table 2-30	BADLPFL Definition and Entry Fields	41
Table 2-31	BADPVFL Definition and Entry Fields.....	41
Table 2-32	BADPVPR Definition and Entry Fields	42
Table 2-33	BADPVTXT Definition and Entry Fields	43
Table 2-34	BOXCLR (DigComp Points) Definition and Entry Fields.....	44
Table 2-35	BOXCLR (DigIn, DigOut, Flag Points) Definition and Entry Fields	45
Table 2-36	BYPASS Definition and Entry Fields.....	46
Table 2-37	CASREQ Definition and Entry Fields	47
Table 2-38	CCSRC Definition and Entry Fields	48
Table 2-39	CHPINOPR Definition and Entry Fields	49
Table 2-40	CMDDISFL Definition and Entry Fields.....	49
Table 2-41	CMDDISPR Definition and Entry Fields.....	50
Table 2-42	CMDFALFL Definition and Entry Fields	51
Table 2-43	COMMAND Definition and Entry Fields	51
Table 2-44	CONTCUT Definition and Entry Fields.....	52
Table 2-45	CRPPXORN Definition and Entry Fields.....	54
Table 2-46	CRUCNORN Definition and Entry Fields	54
Table 2-47	D1 Definition and Entry Fields.....	55
Table 2-48	D2 Definition and Entry Fields.....	55
Table 2-49	D1_0 Definition and Entry Fields.....	56
Table 2-50	D1_1 Definition and Entry Fields.....	57
Table 2-51	D2D1_00 Definition and Entry Fields	58
Table 2-52	D2D1_01 Definition and Entry Fields	59
Table 2-53	D2D1_10 Definition and Entry Fields	60
Table 2-54	D2D1_11 Definition and Entry Fields	61
Table 2-55	DATE Definition and Entry Fields.....	62
Table 2-56	DAY Definition and Entry Fields	62
Table 2-57	DISPTYPE Definition and Entry Fields	63
Table 2-58	DISRC(1–2) Definition and Entry Fields.....	64
Table 2-59	DITYPE Definition and Entry Fields	65
Table 2-60	DLYTIME Definition and Entry Fields.....	65
Table 2-61	DODSTN(1–3) Definition and Entry Fields.....	66
Table 2-62	DOTYPE Definition and Entry Fields	67
Table 2-63	EIPPCODE Definition and Entry Fields.....	68
Table 2-64	EUDESC Definition and Entry Fields	69
Table 2-65	EVTOPT Definition and Entry Fields.....	71
Table 2-66	FBTIME Definition and Entry Fields	72
Table 2-67	FINSTTXT(1–3) Definition and Entry Fields.....	73
Table 2-68	FL Definition and Entry Fields	74
Table 2-69	FLLSBA Definition and Entry Fields.....	75
Table 2-70	FORCE Definition and Entry Fields.....	76

Continued on next page

Tables

Table 2-71	FORCEFL Definition and Entry Fields	77
Table 2-72	GENDESC Definition and Entry Fields	78
Table 2-73	HIGHAL Definition and Entry Fields	79
Table 2-74	HIGHALPR Definition and Entry Fields	80
Table 2-75	HOUR Definition and Entry Fields	81
Table 2-76	I0-2 Definition and Entry Fields	82
Table 2-77	INPTDIR Definition and Entry Fields	83
Table 2-78	INPTDIR Definition and Entry Fields	84
Table 2-79	KEYWORD Definition and Entry Fields	85
Table 2-80	L Definition and Entry Fields	87
Table 2-81	LASTPV Definition and Entry Fields	87
Table 2-82	LIBADOPT Definition and Entry Fields	89
Table 2-83	LISRC(1-12) Definition and Entry Fields	90
Table 2-84	LMNAME Definition and Entry Fields	91
Table 2-85	LMSRC Definition and Entry Fields	91
Table 2-86	LOADSCOP Definition and Entry Fields	93
Table 2-87	LOCALMAN Definition and Entry Fields	94
Table 2-88	LOCUTOFF Definition and Entry Fields	95
Table 2-89	LODSTN(1-12) Definition and Entry Fields	95
Table 2-90	LOENBL(1-12) Definition and Entry Fields	97
Table 2-91	LOGMIX Definition and Entry Fields	97
Table 2-92	LSPPXORN Definition and Entry Fields	98
Table 2-93	LSUCNORN Definition and Entry Fields	98
Table 2-94	MINUTE Definition and Entry Fields	99
Table 2-95	MODATTR Definition and Entry Fields	100
Table 2-96	MODE Definition and Entry Fields	101
Table 2-97	MODEAPPL Definition and Entry Fields	102
Table 2-98	MODEPERM Definition and Entry Fields	102
Table 2-99	MOMSTATE Definition and Entry Fields	103
Table 2-100	MONTH Definition and Entry Fields	103
Table 2-101	MOVPVFL Definition and Entry Fields	104
Table 2-102	MOVPVXT Definition and Entry Fields	104
Table 2-103	NAISLOT Definition and Entry Fields	105
Table 2-104	NAME Definition and Entry Fields	106
Table 2-105	NAOSLOT Definition and Entry Fields	108
Table 2-106	NDCSLOT Definition and Entry Fields	108
Table 2-107	NDISLOT Definition and Entry Fields	109
Table 2-108	NDOSLOT Definition and Entry Fields	109
Table 2-109	NFLAG Definition and Entry Fields	110
Table 2-110	NLOGSLOT Definition and Entry Fields	110
Table 2-111	NMODATTR Definition and Entry Fields	111
Table 2-112	NMODE Definition and Entry Fields	112
Table 2-113	NMODE Definition and Entry Fields	112
Table 2-114	NN(1-1000) Definition and Entry Fields	114
Table 2-115	NNLSBA Definition and Entry Fields	115
Table 2-116	NNUMERIC Definition and Entry Fields	116
Table 2-117	NODEASSN Definition and Entry Fields	117
Table 2-118	NODENUM Definition and Entry Fields	118
Table 2-119	NODENUM Definition and Entry Fields	119
Table 2-120	NODESC Definition and Entry Fields	120
Table 2-121	NODESTAT Definition and Entry Fields	120
Table 2-122	NODESTS Definition and Entry Fields	122
Table 2-123	NODESTS Definition and Entry Fields	123

Continued on next page

Tables

Table 2-124	NODETYP Definition and Entry Fields.....	124
Table 2-125	NODETYP Definition and Entry Fields.....	124
Table 2-126	NODETYP Definition and Entry Fields.....	125
Table 2-127	NODFSTAT Definition and Entry Fields.....	126
Table 2-128	NODINPTS Definition and Entry Fields.....	126
Table 2-129	NODOPTS Definition and Entry Fields.....	127
Table 2-130	NOLINPTS Definition and Entry Fields.....	127
Table 2-131	NOLOGBLK Definition and Entry Fields.....	128
Table 2-132	NOLOPTS Definition and Entry Fields.....	128
Table 2-133	NONECONF Definition and Entry Fields.....	129
Table 2-134	NONE_OP1 to NONE_OP3 Definition and Entry Fields.....	130
Table 2-135	NONETXT Definition and Entry Fields.....	131
Table 2-136	NOSTATES Definition and Entry Fields.....	132
Table 2-137	NTIMER Definition and Entry Fields.....	133
Table 2-138	NTWKNUM Definition and Entry Fields.....	134
Table 2-139	OFFNRMFL Definition and Entry Fields.....	135
Table 2-140	OFFNRMPR Definition and Entry Fields.....	136
Table 2-141	OISRC(1–3) Definition and Entry Fields.....	137
Table 2-142	OP Definition and Entry Fields.....	137
Table 2-143	OP Definition and Entry Fields.....	138
Table 2-144	OP Definition and Entry Fields.....	139
Table 2-145	OPFINAL Definition and Entry Fields.....	140
Table 2-146	OPFINAL Definition and Entry Fields.....	141
Table 2-147	OPFINHI Definition and Entry Fields.....	142
Table 2-148	OPFINLO Definition and Entry Fields.....	143
Table 2-149	OPRATRFL Definition and Entry Fields.....	144
Table 2-150	OPSTTEXT Definition and Entry Fields.....	145
Table 2-151	OPTDIR Definition and Entry Fields.....	146
Table 2-152	OROPT Definition and Entry Fields.....	146
Table 2-153	OVERVAL Definition and Entry Fields.....	148
Table 2-154	OVRDALPR Definition and Entry Fields.....	149
Table 2-155	P0–P2 Definition and Entry Fields.....	150
Table 2-156	PISRC(1–3) Definition and Entry Fields.....	151
Table 2-157	PLCADDR Definition and Entry Fields.....	152
Table 2-158	PMMCMD Definition and Entry Fields.....	153
Table 2-159	PMMCMDTL Definition and Entry Fields.....	154
Table 2-160	PMMOPER Definition and Entry Fields.....	154
Table 2-161	PMMSFST Definition and Entry Fields.....	156
Table 2-162	PMMSTS Definition and Entry Fields.....	157
Table 2-163	PNTFORM Definition and Entry Fields.....	158
Table 2-164	PNTSTATE Definition and Entry Fields.....	159
Table 2-165	PNTTYPE Definition and Entry Fields.....	160
Table 2-166	PRIMMOD Definition and Entry Fields.....	161
Table 2-167	PTDESC Definition and Entry Fields.....	162
Table 2-168	PTEXECST Definition and Entry Fields.....	164
Table 2-169	PTINAL Definition and Entry Fields.....	164
Table 2-170	PV Definition and Entry Fields.....	165
Table 2-171	PV Definition and Entry Fields.....	166
Table 2-172	PV Definition and Entry Fields.....	167
Table 2-173	PV Definition and Entry Fields.....	168
Table 2-174	PV Definition and Entry Fields.....	168
Table 2-175	PV Definition and Entry Fields.....	169
Table 2-176	PVALDB Definition and Entry Fields.....	170

Continued on next page

Tables

Table 2-177	PVALDBEU Definition and Entry Fields	171
Table 2-178	PVAUTO Definition and Entry Fields	171
Table 2-179	PVAUTO Definition and Entry Fields	172
Table 2-180	PVAUTO Definition and Entry Fields	172
Table 2-181	PVAUTOST Definition and Entry Fields.....	173
Table 2-182	PVCALC Definition and Entry Fields	173
Table 2-183	PVCHAR Definition and Entry Fields	174
Table 2-184	PVCHGDLY Definition and Entry Fields	174
Table 2-185	PVCHGTMR Definition and Entry Fields.....	175
Table 2-186	PVCLAMP Definition and Entry Fields	176
Table 2-187	PV clamping	176
Table 2-188	PVEUHI Definition and Entry Fields.....	178
Table 2-189	PVEULO Definition and Entry Fields.....	178
Table 2-190	PVEXEUHI Definition and Entry Fields	179
Table 2-191	PVEXEULO Definition and Entry Fields.....	180
Table 2-192	PVEXHIFL Definition and Entry Fields.....	180
Table 2-193	PVEXLOFL Definition and Entry Fields.....	182
Table 2-194	PVFL Definition and Entry Fields	182
Table 2-195	PVFL Definition and Entry Fields	183
Table 2-196	PVFLTOPT Definition and Entry Fields.....	183
Table 2-197	PVFORMAT Definition and Entry Fields	185
Table 2-198	PVHIFL Definition and Entry Fields.....	186
Table 2-199	PVHIPR Definition and Entry Fields.....	187
Table 2-200	PVHITP Definition and Entry Fields	188
Table 2-201	PVLOFL Definition and Entry Fields	188
Table 2-202	PVLOPR Definition and Entry Fields.....	189
Table 2-203	PVLOTP Definition and Entry Fields	190
Table 2-204	PVNORMAL Definition and Entry Fields	190
Table 2-205	PVNORMFL Definition and Entry Fields	192
Table 2-206	PVP Definition and Entry Fields	192
Table 2-207	PVRAW Definition and Entry Fields	194
Table 2-208	PVRAW Definition and Entry Fields	194
Table 2-209	PVRAWHI Definition and Entry Fields	196
Table 2-210	PVRAWLO Definition and Entry Fields	197
Table 2-211	PVSLTSRC Definition and Entry Fields	198
Table 2-212	PVSOURCE Definition and Entry Fields	199
Table 2-213	PVSRCOPT Definition and Entry Fields	200
Table 2-214	PVSTATES(0–4) Definition and Entry Fields	201
Table 2-215	PVSTS Definition and Entry Fields.....	202
Table 2-216	PVTV Definition and Entry Fields	203
Table 2-217	PVTVP Definition and Entry Fields.....	203
Table 2-218	RCASOPT Definition and Entry Fields.....	204
Table 2-219	REDTAG Definition and Entry Fields	205
Table 2-220	RINITREQ Definition and Entry Fields	206
Table 2-221	RV Definition and Entry Fields	207
Table 2-222	S0BOXCLR Definition and Entry Fields	208
Table 2-223	S1BOXCLR Definition and Entry Fields	209
Table 2-224	S2BOXCLR Definition and Entry Fields.....	210
Table 2-225	SCANRATE Definition and Entry Fields.....	211
Table 2-226	SECOND Definition and Entry Fields.....	211
Table 2-227	SLOTNUM Definition and Entry Fields.....	213
Table 2-228	SMPLTFM Definition and Entry Fields	214
Table 2-229	SO Definition and Entry Fields	214

Continued on next page

Tables

Table 2-230	SO Definition and Entry Fields	215
Table 2-231	SO(i) Definition and Entry Fields	216
Table 2-232	SP Definition and Entry Fields.....	217
Table 2-233	SPSLTSRC Definition and Entry Fields	218
Table 2-234	ST0_OP1–ST0_OP3 Definition and Entry Fields.....	219
Table 2-235	ST1_OP1–ST1_OP3 Definition and Entry Fields.....	219
Table 2-236	ST2_OP1–ST2_OP3 Definition and Entry Fields.....	220
Table 2-237	STATE Definition and Entry Fields.....	220
Table 2-238	STATE(0–2) Definition and Entry Fields	221
Table 2-239	STATETXT(0–1) Definition and Entry Fields	222
Table 2-240	TF Definition and Entry Fields	224
Table 2-241	TIMEBASE Definition and Entry Fields	224
Table 2-242	UCNRECHN Definition and Entry Fields.....	225
Table 2-243	UNCMDFL Definition and Entry Fields.....	225
Table 2-244	UNIT Definition and Entry Fields	226
Table 2-245	WEEKDAY Definition and Entry Fields	227
Table 2-246	YEAR Definition and Entry Fields.....	228

Acronyms

AI	Analog Input
AO.....	Analog Output
AM	Application Module
ASCII	American Standard Code for Information Interchange
BC.....	Bad Control
CL	Control Language
CM	Computing Module
DC.....	Digital Composite
DEB	Data Entity Builder
DI	Digital Input
DO	Digital Output
IEEE.....	Institute of Electrical and Electronics Engineers
LCN.....	Local Control Network
N/A.....	Not Applicable
NaN.....	Not a Number
NIM	Network Interface Module
OP.....	Output Value
PMM	Process Manager Module
PU.....	Processing Unit
PV	Process Variable
RLL	Relay Ladder Logic
RTJ	Real-Time Journal
SM	Safety Manager
SMM	Safety Manager Module
SP	Setpoint
TDC	Total Distributed Control
TPS.....	TotalPlant Solution
UCN	Universal Control Network
US.....	Universal Station

If the acronym or abbreviation you are searching for does not appear in this list, refer to the following parameter listing.

Parameters

\$AUXUNIT	Auxiliary Unit
\$CHKPNT	Checkpoint Record
\$COMCKPT	FSC-SM Node Specific Data Point Checkpoint Record
\$OPTOL	Output Tolerance
\$PAISLOT(xx)	Parameter Analog Input Slot
\$PAOSLOT(xx)	Parameter Analog Output Slot
\$PDCSLOT(xx))	Parameter Digital Composite Slot
\$PDISLOT(xx)	Parameter Digital Input Slot
\$PDOSLOT(xx)	Parameter Digital Output Slot
\$PLOGSLT(xx)	Parameter Logic Slot
\$PTRESID	Point Residency Identifier
\$PTIME(xx)	Parameter Timer
\$PUANLIN(xx)	PUs consumed by Analog Input point
\$PUANLOP(xx)	PUs consumed by Analog Output point
\$PUDIGCP(xx)	PUs consumed by Digital Composite point
\$PUDIGIN(xx)	PUs consumed by Digital Input point
\$PUDIGOP(xx)	PUs consumed by Digital Output point
\$PUFREE(xx)	Free PUs
\$PULOGIC(xx)	PUs consumed by Logic point
\$PUTIME(xx)	PUs consumed by Timer point
\$PVSTREC	PV Value and Status Record
\$RECOVER	Recover All FSC-SMM Alarms
ALENBST	Alarm Enable Status
ALMOPT	Alarm Option
ALPRIOR	Alarm Priority
ASSOCDSP	Associated Display
BADCTLFL	Bad Control Flag
BADCTLPR	Bad OP Control Priority
BADLPFL	Bad Loop Flag
BADPVFL	Bad PV Flag
BADPVPR	Bad PV Alarm Priority
BADPVTXT	Bad PV State Descriptor
BOXCLR	Box Color for Displays
BYPASS	Override Input Bypass Enable
CASREQ	Remote Cascade Request
CCSRC	Contact Cut Out Source
CHPINOPR	Automatic Checkpoint Inhibit Operation
CMDDISFL	Command Disagree Alarm Flag
CMDDISPR	Command Disagree Alarm Priority
CMDFALFL	Command Fail Alarm Flag
COMMAND	Timer Command
CONTCUT	Contact Cut Out
CRPPXORN	Current Hour Point Processing Overrun Counter
CRUNCORN	Current Hour Point Processing Fetch/Store Counter
D1	Digital 1 Input
D2	Digital 2 Input
D1_0	Digital Input 1 Equals a PV State of 0
D1_1	Digital Input 1 Equals a PV State of 1
D2D1_00	Digital Input 2 and Digital Input 1 Both Equal a PV State of 0
D2D1_01	Digital Input 2 Equals a State of 0 and Digital Input 1 Equals a PV State of 1
D2D1_10	Digital Input 2 Equals a State of 1 and Digital Input 1 Equals a PV State of 0
D2D1_11	Digital Input 2 and Digital Input 1 Both Equal a PV State of 1
DATE	FSC-SMM Date

Continued on next page

Parameters

DAY	FSC-SMM Day
DISPTYPE	Display Type
DISRC(1–2)	Digital Composite Input Connection Source
DITYPE	Digital Input Point
DLYTIME	Delay Time
DODSTN(1–3)	Digital Composite Output Connection Source
DOTYPE	Digital Input Point
EIPPCODE	Event Initiated Proceeding Point Identifier
EUDESC	Engineering Units Descriptor
EVTOPT	Event Recording Option
FBTIME	Feedback Time
FINSTTXT(1–3)	Final Output State Descriptor
FL	Box Flag Variables
FLLSBA	Least Significant Source Address
FORCE	Force Enable
FORCEFL	Force Flag
GENDESC	Generic Descriptor
HIGHAL	Highest Alarm Detected
HIGHALPR	Highest Level Alarm's Priority
HOUR	FSC-SMM Hour
I0–2	Override Interlocks for Output States 0, 1, and 2
INPTDIR	Input Direction
KEYWORD	Keyword Descriptor
L	External Output Value
LASTPV	Last PV Value
LIBADOPT	Logic Bad-Input Handling Option
LISRC(1–12)	Logic Input Connection Source
LMNAME	FSC-SMM Redundant Pair Names
LMSRC	Local Manual Source Address
LOADSCOP	Load Scope
LOCALMAN	Local Manual Flag
LOCUTOFF	Low Signal Cut-Off for Flow Inputs
LODSTN(1–12)	Logic Output Connection Destination
LOENBL(1–12)	Logic Output Enable
LOGMIX	Logic Mix
LSPPXORN	Last Hours Point Processing Fetch/Store Overruns
LSUCNORN	Last Hours UCN Access Overruns
MINUTE	FSC-SMM Minute
MODATTR	Mode Attribute
MODE	Mode
MODEAPPL	Mode Applicability
MODEPERM	Mode Permissive
MOMSTATE	Momentary Output States
MONTH	FSC-SMM Month
MOVPVFL	Moving PV Flag
MOVPVTEXT	Moving PV Text Descriptor
NAISLOT	Number of Analog Input Slots
NAME	Tagname
NAOSLOT	Number of Analog Output Slots
NDCSLOT	Number of Digital Composite Slots
NDISLOT	Number of Digital Input Slots
NDOSLOT	Number of Digital Output Slots

Continued on next page

Parameters

NFLAG.....	Number of Flags
NLOGSLOT.....	Number of Logic Slots
NMODATTR.....	Normal Mode Attribute
NMODE.....	Normal Mode
NN(1–1024).....	Numeric Value
NNLSBA.....	Least Significant Alias Address
NNUMERIC.....	Number of Numerics
NODEASSN.....	Node Assignment
NODENUM.....	Node Number
NODESC.....	Number of Generic Descriptors
NODESTAT.....	NIM Node Status
NODESTS.....	NIM Node Summary Status
NODESTS.....	SM Node Summary Status
NODETYP.....	UCN Node Type
NODFSTAT.....	Node's Functional Status
NODINPTS.....	Number of Digital Inputs
NODOPTS.....	Number of Digital Outputs
NOLINPTS.....	Number of Logic Input Points
NOLOGBLK.....	Number of Logic Blocks
NOLOPTS.....	Number of Logic Output Points
NONECONF.....	Add Optional None State
NONE_OP(1–3).....	Value Stored in Output n
NONETXT.....	State Descriptor for the None State
NOSTATES.....	Number of Digital States
NTIMER.....	Number of Timer Slots
NTWKNUM.....	Network Number
OFFNRMFL.....	Off-Normal Alarm Flag
OFFNRMPR.....	Off-Normal Alarm Priority
OISRC(1–3).....	Digital Composite Override Interlock Source
OP.....	Output in Percent (Analog Output Point)
OP.....	Last Digital Output State Requested (Digital Composite Point)
OP.....	Commanded Output State (Digital Output Point)
OPFINAL.....	Percent Output at the Control Element Analog Output Point)
OPFINAL.....	Final Output State Read Back from the FSC-SRS (Digital Composite Point)
OPFINHI.....	Output High Value at Control Element
OPFINLO.....	Output Low Value at Control Element
OPRATRFL.....	Operator Mode Attribute Flag
OPSTTEXT.....	Output State Text
OPTDIR.....	Analog Output Direct/Reverse Action
OROPT.....	Override Option
OVERVAL.....	Overview Value in Percent
OVRDALPR.....	Override Alarm Priority
P(0–2).....	Permissive Interlocks for States 0, 1, and 2
PISRC(1–3).....	Digital Composite Permissive Interlock Source
PLCADDR.....	FSC-SRS Alias Address
PMMCMD.....	FSC-SMM Command
PMMCMDTL.....	FSC-SMM Command Processor Detail Record
PMMOPER.....	FSC-SMM Redundancy Operation
PMMSFST.....	Current FSC-SMM Softfail Status
PMMSTS.....	FSC-SMM Primary Status
PNTFORM.....	Point Form
PNTSTATE.....	Point's Overall State

Continued on next page

Parameters

PNTTYPE	Point Type
PRIMMOD	Primary Module Identifier
PTDESC	Point Descriptor
PTEXECST	Point Execution State
PTINAL	Point in Alarm Indicator
PV	Process Variable Current Value (Analog Input, Numeric and Timer Points)
PV	Process Variable Current State (Digital Composite, Digital Input and Flag)
PVALDB	PV Alarm Dead Band as a Percentage of Full Range
PVALDBEU	PV Alarm Deadband in Engineering Units
PVAUTO	PV Auto Value (Analog Input Points)
PVAUTO	Current PV State (Digital Composite and Digital Input Points)
PVAUTOST	PV Auto Value Status
PVCALC	Calculated PV
PVCHAR	PV Characterization Option
PVCHGDLY	PV Change Delay
PVCHGTMR	PV Change Timer
PVCLAMP	PV Clamping Option
PVEUHI	PV High Range in Engineering Units
PVEULO	PV Low Range In Engineering Units
PVEXEUHI	PV Extended Engineering Unit Range High
PVEXEULO	PV Extended Engineering Unit Range Low
PVEXHIFL	PV Extended High Range Violation
PVEXLOFL	PV Extended Low Range Violation
PVFL	PV Flag
PVFLTPT	Enumeration of FSC-SRS Data Type
PVFORMAT	PV Decimal Point Format
PVHIFL	PV High Alarm Flag
PVHIPR	PV High Alarm Priority
PVHITP	PV High Alarm Trip Point
PVLOFL	PV Low Alarm Flag
PVLOPR	PV Low Alarm Priority
PVLOTP	PV Low Alarm Trip Point
PVNORMAL	PV Normal State
PVNORMFL	PV Normal State Flag
PVP	PV in Percent
PVRAW	PV Raw Value (Analog Input Point)
PVRAW	Raw State of Field Contacts (Digital Input Point)
PVRAWHI	PV Raw High Value
PVRAWLO	PV Raw Low Value
PVSLTSRC	PV Slot Source
PVSOURCE	PV Source
PVSRCOPT	PV Source Option
PVSTATES(0–4)	PV State Descriptors
PVSTS	Status of PV Input Value
PVTV	PV Target Value in Engineering Units
PVTVP	PV Target Value in Percent
RCASOPT	Remote Cascade Option
REDTAG	Red Tag State
RINITREQ	Remote Initialization Request
RV	Remaining Time
S0BOXCLR	State 0 Box Color
S1BOXCLR	State 1 Box Color

Continued on next page

Parameters

S2BOXCLR	State 2 Box Color
SCANRATE	Scan Rate
SECOND	FSC-SMM Second
SLOTNUM	Slot Number
SMPLTFM.....	Safety Manager Platform Type
SO.....	Status Output (Digital Composite and Digital Output Points)
SO.....	Status Output of Timer (Timer point)
SO(i)	Status Output Array
SP	Timer Setpoint Variable
SPSLTSRC.....	Setpoint Source Address
ST0_OP(1-3)	State 0 Outputs, 1 through 3
ST1_OP(1-3)	State 1 Outputs, 1 through 3
ST2_OP(1-3)	State 2 Outputs, 1 through 3
STATE	Timer State
STATE(0-2).....	Current State
STATETXT(0-1).....	State Descriptor Text
TF	PV Filter Lag Time in Minutes
TIMEBASE.....	Time Base
UCNRECHN	UCN Receive Channel
UNCMDFL	Uncommanded Change Alarm Flag
UNIT	Process Unit Identifier
WEEKDAY.....	FSC-SMM Weekday
YEAR.....	FSC-SMM Year

References

For FSC-SM documentation:

Publication Title	Publication Number	Binder Title	Binder Number
<i>FSC Safety Manager Installation Guide</i>	FS20-500	Implementation FSC Safety Manager	TPS 3076
<i>FSC Safety Manager Implementation Guidelines</i>	FS11-500	Implementation FSC Safety Manager	TPS 3076
<i>FSC Safety Manager Control Functions</i>	FS09-500	Implementation FSC Safety Manager	TPS 3076
<i>FSC Safety Manager Parameter Reference Dictionary</i>	FS09-550	Implementation FSC Safety Manager	TPS 3076
<i>FSC Safety Manager Configuration Forms</i>	FS88-500	Implementation FSC Safety Manager	TPS 3076
<i>FSC Safety Manager Service Manual</i>	FS13-500	Implementation FSC Safety Manager	TPS 3076

For FSC documentation:

Publication Title	Publication Number
<i>FSC Safety Manual</i>	PM.MAN.8047
<i>FSC Hardware Manual</i>	PM.MAN.8048
<i>FSC Software Manual</i>	PM.MAN.8025

Section 1 – Introduction

1.1 Section Overview

About this section

This section contains overview information regarding this publication, and parameters and point types associated with the Safety Manager. Also included in this section are listings of parameters applicable to each data point type in the Safety Manager. Topics included in this section are:

Subsection	Topic	See Page
1.1	Section Overview	1
1.2	Parameter Overview	2
1.3	Point Type Overview	6
1.4	CL Access	8
1.5	Parameters Per Point Type.....	9

1.2 Parameter Overview

Parameter definition format

This dictionary lists the parameter definitions in alphabetical order according to the parameter name, which can be up to eight characters in length. Each parameter in this publication is defined using the format shown in Figure 1-1 for the ALMOPT parameter, as an example.

Figure 1-1 Parameter Definition Format

ALMOPT

The ALMOPT parameter defines the types of alarms that can be selected by this data point. Table 2-9 defines this parameter.

Table 2-9 ALMOPT Definition and Entry Fields

Item	Definitions/Settings	Notes
	Alarm Option	
Valid Points	DigComp, and DigIn	
Type	E:\$ALMOPT	
Lock	Engr, PB	
Default	None	
PtRes	FSC-SMM	
Range	None	No alarms are detected
	Offnorml	Off Normal-Alarm if PV and PVNORMAL are not the same state.
	Cmddis	Command Diagree-DigComp only. Alarms if: - field device did not respond to commanded state within the configured feedback time, or - uncommanded changes in the field device are detected
	Chngofst	Change of State-DigIn only

ATTENTION Applies only if range is not set to None, and PNTFORM = Full.

Continued on next page

1.2 Parameter Overview, Continued

Parameter name

For many parameters, the function of the parameter is described using the long name of the parameter name, followed by a description. As shown in Figure 1-1, the long name of the ALMOPT parameter is Alarm Option. Some parameters in this dictionary do not have functional descriptions following the long name; this is because the long name of the parameter sufficiently describes the parameter function.

Type

This entry is the data type that defines how the parameter is viewed by the system. Table 1-1 defines the data types used in this parameter reference dictionary.

Table 1-1 Parameter Data Types

Data Type	Definition
E:	Enumeration — The value for the parameter is chosen from a set of predefined character strings. In the Figure 1-1 example, the enumerations of \$ALMOPT are None , Offnorml , and Cmddis .
Ent.Prm	Entity Parameter Identifier — Consists of a 1-8 or 1-16 character tagname (depending on the option selected), a period, and a 1-8 character parameter name.
Integer	A 16-bit whole number that does not contain a decimal point.
Logical	A binary type with the values of ON (True) and OFF (False), or 0 (Off) and 1 (On).
NaN	Not A Number — Although not a data type, it is used to represent "Not A Number" and is stored in IEEE format.
Prm_Id	Parameter Identifier — 1-8 character parameter name.
Real	A 32-bit floating-point number in IEEE format.
String_L	Character String Length — A character string where maximum length = L. Same as Ascii_L.
Universal Ent.Prm	Universal Entity Parameter Identifier — Similar to the <i>Ent.Prm</i> data type, but the entity name can be entered as an external 16-character tagname or as a UCN node's internal hardware reference address. The hardware reference address syntax can be used to access point parameters (within this same FSC-SM) that are untagged or tagged.

Continued on next page

1.2 Parameter Overview, Continued

Lock

The access lock defines "who" or "what" can change the parameter's value or option and the access level defines "who" or "what" is requesting a parameter value or option change. For example, if a requestor with an access level of Supr tries to change a parameter that has an access lock of Engr, the request will be denied. Table 1-2 defines the access level while Table 1-3 the access lock.

Table 1-2 Access Level Definitions

Access Level	Used by Who or What When a Parameter Change Request is Made
Oper	Operator
Supr or Sup	Supervisor
Engr, Eng or Eg	Engineer
Cont	Continuous_Control (from a module on the LCN)
OnProc	On Process
Prog	User-written programs in an LCN node
PtBld or PB	Point_Builder (Data Entity Builder)
View	View only

Table 1-3 Access Lock/Level Relationship

Access Lock	Access Level of Requestors that can Change the Parameter					
	Oper	Supr	Engr	Cont	Prog	PtBld
Oper	9	9	9	9	9	9
Supr		9	9	9	9	9
Engr			9	9	9	9
OnProc	9	9	9			
Sup/Eng		9	9			
EgOnly			9			
Prog						
Eng/PB			9	9	9	9
PtBld						9
View (Read Only)						

Continued on next page

1.2 Parameter Overview, Continued

Default

The default for the parameter is the default value assigned by the system. The system automatically enters the default value for a parameter when a range or a selection is not entered for a parameter during point building. The default values are also shown on the configuration forms and parameter entry displays.

PtRes

This defines where the parameter physically resides. Two point residencies are used in the Safety Manager's parameter definitions. They are:

- NIM (Network Interface Module)
 - Parameters with a point residency of NIM physically reside in the Network Interface Module.
 - FSC-SMM (Safety Manager Module)
 - Parameters with a point residency of FSC-SMM physically reside in the Safety Manager Module.
-

Range

Defines the range of the value that can be entered for the parameter. Integers that precede enumeration values are sometimes needed by advanced CL users. These integers specify the member's position within the set (i.e. the ordinal).

Attention

Some parameter definitions contain an  (Attention) icon. This icon is used to identify additional information which is important in understanding and using the parameter.

References

Some parameter definitions contain a  (Reference) icon. This icon is used to identify additional information which is important in understanding and using the parameter. This information may be located in another area of this document or found in another document.

1.3 Point Type Overview

Introduction

In addition to the parameter definitions, this dictionary also contains listings of the parameters that are applicable to each FSC-SM point type.

Separate functional elements of the FSC-SM are used to implement various parts of control strategies. Each of these functional elements can be assigned a user-defined tagname to allow for location-independent reference to the data associated with that function. For example, point tags are assigned by the user for analog input and analog output slots.

Point form

The FSC-SM provides a configurable parameter called PNTFORM (Point Form) that allows the user to define which points are to be used as the primary operator interface for point data. The PNTFORM parameter provides the user with two choices for point form:

- Full Point
 - Component Point
-

Full points

Points that are configured as having a "Full" point form include descriptor data and alarm-related parameters. This information is needed when a point is to be used as the primary operator interface to the point's data.

Component points

Points that are configured as having a "Component" point form do not require descriptor data or alarm-related parameters. This type of information is suppressed for component points. The component form should be used

- for points that:
 - provide inputs to full points,
 - handle the outputs from full points; and
 - as part of a "full" point that has been designated a primary operator interface point.
-

Continued on next page

1.3 Point Type Overview, Continued

Point names and related acronyms

Table 1-4 lists the abbreviated point names and related acronyms with their full text description.

Table 1-4 Point Names and Related Acronyms

Abbreviations and Acronyms	Full Text Description
AI	Analog Input
AnalogIn	Analog Input Data Point
AnalogOut	Analog Output Data Point
AO	Analog Output
AutoMan	Auto Manual Station Algorithm
DC	Digital Composite
DI	Digital Input
DigComp	Digital Composite Data Point
DigIn	Digital Input Data Point
DigOut	Digital Output Data Point
DO	Digital Output
Flag	Flag Data Point
Logic	Logic Date Point (Slot)
LCN	Local Control Network
FSC-SM	Safety Manager
FSC-SMM	Safety Manager Module
NIM	Network Interface Module
Node Specif.	Node Specific
Timer	Timer Data Point
UCN	Universal Control Network
UCN Node	Universal Control Network Node



REFERENCE— For additional information regarding point types, refer to Section 1.5 — *Parameters Per Point Type* in this publication.

1.4 CL Access

FSC-SM/CL sequences

Certain parameters are not accessible to FSC-SM/CL sequences. They are:

- NODESTS
 - NODETYP
 - UCNRECHN
-

AM/CL sequences

Certain parameters are not directly available to AM/CL sequences. In this case, access to AM/CL is through custom data segment parameters attached to AM regulatory points. These restricted parameters can be accessed by AM/CL programs as:

- a NIM Reserved Data Point
 - for example, \$NMuuBnn.param, where uu = UCN number and nn = UCN node number.
 - a Regulatory Point General Input
 - using ordinary point parameter access, and
 - must be transferred to parameters of AM regulatory points.
 - an Enumeration (NODESTS, NODETYP and UNRECHN)
 - where a custom data segment is created to allow the parameters to be referenced as general inputs and transferred to user-defined parameters (of a RegCtl Point) that can be accessed by CL.
-

1.5 Parameters Per Point Type

Analog input

The parameters of the Analog Input (AnalogIn) Data Point are listed in alphabetical order in Table 1-5 and Table 1-6.

Table 1-5 Analog Input Data Point Parameters on the FSC-SMM

\$CHKPNT	\$PVSTREC	BADLPFL	BADPVFL
CCSRC (F)	CONTCUT (F)	FORCE	FORCEFL
INPTDIR	LASTPV	LOCUTOFF	PLCADDR
PNTFORM	PNTTYPE	PTEXECST	PTINAL
PV	PVALDB (F)	PVALDBEU (F)	PVAUTO
PVAUTOST	PV CALC	PVCHAR	PVCLAMP
PVEUHI	PVEULO	PVEXEUHI	PVEXEULO
PVEXHIFL	PVEXLOFL	PVFORMAT	PVHIFL
PVHITP (F)	PVLOFL	PVLOTP	PVP
PVRAW	PVRAWHI	PVRAWLO	PVSOURCE (F)
PVSRCOPT (F)	PVSTS	PVTV (F)	PVTVP (F)
TF			

Table 1-6 Analog Input Data Point Parameters on the NIM

\$AUXUNIT	\$PTRESID	\$REALARM (F)	ALENBST (F)
ASSOCDSP	BADPVPR (F)	DISPTYPE	EUDESC
HIGHAL (F)	HIGHALPR (F)	KEYWORD	NAME
NODENUM	NODETYP	NTWKNUM	OVERVAL (F)
PNTSTATE	PRIMMOD (F)	PTDESC (F)	PVHIPR (F)
PVLOPR (F)	SLOTNUM	SMPLTFM	UNIT

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

Analog output

The parameters of the Analog Output (AnalgOut) Data Point are listed in alphabetical order in Table 1-7 and Table 1-8.

Table 1-7 Analog Output Data Point Parameters on the FSC-SMM

\$CHKPNT	CASREQ (F)	FORCE	FORCEFL
MODATTR (F)	MODE (F)	MODEAPPL (F)	MODEPERM (F)
NMODATTR (F)	NMODE (F)	OP	OPFINAL
OPFINHI	OPFINLO	OPTDIR	PLCADDR
PNTFORM	PNTTYPE	PTEXECST	PVFLTPT
REDTAG	RCASOPT (F)	RINITREQ (F)	

Table 1-8 Analog Output Data Point Parameters on the NIM

\$AUXUNIT	\$OPTOL	\$PTRESID	ASSOCDSP
DISPTYPE	EUDESC	KEYWORD (F)	NAME
NODENUM	NODETYP	NTWKNUM	PRIMMOD (F)
PTDESC	SLOTNUM	SMPLTFM	UNIT

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

Digital composite

The parameters of the Digital Composite Point are listed in alphabetical order in Table 1-9 and Table 1-10.

Table 1-9 Digital Composite Data Point Parameters on the FSC-SMM

\$CHKPNT	ALMOPT (F)	BADCTLFL	BADPVFL
BYPASS	CCSRC	CMDDISFL	CMDFALFL
CMDFALTM (F)	D1, D2	D1_0	D1_1
D2D1_00	D2D1_01	D2D1_10	D2D1_11
DISRC(1-2)	DODSTN (1-3)	EVTOPT	FBTIME (F)
I0, I1, I2	LMSRC	LOCALMAN	MODE
MODEAPPL	MODATTR (F)	MODEPERM	MOMSTATE
MOVPVFL	NMODATTR	NMODE	NODINPTS
NODOPTS	NONECONF	NONE_OP (1-3)	NOSTATES
OFFNRMFL	OISRC (1-3)	OP	OPFINAL
OPRATFRL	OROPT	OVRDALOP	OVRDCONF
OVRDESC	OVRDI0FL, OVRDI1FL, OVRDI2FL	P0, P1, P2	PISRC(1-3)
P0, P1, P2	PISRC(1-3)	PTEXECST	PTINAL
PV	PVAUTO	PVFL(0-2)	PVNORMAL (F)
PVSCROPT (F)	PVSOURCE (F)	REDTAG	SO(0-2)
ST0_OP1, ST0_OP2, ST0_OP3	ST1_OP1, ST1_OP2, ST1_OP3	ST2_OP1 ST2_OP2 ST2_OP3	UNCMDFL

Continued on next page

1.5 Parameters Per Point Type, Continued

Table 1-10 Digital Composite Data Point Parameters on the NIM

\$AUXUNIT	\$PTRESID	\$REALARM (F)	ALENBST (F)
ASSOCDSP	BADCTLPR	BADPVPR	BOXCLR (0-2)
CMDDISPR	DISTYPE	EIPPCODE	EUDESC
HIGHAL	HIGHALPR	KEYWORD	NAME
NODENUM	NODETYP	NTWKNUM	OFFNRMPR
OPSTTEXT	OVRDALPR	PNTSTATE	PRIMMOD
PTDESC	PVSTATES(0)-(4)	S0BOXCLR	S1BOXCLR
S2BOXCLR	SLOTNUM	SMPLTFM	STATE(0-2)
STATETXT(0-3)	UNIT		

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

Digital input

Parameters of the Digital Input Point are listed in alphabetical order in Table 1-11 and Table 1-12.

Table 1-11 Digital Input Data Point Parameters on the FSC-SMM

\$CHKPNT	ALMOPT (F)	BADLPFL	BADPVFL
CCSRC (F)	CONTCUT (F)	DITYPE	DLYTIME (F)
EVTOP (F)	FORCE	FORCEFL	INPTDIR (F)
OFFNRMFL	PLCADDR	PNTFORM	PNTTYPE
PTEXECST	PV	PVAUTO	PVCHGDLY (F)
PVCHGTMR	PVFL	PVNORMAL (F)	PVNORMFL
PVRAW	PVSOURCE (F)	PVSRCOPT (F)	

Table 1-12 Digital Input Data Point Parameters on the NIM

\$AUXUNIT	\$PTRESID	\$REALARM (F)	ALENBST (F)
ASSOCDSP	BOXCLR(0-1) (F)	DISPTYPE	EIPPCODE (F)
EUDESC	HIGHAL	HIGHALPR	KEYWORD
NAME	NODENUM	NODETYP	NTWKNUM
OFFNRMPR (F)	PNTSTATE	PRIMMOD (F)	PTDESC
S0BOXCLR	S1BOXCLR	SLOTNUM	SMPLTFM
STATE(0-1)	STATETXT(0-1) (F)	UNIT	

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

Digital output

The parameters of the Digital Output Data point are listed in alphabetical order in Table 1-13 and Table 1-14.

Table 1-13 The Digital Output Data Point Parameters on the FSC-SMM

\$CHKPNT	DOTYPE	FORCE	FORCEFL
MODATTR	MODE	MODEAPPL	MODEPERM (F)
NMODATTR (F)	NMODE	OP	PLCADDR
PNTFORM	PNTTYPE	PTEXECST	REDTAG
SO			

Table 1-14 Digital Output Data Point Parameters on the NIM

\$AUXUNIT	\$PTRESID	ASSOCDSP	BOXCLR(0-1) (F)
DISPTYPE	EUDESC	KEYWORD	NAME
NODENUM	NODETYP	NTWKNUM	PNTSTATE
PRIMMOD (F)	PTDESC	S0BOXCLR	S1BOXCLR
SLOTNUM	SMPLTFM	STATE(0-1)	STATETXT(0-1) (F)
UNIT			

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

Flag

Parameters of the Flag Data Point are listed in alphabetical order in Table 1-15 and Table 1-16.

Table 1-15 Flag Data Point Parameters on the FSC-SMM

\$CHKPNT	CCSRC (F)	CONTCUT	PLCADDR
PNTFORM	PNTTYPE	PV	PVFL

Table 1-16 Flag Data Point Parameters on the NIM

\$AUXUNIT	\$PTRESID	\$REALARM (F)	ASSOCDSP
ALENBST (F)	BOXCLR (0-1) (F)	DISPTYPE	EIPPCODE (F)
EUDESC	HIGHAL	HIGHALPR	KEYWORD
NAME	NODENUM	NODETYP	NTWKNUM
OFFNRMPR (F)	PNTSTATE	PRIMMOD (F)	PTDESC
S0BOXCLR	S1BOXCLR	SLOTNUM	SMPLTFM
STATE(0-1)	STATETXT(0-1) (F)	UNIT	

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

Logic

Parameters of the Logic Data Point are listed in alphabetical order in Table 1-17 and Table 1-18.

Table 1-17 Logic Data Point Parameters on the FSC-SMM

\$CHKPNT	L	LIBADOPT	LISRC(1-12)
LODSTN(1-12)	LOENBL(1-12)	LOGMIX	NOLINPTS
NOLOGBLK	NOLOPTS	PNTFORM	PNTTYPE
PTEXECST			

Table 1-18 Logic Data Point Parameters on the NIM

\$AUXUNIT	\$PRMDESC (F)	\$PTRESID	ASSOCDSP
DISPTYPE	GENDESC(1-12) (F)	NAME	NODENUM
NODESC (F)	NODETYP	NTWKNUM	PRIMMOD (F)
PTDESC	SLOTNUM	SMPLTFM	UNIT

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

Node-specific

The parameters of the Node Specific (Node Specif.) Data Point are listed in alphabetical order in Table 1-19.

Table 1-19 Node Specific Data Points

\$COMCKPT	\$RECOVER	\$UCNANSY	\$UCNASIL
\$UCNATSP	\$UCNBNSY	\$UCNBSIL	BADPVTXT
CHPINOPR	CRPPXORN	CRUCNORN	DATE
DAY	FL	FLLSBA	HOUR
LSPPXORN	LSUCNORN	MINUTE	MONTH
MOVPVTXT	NAISLOT	NAOSLOT	NDCSLOT
NDISLOT	NDOSLOT	NFLAG	NLOGSLOT
NN	NNLSBA	NNUMERIC	NODEASSN
NODENUM	NODESTS	NODETYPE	NODFSTAT
NONETXT	NTIMER	PMMCMD	PMMCMDTL
PMMFLPOS	PMMOPER	PMMSFST	PMMSTS
PVFLTOPT	SCANRATE	SECOND	SMPLTFM
UCNRECHN	UTSDRIFT	UTSNODE	UTSTBCRV
UTSTIME	UTSTIMST	WEEKDAY	YEAR

Continued on next page

1.5 Parameters Per Point Type, Continued

Numeric

The parameters of the Numeric Data Point are listed in alphabetical order in Table 1-20 and Table 1-21.

Table 1-20 Numeric Data Point Parameters on the FSC-SMM

\$CHKPNT	PLCADDR	PNTFORM	PNTTYPE
PV			

Table 1-21 Numeric Data Point Parameters on the NIM

\$AUXUNIT	\$PTRESID	ASSOCDSP	DISPTYPE
EUDESC	KEYWORD	NAME	NODENUM
NODETYP	NTWKNUM	PRIMMOD (F)	PTDESC
SLOTNUM	SMPLTFM	UNIT	

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

Timer

The parameters of the Timer Data Point are listed in alphabetical order in Table 1-22 and Table 1-23.

Table 1-22 Timer Data Point Parameters on the FSC-SMM

\$CHKPNT	COMMAND	PLCADDR	PNTFORM
PNTTYPE	PTEXECST	PV	PVFORMAT
PVSLTSRC	RV	SO	SP
SPSLTSRC	STATE	TIMEBASE	

Table 1-23 Timer Data Point Parameters on the NIM

\$AUXUNIT	\$PTRESID	ASSOCDSP	DISPTYPE
EUDESC	KEYWORD	NAME	NODENUM
NODETYP	NTWKNUM	PRIMMOD (F)	PTDESC
SLOTNUM	SMPLTFM	UNIT	

ATTENTION (F) indicates that this parameter is applicable when PNTFORM = Full.

Continued on next page

1.5 Parameters Per Point Type, Continued

UCN

The parameters of the UCN Data Point are listed in alphabetical order in Table 1-24.

Table 1-24 UCN Data Points

BADPVTXT	MOVPVTXT	NODEASSN	NODENUM
NODESTS	NODETYP	NTWKNUM	SMPLTFM


Section 2 – Parameter Definitions

2.1 Section Overview

About this section

This section contains detailed listings and definitions of the parameters applicable to each Safety Manager data point. Topics included in this section are:

Subsection	Topic	See Page
2.1	Section Overview	21
2.2	\$XXXX—Parameter Definitions	22
2.3	AXXXX—Parameter Definitions	35
2.4	BXXXX—Parameter Definitions	39
2.5	CXXXX—Parameter Definitions	47
2.6	DXXXX—Parameter Definitions	54
2.7	EXXXX—Parameter Definitions	67
2.8	FXXXX—Parameter Definitions	71
2.9	GXXXX—Parameter Definitions	77
2.10	HXXXX—Parameter Definitions	78
2.11	IXXXX—Parameter Definitions	81
2.12	KXXXX—Parameter Definitions	84
2.13	LXXXX—Parameter Definitions	86
2.14	MXXXX—Parameter Definitions	95
2.15	NXXXX—Parameter Definitions	101
2.16	OXXXX—Parameter Definitions	129
2.17	PXXXX—Parameter Definitions	143
2.18	RXXXX—Parameter Definitions	190
2.19	SXXXX—Parameter Definitions	194
2.20	TXXXX—Parameter Definitions	209
2.21	UXXXX—Parameter Definitions	210
2.22	WXXXX—Parameter Definitions	212
2.23	YXXXX—Parameter Definitions	213



For information on how the parameters are used in FSC-SM data points or data point functions, refer to the *FSC Safety Manager Control Functions* manual in this binder.

2.2 \$XXXX—Parameter Definitions

\$AUXUNIT

The \$AUXUNIT parameter defines the Auxiliary Unit of an alarmable process point. If an Auxiliary Unit ID is specified, alarms from this point go to the Auxiliary Unit instead of the Primary Unit. If the \$AUXUNIT parameter is set to null (--), alarms go to the Primary Unit. Table 2-1 defines this parameter.

Table 2-1 \$AUXUNIT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Auxiliary Unit	
Valid Points	AnalogIn, AnalogOut, DigComp, DigIn, DigOut, Flag, Logic, Numeric, and Timer	
Type	E:UNIT	
Lock	Oper	
Default	Null	
PtRes	NIM	
Range	A-Z, 0-9, and Null	Any valid unit ID as configured in the NCF

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$REALARM

With R660, acknowledged and unacknowledged process alarms (event-type 21) are rebroadcast if they have not returned to normal (RTN) within the re-alarmed interval specified by the \$REALARM parameter. The re-alarm feature is applicable for all types of process alarms that can have an RTN event. The user-configured re-alarm interval is the same value for all process alarms associated with the same point. Re-alarmed is consistent across all stations in the console in that area.

Rebroadcast alarms are also sent to the History Module with a new timestamp, and reported to the RTJ and Process Alarm Journal where they will appear as an alarm.

On the alarm displays, the rebroadcast alarm behaves like a new alarm but has a yellow time stamp.

Rebroadcast alarms appear on the GUS Alarm Summary, and on the following GUS/US native-window displays:

- Area Alarm Summary
- Unit Alarm Summary
- Alarm Annunciator
- Point Detail

The re-alarm feature is implemented using the \$REALARM parameter that has a range of 0 through 9999 minutes. The value specified for this parameter determines the interval, in minutes, that will elapse before the specified point is re-alarmed.

Table 2-2 \$REALARM Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Re-alarmed Interval	
Valid Points	Analog Input, Digital Composite, Digital Input, Flag	
Type	Integer	
Lock	Engr	
Default	0 (no alarm)	
PtRes	NIM	
Range	0 through 9999 minutes (value range is from one minute to approximately 167 hours). A value of 0 minute disables the rebroadcast alarm function.	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$CHKPNT

The \$CHKPNT parameter is a special database save function. Table 2-3 defines this parameter.

Table 2-3 \$CHKPNT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Checkpoint Record	
Valid Points	AnalgIn, AnalgOut, DigComp, DigIn, Flag, Logic, Numeric, and Timer	
Type	Blind Record	
Lock	IntUsr	
Default	None	
PtRes	FSC-SMM	
Range	None	

\$COMCKPT

The \$COMCKPT parameter is the FSC-SM node specific data point checkpoint record. Table 2-4 defines this parameter.

Table 2-4 \$COMCKPT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SM Node Specific Data Point Checkpoint Record	
Valid Points	Node Specif.	
Type	Blind Record	
Lock	IntUsr	
Default	None	
PtRes	FSC-SMM	
Range	None	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$OPTOL

The \$OPTOL parameter defines the tolerance limit for a manually entered OP. The difference between a new OP and a current OP is compared against \$OPTOL. If the tolerance is violated in either a positive or negative direction from the current value of the OP, operator confirmation is required before the value is stored. A value of 0.0 disables this check. An NaN or a negative value is not allowed. Table 2-5 defines this parameter.

Table 2-5 \$OPTOL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Output Tolerance	
Valid Points	AnalgOut	
Type	Real (in percent)	
Lock	Engr	
Default	0.0	
PtRes	NIM	
Range	0.0 to 106.9	The value represents a percentage. An NaN or negative number are not allowed.

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PAISLOT(xx)

This parameter indicates the number of Analog Input points configured on the selected node.

Table 2-6 \$PAISLOT(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Parameter Analog Input Slot	
Valid Points	AnalogIn	
Type	Integer	
Lock	View	
Default	0	
PtRes	NIM	
Range	>=0	

\$PAOSLOT(xx)

This parameter indicates the number of Analog Output points configured on the selected node.

Table 2-7 \$PAOSLOT(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Parameter Analog Output Slot	
Valid Points	AnalogOut	
Type	Integer	
Lock	View	
Default	0	
PtRes	NIM	
Range	>=0	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PDCSLOT(xx)

This parameter indicates the number of Digital Composite points configured on the selected node.

Table 2-8 \$PDCSLOT(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Parameter Digital Composite Slot	
Valid Points	DigComp	
Type	Integer	
Lock	View	
Default	0	
PtRes	NIM	
Range	>=0	

\$PDISLOT(xx)

This parameter indicates the number of Digital Input points configured on the selected node.

Table 2-9 \$PDISLOT(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Parameter Digital Input Slot	
Valid Points	DI	
Type	Integer	
Lock	View	
Default	0	
PtRes	NIM	
Range	>=0	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PDOSLOT(xx)

This parameter indicates the number of Digital Output points configured on the selected node.

Table 2-10 \$PDOSLOT(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Parameter Digital Output Slot	
Valid Points	DO	
Type	Integer	
Lock	View	
Default	0	
PtRes	NIM	
Range	>=0	

\$PLOGSLT(xx)

This parameter indicates the number of Logic points configured on the selected node.

Table 2-11 \$PLOGSLT(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Parameter Logic Slot	
Valid Points	Logic	
Type	Integer	
Lock	View	
Default	0	
PtRes	NIM	
Range	>=0	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PTIME(xx)

This parameter indicates the number of Timer points configured on the selected node.

Table 2-12 \$PTIME(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Parameter Timer	
Valid Points	Timer	
Type	Integer	
Lock	View	
Default	0	
PtRes	NIM	
Range	>=0	

\$PTRESID

The \$PTRESID parameter is a point descriptor identifying point residency. Table 2-13 defines this parameter.

Table 2-13 \$PTRESID Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Point Residency Identifier	
Valid Points	AnalIn, AnalOut, DigComp DigIn, DigOut, Flag, Logic, Numeric, and Timer	
Type	Blind Record	
Lock	View	
Default	Blank	
PtRes	NIM	
Range	None	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PUANLIN(xx)

This parameter indicates the number of PUs consumed by the configured Analog Input point type for the selected node.

Table 2-14 \$PUANLIN(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PUs consumed by Analog Input point	
Valid Points	AnalgIn	
Type	Real	
Lock	View	
Default	0.0	
PtRes	NIM	
Range	>=0	

\$PUANLOP(xx)

This parameter indicates the number of PUs consumed by the configured Analog Output point type for the selected node.

Table 2-15 \$PUANLOP(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PUs consumed by Analog Output point	
Valid Points	AnalgOut	
Type	Real	
Lock	View	
Default	0.0	
PtRes	NIM	
Range	>=0	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PUDIGCP(xx)

This parameter indicates the number of PUs consumed by the configured Digital Composite point type for the selected node.

Table 2-16 \$PUDIGCP(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PUs consumed by Digital Composite point	
Valid Points	DigComp	
Type	Real	
Lock	View	
Default	0.0	
PtRes	NIM	
Range	>=0	

\$PUDIGIN(xx)

This parameter indicates the number of PUs consumed by the configured Digital Input point type for the selected node.

Table 2-17 \$PUDIGIN(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PUs consumed by Digital Input point	
Valid Points	DI	
Type	Real	
Lock	View	
Default	0.0	
PtRes	NIM	
Range	>=0	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PUDIGOP(xx)

This parameter indicates the number of PUs consumed by the configured Digital Output point type for the selected node.

Table 2-18 \$PUDIGOP(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PUs consumed by Digital Output point	
Valid Points	DO	
Type	Real	
Lock	View	
Default	0.0	
PtRes	NIM	
Range	>=0	

\$PUFREE(xx)

This parameter indicates the available number of PUs for the selected node.

Table 2-19 \$PUFREE(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Free PUs	
Valid Points	NodeSpecif.	
Type	Real	
Lock	View	
Default	0.0	
PtRes	NIM	
Range	>=0	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PULOGIC(xx)

This parameter indicates the number of PUs consumed by the configured Logic point type for the selected node.

Table 2-20 \$PULOGIC(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PUs consumed by Logic point	
Valid Points	Logic	
Type	Integer	
Lock	View	
Default	0	
PtRes	NIM	
Range	>=0	

\$PUTIME(xx)

This parameter indicates the number of PUs consumed by the configured Timer point type for the selected node.

Table 2-21 \$PUTIME(xx) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PUs consumed by Timer point	
Valid Points	Timer	
Type	Real	
Lock	View	
Default	0.0	
PtRes	NIM	
Range	>=0	

Continued on next page

2.2 \$XXXX—Parameter Definitions, Continued

\$PVSTREC

The \$PVSTREC parameter is a special request which retrieves the PV value and the status of the PV input value (PVSTS). Table 2-22 defines this parameter.

Table 2-22 \$PVSTREC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Value and Status Record	
Valid Points	AnalogIn	
Type	Blind Record	
Lock	View	
Default	None	
PtRes	NIM	
Range	N/A	

\$RECOVER

\$RECOVER is a write-only parameter which indicates recovery of all FSC-SMM alarms when written to a True/On. Table 2-23 defines this parameter.

Table 2-23 \$RECOVER Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Recover All FSC-SMM Alarms	
Valid Points	Node specif.	
Type	Boolean	
Lock	IntUsr	
Default	None	
PtRes	FSC-SMM	
Range	True	

2.3 AXXXX—Parameter Definitions

ALENBST

The ALENBEST parameter defines the alarm reporting function that is to be used when an alarm condition is detected in the data point. Table 2-24 defines this parameter.

Table 2-24 ALENBST Definition and Entry Fields

Item	Definitions/Settings	Notes																
Full Name	Alarm Enable Status																	
Valid Points	AnalIn, DigComp, DigIn, and Flag																	
Type	E:ALENBEST																	
Lock	Engr, Supr, Oper	Configured in Network Configuration under System-Wide Values/Console Data.																
Default	Enable																	
PtRes	NIM																	
Range	The following table defines, based on the range setting, whether the alarms are: • displayed, • logged, or • recorded to the EIP. <table><tr><th>SETTING</th><th>DISPLAYED</th><th>LOGGED</th><th>REPORTED</th></tr><tr><td>Enable</td><td>Yes</td><td>Yes</td><td>Yes</td></tr><tr><td>Disable*</td><td>Yes</td><td>Yes</td><td>Yes</td></tr><tr><td>Inhibit</td><td>No</td><td>No</td><td>No</td></tr></table> * Disabled alarms are not annunciated at Universal Stations, but the alarm indicators appear on the Group and Detail displays		SETTING	DISPLAYED	LOGGED	REPORTED	Enable	Yes	Yes	Yes	Disable*	Yes	Yes	Yes	Inhibit	No	No	No
SETTING	DISPLAYED	LOGGED	REPORTED															
Enable	Yes	Yes	Yes															
Disable*	Yes	Yes	Yes															
Inhibit	No	No	No															

Continued on next page

2.3 AXXXX—Parameter Definitions, Continued

ALMOPT

The ALMOPT parameter defines the types of alarms that can be selected by this data point. Table 2-25 defines this parameter.

Table 2-25 ALMOPT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Alarm Option	
Valid Points	DigComp, and DigIn	
Type	E:\$ALMOPT	
Lock	Engr, PB	
Default	None	
PtRes	FSC-SMM	
Range	None	No alarms are detected.
	Offnorml	Off Normal-Alarm if PV and PVNORMAL are not the same state.
	Cmddis	Command Disagree-DigComp only. Alarms if: • field device did not respond to commanded state within the configured feedback time, or • uncommanded changes in the field device are detected.
	Chngofst	Change of State-DigIn only

Continued on next page

2.3 AXXXX—Parameter Definitions, Continued

ALPRIOR

The ALPRIOR parameter defines the alarm priority for DigComp, DigIn, and Flag Points. Table 2-26 defines this parameter.

Table 2-26 ALPRIOR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Alarm Priority	
Valid Points	Node Specif.	
Type	DigComp, DigIn, and Flag	
Lock	E:ALPRIOR	
Default	Low	
PtRes	NIM	
Range	Emergency	Reported to all alarm summary displays.
	High	Reported to Area and Unit Alarm Summary displays.
	Low	Reported to Unit Alarm Summary Display.
	Journal	Logged, indicators appear on the Group and Detail displays.
	NoAction	Alarm is not reported to the system.

Continued on next page

2.3 AXXXX—Parameter Definitions, Continued

ASSOCDSP

The ASSOCDSP parameter defines the associated display for this point which will be invoked when the ASSOC DISP button is pressed from either the Detail display, or when a point is selected from any Summary or Group display. For entry the user may enter any legal schematic name up to eight characters. A blank name means this function is not configured. Table 2-27 defines this parameter.

Table 2-27 ASSOCDSP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Associated Display	
Valid Points	All point types	Applies to all point types for all UCN Nodes (PM 300, APM, HPM, LM and SM)
Type	String_8	
Lock	Engr	
Default	<blanks>	
PtRes	NIM	
Range	Alphanumerics, A to Z	
	Numerals, 0 to 9	
	Underscore (_)	

2.4 BXXXX—Parameter Definitions

BADCTLFL

The BADCTLFL parameter generates a Bad Control Alarm if the calculated control processor's output state in OPFINAL does not match the commanded state in OP (BADCTLFL=On). Table 2-28 defines this parameter.

Table 2-28 BADCTLFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Bad Control Flag	
Valid Points	DigComp	
Type	Boolean	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Outputs No Bad State
	On	Outputs Bad State

ATTENTION The following information is important to the understanding and use of the BADCTLFL parameter.

- On the point's Group Detail Display
 - the OP state is shown as Undefined, and
 - the Bad Control alarm indicator (BC) is displayed.
- Where more than one control processor output for this point is in use, the FSC-SMM:
 - compares each output with OP,
 - reports the first match in OPFINAL, and
 - generates a Bad Control alarm if no match is found in any output.

Continued on next page

2.4 BXXXX—Parameter Definitions, Continued

BADCTLPR

The BADCTLPR parameter defines the BAD output control PV alarm for the DC point. Table 2-29 defines this parameter.

Table 2-29 BADCTLPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Bad OP Control Priority	
Valid Points		
Type	E:ALPRIOR	
Lock	Eng/PB	
Default	Low	
PtRes	NIM	
Range	NoAction	Alarm is not reported to the system and is not annunciated.
	Journal	Alarm is logged but not reported to the US RTJ or annunciated.
	Low	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit Alarm Summary Display.
	High	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit and Area Alarm Summary Displays.
	Emergency	Alarm is logged, reported to the US RTJ, annunciated, and displayed on all alarm summary displays.
	Printer	Alarm is reported to the US RTJ, but not logged, annunciated or displayed.
	JNLPrint	Alarm is logged and reported to the US RTJ, but not annunciated or displayed.

Continued on next page

2.4 BXXXX—Parameter Definitions, Continued

BADLPFL

The BADLPFL parameter indicates a bad loop has been detected for the FSC-SRS variable related to the data point. Table 2-30 defines this parameter.

Table 2-30 BADLPFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Bad Loop Flag	
Valid Points	AnalIn and DigIn	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Loop is not bad.
	On	Loop is bad.

BADPVFL

The BADPVFL parameter indicates that the PV calculations have determined that the FSC-SRS variable value is out of range. Table 2-31 defines this parameter.

Table 2-31 BADPVFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Bad PV Flag	
Valid Points	AnalIn, DigIn, and DigComp	
Type	Logical	
Lock	View	
Default	–	
PtRes	FSC-SMM	
Range	Off	The value of PV is valid.
	On	A bad PV has been detected.

Continued on next page

2.4 BXXXX—Parameter Definitions, Continued

BADPVPR

The BADPVPR parameter defines the priority of the bad PV alarm. Table 2-32 defines this parameter.

Table 2-32 BADPVPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Bad PV Alarm Priority	
Valid Points		
Type	E:ALPRIOR	
Lock	Eng/PB	
Default	Low	
PtRes	NIM	
Range	NoAction	Alarm is not reported to the system and is not annunciated.
	Journal	Alarm is logged but not reported to the US RTJ or annunciated.
	Low	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit Alarm Summary Display.
	High	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit and Area Alarm Summary Displays.
	Emergency	Alarm is logged, reported to the US RTJ, annunciated, and displayed on all alarm summary displays.
	Printer	Alarm is reported to the US RTJ, but not logged, annunciated or displayed.
	JNLPrint	Alarm is logged and reported to the US RTJ, but not annunciated or displayed.

Continued on next page

2.4 BXXXX—Parameter Definitions, Continued

BADPVTXT

The BADPVTXT parameter defines the state descriptor displayed when a digital composite point state is indeterminate or bad. The bad state can result when PV input signals from the process are in an inconsistent state (e.g. for a valve, the limit switches indicating open and closed are on at the same time). This state descriptor is configured once and applies to all digital composite points in the FSC-SMM. Table 2-33 defines this parameter.

Table 2-33 BADPVTXT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Bad PV State Descriptor	
Valid Points	Node Specif., and UCN Node	
Type	String_8	
Lock	PtBld	
Default	Bad	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	
	Underscore (_)	

Continued on next page

2.4 BXXXX—Parameter Definitions, Continued

BOXCLR (DigComp Points)

The BOXCLR parameter defines the color of the upper, middle and lower boxes that are used to display the current state of the point on the Group and Detail displays. The lower box and its default (Yellow) do not apply if NOSTATES = 2. Table 2-34 defines this parameter.

Table 2-34 BOXCLR (DigComp Points) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Box Color for Displays	
Valid Points	DigComp.	
Type	E:BOXCOLOR	
Lock	Engr, PB	Access lock of View if PNTFORM = Component
Default	Red	Upper box default (State 1)
	Green	Middle box default (State 0)
	Yellow	Lower box default (State 2)
PtRes	NIM	
Range	Black Blue Cyan Green Magenta Red White, or Yellow	

Continued on next page

2.4 BXXXX—Parameter Definitions, Continued

BOXCLR (DigIn, Digout, Flag Points)

The BOXCLR parameter defines the color of the upper, middle and lower boxes that are used to display the current state of the point on the Group and Detail displays. Boxes are applicable when DITYPE is Latched or Status. Table 2-35 defines this parameter.

Table 2-35 BOXCLR (DigIn, DigOut, Flag Points) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Box Color for Displays	
Valid Points	DigIn, Digout, and Flag	
Type	E:BOXCOLOR	
Lock	Engr, PB	Access lock of View if PNTFORM = Component
Default	Green	Upper box default (State 1)
	Yellow	Lower box default (State 0)
PtRes	NIM	
Range	Black Blue Cyan Green Magenta Red White, or Yellow	

Continued on next page

2.4 BXXXX—Parameter Definitions, Continued

BYPASS

The BYPASS parameter allows a store to the OP and the SO parameters that ignore interlock if "On". Table 2-36 defines this parameter.

Table 2-36 BYPASS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Override Input Bypass Enable	
Valid Points	DigComp	
Type	Logical	
Lock	Oper	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Bypass of inputs is not allowed.
	On	Bypass of inputs is allowed.

2.5 CXXXX—Parameter Definitions

CASREQ

The CASREQ parameter defines whether remote cascade mode has been requested for the data point. Table 2-37 defines this parameter.

Table 2-37 CASREQ Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Remote Cascade Request	
Valid Points	AnalogOut	
Type	E:CASREQ	
Lock	Prog	
Default	NotReq	
PtRes	FSC-SMM	
Range	0-NotReq	Remote cascade mode request not made.
	1-Request	Remote cascade mode request made by operator or program.

ATTENTION

The following information is important to the understanding and use of the CASREQ parameter.

- CASREQ does not apply for an AnalogOut Point if RCASOPT = None.
- Ddc is the only remote cascade option for an analog output point.
- The remote cascade mode exits when
 - Mode is changed to Cas, and
 - RCASOPT is Ddc.
- When a request to change Mode to Cas is received from a US or a program
 - MODE does not immediately respond, instead;
 - CASRSQ is set to Request, and
 - “-C” appears to the right of the mode indicator on the Group and Detail displays.
- When continuous control determines that CASREQ contains Request
 - it requests the mode to go to Cas, and
 - the FSC-SMM changes CASREQ to NotReq.

Continued on next page

2.5 CXXXX—Parameter Definitions, Continued

CCSRC

The CCSRC parameter is the source address for a boolean value that determines the state of the CONTCUT parameter. Table 2-38 defines this parameter.

Table 2-38 CCSRC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Contact Cut Out Source	
Valid Points	AnalIn, DigComp, DigIn, and Flag	
Type	Unsigned Integer	UCN
	Real	LCN
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured. UCN access allowed for CONTCUT.
	1 to 65535	Discrete

ATTENTION The following information is important to the understanding and use of the CCSRC parameter.

- For FSC-SM Node Specific Flag points, CONTCUT applies to slots 1 through 512 only.
- Only applies if ALMOPT is not set to None, and PNTFORM = Full.
- When it is not configured:
 - its value is 0, and
 - CONTCUT may be written from another UCN node.

Continued on next page

2.5 CXXXX—Parameter Definitions, Continued

CHPINOPR

The CHPINOPR parameter defines whether automatic database saves (checkpoints) are to be performed for the devices connected to this NIM. Table 2-39 defines this parameter.

Table 2-39 CHPINOPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Automatic Checkpoint Inhibit Operation	
Valid Points	Node specific.	
Type	E:CHPINDAC	
Lock	Oper	
Default	Enable	
PtRes	NIM	
Range	Enable	Automatic checkpoint enabled.
	Disable	Automatic checkpoint disabled.

CMDDISFL

The CMDDISFL parameter indicates whether a field device did not go to the commanded state within the allowed feedback time. Table 2-40 defines this parameter.

Table 2-40 CMDDISFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Command Disagree Alarm Flag	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	No command disagree alarm.
	On	Command disagree alarm detected by the point.

Continued on next page

2.5 CXXXX—Parameter Definitions, Continued

CMDDISPR

The CMDDISPR parameter defines the alarm priority of command disagree, command fail and uncommanded change alarms. Table 2-41 defines this parameter.

Table 2-41 CMDDISPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Command Disagree Alarm Priority	
Valid Points	Node specific.	
Type	E:ALPRIOR	
Lock	Engr	
Default	Low	
PtRes	NIM	
Range	NoAction	Alarm is not reported to the system and is not annunciated.
	Journal	Alarm is logged but not reported to the US RTJ or annunciated.
	Low	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit Alarm Summary Display.
	High	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit and Area Alarm Summary Displays.
	Emergency	Alarm is logged, reported to the US RTJ, annunciated, and displayed on all alarm summary displays.
	Printer	Alarm is reported to the US RTJ, but not logged, annunciated or displayed.
	JNLPrint	Alarm is logged and reported to the US RTJ, but not annunciated or displayed.

Continued on next page

2.5 CXXXX—Parameter Definitions, Continued

CMDFALFL

The CMDFALFL parameter indicates whether the PV failed to move after the output command within the allowed command fail time. Command Fail Alarm priority is determined by CMDDISPR. Table 2-42 defines this parameter.

Table 2-42 CMDFALFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Command Fail Alarm Flag	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	PV moved after the output command.
	On	PV did not move after the output command.

COMMAND

The COMMAND parameter allows the operator to control the operation of the timer data point. Table 2-43 defines this parameter.

Table 2-43 COMMAND Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Timer Command	
Valid Points	Timer	
Type	E:COMMAND	
Lock	Oper	
Default	None	
PtRes	FSC-SMM	
Range	None	No effect on the timer.
	Start	Starts a reset timer.
	Reset	Resets a timer (running or expired).

Continued on next page

2.5 CXXXX—Parameter Definitions, Continued

CONTCUT

The CONTCUT parameter allows a store to the OP and the SO parameters that ignore interlock if "On". Table 2-44 defines this parameter.

Table 2-44 CONTCUT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Contact Cut Out	
Valid Points	AnalIn, DigComp, DigIn, and Flag	
Type	Logical	
Lock	Prog	
Default	False	AnalIn, DigComp and DigIn points
	Off	Flag points
PtRes	FSC-SMM	
Range	On	All points
	Off	All points

ATTENTION The following information is important to the understanding and use of the CONTCUT parameter.

- This parameter can be used to cutout alarms on a point when they are generated because of specific conditions at other points which themselves have alarms. For example:
 - you could configure a logic point to monitor the nuisance alarm conditions and then store the contact cutout state of this point using an output connection, or
 - the contact cutout state can be stored by a sequence program in the FSC-SM or AM which monitors the process conditions to determine when the alarms have to be suppressed.
- If CCSRC is a valid alias address, CONTCUT would be locked at View only, and would equal the value of the FSC-SRS's boolean value of CCSRC.
- This parameter also causes the point's alarms:
 - to be journaled and reported to LCN modules, but
 - not to be reported to the Alarm Summary Display at the US.

For Node Specific Flag points, CUTOUT applies to slots 1-512 only.

Continued on next page

2.5 CXXXX—Parameter Definitions, Continued

CRPPXORN

The CRPPXORN parameter accumulates and displays the number of FSC-SMM points processing overruns that have occurred in the current hour. Table 2-45 defines this parameter.

Table 2-45 CRPPXORN Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Current Hour Point Processing Overrun Counter	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	0	
PtRes	FSC-SMM	
Range	≥ 0	

CRUCNORN

The CRUCNORN parameter accumulates and displays the number of FSC-SMM points prefetch overruns that have occurred in the current hour. Table 2-46 defines this parameter.

Table 2-46 CRUCNORN Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Current Hour Point Processing Fetch/Store Counter	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	0	
PtRes	FSC-SMM	
Range	≥ 0	

2.6 DXXXX—Parameter Definitions

D1

The D1 parameter indicates whether Digital Composite input 1 is On or Off. Table 2-47 defines this parameter.

Table 2-47 D1 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital 1 Input	
Valid Points	DigComp	
Type	Logical	
Lock	Prog	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Input is inactive
	On	Input is active

D2

The D2 parameter indicates whether Digital Composite input 2 is On or Off. Table 2-48 defines this parameter.

Table 2-48 D2 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital 2 Input	
Valid Points	DigComp	
Type	Logical	
Lock	Prog	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Input is inactive
	On	Input is active

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

D1_0

The D1_0 parameter defines the PV state that corresponds to input D1 = Off. Table 2-49 defines this parameter.

Table 2-49 D1_0 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Input 1 Equals a PV State of 0	
Valid Points	DigComp	
Type	E:\$PVSTATS	
Lock	View	
Default	PVState0	
PtRes	FSC-SMM	
Range	PVState0	STATETXT0's content describes D1_0.
	PVState1	STATETXT0's content describes D1_0.

ATTENTION The following information is important to the understanding and use of the D1_0 parameter.

- Applies only if NODINPTS = 1.
- D1_0 is always the opposite state of D1_1.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

D1_1

The D1_1 parameter defines the PV state that corresponds to input D1 = On. Table 2-50 defines this parameter.

Table 2-50 D1_1 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Input 1 Equals a PV State of 1	
Valid Points	DigComp	
Type	E:\$PVSTATS	
Lock	Eng/PB	
Default	PVState0	
PtRes	FSC-SMM	
Range	PVState0	STATETXT0's content describes D1_1.
	PVState1	STATETXT0's content describes D1_1.

ATTENTION The following information is important to the understanding and use of the D1_1 parameter.

- Applies only if NODINPTS = 1.
- D1_0 is always the opposite state of D1_1.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

D2D1_00

The D2D1_00 parameter defines the PV state descriptor that is to be used and displayed when inputs D2 and D1 are both Off (00). Table 2-51 defines this parameter.

Table 2-51 D2D1_00 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Input 2 and Digital Input 1 Both Equal a PV State of 0	
Valid Points	DigComp	
Type	E:\$PVSTATS	
Lock	Eng/PB	
Default	MovPV	
PtRes	FSC-SMM	
Range	PVState0	STATETXT0 descriptor
	PVState1	STATETXT1 descriptor
	PVState2	STATETXT2 descriptor
	BadPV	BADPVTXT descriptor
	MovPV	MOVPVTXT descriptor

ATTENTION The following information is important to the understanding and use of the D2D1_00 parameter.

- D2D1_00 configuration requires NODINPTS = 2.
- Option PVState2 cannot be selected unless NOSTATES = 3.
- STATETXT(0-2) is configured for each DigComp point.
- BADPVTXT and MOVPVTXT are configured during Node Specific Data Point configuration for all DigComp points in this FSC-SMM.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

D2D1_01

The D2D1_01 parameter defines the PV state descriptor that is to be used and displayed when input D2 is Off and Input D1 is On (01). Table 2-52 defines this parameter.

Table 2-52 D2D1_01 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Input 2 Equals a State of 0 and Digital Input 1 Equals a PV State of 1	
Valid Points	DigComp	
Type	E:\$PVSTATS	
Lock	Eng/PB	
Default	PVState1	
PtRes	FSC-SMM	
Range	PVState0	STATETXT0 descriptor
	PVState1	STATETXT1 descriptor
	PVState2	STATETXT2 descriptor
	BadPV	BADPVTXT descriptor
	MovPV	MOVPVTXT descriptor

ATTENTION The following information is important to the understanding and use of the D2D1_01 parameter.

- D2D1_01 configuration requires NODINPTS = 2.
- Option PVState2 cannot be selected unless NOSTATES = 3.
- STATETXT(0-2) is configured for each DigComp point.
- BADPVTXT and MOVPVTXT are configured during Node Specific Data Point configuration for all DigComp points in this FSC-SMM.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

D2D1_10

The D2D1_10 parameter defines the PV state descriptor that is to be used and displayed when input D2 is On and Input D1 is Off (10). Table 2-53 defines this parameter.

Table 2-53 D2D1_10 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Input 2 Equals a State of 1 and Digital Input 1 Equals a PV State of 0	
Valid Points	DigComp	
Type	E:\$PVSTATS	
Lock	Eng/PB	
Default	PVState1	
PtRes	FSC-SMM	
Range	PVState0	STATETXT0 descriptor
	PVState1	STATETXT1 descriptor
	PVState2	STATETXT2 descriptor
	BadPV	BADPVTXT descriptor
	MovPV	MOVPVTXT descriptor

ATTENTION The following information is important to the understanding and use of the D2D1_10 parameter.

- D2D1_10 configuration requires NODINPTS = 2.
- Option PVState2 cannot be selected unless NOSTATES = 3.
- STATETXT(0-2) is configured for each DigComp point.
- BADPVTXT and MOVPVTXT are configured during Node Specific Data Point configuration for all DigComp points in this FSC-SMM.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

D2D1_11

The D2D1_11 parameter defines the PV state descriptor that is to be used and displayed when input D2 and D1 are both On (11). Table 2-54 defines this parameter.

Table 2-54 D2D1_11 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Input 2 and Digital Input 1 Both Equal a PV State of 1	
Valid Points	DigComp	
Type	E:\$PVSTATS	
Lock	Eng/PB	
Default	BadPV	
PtRes	FSC-SMM	
Range	PVState0	STATETXT0 descriptor
	PVState1	STATETXT1 descriptor
	PVState2	STATETXT2 descriptor
	BadPV	BADPVTXT descriptor
	MovPV	MOVPVTXT descriptor

ATTENTION The following information is important to the understanding and use of the D2D1_11 parameter.

- D2D1_11 configuration requires NODINPTS = 2.
- Option PVState2 cannot be selected unless NOSTATES = 3.
- STATETXT(0-2) is configured for each DigComp point.
- BADPVTXT and MOVPVTXT are configured during Node Specific Data Point configuration for all DigComp points in this FSC-SMM.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

DATE

The DATE parameter provides the value representing the Date/Time in the FSC-SMM. Table 2-55 defines this parameter.

Table 2-55 DATE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Date	
Valid Points	Node Specif.	
Type	Time	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	N/A	

DAY

The DAY parameter provides the value of the day portion of the LCN Time in the FSC-SMM. Table 2-56 defines this parameter.

Table 2-56 DAY Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Day	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	1 to 31	

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

DISPTYPE

The DISPTYPE parameter defines the Operator personality, and the type of Detail and Group displays present to represent this point. Table 2-57 defines this parameter.

Table 2-57 DISPTYPE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Display Type	
Valid Points	All Data Types	
Type	E:\$DISPTYPE	
Lock	View	
Default	Null	
PtRes	NIM	
Range	AnalogIn, or Null	Analog Input point range
	AnalogOut, or Null	Analog Output point range
	DigComp, or Null	Digital Composite point range
	DigIn, or Null	Digital Input point range
	DigOut, or Null	Digital Output point range
	Flag, or Null	Flag point range
	Logic, or Null	Logic point range
	Numeric, or Null	Numeric point range
	Timer, or Null	Timer point range

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

DISRC(1-2)

The DISRC(1-2) parameter specifies the sources whose values are to be fetched and delivered to Digital Composite data point inputs D1 and D2. The source can be specified using the "Tagname.Parameter" format or the hardware reference address format. Table 2-58 defines this parameter.

Table 2-58 DISRC(1-2) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Composite Input Connection Source	
Valid Points	DigComp	
Type	Universal Ent.Prm	
Lock	PtBld	
Default	Null	
PtRes	FSC-SMM	
Range	0	Not configured.
(!LCXXXXX)	1 to 65535	
Range (Tagname.Parameter.)		Internal Boolean point parameter

ATTENTION

The following information is important to the understanding and use of the DISRC(1-2) parameter.

- Use the Tagname.Parameter format for tagged points where Tagname can be up to 8, or 16 characters (depending on system option).
 - Embedded space characters are prohibited in tagnames
 - Must be a legitimate parameter name.
- Input connection source examples include:
 - Node Specific (i.e. same node) DigIn slot Tagname.PVFL,
 - Node Specific DigOut slot Tagname.SO,
 - Node Specific Flag slot Tagname.PVFL,
 - !BoxXX.FL(nnnn) for a node specific flag that resides in the same FSC-SMM; XX = FSC-SMM node specific number and nnnn = 1 to 2000, and
 - \$NMhhBxx.FL(nnnn) for node specific flag that resides in the same FSC-SMM; hh is the NIM UCN address, xx is the FSC-SMM node specific number, and nnnn = 1 to 2000.
- Use hardware reference address !LCXXXXX for direct connection to the FSC Control Processor.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

DITYPE

The DITYPE parameter defines the type of digital input point. Table 2-59 defines this parameter.

Table 2-59 DITYPE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Input Point	
Valid Points	DigIn	
Type	E:\$DITYPE	
Lock	PtBld	
Default	Status	
PtRes	FSC-SMM	
Range	Status	Used for alarming and event recording.

DLYTIME

The DLYTIME parameter defines the time (in seconds) that a detected alarm is guaranteed to remain in alarm even if the condition clears. Table 2-60 defines this parameter.

Table 2-60 DLYTIME Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Delay Time	
Valid Points	DigIn	
Type	Integer	
Lock	Supr	
Default	0	Seconds
PtRes	FSC-SMM	
Range	0 to 60	Seconds

ATTENTION Requires that ALMOPT = Offnorm.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

DODSTN(1–3)

The DODSTN(1-3) parameter specifies up to three output connection destinations that are to receive the OP output from this digital composite point. The destination can be specified using the "Tagname.Parameter" format or the hardware reference address format. Table 2-61 defines this parameter.

Table 2-61 DODSTN(1–3) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Composite Output Connection Source	
Valid Points	DigComp	
Type	Universal Ent.Prm	
Lock	PtBld	
Default	Null	
PtRes	FSC-SMM	
Range (hardware address)	LCXXXXX, where X = [0...9]	
Range	Alphanumerics, A to Z	Upper case characters only.
(Tagname. Parameter)	Numerals, 0 to 9	All-numeric tagname prohibited.
	Underscore (_)	Cannot be used as first or consecutive characters.

ATTENTION The following information is important to the understanding and use of the DODSTN(1-3) parameter.

- Use the Tagname.Parameter format for tagged points where Tagname can be up to 8 or 16 characters (depending on system option).
- Embedded space characters are prohibited in tagnames.
- Must be a legitimate parameter name.

Continued on next page

2.6 DXXXX—Parameter Definitions, Continued

DODSTN(1–3), continued

- Input connection source examples include:
 - Node Specific DigOut slot Tagname.PVFL,
 - Node Specific DigOut slot Tagname.SO,
 - Node Specific Flag slot Tagname.PVFL,
 - !BoxXX.FL(nnnn) for a node specific flag that resides in the same FSC-SMM; XX = FSC-SMM node specific number and nnnn = 1 to 2000, and
 - \$NMhhBxx.FL(nnnn) for node specific flag that resides in the same FSC-SMM; hh is the NIM UCN address, xx is the FSC-SMM node specific number, and nnnn = 1 to 2000.

Use hardware reference address !LCXXXXXX for direct connection to the FSC Control Processor.

DOTYPE

The DOTYPE parameter defines the type of digital output point. Table 2-62 defines this parameter.

Table 2-62 DOTYPE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Output Point	
Valid Points	DigOut	
Type	E:\$DOTYPE	
Lock	PtBld	
Default	Status	
PtRes	FSC-SMM	
Range	Status	User for alarming and event recording.

2.7 EXXXX—Parameter Definitions

EIPPCODE

The EIPPCODE parameter defines the tagname of the point an AM or CM that is to be notified when an event is detected by this point. Table 2-63 defines this parameter.

Table 2-63 EIPPCODE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Events Initiated Proceeding Point Identifier	
Valid Points	DigComp, DigIn, and Flag	
Type	Ent.Perm	
Lock	PtBld	
Default	Null	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	All-numeric tagname prohibited.
	Underscore (_)	Cannot be used as first or consecutive characters.

ATTENTION The following information is important to the understanding and use of the EIPPCODE parameter.

- Embedded space characters are prohibited in tagnames
- Configuration requires PNTTYPE = DigIn or DigComp and EVTOPT = Eip or EipSoe.
- In FSC-SMM Node Specific Flag Points, this parameter applies only to slots 1 through 512.

Continued on next page

2.7 EXXXX—Parameter Definitions, Continued

EUDESC

The EUDESC parameter is an eight-character descriptor that defines the name of the engineering units (EU) that are displayed on the Group and Detail Displays for this point as shown in Figure 2-1. In this figure, LBS/SEC is the engineering unit descriptor. Table 2-64 defines this parameter.

Table 2-64 EUDESC Definition and Entry Fields


Item	Definitions/Settings	Notes
Full Name	Engineering Units Descriptor	
Valid Points	AnalogIn, AnalogOut, DigComp, DigIn, DigOut, Flag, Numeric, and Timer	
Type	String_8	
Lock	PtBld	
Default	Blank	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	All-numeric tagname prohibited.
	Special Characters	space ! " % & ' () * + - / : ; > < = ? _ , . \$

Continued on next page

2.7 EXXXX—Parameter Definitions, Continued

EUDESC, continued

Figure 2-1 Group and Detail Displays



Continued on next page

2.7 EXXXX—Parameter Definitions, Continued

EVTOPT

The EVTOPT parameter notifies the AM and CM EIPPCODE data points when EVTOPT = Eip and a PV Alarm is generated. A "process special" is executed on the EIPPCODE point. Table 2-65 defines this parameter.

Table 2-65 EVTOPT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Event Recording Option	
Valid Points	DigComp, and DigIn	
Type	E:\$EVTOPT	
Lock	PtBld	
Default	None	
PtRes	FSC-SMM	
Range	None	Event Initiated Processing is not allowed.
	EIP	Event Initiated Processing is allowed; a process special is triggered in AM/CM.
	SOE (applies only to DigIn points)	Points notifies Sequence of Events Processing.
	EIP-SOE (applies only to DigIn points)	EIP and SOE are both allowed.

ATTENTION The EVTOPT parameter:

- configuration requires that NODINPTS > 0, and
- only applies
 - if ALMOPT is set to None, and
 - PNTFORM = Full.

2.8 FXXXX—Parameter Definitions

FBTIME

The FBTIME parameter sets the amount of time (in seconds) that the point should wait before generating a Command Disagree alarm after the operator has issued a start/stop-type command to a field device. Table 2-66 defines this parameter.

Table 2-66 FBTIME Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Feedback Time	
Valid Points	DigComp	
Type	Integer	
Lock	Eng/PB	
Default	1000	Seconds
PtRes	FSC-SMM	
Range	1 to 1000	Seconds

ATTENTION FBTIME can be increased to compensate for a slow-responding field device that does not respond to the operator's command in time to prevent a command-disagree alarm.

Continued on next page

2.8 FXXXX—Parameter Definitions, Continued

FINSTTXT(1–3)

The FINSTTXT(1-3) parameter provides an array of four descriptor strings, one for each of the four possible output states. The descriptor configured for the output state read back from the FSC Control Processor becomes the OP state for this point on the Group and Detail displays. Because the commanded state can differ from the final output state from the FSC Control Processor, the text in FINSTTXT can differ from the text in OPSTTEXT. Table 2-67 defines this parameter.

Table 2-67 FINSTTXT(1–3) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Final Output State Descriptor	
Valid Points	DigComp	
Type	String_8	
Lock	View	
Default	N/A	
PtRes	NIM	
Range	Alphanumerics, A to Z	
	Numerals, 0 to 9	
	Underscore (_)	

Continued on next page

2.8 FXXXX—Parameter Definitions, Continued

FL(1-2000)

The FL parameter is used to define the box Flag, variables for the Safety Manager. Table 2-68 defines this parameter.

Table 2-68 FL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Box Flag Variables	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	-1	
PtRes	FSC-SMM	
Range	1 to 2000	

ATTENTION

The following information is important to the understanding and use of the FL(1-2000) parameter.

- Each FSC-SMM has a set of 2000 local flag variables which can be used by process modules in this FSC-SMM to implement control operations.
- These flags are local to the FSC-SMM.
- The On state is alarmed for the first 512 flags.

Continued on next page

2.8 FXXXX—Parameter Definitions, Continued

FLLSBA

The FLLSBA parameter defines starting alias address of the Flag, Array in the FSC Control Processor. When the value is 0, there are no flags. Table 2-69 defines this parameter.

Table 2-69 FLLSBA Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Least Significant Source Address	
Valid Points	Node Specif.	
Type	Integer	UCN
	Real	LCN
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured.
	1 to 65535	Discrete

ATTENTION The following information is important to the understanding and use of the FLLSBA parameter.

- The range check for this parameter will be dependent on the NFLAG value.
- FSC-SMM will perform the range checking.

Continued on next page

2.8 FXXXX—Parameter Definitions, Continued

FORCE

The FORCE parameter indicates that the FSC Control Processor variable related to the data point is configured so that forcing is enabled. Table 2-70 defines this parameter.

Table 2-70 FORCE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Force Enable	
Valid Points	AnalogIn, AnalogOut, DigIn, and DigOut	
Type	Logical	
Lock	View	
Default	–	Depends on the configuration of the variable in the FSC Control Processor.
PtRes	FSC-SMM	
Range	Off	Forcing of the FSC Control Processor variable is not enabled.
	On	Forcing of the FSC Control Processor variable is enabled.

Continued on next page

2.8 FXXXX—Parameter Definitions, Continued

FORCEFL

The FORCEFL parameter indicates that the FSC Control Processor variable related to the data point is forced provided FORCE=On. Table 2-71 defines this parameter.

Table 2-71 FORCEFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Force Flag	
Valid Points	AnalogIn, AnalogOut, DigIn, and DigOut	
Type	Logical	
Lock	View	
Default	–	Depends on whether forcing is applied by the operator using the FSC user software at run-time.
PtRes	FSC-SMM	
Range	Off	The variable is not forced.
	On	The variable is forced.

2.9 GXXXX—Parameter Definitions

GENDESC

The GENDESC parameter defines up to 12 generic descriptors that can be assigned up to 12 logic channels. Table 2-72 defines this parameter.

Table 2-72 GENDESC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Generic Descriptor	
Valid Points	Logic	
Type	String_8	
Lock	PtBld	
Default	Blank	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	All-numeric tagname prohibited.
	Special Characters	space ! " % & ' () * + - / : ; > < = ? _ , . \$

2.10 HXXXX—Parameter Definitions

HIGHAL

The HIGHAL parameter is used by the system to ensure that when two or more different types of alarms occur on a point at the same time, the most important alarm appears on the point's Group, Detail and Alarm Summary displays. Table 2-73 defines this parameter.

Table 2-73 HIGHAL Definition and Entry Fields

Item	Definitions/Settings	Notes																																															
Full Name	Highest Alarm Detected																																																
Valid Points	AnalogIn, DigComp, DigIn, and Flag																																																
Type	E:ALMTYPE																																																
Lock	View																																																
Default	NoAlarm																																																
PtRes	NIM																																																
Range	The alarm types associated with HIGHAL differ for each of the valid points. The following table identifies the alarm and its compatible point type.																																																
	<table><tr><th>ALARM TYPE</th><th>AI</th><th>DC</th><th>DI</th><th>FLG</th></tr><tr><td>BadCTI-Bad Control Alarm</td><td></td><td>X</td><td></td><td></td></tr><tr><td>BadPV-Bad PV</td><td>X</td><td></td><td></td><td></td></tr><tr><td>CmdDis-Command Disagree</td><td></td><td>X</td><td>X</td><td></td></tr><tr><td>NoAlarm-No Alarm Detected</td><td>X</td><td>X</td><td>X</td><td>X</td></tr><tr><td>OffNorm-Off Normal State</td><td></td><td>X</td><td>X</td><td>X</td></tr><tr><td>PVHI-PV High</td><td>X</td><td></td><td></td><td></td></tr><tr><td>PVLO-PV Low</td><td>X</td><td></td><td></td><td></td></tr><tr><td>UnCEvt-Uncertain Event Detected</td><td></td><td>X</td><td>X</td><td></td></tr></table>				ALARM TYPE	AI	DC	DI	FLG	BadCTI-Bad Control Alarm		X			BadPV-Bad PV	X				CmdDis-Command Disagree		X	X		NoAlarm-No Alarm Detected	X	X	X	X	OffNorm-Off Normal State		X	X	X	PVHI-PV High	X				PVLO-PV Low	X				UnCEvt-Uncertain Event Detected		X	X	
ALARM TYPE	AI	DC	DI	FLG																																													
BadCTI-Bad Control Alarm		X																																															
BadPV-Bad PV	X																																																
CmdDis-Command Disagree		X	X																																														
NoAlarm-No Alarm Detected	X	X	X	X																																													
OffNorm-Off Normal State		X	X	X																																													
PVHI-PV High	X																																																
PVLO-PV Low	X																																																
UnCEvt-Uncertain Event Detected		X	X																																														

ATTENTION The following information is important to the understanding and use of the HIGHAL parameter.

- The OffNorm alarm Type indicates that the current PV state is not the configured PVNORMAL state.
- For the Flag Point, the Off Normal state (STATE1) is the alarmed state.
- The BadCtl alarm indicates that BADCTLFL = On.

Continued on next page

2.10 HXXXX—Parameter Definitions, Continued

HIGHALPR

The HIGHALPR parameter defines the priority of the highest alarm currently detected at the data point. Table 2-74 defines this parameter.

Table 2-74 HIGHALPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Highest Level Alarm's Priority	
Valid Points	AnalogIn, DigComp, DigIn, and Flag	
Type	E:ALPRIOR	
Lock	View	
Default	NoAction	
PtRes	NIM	
Range	NoAction	Alarm is not reported to the system and is not annunciated.
	Journal	Alarm is logged but not reported to the US RTJ or annunciated.
	Low	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit Alarm Summary Display.
	High	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit and Area Alarm Summary Displays.
	Emergency	Alarm is logged, reported to the US RTJ, annunciated, and displayed on all alarm summary displays.
	Printer	Alarm is reported to the US RTJ, but not logged, annunciated or displayed.
	JNLPrint	Alarm is logged and reported to the US RTJ, but not annunciated or displayed.

Continued on next page

2.10 HXXXX—Parameter Definitions, Continued

hour

The HOUR parameter provides the value of the hour portion of the LCN Time in the FSC-SMM. Table 2-75 defines this parameter.

Table 2-75 HOUR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Hour	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	0 to 23	

2.11 IXXXX—Parameter Definitions

I0-2

The I0-2 parameter permits the FSC Control Processor to control (turn On or Off) the override interlocks. Table 2-76 defines this parameter.

Table 2-76 I0-2 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Override Interlocks for Output States 0, 1 and 2	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Override interlock has no effect on the point state.
	On	Override interlock prevents UCN-initiated writes to OP.

ATTENTION

The following information is important to the understanding and use of the I0-2 parameter.

- The override control function must be present in the FSC Control Processor.
- Digital Composite points will update the OP in regard to the output states. This, in turn, reflects the override function.
- The operator cannot change the output state when any override interlock is On.
- An override interlock is provided for each of the three states (I0, I1 and I2).

Continued on next page

2.11 IXXXX—Parameter Definitions, Continued

INPTDIR (AnalogIn points)

When used with Analog Input Points, the INPTDIR parameter specifies whether direct or reverse action is to be used for the PV input at this data point. Table 2-77 defines this parameter.

Table 2-77 INPTDIR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Input Direction	Analog Input points.
Valid Points	AnalogIn	
Type	E:POLARITY	
Lock	Eng/PB	
Default	Direct	
PtRes	FSC-SMM	
Range	Direct	Highest energy from sensor = 100% PV.
	Indirect	Highest energy from sensor = 0% PV.

ATTENTION The following information is important to the understanding and use of the INPTDIR parameter.

- Direct means PVCALC increases as PVRAW increases.
- Indirect means PVCALC decreases as PVRAW increases.
- Applies only if PVCHAR = Linear or Sqrroot.

Continued on next page

2.11 IXXXX—Parameter Definitions, Continued


INPTDIR (DigIn points)

When used with Digital Input Points, the INPTDIR parameter defines the contact condition required to light the upper or lower box on its Group or Detail displays (see Figure 2-2). Table 2-78 defines this parameter.

Table 2-78 INPTDIR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Input Direction	Digital Input points.
Valid Points	DigIn	
Type	E:POLARITY	
Lock	Eng/PB	
Default	Direct	
PtRes	FSC-SMM	
Range	Direct	Open $\geq$ PVRAW = Off Closed $\leq$ PVRAW = On.
	Reverse	Open $\geq$ PVRAW = On Closed $\leq$ PVRAW = Off.

Figure 2-2 Digital Input Point Group and Detail Display Examples



2.12 KXXXX—Parameter Definitions

KEYWORD

The KEYWORD parameter defines an eight-character descriptor that is used to describe an important aspect of this particular data point. Table 2-79 defines this parameter.

Table 2-79 KEYWORD Definition and Entry Fields


Item	Definitions/Settings	Notes
Full Name	Keyword Descriptor	
Valid Points	AnalogIn, AnalogOut, DigComp, DigIn, DigOut, Flag, Numeric, and Timer	
Type	String_8	
Lock	PtBld	
Default	Blank	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	All-numeric tagname prohibited.
	Underscore (_)	Cannot be used as the first character and consecutive underscores are prohibited.

Continued on next page

2.12 KXXXX—Parameter Definitions, Continued

KEYWORD,
continued

Figure 2-3 Group and Detail Displays



2.13 LXXXX—Parameter Definitions

L(1-12)

The L parameter defines whether an external output value is logical or real. Table 2-80 defines this parameter.

Table 2-80 L Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	External Output Value	
Valid Points	Logic	
Type	Logical	
	Real	
Lock	View	
Default	NaN	
PtRes	FSC-SMM	
Range	N/A	

ATTENTION The following information is important to the understanding and use of the L(1-12) parameter.

- Each input may be logical or real.
- If accessed from the LCN, L must be accessed as a Logical data type.
- The actual data type cannot be checked against the connection requirement during point building.
- A mismatch cannot be determined until run time; therefore, the user cannot be flagged regarding an error.

LASTPV

The LASTPV parameter contains the last valid PV value. Table 2-81 defines this parameter.

Table 2-81 LASTPV Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Last PV Value	
Valid Points	AnalIn	
Type	Real	
Lock	View	
Default	NaN	
PtRes	FSC-SMM	
Range	N/A	

Continued on next page

2.13 LXXXX—Parameter Definitions, Continued

LIBADOPT

The LIBADOPT parameter defines the default value (Hold, Off, On) used whenever a Boolean input fetch for a logic slot input connection fails. Table 2-82 defines this parameter.

Table 2-82 LIBADOPT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Logic Bad-Input Handling Option	
Valid Points	Logic	
Type	E:\$LIBADOP	
Lock	PtBld	
Default	Hold	
PtRes	FSC-SMM	
Range	On	On state is substituted for a bad input.
	Off	Off state is substituted for a bad input.
	Hold	Hold state is substituted for a bad input.

ATTENTION The following information is important to the understanding and use of the LIBADOPT parameter.

- This option applies only to boolean parameters being transferred by the Logic Point.
- For non-boolean parameters, the default state of "HOLD" always applies.

Continued on next page

2.13 LXXXX—Parameter Definitions, Continued

LISRC(1–12)

The LISRC(1–12) parameter specifies the sources whose values are to be fetched and delivered to Logic data point slots L1 through L12. The source can be specified using the "Tagname.Parameter" format or the hardware reference address format. Table 2-83 defines this parameter.

Table 2-83 LISRC(1–12) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Logic Input Connection Source	
Valid Points	Logic	
Type	Universal Ent.Prm	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured.
(!LCXXXXX)	1 to 65535	
Range (Tagname. Parameter)		Internal Boolean point parameter

ATTENTION

The following information is important to the understanding of the LISRC(1–12) parameter.

- Any parameter of any point of any node can be used as long as it returns a value with the type:
 - Boolean
 - Real
 - Integer
 - Unsigned integer
 - Enumeration
 - Self-defining enumeration
- The Logic point will transfer all data types to output as a "Real" value (except Boolean, which gets transferred as Boolean).
- Use hardware reference address !LCXXXXX for direct connection to the FSC Control Processor.

Continued on next page

2.13 LXXXX—Parameter Definitions, Continued

LMNAME

The LMNAME parameter defines a two-element array of up to eight characters per element which names each of the Safety Manager's redundant FSC-SMM modules. Table 2-84 defines this parameter.

Table 2-84 LMNAME Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Redundant Pair Names	
Valid Points	Node Specif.	
Type	String_8	
Lock	PtBld	
Default	Pref	
	Non-Pref	
PtRes	NIM	
Range	Preferred	Identifies the preferred FSC-SMM of a redundant pair.
	Non-Preferred	Identifies the non-preferred FSC-SMM of a redundant pair.

LMSRC

The LMSRC parameter defines the Local Manual source address within the FSC Control Processor. Table 2-85 defines this parameter.

Table 2-85 LMSRC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Local Manual Source Address	
Valid Points	DigComp	
Type	Unsigned Integer	UCN
	Real	LCN
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured.
	1 to 65535	

Continued on next page

2.13 LXXXX—Parameter Definitions, Continued

LOADSCOP

The LOADSCOP parameter defines the scope of the point-build procedure for the NIM and FSC-SM configuration. Table 2-86 defines this parameter.

Table 2-86 LOADSCOP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Load Scope	
Valid Points	UCN Node	
Type	E:\$LOADSCOP	
Lock	PtBld	
Default	NimOnly	
PtRes	NIM	
Range	NimOnly	Configured data is to be loaded in the NIM.
	NimAndPM	Configured data is to be loaded in the NIM and the FSC-SM

ATTENTION The following information is important to the understanding and use of the LOADSCOP parameter.

- Indicates whether or not a given parameter is checked at the NIM or FSC-SM level. If at the NIM level
 - FSC-SM-resident parameters are checked for form only, and not validity.
- When points are built to a NIM and the NIM is started with no database, the points need to be reloaded from checkpoint or be reloaded.
 - If the database is to be reconfigured, the FSC-SMM must be in Idle and the point execution state must be inactive.
 - This allows the point build operation to override the database that already exists.
- To delete entities from the FSC-SM database, the LOADSCOP parameter must be changed from NimAndPM and NimOnly.
 - The database can then be reloaded and the desired entities can be deleted.

Continued on next page

2.13 LXXXX—Parameter Definitions, Continued

LOCALMAN

The LOCALMAN parameter represents a flag which indicates whether the points output(s) is being controlled manually or automatically. Table 2-87 defines this parameter.

Table 2-87 LOCALMAN Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Local Manual Flag	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Automatic – Output is not being controlled locally.
	On	Manual – Output is being controlled locally.

ATTENTION The following information is important to the understanding and use of the LOCALMAN parameter.

- When this flag is on, it usually indicates that the "hand/off/auto" switch is not in the "auto" position.
- This flag is off when Local Manual Source Address (LMSRC) equals 0.

ATTENTION This parameter is only an indication. It does not affect the operation of the FSC-SMM's DC point.

Continued on next page

2.13 LXXXX—Parameter Definitions, Continued

LOCUTOFF

The LOCUTOFF parameter defines the low cut-off point for flow inputs. Table 2-88 defines this parameter.

Table 2-88 LOCUTOFF Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Low Signal Cut-Off for Flow Inputs	
Valid Points	AnalIn	
Type	Real	
Lock	Eng/PB	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN PVEULO to PVEUHI,	

ATTENTION Applies only if PVCHAR = Linear or Sqrroot.

LODSTN(1–12)

The LODSTN(1–12) parameter specifies up to 12 destinations to which the current values of the logic slot outputs are supplied. They are specified using the FSC Control Processor's alias address. The source can be specified using the "Tagname.Parameter" format or the hardware reference address format. Table 2-89 defines this parameter.

Table 2-89 LODSTN(1–12) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Logic Output Connection Destination	
Valid Points	Logic	
Type	Universal Ent.Prm	
Lock	PtBld	
Default	0	Not configured.
PtRes	FSC-SMM	
Range	0	Not configured.
(!LCXXXXX)	1 to 65535	
Range (Tagname. Parameter)		Internal Boolean point parameter

ATTENTION Use hardware reference address !LCXXXXX for direct connection to the FSC Control Processor.

Continued on next page

2.13 LXXXX—Parameter Definitions, Continued

LOENBL(1–12)

The LOENBL(1–12) parameter specifies source (alias) address in the FSC Control Processor for the Logic Output Enable. It allows the respective output connection defined by LODSTN to write the value of the specified logic slot parameter to the destination. The logic output is allowed when the enable function is On. Table 2-90 defines this parameter.

Table 2-90 LOENBL(1–12) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Logic Output Enable	
Valid Points	Logic	
Type	Unsigned Integer	UCN
	Real	LCN
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured.
	1 to 65535	

LOGMIX

The LOGMIX parameter indicates the configuration of the logic point. Note that in the FSC-SM, there are no options for internal control blocks. Table 2-91 defines this parameter.

Table 2-91 LOGMIX Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Logic Mix	
Valid Points	Logic	
Type	E:\$LOGMIX	
Lock	View	
Default	12_0_12	
PtRes	FSC-SMM	
Range	12_0_12	Fixed

Continued on next page

2.13 LXXXX—Parameter Definitions, Continued

LSPPXORN

The LSPPXORN parameter indicates the number of point processing overruns that have been detected in the last hour. Table 2-92 defines this parameter.

Table 2-92 LSPPXORN Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Last Hours Point Processing Fetch/Store Overruns	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	0	
PtRes	FSC-SMM	
Range	≥ 0	

ATTENTION LSPPXORN is set equal to the contents of CRPPXORN every hour, on the hour.

LSUCNORN

The LSUCNORN parameter indicates the number of UCN access overruns that have been detected in the last hour. Table 2-93 defines this parameter.

Table 2-93 LSUCNORN Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Last Hours UCN Access Overruns	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	0	
PtRes	FSC-SMM	
Range	≥ 0	

2.14 MXXXX—Parameter Definitions

MINUTE

The MINUTE parameter provides the value of the minute portion of the LCN Time in the FSC-SMM. Table 2-94 defines this parameter.

Table 2-94 MINUTE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Minute	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	0 to 59	

Continued on next page

2.14 MXXXX—Parameter Definitions, Continued

MODATTR

The MODATTR parameter defines whether an operator or sequence program has the authority to change certain parameters of this data point. Table 2-95 defines this parameter.

Table 2-95 MODATTR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Mode Attribute	
Valid Points	AnalogOut, DigComp, and DigOut	
Type	E:MODATTR	
Lock	Oper	
Default	Operator	
PtRes	FSC-SMM	
Range	Operator	Operator can set: • Mode, • OP, • SP, • Ratio, and • Bias
	Program	Program can set: • Mode, • OP, • SP, • Ratio, and • Bias

ATTENTION The following information is important to the understanding and use of the MODATTR parameter.

- At the Universal Station, the mode attribute is displayed next to the mode of the data point.
- If the mode attribute is:
 - Program — a -P appears to the left of MODE.
 - Operator — blanks are displayed to the left of mode.
- MODATTR change requires REDTAG = Off.
- When NMODATTR = None and the "normal mode" button on the Operator's keyboard is pressed, MODATTR = NMODATTR.

Continued on next page

2.14 MXXXX—Parameter Definitions, Continued

MODE

The MODE parameter defines the current mode of the data point. Table 2-96 defines this parameter.

Table 2-96 MODE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Mode	
Valid Points	AnalgOut, DigOut, and DigCompt	
Type	E:MODE	
Lock	Oper	
Default	Manual	
PtRes	FSC-SMM	
Range	Man	Manual – Operator or Program provides the current OP value.
	Cas	Cascade – Point receives its OP value from a primary data point.
	Normal	NMODE determines this point's mode.

ATTENTION The following information is important to the understanding and use of the MODE parameter.

- MODATTR determines whether operator or the sequence program provides the output value for this point.
- If PNTFORM = Component, then the MODE parameter is not applicable for this data point
- When the range is set to 2–Cas and RCASOPT = Ddc:
 - the data point receives its OP value from an AM point.
- MODE change by an operator requires that:
 - MODATTR = Operator,
 - MODEPERM = Permit, and
 - REDTAG = Off.
- MODE change by a program requires that:
 - MODATTR = Operator, and
 - REDTAG = Off.

Continued on next page

2.14 MXXXX—Parameter Definitions, Continued

MODEAPPL

The MODEAPPL parameter is an array (1...4) of Booleans which correspond to the four possible operating modes. When a given Boolean is true, the corresponding mode is allowed for the data point. Table 2-97 defines this parameter.

Table 2-97 MODEAPPL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Mode Applicability	
Valid Points	AnalgOut, DigComp, and DigOut	
Type	Logical	Array (1...4)
Lock	View	
Default	Man = True	(1)
	Auto = False	(2)
	Bcas = False	(3)
	Cas = True or False	True for AnalgOut (4) False for DigComp and DigOut.
PtRes	FSC-SMM	
Range	N/A	

MODEPERM

The MODEPERM parameter determines whether the operator can change the mode of this point. Table 2-98 defines this parameter.

Table 2-98 MODEPERM Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Mode Permissive	
Valid Points	AnalgOut, DigComp, and DigOut	
Type	E:MODEPERM	
Lock	Eng/PB	
Default	Permit	
PtRes	FSC-SMM	
Range	Permit	Operator can change mode.
	NotPerm	Operator cannot change mode.

Continued on next page

2.14 MXXXX—Parameter Definitions, Continued

MOMSTATE

The MOMSTATE parameter defines which of the output states are momentary. Table 2-99 defines this parameter.

Table 2-99 MOMSTATE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Momentary Output States	
Valid Points	DigComp	
Type	E:MOMSTAT	
Lock	Eng/PB	
Default	None	
PtRes	FSC-SMM	
Range	None	No momentary output states.
	Mom_0	State 0 is momentary if NOSTATES = 2.
	Mom_1	State 1 is momentary if NOSTATES = 2 or 3.
	Mom_2	State 2 is momentary if NOSTATES = 3.
	Mom_1_2	State 1 and 2 are momentary; valid if NOSTATES = 3.

MONTH

The MONTH parameter provides the value of the month portion of the LCN Time in the FSC-SMM. Table 2-100 defines this parameter.

Table 2-100 MONTH Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Month	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	1 to 12	

Continued on next page

2.14 MXXXX—Parameter Definitions, Continued

MOVPVFL

The MOVPVFL parameter indicates whether the PV is moving from one state to another. Table 2-101 defines this parameter.

Table 2-101 MOVPVFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Moving PV Flag	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	PV is not moving.
	On	PV is moving.

MOVPVTEXT

The MOVPVTEXT parameter defines the state descriptor that is displayed when the digital composite point is changing from one state to another, or is between states. This descriptor will be displayed for all digital composite points in this FSC-SM. Table 2-102 defines this parameter.

Table 2-102 MOVPVTEXT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Moving PV Text Descriptor	
Valid Points	Node Specif.	
Type	String_8	
Lock	PtBld	
Default	Moving	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	
	Underscore (_)	

ATTENTION If NODENUM is an even number, this parameter is hidden on the UCN Node Configuration Display.

2.15 NXXXX—Parameter Definitions

NAISLOT

The NAISLOT parameter defines the number of Analog Input slots assigned to the point. Table 2-103 defines this parameter.

Table 2-103 NAISLOT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Analog Input Slots	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 1000	

ATTENTION

The following information is important to the understanding and use of the NAISLOT parameter.

- The actual range depends on the configured scan rate.
- The range check will be based on scan rate and overall box configuration.
- The FSC-SMM will perform the range checking.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NAME

The NAME parameter identifies this point to the system, reports, logs, and on Group and Detail displays as illustrated in Figure 2-4. Table 2-104 defines this parameter.

Table 2-104 NAME Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Tagname	
Valid Points		
Type	Ent.Prm	
Lock	Eng/PB	
Default	N/A	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	All-numeric tagname prohibited.
	Underscore (_)	Cannot be used as first or consecutive characters.

ATTENTION The following information is important to the understanding and use of the NAME parameter.


- Use the Tagname.Parameter format for tagged points where Tagname can be up to 8 or 16 characters (depending on system option).
 - Embedded space characters are prohibited in tagnames.
- When configuring data points:
 - Flag and Numeric points do not have to be configured using the Data Entity Builder (DEB).
 - All other data points must be configured using the DEB, and require a tagname to be specified during the point build process.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NAME
Continued

Figure 2-4 Group and Detail Displays



Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NAOSLOT

The NAOSLOT parameter defines the number of Analog Output slots assigned to the point. Table 2-105 defines this parameter.

Table 2-105 NAOSLOT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Analog Output Slots	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 1000	

ATTENTION The actual range check will be calculated on the PU count for each point type and the mix of configured points desired. The FSC-SMM will perform the range checking.

NDCSLOT

The NDCSLOT parameter defines the number of Digital Composite slots reserved for this Safety Manager. Table 2-106 defines this parameter.

Table 2-106 NDCSLOT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Digital Composite Slots	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 1000	

ATTENTION The actual range check will be calculated on the PU count for each point type and the mix of configured points desired. The FSC-SMM will perform the range checking.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NDISLOT

The NDISLOT parameter defines the number of Digital Input slots reserved for this Safety Manager. Table 2-107 defines this parameter.

Table 2-107 NDISLOT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Digital Input Slots	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 2000	

ATTENTION The actual range check will be calculated on the PU count for each point type and the mix of configured points desired. The FSC-SMM will perform the range checking.

NDOSLOT

The NDOSLOT parameter defines the number of Digital Output slots reserved for this Safety Manager. Table 2-108 defines this parameter.

Table 2-108 NDOSLOT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Digital Output Slots	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 2000	

ATTENTION The actual range check will be calculated on the PU count for each point type and the mix of configured points desired. The FSC-SMM will perform the range checking.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NFLAG

The NFLAG parameter defines the number of flags in the Node Specific data point. Table 2-109 defines this parameter.

Table 2-109 NFLAG Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Flags	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 2000	

ATTENTION The actual range check for this parameter will depend on the FLLSBA. The FSC-SMM will perform the range checking.

NLOGSLOT

The NLOGSLOT parameter defines the number of Logic slots reserved for this Safety Manager. Table 2-110 defines this parameter.

Table 2-110 NLOGSLOT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Logic Slots	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 30*	

* May be lower for 0.5 second scan rate.

ATTENTION The actual range check will be calculated on the PU count for each point type and the mix of configured points desired. The FSC-SMM will perform the range checking.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NMODATTR

The NMODATTR parameter defines whether an operator or program can change certain parameters (such as Mode, SP, OP) of a data point when it is in the normal mode. Table 2-111 defines this parameter.

Table 2-111 NMODATTR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Normal Mode Attribute	
Valid Points	AnalogOut, DigComp, and DigOut	
Type	E:NMODATTR	
Lock	Engr	
Default	None	
PtRes	FSC-SMM	
Range	None	MODATTR is not affected (none configured).
	Operator	MODATTR changes to Operator when "Normal Mode" key is pressed.
	Program	MODATTR changes to Program when "Normal Mode" key is pressed.

ATTENTION The following information is important to the understanding and use of the NMODATTR parameter.

- If NMODATTR = Operator or Program, and the "Normal Mode" key on the operator's keyboard is pressed
 - MODATTR = NMODATTR.
- If NMODATTR is to be changed
 - the engineer must change it.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NMODE (AnalgOut)

The NMODE parameter allows an engineer to define the normal mode for this data point. Table 2-112 defines this parameter.

Table 2-112 NMODE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Normal Mode	For Analog Output points.
Valid Points	AnalgOut	
Type	E:MODE	
Lock	Engr	
Default	None	
PtRes	FSC-SMM	
Range	None	No Normal operating mode is configured.
	Man	Manual operation is configured as the normal mode.
	Cas	Cascade operation is configured as the normal mode.

ATTENTION NMODE configuration for the Cas range option requires that RCASOPT = Ddc.

NMODE (DigComp, DigOut)

The NMODE parameter allows an engineer to define the normal mode for this data point. Table 2-113 defines this parameter.

Table 2-113 NMODE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Normal Mode	For Digital Composite and Digital Output points
Valid Points	DigComp, and DigOut	
Type	E:MODE	
Lock	View	
Default	None	
PtRes	FSC-SMM	
Range	Man	Manual operation is configured as the normal mode.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NN(1–1000)

The NN(1–1000) parameter provides the value of the specified numeric variable in an array of up to 1000. The upper boundary of this array is determined by the parameter NNUMERIC. Table 2-114 defines this parameter.

Table 2-114 NN(1–1000) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Numeric Value	
Valid Points	Node Specif.	
Type	Real	
Lock	Oper	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	Not a Number
	Real	Real Number

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NNLSBA

The NNLSBA parameter defines the starting (least significant) alias address of a contiguous block within the FSC-SRS. Table 2-115 defines this parameter.


Table 2-115 NNLSBA Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Least Significant Alias Address	
Valid Points	Node Specif.	
Type	Integer	UCN
	Real	LCN
Lock	PtBId	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured.
	1 to 65535	

ATTENTION

The following information is important to the understanding and use of the NNLSBA parameter.

- The actual range check will depend on the NNUMERIC value.
- The FSC-SMM will perform the range checking.
- PLC addresses must be contiguous in BI, COM area.



For more information on alias addresses refer to section 2.2 of the *FSC Safety Manager Implementation Guidelines* in this binder.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NNUMERIC

The NNUMERIC parameter defines the number of Numerics in the data point. Table 2-116 defines this parameter.

Table 2-116 NNUMERIC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Numerics	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 1000	

ATTENTION

The following information is important to the understanding and use of the NNUMERIC parameter.

- The actual range check will be dependent on the value of NNLSBA.
- The FSC-SMM will perform the range checking.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODEASSN (UCN Node)

The NODEASSN parameter defines whether this or another NIM is the primary NIM for UCN. Table 2-117 defines this parameter.

Table 2-117 NODEASSN Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Node Assignment	
Valid Points	UCN Node	
Type	E:\$NODEASN	
Lock	PtBld	
Default	ThisNIM	
PtRes	NIM	
Range	ThisNIM	This NIM is the primary NIM for this UCN.
	RemotNIM	Another NIM is the primary NIM for this UCN.

ATTENTION

The following information is important to the understanding and use of the NODEASSN parameter.

- When multiple NIMs are connected to a single UCN network, the one identified as ThisNIM functions as the primary NIM.
- ThisNIM supports parameter:
 - fetch/store operations,
 - alarms,
 - AM control strategy, and
 - checkpointing operations.
- RemotNIM is connected to a separate LCN network.
- During node specific configuration:
 - checkpointing, and database restore operations occur on the RemotNIM.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODENUM (UCN Node and Node Specif.)

The NODENUM parameter defines the address of the NIM and the FSC-SMs on this UCN. Table 2-118 defines this parameter.

Table 2-118 NODENUM Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Node Number	For Node Specific points.
Valid Points	UCN Node, and Node Specif.	
Type	Integer	
Lock	PtBld	
Default	N/A	
PtRes	FSC-SMM	
Range	0 to 64	

ATTENTION The following information is important to the understanding and use of the NODENUM parameter.

- The node number assigned to the NIM must be the lowest node number in this UCN.
- The NODENUM must be an odd number whether PKGOPT = Option 1 (nonredundant) or Option 2 (redundant).
- The odd number NODENUM restriction and because the NIM takes up one odd address and the next consecutive even address, the maximum number of non-NIM nodes on a single UCN is 31.
- The maximum number of non-NIM nodes on a single UCN is 31 (32 total nodes, 64 node addresses) because each UCN node can be assigned two node addresses to support redundancy:
 - The primary of the node pair requires an odd node address, and
 - The secondary of the node pair requires the next consecutive even address.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODENUM
(all points except
Node Specif. and UCN
Node)

The NODENUM parameter defines the UCN address of the Safety Manager in which this point resides. Table 2-119 defines this parameter.

Table 2-119 NODENUM Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Node Number	For Analog Input, Analog Output, Digital Composite, Digital Input, Digital Output, Flag, Logic, Numeric, and Timer points.
Valid Points	AnalogIn, AnalogOut, DigIn, DigOut, DigComp, Flag, Logic, Timer, and Numeric	
Type	Integer	
Lock	PtBld	
Default	None	
PtRes	NIM	
Range	1 to 64	

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODESC

The NODESC parameter defines the number of user-defined generic descriptors that are to be used on this Logic slot. Table 2-120 defines this parameter.

Table 2-120 NODESC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Generic Descriptors	
Valid Points	Logic	
Type	Integer	
Lock	PB	
Default	0	
PtRes	NIM	
Range	0 to 12	

ATTENTION

To allow the you to customize the descriptors used for displaying the logic slot on the Universal Station displays:

- the parameter in the logic slot to which the generic descriptor is attached is defined by the PRMDESC(n) parameter, and
- the corresponding descriptors are defined by the GENDESC(n) parameters.

NODESTAT

The NODESTAT parameter indicates the current status of the NIM.

Table 2-121 defines this parameter.

Table 2-121 NODESTAT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	NIM Node Status	
Valid Points	UCN Node	
Type	E:\$NODESTA	
Lock	View	
Default	N/A	
PtRes	NIM	
Range	ConfigMis	Configuration mismatch.
	OffNet	No NIM/FSC-SMM communication.
	Run	NIM is configured and running.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODESTS (UCN Node)

The NODESTS parameter indicates the current overall status of the NIM. Table 2-122 defines this parameter.

Table 2-122 NODESTS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	NIM Node Summary Status	For UCN Node points.
Valid Points	UCN Node	
Type	E:\$DSPSTAT	
Lock	View	
Default	N/A	
PtRes	NIM	
Range	ConfigMis	Configuration mismatch.
	Fail	Complete failure.
	NotSync	Not synchronized.
	OffNet	No NIM/FSC-SMM communication.
	OK	NIM is performing normally.
	PartFail	Partial failure.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODESTS (Node Specif.)

The NODESTS parameter indicates the current overall status of the Safety Manager on the UCN. Table 2-123 defines this parameter.

Table 2-123 NODESTS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SM Node Summary Status	
Valid Points	Node Specif.	
Type	E:\$DSPSTAT	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	OK	FSC-SMM is performing normally (no Soft Failures).
	PartFail	Partial failure in a running FSC-SM (Soft Failures).
	Idle	FSC-SMM is idle (not processing any points) without Soft Failures.
	PF_Idle	FSC-SMM is idle (not processing any points) with Soft Failures.
	Failed	FSC-SM sent 'failed' message to NIM.
	Alive	No event reports or point processing.
	Loading	FSC-SMM personality or database is loading.
	PowerOn	AC and DC power is on at the FSC-SMM.
	OffNet	No NIM/FSC-SMM communication.

ATTENTION Loading of the FSC-SMM's operating personality requires that NODESTS = Alive.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODETYPE (UCN Node)

The NODETYPE parameter defines the type of UCN node as Network Interface Module. Table 2-124 defines this parameter.

Table 2-124 NODETYPE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	UCN Node Type	
Valid Points	UCN Node	
Type	E:\$UCNNDTY	
Lock	PtBId	
Default	NIM	
PtRes	NIM	
Range	NIM	Network Interface Module

NODETYPE (Node Specif. and UCN Node)

The NODETYPE parameter defines the type of UCN node as Safety Manager. Table 2-125 defines this parameter.

Table 2-125 NODETYPE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	UCN Node Type	
Valid Points	Node Specif., UCN Node	
Type	E:\$HPNNDTY	
Lock	PtBId	
Default	NotConfig	
PtRes	NIM	
Range	NotConfig	Not configured.
	FSC-SM	Safety Manager

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODETYP
(AnalogIn, AnalogOut,
DigComp, DigIn,
DigOut, Flag, Logic,
Numeric, Timer)

The NODETYP parameter defines the type of UCN node as Safety Manager. Table 2-126 defines this parameter.

Table 2-126 NODETYP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	UCN Node Type	
Valid Points	AnalogIn, AnalogOut, DigComp, DigIn, DigOut, Flag, Logic, Numeric, and Timer	
Type	E:\$UCNNDTY	
Lock	View	
Default	NotConfig	Not configured.
PtRes	NIM	
Range	FSC-SM	Safety Manager

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODFSTAT

The NODFSTAT parameter defines the status of the UCN node. Table 2-127 defines this parameter.

Table 2-127 NODFSTAT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Node's Functional Status	
Valid Points	Node Specif.	
Type	E:\$NODFSTA	
Lock	Supr	
Default	Basic	Not configured.
PtRes	NIM	
Range	Full	All LCN devices can read/write from/to this node.
	Basic	AM and CM cannot write to this node.

NODINPTS

The NODINPTS parameter defines the number of digital input connections to this data point. Table 2-128 defines this parameter.

Table 2-128 NODINPTS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Digital Inputs	
Valid Points	DigComp	
Type	Integer	
Lock	PtBld	
Default	1	
PtRes	FSC-SMM	
Range	0	No digital inputs.
	1	One digital input.
	2	Two digital inputs.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NODOPTS

The NODOPTS parameter defines the number of digital output connections to this data point. Table 2-129 defines this parameter.

Table 2-129 NODOPTS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Digital Outputs	
Valid Points	DigComp	
Type	Integer	
Lock	PtBld	
Default	1	
PtRes	FSC-SMM	
Range	0	No digital outputs
	1	One digital output
	2	Two digital outputs
	3	Three digital outputs

NOLINPTS

The NOLINPTS parameter defines the number of inputs to this Logic Block. Table 2-130 defines this parameter.

Table 2-130 NOLINPTS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Logic Input Points	
Valid Points	Logic	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	12	

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NOLOGBLK

The NOLOGBLK parameter defines the number of logic blocks that have been configured for a particular logic slot. Table 2-131 defines this parameter.

Table 2-131 NOLOGBLK Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Logic Blocks	
Valid Points	Logic	
Type	Integer	
Lock	View	
Default	None	
PtRes	FSC-SMM	
Range	0	

ATTENTION In the Safety Manager, Logic Block points are intended for data transfer only.

NOLOPTS

The NOLOPTS parameter defines the number of outputs to this Logic Block. Table 2-132 defines this parameter.

Table 2-132 NOLOPTS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Logic Output Points	
Valid Points	Logic	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	12	

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NONECONF

The NONECONF parameter permits the addition of the optional "None" state to be added to the three standard output states for this point. Table 2-133 defines this parameter.

Table 2-133 NONECONF Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Add Optional None State	
Valid Points	DigComp	
Type	Boolean	
Lock	PtBld	
Default	Off	
PtRes	FSC-SMM	
Range	Off	None state not configured.
	On	None state configured.

ATTENTION

The following information is important to the understanding and use of the NONECONF parameter.

- The three standard output states for the Digital Composite point include:
 - 1 — First Active State,
 - 0 — Inactive (Middle) State, and
 - 3 — Second Active State.
- When NONECONF = On, then state 2, the None State is added to this point.
- If the output read back from the FSC-SRS is defined as NONE_OP1 through NONE_OP3, no alarm is generated, even though the state read back does not match the commanded state in OP.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NONE_OP1 – NONE_OP3

The NONE_OP1 to NONE_OP3 parameters identify the values to be stored in Output n when the output is in the None State. Table 2-134 defines this parameter.

Table 2-134 NONE_OP1 to NONE_OP3 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Value Stored in Output n	
Valid Points	DigComp	
Type	Boolean	
Lock	EngPB	
Default	Off	
PtRes	FSC-SMM	
Range	Off	
	On	

ATTENTION The following information is important to the understanding and use of the NONECONF parameter.

- n = output 1, 2, or 3.
- NONE_OP1 is configured only if NODOPTS $\geq$ 1.
- NONE_OP2 is configured only if NODOPTS $\geq$ 2.
- NONE_OP3 is configured only if NODOPTS $\geq$ 3.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NONETXT

The NONETXT parameter defines the state descriptor for the None State. Table 2-135 defines this parameter.

Table 2-135 NONETXT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	State Descriptor for the None State	
Valid Points	Node Specific	
Type	String_8	
Lock	PtBld	
Default	N/A	
PtRes	FSC-SMM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	
	Underscore (_)	

ATTENTION The following information is important to the understanding and use of the NONETXT parameter.

- If the output state read back from the FSC-SRS is defined as NONE_OP1 through NONE_OP3:
 - the character string configured in NONETXT is transferred into FINSTTXT(2), and
 - becomes the OP state shown for this point on the Group and Detail displays.

This parameter is part of the Box point (it is not accessible from a DC point tagname).

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NOSTATES

The NOSTATES parameter defines the number of digital states in this point. Table 2-136 defines this parameter.

Table 2-136 NOSTATES Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Digital States	
Valid Points	DigComp	
Type	Integer	
Lock	PtBld	
Default	2	
PtRes	FSC-SMM	
Range	2	Two states can be configured. • STATE 0, and • STATE 1.
	3	Three states can be configured. • STATE 0, • STATE 1, and • STATE 2.

ATTENTION The following information is important to the understanding and use of the NOSTATES parameter.

- Available states include:
 - State 1 — First active state,
 - State 2 — Inactive (middle) state, and
 - State 3 — Second active state.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NTIMER

The NTIMER parameter defines the number of Timer slots in the data point. Table 2-137 defines this parameter.

Table 2-137 NTIMER Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Number of Timer Slots	
Valid Points	Node Specif.	
Type	Integer	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0 to 1500	

ATTENTION

The following information is important to the understanding and use of the NTIMER parameter.

- The actual range check will be calculated on the PU count for each point and the mix of configured points desired.
- The FSC-SMM will perform the range checking.

Continued on next page

2.15 NXXXX—Parameter Definitions, Continued

NTWKNUM

The NTWKNUM parameter defines the UCN network on which the NIM and FSC-SM reside. Table 2-138 defines this parameter.

Table 2-138 NTWKNUM Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Network Number	
Valid Points	AnalogIn, AnalogOut, DigComp, DigIn, DigOut, Flag, Logic, Numeric, Timer, and UCN Node	
Type	Integer	
Lock	PtBld	
Default	N/A	
PtRes	NIM	
Range	1 to 20	

2.16 OXXXX—Parameter Definitions

OFFNRMFL

The OFFNRMFL parameter indicates whether an off-normal alarm has been detected at this data point. Table 2-139 defines this parameter.

Table 2-139 OFFNRMFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Off-Normal Alarm Flag	
Valid Points	DigComp, and DigIn	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	No alarm.
	On	Alarm — Current PV state is not the same as the configured PVNORMAL state.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OFFNRMPR

The OFFNRMPR parameter defines the priority of an off-normal alarm generated by a data point. The alarm priority determines how the alarm is handled by the system. This parameter does not affect data point alarm detection and alarm indicator visibility on group and detail displays. Table 2-140 defines this parameter.

Table 2-140 OFFNRMPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Off-normal Alarm Priority	
Valid Points	DigIn, DigComp, and Flag	
Type	E:ALPRIOR	
Lock	Eng/PB	
Default	Low	
PtRes	NIM	
Range	NoAction	Alarm is not reported to the system and is not annunciated.
	Journal	Alarm is logged but not reported to the US RTJ or annunciated.
	Low	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit Alarm Summary Display.
	High	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit and Area Alarm Summary Displays.
	Emergency	Alarm is logged, reported to the US RTJ, annunciated, and displayed on all alarm summary displays.
	Printer	Alarm is reported to the US RTJ, but not logged, annunciated or displayed.
	JNLPrint	Alarm is logged and reported to the US RTJ, but not annunciated or displayed.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OISRC(1–3)

The OISRC(1–3) parameter identifies the alias address in the FSC-SRS used for the Override Interlock Source. Table 2-141 defines this parameter.

Table 2-141 OISRC(1–3) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Composite Override Interlock Source	
Valid Points	DigComp	
Type	Unsigned Integer	UCN
	Real	LCN
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured.
	1 to 65535	

OP (AnalgOut)

The OP parameter defines the output value from this point. This value is in Percent. Table 2-142 defines this parameter.

Table 2-142 OP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Output in Percent	
Valid Points	AnalgOut	
Type	Real	
Lock	Oper	
Default	0% of Full Scale	
PtRes	FSC-SMM	
Range	0% to 100%	

ATTENTION To manually change the output value requires that MODE = Man and REDTAG = Off.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OP (DigComp)

The OP parameter identifies the last digital state commanded by an operator at a US or by a user-written program. This value is in Percent. Table 2-143 defines this parameter.

Table 2-143 OP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Last Digital Output State Requested	
Valid Points	DigComp	
Type	E:STATETXT	
Lock	Oper	
Default	STATETXT(0)	
PtRes	FSC-SMM	
Range	STATETXT(0)	State 0 — Inactive Descriptor
	STATETXT(1)	State 1 — Active Descriptor
	STATETXT(2)	State 2 — None Descriptor
	STATETXT(3)	State 3 — Active Descriptor

ATTENTION The following information is important to the understanding and use of the OP parameter.

- User programs and schematics (custom displays) write the commanded state to OP and the new value is read back from the FSC-SRS into OPFINAL.
- Commands from the Operator Keyboard are written to OP and read back from the FSC-SRS into OPFINAL.
- OP contains the text that represents the last-commanded output state (e.g. FORWARD, STOP, REVERSE).
- If the state is ≥ 4 , OP contains Undefined.
- A change in the value in OP requires MODE = Man and REDTAG = Off.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OP (DigOut)

The OP parameter is a self-defining enumeration of STATETXT and reflects the status of the SO parameter. Table 2-144 defines this parameter.

Table 2-144 OP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Commanded Output State	
Valid Points	DigOut	
Type	E:STATETXT	
Lock	Oper, or Um_Cont_Ctrl	
Default	STATETXT(0)	
PtRes	FSC-SMM	
Range	STATETXT(0)	State 0 — Inactive Descriptor
	STATETXT(1)	State 1 — Active Descriptor

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OPFINAL (AnalgOut)

The OPFINAL parameter defines the percent of the output value after direct or reverse control action and output characterization have been applied. Table 2-145 defines this parameter.

Table 2-145 OPFINAL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Percent Output at the Control Element	
Valid Points	AnalgOut	
Type	Real	
Lock	View	
Default	0% of Full Scale	
PtRes	FSC-SMM	
Range	0% to 100%	

ATTENTION

The following information is important to the understanding and use of the OPFINAL parameter.

- If the output has been configured for direct action (OPTDIR), in the FSC-SRS:
 - 0.0% represents a value of OPFINLO to the control element, and
 - 100% represents a value of OPFINHI to the control element.
- If the output has been configured for reverse action (OPTDIR), in the FSC-SRS:
 - 0.0% represents a value of OPFINHI to the control element, and
 - 100% represents a value of OPFINLO to the control element.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OPFINAL (DigComp)

The OPFINAL parameter provides a mechanism to read the final output state back from the FSC-SRS where it is compared with the commanded state (OP). Table 2-146 defines this parameter.

Table 2-146 OPFINAL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Final Output State Read Back from the FSC-SRS	
Valid Points	DigComp	
Type	E:FINSTXT	
Lock	Oper	
Default	N/A	
PtRes	FSC-SMM	
Range	FINSTTXT(0)	State 0 — Inactive Descriptor
	FINSTTXT(1)	State 1 — Active Descriptor
	FINSTTXT(2)	State 2 — None Descriptor
	FINSTTXT(3)	State 3 — Active Descriptor

ATTENTION The following information is important to the understanding and use of the OP parameter.

- Where more than one FSC-SRS output for this point is in use, the FSC-SMM compares each output with OP, and reports the first match in OPFINAL.
- A Bad Control alarm (BADCTLFL = On) is generated if no match is found on any output.
- User programs and schematics (custom displays) write the new commanded state into OP and the new value is read back from the FSC-SRS into OPFINAL.
- When a new state command is issued from the LCN:
 - OP receives the new state,
 - during the next FSC-SRS scan, the state is put into OPFINAL by the final output value read back from the FSC-SRS.
- If the state is ≥ 4 , OPFINAL contains Undefined.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OPFINHI


The OPFINHI parameter indicates the high value for raw analog output data. Table 2-147 defines this parameter.

Table 2-147 OPFINHI Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Output High Value at Control Element	
Valid Points	AnalgOut	
Type	Real	
Lock	PtBld	
Default	4095	100% OP Value
PtRes	FSC-SMM	
Range	> OPFINLO and ≤ 4095	Applies for FSC-SM PI 53.00
	> OPFINLO	Applies for FSC-SM PI 53.01

ATTENTION The following information is important to the understanding and use of the OPFINHI parameter.

- Used in conversion of OP (%) to machine counts to reflect the 100% machine count.



Refer to the OPFINLO parameter for information regarding the configuring the low value for raw analog output data.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OPFINLO

The OPFINLO parameter indicates the low value for raw analog output data. Table 2-148 defines this parameter.


Table 2-148 OPFINLO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Output Low Value at Control Element	
Valid Points	AnalgOut	
Type	Real	
Lock	PtBld	
Default	0	0% OP Value
PtRes	FSC-SMM	
Range	≥ 0 <i>and</i> $< \text{OPFINHI}$	Applies for FSC-SM PI 53.00
	$< \text{OPFINHI}$	Applies for FSC-SM PI 53.01

ATTENTION

The following information is important to the understanding and use of the OPFINLO parameter.

- Used in conversion of OP (%) to machine counts to reflect the 100% machine count.



Refer to the OPFINHI parameter for information regarding the configuring the high value for raw analog output data.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OPRATRFL

The OPRATRFL parameter indicates whether the current mode attribute is Operator. Table 2-149 defines this parameter.

Table 2-149 OPRATRFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Operator Mode Attribute Flag	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	None	
PtRes	FSC-SMM	
Range	Off	Current mode attribute is Program or None.
	On	Current mode attribute is Operator.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OPSTTEXT

The OPSTTEXT parameter defines the state descriptor configured for STATETXT(0) through STATETXT(2). Table 2-150 defines this parameter.

Table 2-150 OPSTTEXT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Output State Text	
Valid Points	DigComp	
Type	E:STATETXT	
Lock	View	
Default	N/A	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	
	Underscore (_)	

ATTENTION The following information is important to the understanding and use of the OPSTTEXT parameter.

- OPSTTEXT:
 - is the descriptor in OPSTTEXT representing the last-commanded output state value in OP,
 - is used to light the commanded state box that represents the last-commanded state on the Group and Detail displays for this point.
- Because the commanded state can differ from the final output state in the FSC-SRS, the text in OPSTTEXT can differ from the text in FINSTTEXT.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OPTDIR

The OPTDIR parameter defines the output action of the OPFINAL value of the data point. Table 2-151 defines this parameter.

Table 2-151 OPTDIR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Analog Output Direct/Reverse Action	When OPTDIR is set to Reverse, the Output value is reversed.
Valid Points	AnalgOut	
Type	E:POLARITY	
Lock	Eng/PB	
Default	Direct	
PtRes	FSC-SMM	
Range	Direct	For final OP: • 0% = OPFINLO FSC-SRS value, and • 100% = OPFINHI FSC-SRS value.
	Reverse	For final OP: • 0% = OPFINHI FSC-SRS value, and • 100% = OPFINLO FSC-SRS value.

OROPT

The OROPT parameter defines whether the operator can put the point in a bypass state where any of the I0-I2 inputs can be bypassed. Table 2-152 defines this parameter.

Table 2-152 OROPT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Override Option	
Valid Points	DigComp	
Type	Logical	
Lock	Eng/PB	
Default	Off	
PtRes	FSC-SMM	
Range	Off	No override.
	On	Inputs can be overridden.

Continued on next page

2.16 OXXXX—Parameter Definitions, Continued


OVERVAL

The OVERVAL parameter defines the amount of deviation (PV -SP, in %) that causes the PV to reach the overview limit. As illustrated in Figure 2-5, the baseline shows the normal operating value for this PV. Table 2-153 defines this parameter.

Table 2-153 OVERVAL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Overview Value in Percent	
Valid Points	AnalIn	
Type	Integer	
Lock	Eng/PB	
Default	25	
PtRes	NIM	
Range	0 to 100	Entering a zero suppresses the value. • The value is not shown on the display.

Figure 2-5 Overview Limit



Continued on next page

2.16 OXXXX—Parameter Definitions, Continued

OVRDALPR

The OVRDALPR parameter defines the priority of an alarm generated by a data point. The alarm priority determines how the alarm is handled by the system. This parameter does not affect data point alarm detection and alarm indicator visibility on group and detail displays. Table 2-154 defines this parameter.

Table 2-154 OVRDALPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Override Alarm Priority	
Valid Points	DigComp	
Type	E:ALPRIOR	
Lock	Engr	
Default	Low	
PtRes	NIM	
Range	NoAction	Alarm is not reported to the system and is not annunciated.
	Journal	Alarm is logged but not reported to the US RTJ or annunciated.
	Low	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit Alarm Summary Display.
	High	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit and Area Alarm Summary Displays.
	Emergency	Alarm is logged, reported to the US RTJ, annunciated, and displayed on all alarm summary displays.
	Printer	Alarm is reported to the US RTJ, but not logged, annunciated or displayed.
	JNLPrint	Alarm is logged and reported to the US RTJ, but not annunciated or displayed.

2.17 PXXXX—Parameter Definitions

P0–P2

The P0–P2 parameters assign permissive interlocks to the point states which determine whether the operator and user program are allowed to use the respective state, or are locked out from that state. Table 2-155 defines this parameter.

Table 2-155 P0–P2 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Permissive Interlocks for States 0, 1 and 2	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	On	
PtRes	FSC-SMM	
Range	Off	Respective state is locked out.
	On	Respective state is permitted.

ATTENTION The following information is important to the understanding and use of the P0–P2 parameters.

- Configuration of this parameter requires that PTEXECST = Inactive or PNTSTATE = Idle.
- A permissive interlock is provided for, and corresponds to, each state as follows:
 - P0 — STATE0,
 - P1 — STATE1, and
 - P2 — STATE2.
- The permissive interlocks themselves never cause the outputs to change.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PISRC(1–3)

The PISRC(1–3) parameter identifies the alias address in the FSC Control Processor used for the Permissive Interlock source. Table 2-156 defines this parameter.

Table 2-156 PISRC(1–3) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Digital Composite Permissive Interlock Source	
Valid Points	DigComp	
Type	Unsigned Integer	UCN
	Real	LCN
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured.
	1 to 65535	

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PLCADDR

The PLCADDR parameter identifies the alias address in the FSC Control Processor used for the PVRAW input. Table 2-157 defines this parameter.

Table 2-157 PLCADDR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC Control Processor Alias Address	
Valid Points	AnalogIn, AnalogOut, DigIn, DigOut, Flag, Logic, Numeric, and Timer	
Type	Unsigned Integer	
Lock	PtBld	Configured in Network Configuration under System-Wide Values/Console Data.
Default	0	Not configured.
PtRes	FSC-SMM	
Range	1 to 65535	For more information refer to Section 2.2 of the <i>FSC Safety Manager Implementation Guidelines</i> .

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PMMCMD

The PMMCMD parameter permits the operator to change FSC-SMM operating states (e.g. reset or switched over to its redundant partner). Table 2-158 defines this parameter.

Table 2-158 PMMCMD Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Command	
Valid Points	Node Specif.	
Type	E:\$PMMCMD	
Lock	OnProc	
Default	None	
PtRes	FSC-SMM	
Range	None	No command request has been issued.
	Run	Change to Run state for point processing.
	Idle	Change to Idle state for database reloading.
	ShutDown	Change to Alive state for personality reloading.
	RsUcnLsb	Reset the Local Statistics block to zero.
	SwapPri	Switchover the redundant FSC-SMM.

ATTENTION The following information is important to the understanding and use of the PMMCMD parameter.

- When points are built to a NIM and the NIM is restarted with no database, the points need to be:
 - reloaded from checkpoint, or
 - reconfigured.
- To allow the point build operation to override the existing database when it is to be reconfigured the:
 - FSC-SMM must be in Idle, and
 - point execution state must be inactive.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PMMCMDTL

The PMMCMDTL parameter defines the command processor record for the point. Table 2-159 defines this parameter.

Table 2-159 PMMCMDTL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Command Processor Detail Record	
Valid Points	Node Specif.	
Type	Blind Record	
Lock	View	
Default	None	
PtRes	FSC-SMM	
Range	None	No command request has been issued.
	Null	

PMMOPER

The PMMOPER parameter indicates the redundancy status of this FSC-SMM. Table 2-160 defines this parameter.

Table 2-160 PMMOPER Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Redundancy Operation	
Valid Points	Node Specif.	
Type	E:\$OPERATE	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	NonRedun	This FSC-SMM has no redundant partner for backup.
	Primary	This FSC-SMM is the primary point processor in a redundant pair.
	Secondary	This FSC-SMM is the secondary point processor in a redundant pair.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PMMSFST

The PMMSFST parameter defines the current FSC-SM softfail status. Table 2-161 defines this parameter.

Table 2-161 PMMSFST Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Current FSC-SMM Softfail Status	
Valid Points	Node Specif.	
Type	Blind Record	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	N/A	

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PMMSTS

The PMMSTS parameter identifies the status of the primary FSC-SMM. Table 2-162 defines this parameter.

Table 2-162 PMMSTS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Primary Status	
Valid Points	Node Specif.	
Type	E:\$PMMSTS	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	0 – OffNet	No NIM/FSC-SMM communication.
	1 – ConfigMs	Configuration mismatch detected.
	2 – Idle	Event reports functioning; no point processing.
	3 – IdleSF	Soft fail occurred in Idle state.
	4 – OK	FSC-SMM is operating normally.
	5 – SoftFail	Soft fail occurred in Run state.
	6 – Fail	Box failure detected. • FSC-SMM can be accessed, but • CPU has been halted.
	10 – Alive	No event reports or point processing.
	11 – AliveSF	Soft fail occurred in Idle state.
	12 – Test	FSC-SMM in Test mode.
	13 – Test	Soft fail occurred in Test mode.
	14 – Loading	Personality or database is being loaded.

ATTENTION The following information is important to the understanding and use of the PMMSTS parameter.

- Loading the FSC-SMM's operating personality software requires that PMMSTS = Alive.
- Loading the FSC-SMM's database requires that PMMSTS = Idle:
 - Use PMMCMD "Shutdown" and "Idle" commands respectively.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PNTFORM

The PNTFORM parameter defines the form of the data point that is implemented. Table 2-163 defines this parameter.

Table 2-163 PNTFORM Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Point Form	
Valid Points	AnalogIn, AnalogOut, DigComp, DigIn, DigOut, Flag, Logic, Numeric, and Timer	
Type	E:\$PNTFORM	
Lock	PtBld	
Default	Full	
PtRes	FSC-SMM	
Range	Full	Point is fully displayed and alarmed.
	Component	Point is partially displayed but not alarmed.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PNTSTATE

The PNTSTATE parameter defines the state of the data point based on the FSC-SMM's state. Table 2-164 defines this parameter.

Table 2-164 PNTSTATE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Point's Overall State	
Valid Points	AnalogIn, AnalogOut, DigComp, DigIn, DigOut, Flag, Logic, and Timer	
Type	E:\$PNTSTATE	
Lock	View	
Default	None	
PtRes	NIM	
Range	Config	Configuration problem (i.e., mismatch, etc.).
	Fail	No NIM/FSC-SMM communication.
	Idle	Point's FSC-SMM in the Idle state.
	OK	Point's FSC-SMM in the Run state and in OK.
	Test	Point's FSC-SMM is being tested.
	Saved	Save Data (checkpoint) operation in progress.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PNTTYPE

The PNTTYPE parameter defines the type of point in the Safety Manager. Table 2-165 defines this parameter.

Table 2-165 PNTTYPE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Point Type	
Valid Points	All Data Types	
Type	E:PNTTYPE	
Lock	PtBld	
Default	(See Range)	Each point defaults to its Range.
PtRes	NIM	
Range	AnalogIn	Analog Input point
	AnalogOut	Analog Output point
	DigComp	Digital Composite point
	DigIn	Digital Input point
	DigOut	Digital Output point
	Flag	Flag point
	Logic	Logic point
	Numeric	Numeric point
	Timer	Timer point

ATTENTION The following information is important to the understanding and use of the PNTTYPE parameter.

- Writing this parameter causes the point to be initialized.
 - Although "Not Configured" is in the range of values, it is not written to the system.
 - Instead, it triggers a point deletion and re-initialization, and only the actual point type is stored.
- Range values are determined from the NIM Build Type Select menu.
 - These points are not configured.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PRIMMOD

The PRIMMOD parameter contains the tagname of the PMM point to which this data is assigned Table 2-166 defines this parameter.

Table 2-166 PRIMMOD Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Primary Module Identifier	
Valid Points	AnaIIn, DigComp, and DigIn	
Type	Ent.Prm	
Lock	PtBId	
Default	Null	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	All-numeric tagname prohibited.
	Underscore (_)	Cannot be used as first or consecutive characters.
	*	Defaults to the point's tagname.

ATTENTION The following information is important to the understanding and use of the PRIMMOD parameter.

- Use the Tagname.Parameter format for tagged points where Tagname can be up to 8 or 16 characters (depending on system option).
 - Embedded space characters are prohibited in tagnames.
 - Must be a legitimate parameter name.
- The name of the Batch History data point (used by the AM for collecting batch histories):
 - is specified by this tagname, and
 - collects batch history for this data point.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PTDESC

The PTDESC parameter is a 24-character descriptor used to describe the point and appears on the Group and Detail displays as illustrated in Figure 2-6. Table 2-167 defines this parameter.

Table 2-167 PTDESC Definition and Entry Fields


Item	Definitions/Settings	Notes
Full Name	Point Descriptor	
Valid Points	AnalogIn, AnalogOut, DigIn, DigOut, DigComp, Flag, Numeric, and Logic	
Type	String_24	
Lock	PtBld	
Default	Blank	
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	All-numeric tagname prohibited.
	Special Characters	space ! " % & ' () * + - / : ; > < = ? _ , . \$

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PTDESC,
Continued

Figure 2-6 Group and Detail Displays



Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PTEXCST

The PTEXCST parameter defines the current execution state of the point. Table 2-168 defines this parameter.

Table 2-168 PTEXCST Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Point Execution State	
Valid Points	AnalogIn, AnalogOut, DigComp, DigIn, DigOut, Logic, and Timer	
Type	E:PTEXCST	
Lock	Supr	
Default	Inactive	
PtRes	FSC-SMM	
Range	Inactive	Point is not scanned/processed.
	Active	Point is scanned/processed.

PTINAL

The PTINAL parameter indicates when an alarm condition has been detected at this point. Table 2-169 defines this parameter.

Table 2-169 PTINAL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Point in Alarm Indicator	
Valid Points	AnalogIn, and DigComp	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Point is not in alarm.
	On	Point is in alarm.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PV (AnalogIn)


The PV parameter defines the PV's current value after PV is selected from a field device, an operator input, or a program input. Table 2-170 defines this parameter.

Table 2-170 PV Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Process Variable Current Value	
Valid Points	AnalogIn	
Type	Real	
Lock	Oper	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	Not a number
	PVEXEUHI to PVEXEULO	Range as defined by the PV extended engineering units high and Low values.

ATTENTION The following information is important to the understanding and use of the PV parameter.

- For an operator to change the PV requires that:
 - PVSRCOPT = All, and
 - PVSOURCE = Man.
- For a program to change the PV requires that:
 - PVSRCOPT = All, and
 - PVSOURCE = Sub.



For additional information regarding the PV parameter, refer to the PVSRCOPT and PVSOURCE parameters.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PV (DigComp)


The PV parameter defines the PV's current state after PV is selected from a field device, an operator input, or a program input. Table 2-171 defines this parameter.

Table 2-171 PV Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Process Variable Current State	
Valid Points	DigComp	
Type	E:PVSTATES	
Lock	Oper	
Default	Bad	
PtRes	FSC-SMM	
Range	PVSTATES(0)	Defined by STATETXT(0)
	PVSTATES(1)	Defined by STATETXT(1)
	PVSTATES(2)	Defined by BADPVTXT
	PVSTATES(3)	Defined by MOVVPTXT
	PVSTATES(4)	Defined by STATETXT(2)

ATTENTION The following information is important to the understanding and use of the PV parameter.

- For an operator to change the PV requires that:
 - PVSRCOPT = All, and
 - PVSOURCE = Man.
- For a program to change the PV requires that:
 - PVSRCOPT = All, and
 - PVSOURCE = Sub.



For additional information regarding the PV parameter, refer to the PVSRCOPT and PVSOURCE parameters.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PV
(DigIn)


The PV parameter indicates the current state of the PV input to this data point. Table 2-172 defines this parameter.

Table 2-172 PV Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Process Variable Current State	
Valid Points	DigIn	
Type	E:STATETXT	
Lock	Oper	
Default	Off	
PtRes	FSC-SMM	
Range	STATETXT(0)	State 0 — Inactive Descriptor
	STATETXT(1)	State 1 — Active Descriptor

ATTENTION The following information is important to the understanding and use of the PV parameter.

- For an operator to change the PV requires that:
 - PVSRCOPT = All, and
 - PVSOURCE = Man.
- For a program to change the PV requires that:
 - PVSRCOPT = All, and
 - PVSOURCE = Sub.



For additional information regarding the PV parameter, refer to the PVSRCOPT and PVSOURCE parameters.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PV (Flag)

The PV parameter indicates the current state of the PV input to this data point. Table 2-173 defines this parameter.

Table 2-173 PV Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Process Variable Current State	
Valid Points	Flag	
Type	E:STATETXT	
Lock	Oper	
Default	Off	
PtRes	FSC-SMM	
Range	STATETXT(0)	State 0 — Inactive Descriptor
	STATETXT(1)	State 1 — Active Descriptor

PV (Numeric)

The PV parameter indicates the value of the numeric. Table 2-174 defines this parameter.

Table 2-174 PV Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Process Variable Current Value	
Valid Points	Numeric	
Type	Real	
Lock	Oper	
Default	NaN	
PtRes	FSC-SMM	
Range	All values	Real

ATTENTION This value maps into parameter NN(n) in the Safety Manager where n = SLOTNUM.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PV (Timer)

The PV parameter indicates the current time in seconds or minutes. Table 2-175 defines this parameter.

Table 2-175 PV Definition and Entry Fields

Item	Definitions/Settings		Notes
Full Name	Process Variable Current Value		
Valid Points	Timer		
Type	Real		
Lock	View		
Default	0		
PtRes	FSC-SMM		
Range	If timebase is...	Then range is...	
	100 ms	1 .. 204.7 seconds	
	1 s	1 .. 2047 seconds	
	1 m	1 .. 2047 minutes	

ATTENTION The following information is important to the understanding and use of the PV parameter.

- The timer starts at a value of zero (0) and is incremented towards the preset time established by the SP parameter.
- PVFORMAT only affects how the PV value is displayed (how many digits after the decimal point).

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVALDB

The PVALDB parameter defines the percent of the full range engineering units full range used for deadband adjustment. Table 2-176 defines this parameter.

Table 2-176 PVALDB Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Alarm Dead Band as a Percentage of Full Range	
Valid Points	AnalIn	
Type	E:PVALDB	
Lock	Eng/PB	
Default	One	
PtRes	FSC-SMM	
Range	Half	½% of Engineering Units range.
	One	1% of Engineering Units range.
	Two	2% of Engineering Units range.
	Three	3% of Engineering Units range.
	Four	4% of Engineering Units range.
	Five	5% of Engineering Units range.
	Six	6% of Engineering Units range.

ATTENTION The following information is important to the understanding and use of the PVALDB parameter.

- Alarm deadband is used to prevent excessive recurrence of alarms by adjusting the percent of the engineering unit range at which the alarm "returns to normal."
- An increase in the deadband percent of PV range (PVEULO to PVEUHI) causes PV or deviation alarms to return to normal less frequently.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVALDBEU

The PVALDBEU parameter defines the percent of the full range engineering units full range used for deadband. Table 2-177 defines this parameter.

Table 2-177 PVALDBEU Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Alarm Deadband in Engineering Units	
Valid Points	AnalIn	
Type	E:PVALDB	
Lock	Eng/PB	
Default	1.0	
PtRes	FSC-SMM	
Range	≥ 0.0	

PVAUTO (AnalIn)

The PVAUTO parameter indicates the value of the PV after PVCALC is range checked, filtered, and clamped. Table 2-178 defines this parameter.

Table 2-178 PVAUTO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Auto Value	
Valid Points	AnalIn	
Type	Real	
Lock	View	
Default	NaN	
PtRes	FSC-SMM	
Range	N/A	

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVAUTO (DigComp)

The PVAUTO parameter indicates the current PV state, based on the point's input states. Table 2-179 defines this parameter.

Table 2-179 PVAUTO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Current PV State	
Valid Points	DigComp	
Type	E:\$PVSTATS	
Lock	View	
Default	BADPVTXT	
PtRes	FSC-SMM	
Range	STATETXT(0)	
	STATETXT(1)	
	STATETXT(2)	Used only if NOSTATES =3
	BADPVTXT	
	MOVPVTXT	

PVAUTO (DigIn)

The PVAUTO parameter indicates the current PV state that corresponds to the field contact input after direct/reverse correction. Table 2-180 defines this parameter.

Table 2-180 PVAUTO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Current PV State	
Valid Points	DigIn	
Type	E:STATETXT	
Lock	View	
Default	None	
PtRes	FSC-SMM	
Range	STATETXT(0)	
	STATETXT(1)	

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVAUTOST

The PVAUTOST parameter indicates the current status of the PVAUTO value. Table 2-181 defines this parameter.

Table 2-181 PVAUTOST Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Auto Value Status	
Valid Points	AnalIn	
Type	E:PVVALST	
Lock	View	
Default	Bad	
PtRes	FSC-SMM	
Range	Bad	All inputs, or the result in PVCALC is bad.
	Uncertn	Final result in PVCALC is an uncertain value.
	Normal	Final result in PVCALC is a normal value.

PVCALC

The PVCALC parameter represents the PV value in Engineering Units after the raw PV (PVRAW) input to this point has been characterized. Table 2-182 defines this parameter.

Table 2-182 PVCALC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Calculated PV	
Valid Points	AnalIn	
Type	Real	
Lock	View	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	
	PVEXEUHI to PVEXEULO	

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVCHAR

The PVCHAR parameter defines the display characterization to be used for characterizing the in PV value. Table 2-183 defines this parameter.

Table 2-183 PVCHAR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Characterization Option	
Valid Points	AnalIn	
Type	E:VALCHAR	
Lock	PtBld	
Default	Linear	
PtRes	FSC-SMM	
Range	Linear Square Root	

PVCHGDLY

The PVCHGDLY parameter defines, in seconds, the preset value for the PV change delay function which in conjunction with PVCHGTMR throttles time-stamped event collection. Table 2-184 defines this parameter.

Table 2-184 PVCHGDLY Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Change Delay	
Valid Points	DigIn	
Type	Integer	
Lock	Supr	
Default	0	
PtRes	FSC-SMM	
Range	0 to 60	Seconds.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVCHGTMR

The PVCHGTMR parameter defines, in seconds, the accumulation for the PV change timer function which in conjunction with PVCHGDLY throttles time-stamped event collection. Table 2-185 defines this parameter.

Table 2-185 PVCHGTMR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Change Timer	
Valid Points	DigIn	
Type	Integer	
Lock	View	
Default	0	
PtRes	FSC-SMM	
Range	N/A	

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVCLAMP

The PVCLAMP parameter defines whether PV clamping is to be used for the data point. Table 2-186 defines this parameter.

Table 2-186 PVCLAMP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Clamping Option	
Valid Points	AnalIn	
Type	E:PVCLAMP	
Lock	Eng/PB	
Default	NoClamp	
PtRes	FSC-SMM	
Range	NoClamp	No clamping of the PV value.
	Clamp	Clamp PV value at PVEXEUHI/ PVEXEULO.

ATTENTION The PVCLAMP parameter is used for PV range checking, which ensures that the output of the PV characterization is within the limits defined by the parameters PVEXEULO and PVEXEUHI. Table 2-187 explains how PV clamping works exactly.

Table 2-187 PV clamping

If PVCLAMP is ...	And PVAUTO ...	Then ...	And PV is ...
NoClamp	exceeds PVEUHI	nothing happens.	–
	exceeds PVEXEUHI	PVSTS goes Bad, PVEXHIFL goes On, and BADPVFL goes On.	Set to NaN.
	goes below PVEULO	nothing happens.	–
	goes below PVEXEULO	PVSTS goes Bad, PVEXLOFL goes On, and BADPVFL goes On.	Set to NaN.
Clamp	exceeds PVEUHI	nothing happens.	–
	exceeds PVEXEUHI	PVSTS goes Uncertain, PVEXHIFL goes On, and BADPVFL remains Off.	clamped to PVEXEUHI.
	goes below PVEULO	nothing happens.	–
	goes below PVEXEULO	PVSTS goes Uncertain, PVEXLOFL goes On, and BADPVFL remains Off.	clamped to PVEXEULO.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVEUHI

The PVEUHI parameter defines the high limit of the PV's engineering unit range. Table 2-188 defines this parameter.

Table 2-188 PVEUHI Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV High Range in Engineering Units	
Valid Points	AnalIn	
Type	Real	
Lock	Engr	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	Initially only.
	PVEULO to PVEXEUHI	

PVEULO

The PVEULO parameter defines the low limit of the PV's engineering unit range. Table 2-189 defines this parameter.

Table 2-189 PVEULO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Low Range in Engineering Units	
Valid Points	AnalIn	
Type	Real	
Lock	Engr	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	Initially only.
	PVEXEULO to PVEUHI	

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVEXEUHI

The PVEXEUHI parameter defines the high limit of the PV's extended engineering unit range. Table 2-190 defines this parameter.

Table 2-190 PVEXEUHI Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Extended Engineering Unit Range High	
Valid Points	AnalIn	
Type	Real	
Lock	PtBld	
Default	NaN	
PtRes	FSC-SMM	
Range	≥ PVEUHI or NaN	

ATTENTION The following information is important to the understanding and use of the PVEXEUHI parameter.

- Used in conjunction, PVEXEUHI and PVEXEULO are used to clamp or detect a bad PV value.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVEXEULO

The PVEXEULO parameter defines the low limit of the PV's extended engineering unit range. Table 2-191 defines this parameter.

Table 2-191 PVEXEULO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Extended Engineering Unit Range Low	
Valid Points	AnalIn	
Type	Real	
Lock	PtBld	
Default	NaN	
PtRes	FSC-SMM	
Range	≤ PVEULO or NaN	

ATTENTION

The following information is important to the understanding and use of the PVEXEULO parameter.

- Used in conjunction, PVEXEULO and PVEXEUIH are used to clamp or detect a bad PV value.

PVEXHIFL

The PVEXHIFL parameter indicates that the PV has exceeded the extended-high range alarm trip-point. Table 2-192 defines this parameter.

Table 2-192 PVEXHIFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Extended High Range Violation	
Valid Points	AnalIn	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Extended high range not exceeded.
	On	Extended high range exceeded.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVEXLOFL

The PVEXLOFL parameter indicates that the PV has exceeded the extended-low range alarm trip-point. Table 2-193 defines this parameter.

Table 2-193 PVEXLOFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Extended Low Range Violation	
Valid Points	AnalIn	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Extended low range not exceeded.
	On	Extended low range exceeded.

PVFL (DigComp)

The PVFL parameter indicates the current PV state as three separate Boolean parameters. PVFL(n) is On when the PV is in the n state where n = 0, 1, or 2. Table 2-194 defines this parameter.

Table 2-194 PVFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Flag	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	PV is not in state 0, 1, or 2.
	On	PV is in state 0, 1, or 2.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVFL (DigIn, Flag)

The PVFL parameter indicates the current PV state as three separate Boolean parameters. PVFL(n) is On when the PV is in the n state where n = 0, 1, or 2. Table 2-195 defines this parameter.

Table 2-195 PVFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Flag	
Valid Points	DigIn, Flag	
Type	Logical	
Lock	Oper	
Default	Off	
PtRes	FSC-SMM	
Range	Off	PV = STATETXT(0)
	On	PV = STATETXT(1)

PVFLTOPT (AnalogIn, AnalogOut, Node Specif., Numeric)

The PVFLTOPT parameter provides a value which identifies the FSC Control Processor data type and is determined by PLCADDR. Table 2-196 defines this parameter.

Table 2-196 PVFLTOPT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Enumeration of FSC Control Processor Data Type	
Valid Points	AnalogIn, AnalogOut, Node Specif., and Numeric	
Type	E:\$PVFLTOP	
Lock	View	
Default	NotConfig	
PtRes	FSC-SMM	
Range	Real	
	Boolean	

ATTENTION The value for this parameter will be determined by NNLSBA.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVFORMAT

The PVFORMAT parameter defines the decimal point format used with PV. Table 2-197 defines this parameter.

Table 2-197 PVFORMAT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Decimal Point Format	
Valid Points	Analog, Numeric, and Timer	
Type	E:VALFORMAT	
Lock	Engr	
Default	D1	
PtRes	FSC-SMM (Analog & Timer) NIM (Numeric)	
Range	D0 – (XXXX.)	Zero places right of the decimal.
	D1 – (XXX.X)	One places right of the decimal.
	D2 – (XX.XX)	Two places right of the decimal.
	D3 – (X.XXX)	Three places right of the decimal.

ATTENTION

- For Timers, the following applies:
- PVFORMAT = D0 if the time base (as defined by the TIMEBASE parameter) is set to minutes (m) or seconds (s).
 - PVFORMAT = D1 if the time base (as defined by the TIMEBASE parameter) is set to 100 milliseconds (ms).

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVHIFL

The PVHIFL parameter indicates that the PV exceeded the alarm trip-point established for PVHITP. Table 2-198 defines this parameter.

Table 2-198 PVHIFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV High Alarm Flag	
Valid Points	AnalIn	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	No PV High Alarm.
	On	PV High Alarm.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVHIPR

The PVHIPR parameter defines the priority of the PV high alarm for this point. Table 2-199 defines this parameter.

Table 2-199 PVHIPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV High Alarm Priority	
Valid Points	AnalIn	
Type	E:ALPRIOR	
Lock	Eng/PB	
Default	Low	
PtRes	NIM	
Range	NoAction	Alarm is not reported to the system and is not annunciated.
	Journal	Alarm is logged but not reported to the US RTJ or annunciated.
	Low	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit Alarm Summary Display.
	High	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit and Area Alarm Summary Displays.
	Emergency	Alarm is logged, reported to the US RTJ, annunciated, and displayed on all alarm summary displays.
	Printer	Alarm is reported to the US RTJ, but not logged, annunciated or displayed.
	JNLPrint	Alarm is logged and reported to the US RTJ, but not annunciated or displayed.

ATTENTION PVHIPR configuration requires PVHITP $\neq$ NaN.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVHITP

The PVHITP parameter defines the trip-point for the PV high alarm for this point. Table 2-200 defines this parameter.

Table 2-200 PVHITP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV High Alarm Trip Point	
Valid Points	AnalIn	
Type	Real	
Lock	Supr	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	
	PVLOTP to PVEUHI	

PVLOFL

The PVLOFL parameter indicates that the PV has exceeded the alarm trip-point established for PVLOTP. Table 2-201 defines this parameter.

Table 2-201 PVLOFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Low Alarm Flage	
Valid Points	AnalIn	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	No PV Low Alarm.
	On	PV Low Alarm.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVLOPR

The PVLOPR parameter defines the priority of the PV low alarm for this point. Table 2-202 defines this parameter.

Table 2-202 PVLOPR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Low Alarm Priority	
Valid Points	AnalIn	
Type	E:ALPRIOR	
Lock	Eng/PB	
Default	Low	
PtRes	NIM	
Range	NoAction	Alarm is not reported to the system and is not annunciated.
	Journal	Alarm is logged but not reported to the US RTJ or annunciated.
	Low	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit Alarm Summary Display.
	High	Alarm is logged, reported to the US RTJ, annunciated, and displayed on the Unit and Area Alarm Summary Displays.
	Emergency	Alarm is logged, reported to the US RTJ, annunciated, and displayed on all alarm summary displays.
	Printer	Alarm is reported to the US RTJ, but not logged, annunciated or displayed.
	JNLPrint	Alarm is logged and reported to the US RTJ, but not annunciated or displayed.

ATTENTION PVLOPR configuration requires PVLOTP $\neq$ NaN.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVLOTP

The PVLOTP parameter defines the trip-point for the PV low alarm for this point. Table 2-203 defines this parameter.

Table 2-203 PVLOTP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Low Alarm Trip Point	
Valid Points	AnalogIn	
Type	Real	
Lock	Supr	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	
	PVEULO to PVHITP	

PVNORMAL

The PVNORMAL parameter defines the normal state of the PV using the appropriate STATETXT descriptor. Table 2-204 defines this parameter.

Table 2-204 PVNORMAL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Normal State	
Valid Points	DigComp, and DigIn	
Type	E:STATETXT	
Lock	Oper	
Default	Off	
PtRes	FSC-SMM	
Range	STATETXT(0)	Defaulted to Off for PV State 0.
	STATETXT(1)	Defaulted to Off for PV State 1.
	STATETXT(2)	Defaulted to Off for PV State 2. • Does not apply to DigIn point.

ATTENTION

The following information is important to the understanding and use of the PVNORMAL parameter.

- A PVNORMAL change requires that ALMOPT = Offnorm.
- PV normal state text descriptor describes the normal (desired) state, such as Run, Stop, Open or Closed.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVNORMFL

The PVNORMFL parameter indicates whether the normal state of the PV is active. Table 2-205 defines this parameter.

Table 2-205 PVNORMFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Normal State Flag	
Valid Points	DigIn	
Type	Logical	
Lock	Oper	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Point is not in Normal state.
	On	Point is in Normal state.

ATTENTION

The following information is important to the understanding and use of the PVNORMFL parameter.

- A PVNORMFL change requires that ALMOPT = Offnorm.
- Setting PVNORMFL to:
 - Off — causes the text in STATETXT(0) to be used to describe the normal state of the PV.
 - On — causes the text in STATETXT(1) to be used to describe the normal state of the PV.

PVP

The PVP parameter defines the PV as a percentage of the PVEULO to the PVEUHI range. Table 2-206 defines this parameter.

Table 2-206 PVP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV in Percent	
Valid Points	AnalIn	
Type	Real	
Lock	View	
Default	NaN	
PtRes	FSC-SMM	
Range	NAN, 0 TO 100%	

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVRAW (AnalogIn)

The PVRAW parameter indicates the raw input value of the PV before PV characterization is performed. Table 2-207 defines this parameter.

Table 2-207 PVRAW Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Raw Value	
Valid Points	AnalogIn	
Type	Logical	
Lock	View	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN, 0 to 100%	

ATTENTION The units of value for the PV are determined as a percent of the raw data range (PVRAWLO – PVRAWHI).

PVRAW (DigIn)

The PVRAW parameter indicates the current state of the field contacts before input direction conversion. Table 2-208 defines this parameter.

Table 2-208 PVRAW Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Raw State of Field Contacts	
Valid Points	DigIn	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	
	On	

ATTENTION PVRAW is derived from the and from:

- the open or closed state of field contacts, and
- the configured direct or reverse input direction (INPTDIR).

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVRAWHI

The PVRAWHI parameter indicates the high value for raw analog input data from the FSC Control Processor. Table 2-209 defines this parameter.

Table 2-209 PVRAWHI Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Raw High Value	
Valid Points	AnalIn	
Type	Real	
Lock	PtBld	
Default	4095	
PtRes	FSC-SMM	
Range	> PVRAWLO	

ATTENTION The following information is important to the understanding and use of the PVRAWHI parameter.

- Used in conversion to PVRAW as a percent.
 - PVRAWHI = 100% machine counts.
 - PVRAWLO = 0% machine counts.
- When AI points are linked to FSC AI or AO variables, a typical application would be in converting a 4 to 20 mA signal (655-3276) to 0-100%.
- For FSC-SM PI 53.00 only:
When linked to FSC BI or BO variables, the range is 0-4095.
- For FSC-SM PI 53.01 only:
When linked to FSC BI or BO variables, the full floating point range is supported.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVRAWLO

The PVRAWLO parameter indicates the low value for raw analog input data from the FSC Control Processor. Table 2-210 defines this parameter.

Table 2-210 PVRAWLO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Raw Low Value	
Valid Points	AnalIn	
Type	Real	
Lock	PtBld	
Default	0	
PtRes	FSC-SMM	
Range	< PVRAWHI	

ATTENTION The following information is important to the understanding and use of the PVRAWLO parameter.

- Used in conversion to PVRAW as a percent.
 - PVRAWLO = 0% machine counts.
 - PVRAWHI = 100% machine counts.
- When AI points are linked to FSC AI or AO variables, a typical application would be in converting a 4 to 20 mA signal (655-3276) to 0-100%.
- For FSC-SM PI 53.00 only:
When linked to FSC BI or BO variables, the range is 0-4095.
- For FSC-SM PI 53.01 only:
When linked to FSC BI or BO variables, the full floating point range is supported.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVSLTSRC

The PVSLTSRC parameter identifies the target alias address in the FSC Control Processor for the accumulator (PV) value. Table 2-211 defines this parameter.

Table 2-211 PVSLTSRC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Slot Source	
Valid Points	Timer	
Type	Unsigned Integer	UCN
	Real	LCN
Lock	PtBld	
Default	0	Not configured.
PtRes	FSC-SMM	
Range	0	Not configured.
	1 to 65535	Integer

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVSOURCE

The PVSOURCE parameter defines the source of the PV input to this data point. Table 2-212 defines this parameter.

Table 2-212 PVSOURCE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Source	
Valid Points	AnalIn, DigComp, and DigIn	
Type	E:PVSOURCE	
Lock	Oper	
Default	Auto	
PtRes	FSC-SMM	
Range	Sub	PV value is provided by a sequence program.
	Man	PV value is provided by an operator or program.
	Auto	PV value is provided by field wiring.
	Track	PV tracks OP. • DigComp points only.

ATTENTION The following information is important to the understanding and use of the PVSOURCE parameter.

- PVSOURCE change by an operator requires that PVSRCOPT = All.
- If ALMOPT = CmdDis, the track option cannot be used.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVSRCOPT

The PVSRCOPT parameter defines the source options available for this data point. Table 2-213 defines this parameter.

Table 2-213 PVSRCOPT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Source Option	
Valid Points	AnalIn, DigComp, and DigIn	
Type	E:PVSRCOPT	
Lock	Eng/PB	
Default	OnlyAuto	
PtRes	FSC-SMM	
Range	OnlyAuto	PV source selection is not available. • A field writing or memory fetch supplies the PV value.
	All	PV is provided by: • an operator, • a sequence program, or • field wiring.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVSTATES(0–4)

The PVSTATES(0–4) parameters contain the PV state descriptors that describe the five possible states of a DigComp PV. Table 2-214 defines this parameter.

Table 2-214 PVSTATES(0–4) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV State Descriptors	
Valid Points	DigComp	
Type	String_8	
Lock	View	
Default	None	
PtRes	NIM	
Range	N/A	

ATTENTION

The following information is important to the understanding and use of the PVSTATES(0–4) parameters.

- The descriptors are set equal to whatever is configured:
 - BADPVTXT and MOVPVTXT during FSC-SM node specific configuration, and
 - STATETXT(0) and STATETXT(1) during point configuration.
- If PVSTATES is to be accessed by CL programs, then:
 - PVSTATES(0) = STATETXT(0),
 - PVSTATES(1) = STATETXT(1),
 - PVSTATES(2) = BADPVTXT,
 - PVSTATES(3) = MOVPVTXT,
 - PVSTATES(4) = STATETXT(2); only applies if NOSTATES = 3.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVSTS

The PVSTS parameter defines the current status of the PV input value. Table 2-215 defines this parameter.

Table 2-215 PVSTS Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Status of PV Input Value	
Valid Points	Analgn	
Type	E:PVVALST	
Lock	View	
Default	Bad	
PtRes	FSC-SMM	
Range	Bad	Value is bad and replaced with NaN.
	Uncertn	Status of the value is uncertain.
	Normal	Value is good.

Continued on next page

2.17 PXXXX—Parameter Definitions, Continued

PVTV

The PVTV parameter defines the target value of the PV in engineering units. Table 2-216 defines this parameter.

Table 2-216 PVTV Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Target Value in Engineering Units	
Valid Points	AnalIn	
Type	Real	
Lock	Oper	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	Not a number.
	PVEXEULO to PVEXEUHI	

ATTENTION On Group and Detail displays, this value appears as the setpoint value (SP, horizontal bar).

PVTVP

The PVTVP parameter defines the target value of the PV as a percentage of the PVEULO to PVEUHI range. Table 2-217 defines this parameter.

Table 2-217 PVTVP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Target Value in Percent	
Valid Points	AnalIn	
Type	Real	
Lock	View	
Default	NaN	
PtRes	FSC-SMM	
Range	NaN	Not a number.
	0 to 100%	

2.18 RXXXX—Parameter Definitions

RCASOPT

The RCASOPT parameter defines whether the AM is to provide the output value for this data point. Table 2-218 defines this parameter.

Table 2-218 RCASOPT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Remote Cascade Option	
Valid Points	AnalgOut	
Type	E:\$RCASOPT	
Lock	Eng/PB	
Default	None	
PtRes	FSC-SMM	
Range	None	No cascade mode of any type is allowed.
	Ddc	Direct Digital Control; in cascade mode, the AM controls this point's OP.

ATTENTION Available only when the point has been configured as a Full point.

Continued on next page

2.18 RXXXX—Parameter Definitions, Continued

REDTAG

The REDTAG parameter allows you to set the point as being "out-of-service." Table 2-219 defines this parameter.

Table 2-219 REDTAG Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Red Tag State	
Valid Points	AnalogOut, DigOut, and DigComp	
Type	E:REDTAG	
Lock	Supr, Engr	
Default	Off	
PtRes	FSC-SMM	
Range	Off	Data point is in service.
	On	Data point is marked as out-of-service.

ATTENTION

The following information is important to the understanding and use of the REDTAG parameter.

- Out-of-Service indicates that this point or the associated control loop:
 - needs repair, or
 - is being repaired.
- REDTAG change requires that:
 - MODE = Man, and
 - MODATTR = Oper.
- Once a point is red tagged, parameters MODE, MODATTR and OP cannot be changed from the UCN.
- The point must be taken out-of-service in the LCS before REDTAG is set On.

Continued on next page

2.18 RXXXX—Parameter Definitions, Continued

RINITREQ

The RINITREQ parameter indicates whether an initialization request has been made. Table 2-220 defines this parameter.

Table 2-220 RINITREQ Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Remote Initialization Request	
Valid Points	AnalgOut	
Type	Logical	
Lock	View	
Default	On	
PtRes	FSC-SMM	
Range	Off	No remote initialization request.
	On	Remote initialization request has been made.

ATTENTION RINITREQ does not apply if RCASOPT = None.

Continued on next page

2.18 RXXXX—Parameter Definitions, Continued

RV

The RV parameter indicates the amount of time remaining (in seconds or minutes) that the time has yet to run. Table 2-221 defines this parameter.

Table 2-221 RV Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Remaining Time	
Valid Points	Timer	
Type	Real	
Lock	View	
Default	0	
PtRes	FSC-SMM	
Range	If timebase is...	Then range is...
	100 ms	1 .. 204.7 seconds
	1 s	1 .. 2047 seconds
	1 m	1 .. 2047 minutes

ATTENTION The following information is important to the understanding and use of the PV parameter.

- The timer starts at a value of zero (0) and is incremented towards the preset time established by the SP parameter.
- PVFORMAT only affects how the RV value is displayed (how many digits after the decimal point).
- RV represents the remaining time computed as $SP - PV$.
- If $SP = 0$, then $RV = 0$.

2.19 SXXXX—Parameter Definitions

S0BOXCLR

The S0BOXCLR parameter defines the color to appear on the Group and Detail displays for this point when the corresponding state box is turned on. Table 2-222 defines this parameter.

Table 2-222 S0BOXCLR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	State 0 Box Color	
Valid Points	DigComp, DigIn, DigOut, and Flag	
Type	E:BOXCOLOR	
Lock	View	
Default	Yellow	Default color for all valid point types.
PtRes	NIM	
Range	Red, Green, White, Black, Cyan, Yellow, Blue, or Magenta	Choice.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

S1BOXCLR

The S1BOXCLR parameter defines the color to appear on the Group and Detail displays for this point when the corresponding state box is turned on. Table 2-223 defines this parameter.

Table 2-223 S1BOXCLR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	State 1 Box Color	
Valid Points	DigComp, DigIn, DigOut, and Flag	
Type	E:BOXCOLOR	
Lock	View	
Default	Yellow	DigIn only.
	Green	DigComp, DigOut, Flag
PtRes	NIM	
Range	Red, Green, White, Black, Cyan, Yellow, Blue, or Magenta	Choice.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

S2BOXCLR

The S2BOXCLR parameter defines the color to appear on the Group and Detail displays for this point when the corresponding state box is turned on. Table 2-224 defines this parameter.

Table 2-224 S2BOXCLR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	State 2 Box Color	
Valid Points	DigComp	
Type	E:BOXCOLOR	
Lock	View	
Default	N/A	
PtRes	NIM	
Range	Red, Green, White, Black, Cyan, Yellow, Blue, or Magenta	Choice.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

SCANRATE

The SCANRATE parameter defines the number of times each second that all slots of a particular type are scanned and processed. Table 2-225 defines this parameter.

Table 2-225 SCANRATE Definition and Entry Fields

Item	Definitions/Settings	Notes															
Full Name	Scan Rate																
Valid Points	Node Specif.																
Type	E:\$LMSCNRT																
Lock	PtBId																
Default	AR2DT2																
PtRes	FSC-SMM																
Range	The following table defines the scan rate (in seconds) associated with each range selection.																
	<table border="1"> <thead> <tr> <th>Range Selection</th><th>Analog Scan Frequency</th><th>Digital, Timer, Logic Scan Frequency</th></tr> </thead> <tbody> <tr> <td>Null</td><td>N/A</td><td>N/A</td></tr> <tr> <td>AR1DT2</td><td>1 per second</td><td>2 per second</td></tr> <tr> <td>AR2DT2</td><td>2 per second</td><td>2 per second</td></tr> <tr> <td>AR1DT1</td><td>1 per second</td><td>1 per second</td></tr> </tbody> </table>	Range Selection	Analog Scan Frequency	Digital, Timer, Logic Scan Frequency	Null	N/A	N/A	AR1DT2	1 per second	2 per second	AR2DT2	2 per second	2 per second	AR1DT1	1 per second	1 per second	
Range Selection	Analog Scan Frequency	Digital, Timer, Logic Scan Frequency															
Null	N/A	N/A															
AR1DT2	1 per second	2 per second															
AR2DT2	2 per second	2 per second															
AR1DT1	1 per second	1 per second															

SECOND

The **SECOND** parameter provides the value representing second portion of the LCN Time in the FSC-SMM. Table 2-226 defines this parameter.

Table 2-226 SECOND Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Second	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	0 to 59	

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

SLOTNUM

The SLOTNUM parameter defines the slot where a particular point resides. Table 2-227 defines this parameter.

Table 2-227 SLOTNUM Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Slot Number	
Valid Points	AnalIn, AnalOut, DigIn, DigOut, DigComp, Flag, Logic, Numeric, and Timer	
Type	Integer	
Lock	PtBld	
Default	None	
PtRes	NIM	
Range	Depends on point type	

ATTENTION The actual range check will be calculated on the PU count for each Point type and the mix of configured points desired.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

SMPLTFM

The SMPLTFM parameter specifies the SM platform, either FSC-SRS or TRICON. Table 2-228 defines this parameter.

Table 2-228 SMPLTFM Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Safety Manager Platform Type	
Valid Points		
Type	E:\$FSC-SMPLTFM	
Lock	PtBld	
Default	-	
PtRes	FSC-SMM	
Range	0 – TRICON	
	1 – FSC-SRS	

SO (DigOut)

The SO parameter indicates the output from a Digital Composite or Digital Output point. Table 2-229 defines this parameter.

Table 2-229 SO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Status Output	
Valid Points	DigOut	
Type	Logical	
Lock	Oper	DigOut points.
	Um_Cont_Ctrl	DigOut point only.
Default	Off	
PtRes	FSC-SMM	
Range	Off	Field contact is de-energized.
	On	Field contact is energized.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

SO (Timer)

The SO parameter indicates whether the PV's elapsed time has reached the SP's preset time. Table 2-230 defines this parameter.

Table 2-230 SO Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Status Output of Timer	
Valid Points	Timer	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	PV = SP
	On	PV ≠ SP

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

SO(i) (DigComp)

The SO(i) parameter indicates the current state of the Digital Composite slot. Table 2-231 defines this parameter.

Table 2-231 SO(i) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Status Output Array	
Valid Points	DigComp	
Type	Logical	
Lock	Program	
Default	Off	
PtRes	FSC-SMM	
Range	Off	
	On	

ATTENTION The following information is important to the understanding and use of the SO(i) parameter.

- For reads the current state is identified as:
 - i = 0 for a state of 0,
 - i = 1 for a state of 1, and
 - i = 2 for a state of 2.
- For writes the current state is identified as:
 - i = 0 for a state of 0 (a value of ON sets OP to state 0),
 - i = 1 for a state of 0 (a value of ON sets OP to state 0),
 - i = 2 for a state of 0 (a value of ON sets OP to state 0), and
 - A value of OFF has no effect on OP.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

SP

The SP parameter defines the Timer's preset time in seconds or minutes. Table 2-232 defines this parameter.

Table 2-232 SP Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Timer Setpoint Variable	
Valid Points	Timer	
Type	Real	
Lock	Oper	
Default	0	
PtRes	FSC-SMM	
Range	If timebase is...	Then range is...
	100 ms	1 .. 204.7 seconds
	1 s	1 .. 2047 seconds
	1 m	1 .. 2047 minutes

ATTENTION The following information is important to the understanding and use of the PV parameter.

- PVFORMAT only affects how the SP value is displayed (how many digits after the decimal point).
- The FSC-SMM monitors the FSC-SRS value between write operations.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

SPSLTSRC

The SPSLTSRC parameter defines the preset value's source (alias) address within the FSC-SRS. Table 2-233 defines this parameter.

Table 2-233 SPSLTSRC Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Setpoint Source Address	
Valid Points	Timer	
Type	Unsigned Integer	
Lock	View	
Default	0	
PtRes	FSC-SMM	
Range	0	Not configured.
	1 to 65535	

ATTENTION The preset (SP) value is not necessarily the FSC-SRS alias address adjacent to the accumulator (PV) address.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

ST0_OP1–ST0_OP3

The ST0_OP1–ST0_OP3 parameters define the value (On or Off) that is to be written to output 1, 2, or 3 when the OP is in State 0. Table 2-234 defines this parameter.

Table 2-234 ST0_OP1–ST0_OP3 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	State 0 Outputs, 1 through 3	
Valid Points	DigComp	
Type	Logical	
Lock	Eng/PB	
Default	Off	
PtRes	FSC-SMM	
Range	Off	
	On	

ST1_OP1–ST1_OP3

The ST1_OP1–ST1_OP3 parameter defines the value (On or Off) that is to be written to output 1, 2, or 3 when the OP is in State 1. Table 2-235 defines this parameter.

Table 2-235 ST1_OP1–ST1_OP3 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	State 1 Outputs, 1 through 3	
Valid Points	DigComp	
Type	Logical	
Lock	Eng/PB	
Default	Off	
PtRes	FSC-SMM	
Range	Off	
	On	

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

ST2_OP1–ST2_OP3

The ST2_OP1–ST2_OP3 parameter defines the value (On or Off) that is to be written to output 1, 2, or 3 when the OP is in State 1. Table 2-236 defines this parameter.

Table 2-236 ST2_OP1–ST2_OP3 Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	State 2 Outputs, 1 through 3	
Valid Points	DigComp	
Type	Logical	
Lock	Eng/PB	
Default	Off	
PtRes	FSC-SMM	
Range	Off	
	On	

STATE

The STATE parameter indicates the current state of the timer data point. Table 2-237 defines this parameter.

Table 2-237 STATE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Timer State	
Valid Points	Timer	
Type	E:STATE	
Lock	View	
Default	Stopped	
PtRes	FSC-SMM	
Range	Disable	
	Enable	

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

STATE(0–2)

The STATE(0–2) parameters indicate the current state of the data points on the displays. Table 2-238 defines this parameter.

Table 2-238 STATE(0–2) Definition and Entry Fields

Item	Definitions/Settings	Notes																				
Full Name	Current State																					
Valid Points	DigComp, DigIn, DigOut, and Flag																					
Type	String_8																					
Lock	View																					
Default	The following table defines the default value assigned to each point type and state combination. <table><tr><th>Point Type</th><th>Default State 0</th><th>Default State 1</th><th>Default State 2</th></tr><tr><td>DigComp</td><td>None</td><td>None</td><td>None</td></tr><tr><td>DigIn</td><td>None</td><td>None</td><td>N/A</td></tr><tr><td>DigOut</td><td>Off</td><td>On</td><td>N/A</td></tr><tr><td>Flag</td><td>None</td><td>None</td><td>N/A</td></tr></table>		Point Type	Default State 0	Default State 1	Default State 2	DigComp	None	None	None	DigIn	None	None	N/A	DigOut	Off	On	N/A	Flag	None	None	N/A
Point Type	Default State 0	Default State 1	Default State 2																			
DigComp	None	None	None																			
DigIn	None	None	N/A																			
DigOut	Off	On	N/A																			
Flag	None	None	N/A																			
PtRes	NIM																					
Range	N/A																					

ATTENTION The following information is important to the understanding and use of the OPFINLO parameter.

- These parameters represent the STATETXT descriptors as:
 - STATE0 = STATETXT(0),
 - STATE1 = STATETXT(1), and
 - STATE2 = STATETXT(2).
- STATETXT(2) applies to only the Digital Composite point.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

STATETXT(0–1)

The STATETXT(0–1) parameters define the states of the point using descriptors which can have up-to-eight characters. Table 2-239 defines this parameter.

Table 2-239 STATETXT(0–1) Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	State Descriptor Text	
Valid Points	DigComp, DigIn, and Flag	
Type	String_8	
Lock	PtBld	
Default	0	Off
	1	On
PtRes	NIM	
Range	Alphanumerics, A to Z	Upper case characters only.
	Numerals, 0 to 9	
	Underscore (_)	

ATTENTION

The following information is important to the understanding and use of the STATETXT(0–1) parameter.

- STATETXT(0–1) have access locks of View if PNTFORM = Component.
- For a DigComp point, STATETXT(2) for state 2 only applies if NOSTATES = 3.
- STATETXT(0) corresponds to:
 - the Inactive state,
 - PVFL = Off (direct acting), or On (reverse acting),
 - the middle box for DigComp point on Group and Detail Displays, and
 - the lower box for a DigIn point on Group and Detail displays.
- STATETXT(1) corresponds to:
 - the first Active state,
 - PVFL = On (direct acting), or Off (reverse acting), and
 - the upper box for point on Group and Detail displays.

Continued on next page

2.19 SXXXX—Parameter Definitions, Continued

STATETXT(0–1),
continued

-
- STATETXT(1) corresponds to:
 - the second Active state,
 - the lower box for a DigComp point on Group and Detail displays, and
 - does not apply to the DigIn or Flag points.
-

2.20 TXXXX—Parameter Definitions

TF

The TF parameter defines the filtering time lag to be used after the PV range has been checked. Table 2-240 defines this parameter.

Table 2-240 TF Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	PV Filter Lag Time in Minutes	
Valid Points	AnalIn	
Type	Real	
Lock	Supr	
Default	0.0000	Minutes
PtRes	FSC-SMM	
Range	0.00001 to 60.0000	Minutes

ATTENTION A value of 0.0000 minutes specifies that the PV is not delayed.

TIMEBASE

The TIMEBASE parameters define the time base to be used for the Timer data point. Table 2-241 defines this parameter.

Table 2-241 TIMEBASE Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Time Base	
Valid Points	Timer	
Type	E:TIMEBASE	
Lock	View	
Default	Seconds	
PtRes	FSC-SMM	
Range	100 Milliseconds (ms)	
	Seconds (s)	
	Minutes (m)	

ATTENTION This parameter is used for display purposes only. It cannot change the Timer from one time base to another.

2.21 UXXXX—Parameter Definitions

UCNRECHN

The UCNRECHN parameters indicates the channel to which the node is listening. Table 2-242 defines this parameter.

Table 2-242 UCNRECHN Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	UCN Receive Channel	
Valid Points	Node Specif., UCN Node	
Type	E:\$RECCHN	
Lock	View	
Default	ChannelA	
PtRes	FSC-SMM	
Range	ChannelA	Listening to UCN Channel B.
	ChannelB	Listening to UCN Channel B.

UNCMDFL

The UNCMDFL parameters indicates whether an uncommanded change has been detected in the field device. Table 2-243 defines this parameter.

Table 2-243 UNCMDFL Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Uncommanded Change Alarm Flag	
Valid Points	DigComp	
Type	Logical	
Lock	View	
Default	Off	
PtRes	FSC-SMM	
Range	Off	No uncommanded change alarm has been detected by this point.
	On	An uncommanded change alarm has been detected by this point.

Continued on next page

2.21 UXXXX—Parameter Definitions, Continued

UNIT

The UNIT parameter defines the process unit to which this point is assigned. Table 2-244 defines this parameter.

ATTENTION UNIT is the external parameter name.
UNITNUM is the internal parameter name.

Table 2-244 UNIT Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	Process Unit Identifier	
Valid Points		
Type	Integer	
Lock	PtBld	
Default	N/A	
PtRes	NIM	
Range	Alphanumerics, A to Z	
	Numerals, 0 to 9	

ATTENTION The following information is important to the understanding and use of the UNIT parameter.

- The unit identifier is originally assigned during network configuration, and it appears in the displays and listings throughout the system.
- Up to 100 unit numbers can be configured.
- Single digit unit number are not allowed, as an example
 - unit 3 must be entered as 03.
- A real number is returned for this parameter by the Picture Editor and by a CL program.
 - This number is equivalent to the ordinal number in the enumeration list of units.

2.22 WXXXX—Parameter Definitions

WEEKDAY

The WEEKDAY parameter provides the value of the weekday portion of the LCN Time in the FSC-SMM. Table 2-245 defines this parameter.

Table 2-245 WEEKDAY Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Weekday	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	1 to 7	Sunday <i>to</i> Saturday

2.23 YXXXX—Parameter Definitions

YEAR

The YEAR parameter provides the value of the year portion of the LCN Time in the FSC-SMM. Table 2-246 defines this parameter.

Table 2-246 YEAR Definition and Entry Fields

Item	Definitions/Settings	Notes
Full Name	FSC-SMM Year	
Valid Points	Node Specif.	
Type	Integer	
Lock	View	
Default	N/A	
PtRes	FSC-SMM	
Range	1979 to 2115	

Index

\$

\$AUXUNIT, 22
\$CHKPNT, 23
\$COMCKPT, 23
\$OPTOL, 24
\$PAISLOT(xx), 26
\$PAOSLOT(xx), 26
\$PDCSLOT(xx), 27
\$PDISLOT(xx), 27
\$PDOSLOT(xx), 28
\$PLOGSLT(xx), 28
\$PTIME(xx), 29
\$PTRESID, 25
\$PUANLIN(xx), 30
\$PUANLOP(xx), 30
\$PUDIGCP(xx), 31
\$PUDIGIN(xx), 31
\$PUDIGOP(xx), 32
\$PUFREE(xx), 32
\$PULOGIC(xx), 33
\$PUTIME(xx), 33
\$PVSTREC, 25
\$REALARM, 23
\$RECOVER, 26

A

Access levels, 4
Access lock, 4
Access lock/level relationship, 4
Add Optional None State, 115
Alarm Enable Status, 27
Alarm Option, 28
Alarm Priority, 29
ALENBST, 27
ALMOPT, 28
ALPRIOR, 29
AM/CL sequences, 8
Analog Input data point parameters on the FSC-SMM, 9
Analog Input data point parameters on the NIM, 9
Analog Output data point parameters on the FSC-SMM, 10
Analog Output data point parameters on the NIM, 10
Analog Output Direct/Reverse Action, 132
ASSOCDSP, 30
Associated Display, 30
Attention, 5
Automatic Checkpoint Inhibit Operation, 41
Auxiliary Unit, 22

B

Bad Control Flag, 31
Bad Loop Flag, 33
Bad OP Control Priority, 32
Bad PV Alarm Priority, 34
Bad PV Flag, 33
Bad PV State Descriptor, 35
BADCTLFL, 31
BADCTLPR, 32
BADLPFL, 33
BADPVFL, 33, 160
BADPVPR, 34
BADPVTXT, 35
Box Color for Displays, 36, 37
Box Flag Variables, 65
BOXCLR, 36, 37
BYPASS, 38

C

Calculated PV, 157
CASREQ, 39
CCSRC, 40
Character string length, 3
Checkpoint Record, 23
CHPINOPR, 41
Clamping, 160
CMDDISFL, 41
CMDDISPR, 42
CMDFALFL, 43
COMMAND, 43
Command Disagree Alarm Flag, 41
Command Disagree Alarm Priority, 42
Command Fail Alarm Flag, 43
Commanded Output State, 125
Component points, 6
Contact Cut Out, 44
Contact Cut Out Source, 40
CONTCUT, 44
CRPPXORN, 45
CRUCNORN, 45
Current FSC-SMM Softfail Status, 140
Current Hour Point Processing Fetch/Store Counter, 45
Current Hour Point Processing Overrun Counter, 45
Current PV State, 156
Current State, 198

Index

D

D1, 46
D1_0, 47
D1_1, 48
D2, 46
D2D1_00, 49
D2D1_01, 50
D2D1_10, 51
D2D1_11, 52
DATE, 53
DAY, 53
Default, 5
Delay Time, 56
Digital, 49
Digital 1 Input, 46
Digital 2 Input, 46
Digital Composite data point parameters on the FSC-SMM, 11
Digital Composite data point parameters on the NIM, 12
Digital Composite Input Connection Source, 55
Digital Composite Output Connection Source, 57
Digital Composite Override Interlock Source, 123
Digital Composite Permissive Interlock Source, 136
Digital Input 1 Equals a PV State of 0, 47
Digital Input 1 Equals a PV State of 1, 48
Digital Input 2 and Digital Input 1 Both Equal a PV State of 1, 52
Digital Input 2 Equals a State of 0 and Digital Input 1 Equals a PV State of 1, 50
Digital Input 2 Equals a State of 1 and Digital Input 1 Equals a PV State of 0, 51
Digital Input data point parameters on the FSC-SMM, 13
Digital Input data point parameters on the NIM, 13
Digital Input Point, 56, 58
Digital Output data point parameters on the FSC-SMM, 14
Digital Output data point parameters on the NIM, 14
Display Type, 54
DISPTYPE, 54
DISRC(1–2), 55
DITYPE, 56
DLYTIME, 56
DODSTN(1–3), 57
DOTYPE, 58

E

EIPPCODE, 59
Engineering Units Descriptor, 60
Entity parameter identifier, 3
Enumeration of FSC Control Processor Data Type, 165
EUDESC, 60
Event Recording Option, 62
Events Initiated Proceeding Point Identifier, 59
EVTOPT, 62
External Output Value, 78

F

FBTIME, 63
Feedback Time, 63
Final Output State Descriptor, 64
Final Output State Read Back from the FSC-SRS, 127
FINSTTXT(1–3), 64
FL(1-2000), 65
Flag data point parameters on the FSC-SMM, 15
Flag data point parameters on the NIM, 15
FLLSBA, 66
FORCE, 67
Force Enable, 67
Force Flag, 68
FORCEFL, 68
FSC Control Processor Alias Address, 137
FSC Safety Manager Module (FSC-SMM), 5
FSC-SM Node Specific Data Point Checkpoint Record, 23
FSC-SM Node Summary Status, 109
FSC-SM/CL sequences, 8
FSC-SMM Command, 138
FSC-SMM Command Processor Detail Record, 139
FSC-SMM Date, 53
FSC-SMM Day, 53
FSC-SMM Hour, 72
FSC-SMM Minute, 87
FSC-SMM Month, 91
FSC-SMM Primary Status, 141
FSC-SMM Redundancy Operation, 139
FSC-SMM Redundant Pair Names, 81
FSC-SMM Second, 189
FSC-SMM Weekday, 204
FSC-SMM Year, 205
Full points, 6

Index

G

GENDESC, 69
Generic Descriptor, 69

H

HIGHAL, 70
HIGHALPR, 71
Highest Alarm Detected, 70
Highest Level Alarm's Priority, 71
HOUR, 72

I, J

I0–2, 73
INPTDIR, 74, 75, 173
Input Direction, 74, 75

K

KEYWORD, 76
Keyword Descriptor, 76

L

L(1-12), 78
Last Digital Output State Requested, 124
Last Hours Point Processing Fetch/Store Overruns, 86
Last Hours UCN Access Overruns, 86
Last PV Value, 78
LASTPV, 78
Least Significant Alias Address, 102
Least Significant Source Address, 66
LIBADOPT, 79
LISRC(1–12), 80
LMNAME, 81
LMSRC, 81
Load Scope, 82
LOADSCOP, 82
Local Manual Flag, 83
Local Manual Source Address, 81
LOCALMAN, 83
Lock, 4
LOCUTOFF, 84
LODSTN(1–12), 84
LOENBL(1–12), 85
Logic Bad-Input Handling Option, 79
Logic data point parameters on the FSC-SMM, 16
Logic data point parameters on the NIM, 16
Logic Input Connection Source, 80
Logic Mix, 85

Logic Output Connection Destination, 84
Logic Output Enable, 85
LOGMIX, 85
Low Signal Cut-Off for Flow Inputs, 84
LSPPXORN, 86
LSUCNORN, 86

M

MINUTE, 87
MODATTR, 88
MODE, 89
Mode Applicability, 90
Mode Attribute, 88
Mode Permissive, 90
MODEAPPL, 90
MODEPERM, 90
Momentary Output States, 91
MOMSTATE, 91
MONTH, 91
Moving PV Flag, 92
Moving PV Text Descriptor, 92
MOVPVFL, 92
MOVPVTEXT, 92

N

NAISLOT, 93
NAME, 94
NAOSLOT, 96
NDCSLOT, 96
NDISLOT, 97
NDOSLOT, 97
Network Interface Module, 5
Network Number, 120
NFLAG, 98
NIM, 5
NIM Node Status, 107
NIM Node Summary Status, 108
NLOGSLOT, 98
NMODATTR, 99
NMODE, 100
NN(1–1000), 101
NNLSBA, 102
NNUMERIC, 103
Node Assignment, 104
Node Number, 105, 106
Node's Functional Status, 112
NODEASSN (UCN Node), 104
NODENUM, 105, 106
NODESC, 107
Node-specific data point parameters, 17
NODESTAT, 107

Index

NODESTS, 109
NODETYP, 110, 111
NODFSTAT, 112
NODINPTS, 112
NODOPTS, 113
NOLINPTS, 113
NOLOGBLK, 114
NOLOPTS, 114
NONE_OP1 - NONE_OP3, 116
NONECONF, 115
NONETXT, 117
Normal Mode, 100
Normal Mode Attribute, 99
NOSTATES, 118
Not A Number (NaN), 3
NTIMER, 119
NTWKNUM, 120
Number of Analog Input Slots, 93
Number of Analog Output Slots, 96
Number of Digital Composite Slots, 96
Number of Digital Input Slots, 97
Number of Digital Inputs, 112
Number of Digital Output Slots, 97
Number of Digital Outputs, 113
Number of Digital States, 118
Number of Flags, 98
Number of Generic Descriptors, 107
Number of Logic Blocks, 114
Number of Logic Input Points, 113
Number of Logic Output Points, 114
Number of Logic Slots, 98
Number of Numerics, 103
Number of Timer Slots, 119
Numeric data point parameters on the FSC-SMM, 18
Numeric data point parameters on the NIM, 18
Numeric Value, 101

O

Off-Normal Alarm Flag, 121
Off-normal Alarm Priority, 122
OFFNRMFL, 121
OFFNRMPR, 122
OISRC(1-3), 123
OP, 123, 124, 125
Operator Mode Attribute Flag, 130
OPFINAL, 126, 127
OPFINHI, 128
OPFINLO, 129
OPRATRFL, 130
OPSTTEXT, 131
OPTDIR, 132
OROPT, 132
Output High Value at Control Element, 128

Output in Percent, 123
Output Low Value at Control Element, 129
Output State Text, 131
Output Tolerance, 24
Override Alarm Priority, 134
Override Input Bypass Enable, 38
Override Interlocks for Output States 0, 1 and 2, 73
Override Option, 132
OVERVAL, 133
Overview Value in Percent, 133
OVRDALPR, 134

P, Q

P0-P2, 135
Parameter data types, 3
Parameter definition format, 2
Parameter identifier, 3
Parameter name, 3
Parameters on the FSC-SMM
 Analog Input data points, 9
 Analog Output data points, 10
 Digital Composite data points, 11
 Digital Input data points, 13
 Digital Output data points, 14
 Flag data points, 15
 Logic data points, 16
 Numeric data points, 18
 Timer data points, 19
Parameters on the NIM
 Analog Input data points, 9
 Analog Output data points, 10
 Digital Composite data points, 12
 Digital Input data points, 13
 Digital Output data points, 14
 Flag data points, 15
 Logic data points, 16
 Numeric data points, 18
 Timer data points, 19
Percent Output at the Control Element, 126
Permissive Interlocks for States 0, 1 and 2, 135
PISRC(1-3), 136
PLCADDR, 137
PMMCMD, 138
PMMCMDTL, 139
PMMOPER, 139
PMMSFST, 140
PMMSTS, 141

Index

PNTFORM, 142
PNTSTATE, 143
PNTTYPE, 144
Point Descriptor, 146
Point Execution State, 148
Point form, 6, 142
Point in Alarm Indicator, 148
Point names and related acronyms, 7
Point residency, 5
Point Residency Identifier, 25
Point Type, 144
Point's Overall State, 143
Primary Module Identifier, 145
PRIMMOD, 145
Process Unit Identifier, 203
Process Variable Current State, 150, 151, 152
Process Variable Current Value, 149, 152, 153
PTDESC, 146, 147
PTEXECST, 148
PTINAL, 148
PtRes, 5
PV, 149, 150, 151, 152, 153
PV Alarm Dead Band as a Percentage of Full Range, 154
PV Alarm Deadband in Engineering Units, 155
PV Auto Value, 155
PV Auto Value Status, 157
PV Change Delay, 158
PV Change Timer, 159
PV Characterization Option, 158
PV Clamping Option, 160
PV Decimal Point Format, 166
PV Extended Engineering Unit Range High, 162
PV Extended Engineering Unit Range Low, 163
PV Extended High Range Violation, 163
PV Extended Low Range Violation, 164
PV Filter Lag Time in Minutes, 201
PV Flag, 164, 165
PV High Alarm Flag, 167
PV High Alarm Priority, 168
PV High Alarm Trip Point, 169
PV High Range in Engineering Units, 161
PV in Percent, 172
PV Low Alarm Flag, 169
PV Low Alarm Priority, 170
PV Low Alarm Trip Point, 171
PV Low Range in Engineering Units, 161
PV Normal State, 171
PV Normal State Flag, 172
PV Raw High Value, 174
PV Raw Low Value, 175
PV Raw Value, 173
PV Slot Source, 176
PV Source, 177
PV Source Option, 178
PV State Descriptors, 179
PV Target Value in Engineering Units, 181
PV Target Value in Percent, 181
PV Value and Status Record, 25
PVALDB, 154
PVALDBEU, 155
PVAUTO, 155, 156, 160
PVAUTOST, 157
PVCALC, 157
PVCHAR, 158
PVCHGDLY, 158
PVCHGTMR, 159
PVCLAMP, 160
PVEUHI, 161
PVEULO, 161
PVEXEUHI, 160, 162
PVEXEULO, 160, 163
PVEXHIFL, 160, 163
PVEXLOFL, 160, 164
PVFL, 164, 165
PVFLTOPT, 165
PVFORMAT, 166
PVHIFL, 167
PVHIPR, 168
PVHITP, 169
PVLOFL, 169
PVLOPR, 170
PVLOTP, 171
PVNORMAL, 171
PVNORMFL, 172
PVP, 172
PVRAW, 173
PVRAWHI, 174
PVRAWLO, 175
PVSLTSRC, 176
PVSOURCE, 177
PVSRCOPT, 178
PVSTATES(0-4), 179
PVSTS, 160, 180
PVTVP, 181
PVTVP, 181

Index

R

Range, 5
Raw State of Field Contacts, 173
RCASOPT, 182
Recover All FSC SMM Alarms, 26
Red Tag State, 183
REDTAG, 183
References, 5
Remaining Time, 185
Remote Cascade Option, 182
Remote Cascade Request, 39
Remote Initialization Request, 184
RINITREQ, 184
RV, 185

S

S0BOXCLR, 186
S1BOXCLR, 187
S2BOXCLR, 188
Safety Manager Platform Type, 191
Scan Rate, 189
SCANRATE, 189
SECOND, 189
Setpoint Source Address, 195
Slot Number, 190
SLOTNUM, 190
SMPLTFM, 191
SO, 191, 192
SO(i), 193
SP, 194
SPSLTSRC, 195
ST0_OP1-ST0_OP3, 196
ST1_OP1-ST1_OP3, 196
ST2_OP1-ST2_OP3, 197
STATE, 197
State 0 Box Color, 186
State 0 Outputs, 1 through 3, 196
State 1 Box Color, 187
State 1 Outputs, 1 through 3, 196
State 2 Box Color, 188
State 2 Outputs, 1 through 3, 197
State Descriptor for the None State, 117
State Descriptor Text, 199

STATE(0-2), 198
STATETXT(0-1), 199
Status of PV Input Value, 180
Status Output, 191
Status Output Array, 193
Status Output of Timer, 192

T

Tagname, 94
TF, 201
Time Base, 201
TIMEBASE, 201
Timer Command, 43
Timer data point parameters on the FSC-SMM, 19
Timer data point parameters on the NIM, 19
Timer Setpoint Variable, 194
Timer State, 197

U

UCN data point parameters, 20
UCN Node Type, 110, 111
UCN Receive Channel, 202
UCNRECHN, 202
UNCMDFL, 202
Uncommanded Change Alarm Flag, 202
UNIT, 203
Universal entity parameter identifier, 3

V

Value Stored in Output n, 116

W, X

WEEKDAY, 204

Y, Z

YEAR, 205

