

Facility Condition Assessment Summary Report

This report provides a summary of the Facility Condition Index (FCI) value of a school facility and select major building systems. The FCI calculation represents the cost of needed repairs divided by the replacement value. The FCI is a numerical value of condition and helps to identify the need for renewal or replacement of specific parts of the facility. The FCI is particularly useful when comparing similar facilities within the same portfolio.

Penrose LSH School

Governance	DISTRICT	Report Type	Elementarymiddle
Address	2515 S. 78Th St. Philadelphia, Pa 19153	Enrollment	
Phone/Fax	215-492-6455 / 215-492-6985	Grade Range	'00-08'
Website	Www.Philasd.Org/Schools/Penrose	Admissions Category	Neighborhood
		Turnaround Model	N/A

Building/System FCI Tiers

Facility Condition Index (FCI) = $\frac{\text{Cost of Assessed Deficiencies}}{\text{Replacement Value}}$				
< 15%	15 to 25%	25 to 45%	45 to 60%	> 60%
Buildings				
Minimal Current Capital Funding Required	Refurbish Systems in building	Replace Systems in building.	Building should be considered for major renovation.	Building should be considered for closing/replacement.
Systems				
Perform routine maintenance on system	System requires minor repairs	System should be studied to determine repair vs. replacement.	System is nearing end of its life expectancy and should be considered for replacement	System should be replaced as part of the Capital Program

Building and Grounds

	FCI	Repair Costs	Replacement Cost
Overall	13.29%	\$8,286,194	\$62,346,372
Building	02.73 %	\$405,035	\$14,824,649
Grounds	23.23 %	\$600,406	\$2,584,878

Major Building Systems

Building System	System FCI	Repair Costs	Replacement Cost
Roof (Shows physical condition of roof)	04.36 %	\$43,990	\$1,009,266
Exterior Walls (Shows condition of the structural condition of the exterior facade)	00.94 %	\$7,349	\$785,433
Windows (Shows functionality of exterior windows)	58.86 %	\$201,846	\$342,904
Exterior Doors (Shows condition of exterior doors)	00.00 %	\$0	\$42,014
Interior Doors (Classroom doors)	00.00 %	\$0	\$94,594
Interior Walls (Paint and Finishes)	00.00 %	\$0	\$422,906
Plumbing Fixtures	01.89 %	\$15,041	\$794,490
Boilers	00.00 %	\$0	\$469,700
Chillers/Cooling Towers	00.00 %	\$0	\$615,868
Radiators/Unit Ventilators/HVAC	00.00 %	\$0	\$1,081,542
Heating/Cooling Controls	00.00 %	\$0	\$339,633
Electrical Service and Distribution	00.00 %	\$0	\$244,033
Lighting	00.00 %	\$0	\$872,479
Communications and Security (Cameras, Pa System and Fire Alarm)	34.44 %	\$112,560	\$326,802

Please note that some FCIs may be over 100% because there are times when replacing a building system requires that other building systems be upgraded to complete the installation. A FCI of 0.0% represents that there are no current deficiencies with the associated system.