

Structural survey: summary of findings

Client: BürgerEnergie Eschenbrück eG. Engineer: Dr. Ines Kraft, Ingenieurbüro Kraft & Partner. Date: 22 April 2026. Site visits: 14 and 16 April 2026.

Roof A - Grundschule am Lindenhof

Concrete flat roof, renovated in 2019. The load reserve of 0.85 kN/m² is sufficient for a ballasted east-west or south-facing system. No restrictions.

Roof B - Sporthalle Nord

Timber roof structure from 1978. The west and middle sections have a load reserve of 0.42 kN/m². The east section has a load reserve of only 0.12 kN/m² and must not carry modules.

Recommendation

With the planned Helion H-440 modules (24.3 kg each) and ballast, the plant should be limited to approximately 165 kWp in total. Lighter modules would allow more modules on roof B; the client should send the data sheet of any alternative module for a re-check.

The battery room in the school basement needs a fire door of class F90 before the battery is installed.

Fee

Invoice KP-2026-007 for this survey: 4,380 euros.