WORK ORDER WO-2291
Equipment: PMP-104 (Coolant Pump 4)
Date: March 3, 2026
Technician: Maria Lopez
Work done: Replaced 2 bearings and 1 mechanical seal.
Downtime: 1.5 hours
Status: Closed - running normally