WORK ORDER WO-5017
Equipment: FAN-33 exhaust fan
Date: September 22, 2026
Technician: Sam Rivera
Replaced 1 motor capacitor. Status: closed.