WORK ORDER WO-7003
Equipment: ELV-1 freight elevator
Date: May 30, 2026
Technician: Ben Ortiz
Door sensor fault reported. Cleaned and realigned sensor, fault came back.
Waiting on replacement sensor from vendor. Elevator out of service 8 hours.