

**Annual performance report for:** Peake GB Ltd

**Permit Number:** EPR/YP3934SM/V003

**Year:** 2022

This report is required under the Industrial Emissions Directive’s Article 55(2) requirements on reporting and public information on waste incineration plants and co-incineration plants, which require the operator to produce an annual report on the functioning and monitoring of the plant and make it available to the public.

**1. Introduction**

Name and address of plant	Peake GB Ltd Stoneybridge Park Liskeard Cornwall PL14 3NQ
Description of waste input	Waste input is mainly clinical waste generated in the South West, either collected by the company or brought in from third parties. Other wastes include hazardous wastes contaminated packaging, confidential papers, ABP & plant tissue wastes.
Operator contact details if members of the public have any questions	

**2. Plant description**

<p>The plant at Stoneybridge Park is a High Temperature Incineration facility which incinerates hazardous &amp; non-hazardous wastes from hospitals, healthcare premises and other establishments in the South West. The plant is licensed to operate 24/7 with a maximum throughput of 650kg/hr. The plant is of a Rotary Kiln design which is capable of handling a wide range of wastes, the waste is fed into the plant by use of a bin tipper and ram loading box. The IBA (bottom ash) is discharged into skips at base of a transition chamber, the flue gases pass on to the secondary chamber then a heat exchanger, where the gasses are cooled before entering the reactor tower &amp; abatement plant where sodium bicarbonate and activated carbon is injected to neutralise acid gasses. The sorbents are then captured on ceramic filter elements, to provide a further reaction surface before being recirculated and then discharged into IBC’s for disposal. The cleaned flue gasses pass through the ceramic filters to the ID fan and on to the discharge stack.</p>
--

### 3. Summary of Plant Operation


Clinical waste received	2531 tonnes
Other waste received	639 tonnes
Total waste received	3170 tonnes
Total plant operational hours	6720 hours
Total hours of “abnormal operation” (see permit for definition)	28 hours
Total quantity of incinerator bottom ash (IBA) produced	343 tonnes
Disposal or recovery route for IBA	Disposal by Treatment (D09)
Did any batches of IBA test as hazardous? If yes, state quantity	343 tonnes
Total quantity of air pollution control (APC) residues produced	121 tonnes
Disposal or recovery route for APC residues	Disposal by Treatment (D09)

## 4. Summary of Plant Emissions


### 4.1 Summary of continuous emissions monitoring results for emissions to air

The following charts show the performance of the plant against its emission limit values (ELVs) for substances that are continuously monitored.


Line 1 - Hydrogen chloride




Line 1 – Sulphur dioxide




Line 1 – Oxides of nitrogen




Line 1 – Carbon monoxide



Line 1 – Particulates (DUST)



Line 1 – Total organic carbon (VOC)



## 4.2 Summary of periodic monitoring results for emissions to air

The table below shows the results of periodically monitored substances.

Substance	Emission limit value	Results	
		24.05.22	25/10/22
Mercury and its compounds	0.05 mg/m <sup>3</sup>	0.0017 mg/m <sup>3</sup>	0.0025 mg/m <sup>3</sup>
Cadmium & thallium and their compounds (total)	0.05 mg/m <sup>3</sup>	0.0012 mg/m <sup>3</sup>	0.00079 mg/m <sup>3</sup>
Sb, As, Pb, Cr, Co, Cu, Mn, Ni and V and their compounds (total)	0.5 mg/m <sup>3</sup>	0.23 mg/m <sup>3</sup>	0.047 mg/m <sup>3</sup>
Dioxins and furans (I-TEQ)	0.1 ng/m <sup>3</sup>	0.2 ng/m <sup>3</sup>	0.043 ng/m <sup>3</sup>
Hydrogen Fluoride	2.0 mg/m <sup>3</sup>	0.15 mg/m <sup>3</sup>	0.07 mg/m <sup>3</sup>

## 4.3 Summary of monitoring results for emissions to water

There are no emissions to water from the process [other than clean surface water].

## 5. Summary of Plant Compliance

Independent bi-annual testing & CEMS monitoring reports are carried out on the plant in accordance with permit requirements and the results submitted to the Agency. Where there have been emission non-compliances during 2022 these have been notified to the Agency. The site is certified to Environmental Management Systems Standards, ISO 14001 & ISO 9001 which is audited on a regular basis by Independent European Certification Ltd.

### 5.2 Summary of any complaints received and actions to taken to resolve them.

Date of complaint	Summary of complaint	Reason for complaint including whether substantiated by the operator or the EA	If substantiated, measures to prevent reoccurrence
	none		

## 6. Summary of plant improvements

<b>Summary of any permit improvement conditions that have been completed within the year and the resulting environmental benefits.</b>
None
<b>Summary of any changes to the plant or operating techniques which required a variation to the permit and a summary of the resulting environmental impact.</b>
None
<b>Summary of any other improvements made to the plant or planned to be made and a summary of the resulting environmental benefits.</b>
An Exhaust Gas Recirculation duct (EGR) is in the process of being designed with the aim to look to reduce oxygen levels and further improve emission results.