

January 23, 2025 23:01:44

B-RISK Fire Simulator and Design Fire Tool (Ver 2024.1)

Input Filename : input1.xml

Base File : C:\Users\franc\CSTBGroup\These_Francois_Consigny - Documents\Calculs

Feu\Programmes\python\Brisk_pre_calculated\McGregor 3\basemodel_Iter0.xml

User Mode : Risk Simulator

Simulation Time = 3600.00 seconds.

Initial Time-Step = 1.00 seconds.

=====

Description of Rooms

=====

Room 1 : McGregor 3

Room Length (m) = 3.50

Room Width (m) = 4.50

Maximum Room Height (m) = 2.50

Minimum Room Height (m) = 2.50

Floor Elevation (m) = 0.000

Absolute X Position (m) = 0.000

Absolute Y Position (m) = 0.000

Room 1 has a flat ceiling.

Shape Factor (A_f/H^2) = 2.5

Wall Surface is CLT

Wall Density (kg/m3) = 515.0

Wall Conductivity (W/m.K) = 0.130

Wall Specific Heat (J/kg.K) = 1600

Wall Emissivity = 1.00

Wall Thickness (mm) = 105.0

SQROOT Thermal Inertia ($J.m-2.s-1/2.K-1$) = 327

Wall Substrate is GYP1/2

Wall Substrate Density (kg/m3) = 790.0

Wall Substrate Conductivity (W/m.K) = 0.160

Wall Substrate Specific Heat (J/kg.K) = 900

Wall Substrate Thickness (mm) = 12.7

Ceiling Surface is CLT

Ceiling Density (kg/m3) = 515.0

Ceiling Conductivity (W/m.K) = 0.130

Ceiling Specific Heat (J/kg.K) = 1600

Ceiling Emissivity = 1.00

Ceiling Thickness (mm) = 105.0

SQROOT Thermal Inertia ($J.m-2.s-1/2.K-1$) = 327

Ceiling Substrate is GYP1/2

Ceiling Substrate Density (kg/m3) = 790.0

Ceiling Substrate Conductivity (W/m.K) = 0.160

Ceiling Substrate Specific Heat (J/kg.K) = 900

Ceiling Substrate Thickness (mm) = 12.7

Floor Surface is fibre cement sheet

Floor Density (kg/m3) = 1490.0

Floor Conductivity (W/m.K) = 0.720

Floor Specific Heat (J/kg.K) = 840

Floor Emissivity = 0.88

Floor Thickness = (mm) 25.4

SQROOT Thermal Inertia ($J.m-2.s-1/2.K-1$) = 949

Floor Substrate is GYP1/2

Floor Substrate Density (kg/m3) = 790.0

Floor Substrate Conductivity (W/m.K) = 0.160

Floor Substrate Specific Heat (J/kg.K) = 900

Floor Substrate Thickness (mm) = 15.9

=====

Wall Vents

```

=====
Vent 1 : McGregor 3_01
    From room 1 to 2
    Front face of room 1
    Offset (m) = 1.216
    Vent Width (m) = 1.069
    Vent Height (m) = 2.000
    Vent Sill Height (m) = 0.000
    Vent Soffit Height (m) = 2.000
    Opening Time (sec) = 0
    Closing Time (sec) = 0
    Discharge Coefficient (-) = 0.680

=====
Ceiling/Floor Vents
=====
Ambient Conditions
=====
Interior Temp (C) = 16.0
Exterior Temp (C) = 16.0
Relative Humidity (%) = 50

=====
Tenability Parameters
=====
Monitoring Height for Visibility and FED (m) = 2.00
Asphyxiant gas model = FED(CO) C/VM2
Visibility calculations assume: reflective signs
Egress path segments for FED calculations
1. Start Time (sec) 0
1. End Time (sec) 600
1. Room 1
2. Start Time (sec) 0
2. End Time (sec) 0
2. Room 0
3. Start Time (sec) 0
3. End Time (sec) 0
3. Room 0

=====
Sprinkler / Detector Parameters
=====
    Ceiling Jet model used is NIST JET.
    Sprinkler System Reliability 1.000
    Sprinkler Probability of Suppression 0.000
    Sprinkler Cooling Coefficient 1.000

=====
Smoke Detector Parameters
=====
    Smoke Detection System Reliability 1.000

=====
Mechanical Ventilation (to/from outside)
=====
Mechanical Ventilation not installed.
    Mech ventilation system reliability 1.000

=====
Description of the Fire
=====
CO Yield pre-flashover(g/g) = 0.040
Soot Alpha Coefficient = 2.50
Smoke Epsilon Coefficient = 1.20
Flame Emission Coefficient (1/m) = 13.32
Fuel - Carbon Moles 3.00
Fuel - Hydrogen Moles 8.00
Fuel - Oxygen Moles 0.00
Fuel - Nitrogen Moles 0.00
Stoichiometric air/fuel ratio 0.0

```

Burning objects are manually positioned in room.

Enhanced burning submodel is OFF

Burning Object No 1

3 MW propane gas burner

Located in Room	1
Energy Yield (kJ/g) =	43.7
CO2 Yield (kg/kg fuel) =	1.330
HCN Yield (kg/kg fuel) =	0.000
H2O Yield (kg/kg fuel) =	1.636
Soot Yield (kg/kg fuel) =	0.024
Heat Release Rate Per Unit Area (kW/m2) =	250.0
Radiant Loss Fraction =	0.30
Fire Elevation (m) =	0.000
Fire Object Length (m) =	1.700
Fire Object Width (m) =	1.300
Fire Object Height (m) =	0.000
Location, X-coordinate (m) =	2.150
Location, Y-coordinate (m) =	3.350
Fire Location (for entrainment)=	CORNER
Plume behaviour is	UNDISTURBED

Time (sec)	Heat Release (kW)
0	0
75	0
150	600
225	1200
300	1800
375	2400
450	3000
525	3000
600	3000
675	3000
750	3000
825	3000
900	3000
975	3000
1050	3000
1125	2500
1200	2000
1275	1500
1350	1000
1425	500
1500	0
1575	0
1650	0
1725	0
1800	0
1875	0
1950	0
2025	0
2100	0
2175	0
2250	0
2325	0
2400	0
2475	0
2550	0
2625	0
2700	0
2775	0
2850	0
2925	0
3000	0
3075	0
3150	0
3225	0
3300	0
3375	0
3450	0
3525	0
3600	0

```

=====
Postflashover Inputs
=====
Postflashover model is OFF.

=====
Results from Fire Simulation
=====

0 min    00 sec
          (0 sec)
          Room 1    Outside

          Layer (m)          2.500
          Upper Temp (C)     16.0
          Lower Temp (C)     16.0
          HRR (kW)           0.0
          Visibility (m) at 2m 20+
          FED gases on egress path = 0.000
          FED thermal on egress path = 0.000

0 min    36 sec
          (36 sec)
          Room 1    Outside

          Layer (m)          2.500
          Upper Temp (C)     16.0
          Lower Temp (C)     16.0
          HRR (kW)           0.0
          Visibility (m) at 2m 20+
          FED gases on egress path = 0.000
          FED thermal on egress path = 0.000

1 min    12 sec
          (72 sec)
          Room 1    Outside

          Layer (m)          2.500
          Upper Temp (C)     16.0
          Lower Temp (C)     16.0
          HRR (kW)           0.0
          Visibility (m) at 2m 20+
          FED gases on egress path = 0.000
          FED thermal on egress path = 0.000

1 min    48 sec
          (108 sec)
          Room 1    Outside

          Layer (m)          1.587
          Upper Temp (C)     167.5
          Lower Temp (C)     19.2
          HRR (kW)           264.0
          Visibility (m) at 2m 2.42
          FED gases on egress path = 0.002
          FED thermal on egress path = 0.101

2 min    24 sec
          (144 sec)
          Room 1    Outside

          Layer (m)          1.505
          Upper Temp (C)     289.7
          Lower Temp (C)     30.9
          HRR (kW)           552.0
          Visibility (m) at 2m 1.16
          FED gases on egress path = 0.014
          FED thermal on egress path = 1.000

3 min    00 sec
          (180 sec)
          Room 1    Outside

          Layer (m)          1.498
          Upper Temp (C)     376.2
          Lower Temp (C)     48.7
          HRR (kW)           840.0

```

	Visibility (m) at 2m	0.84		
	FED gases on egress path =	0.059		
	FED thermal on egress path =	1.000		
3 min	36 sec			
	(216 sec)	Room 1	Outside	
	Layer (m)	1.487		
	Upper Temp (C)	448.5		
	Lower Temp (C)	68.6		
	HRR (kW)	1128.0		
	Visibility (m) at 2m	0.71		
	FED gases on egress path =	0.329		
	FED thermal on egress path =	1.000		
4 min	12 sec			
	(252 sec)	Room 1	Outside	
	Layer (m)	1.471		
	Upper Temp (C)	518.0		
	Lower Temp (C)	85.6		
	HRR (kW)	1416.0		
	Visibility (m) at 2m	0.62		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
4 min	48 sec			
	(288 sec)	Room 1	Outside	
	Layer (m)	1.458		
	Upper Temp (C)	588.1		
	Lower Temp (C)	106.8		
	HRR (kW)	1704.0		
	Visibility (m) at 2m	0.56		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
5 min	24 sec			
	(324 sec)	Room 1	Outside	
	Layer (m)	1.448		
	Upper Temp (C)	658.2		
	Lower Temp (C)	134.8		
	HRR (kW)	1978.9		
	Visibility (m) at 2m	0.51		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
6 min	00 sec			
	(360 sec)	Room 1	Outside	
	Layer (m)	1.438		
	Upper Temp (C)	712.9		
	Lower Temp (C)	160.9		
	HRR (kW)	2045.7		
	Visibility (m) at 2m	0.46		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
6 min	36 sec			
	(396 sec)	Room 1	Outside	
	Layer (m)	1.424		
	Upper Temp (C)	750.5		
	Lower Temp (C)	177.0		
	HRR (kW)	2093.8		
	Visibility (m) at 2m	0.41		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
7 min	12 sec			
	(432 sec)	Room 1	Outside	

	Layer (m)	1.411		
	Upper Temp (C)	779.3		
	Lower Temp (C)	189.4		
	HRR (kW)	2136.9		
	Visibility (m) at 2m	0.37		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
7 min	48 sec			
	(468 sec)	Room 1	Outside	
	Layer (m)	1.406		
	Upper Temp (C)	803.3		
	Lower Temp (C)	206.0		
	HRR (kW)	2159.4		
	Visibility (m) at 2m	0.35		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
8 min	24 sec			
	(504 sec)	Room 1	Outside	
	Layer (m)	1.409		
	Upper Temp (C)	823.3		
	Lower Temp (C)	220.6		
	HRR (kW)	2165.9		
	Visibility (m) at 2m	0.36		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
9 min	00 sec			
	(540 sec)	Room 1	Outside	
	Layer (m)	1.411		
	Upper Temp (C)	840.9		
	Lower Temp (C)	233.7		
	HRR (kW)	2171.0		
	Visibility (m) at 2m	0.37		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
9 min	36 sec			
	(576 sec)	Room 1	Outside	
	Layer (m)	1.412		
	Upper Temp (C)	856.5		
	Lower Temp (C)	245.6		
	HRR (kW)	2175.2		
	Visibility (m) at 2m	0.37		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
10 min	12 sec			
	(612 sec)	Room 1	Outside	
	Layer (m)	1.414		
	Upper Temp (C)	870.7		
	Lower Temp (C)	256.6		
	HRR (kW)	2178.7		
	Visibility (m) at 2m	0.38		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
10 min	48 sec			
	(648 sec)	Room 1	Outside	
	Layer (m)	1.415		
	Upper Temp (C)	881.5		
	Lower Temp (C)	266.2		
	HRR (kW)	2182.1		
	Visibility (m) at 2m	0.38		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		

11 min	24 sec (684 sec)	Room 1	Outside
	Layer (m)	1.416	
	Upper Temp (C)	891.9	
	Lower Temp (C)	274.7	
	HRR (kW)	2184.4	
	Visibility (m) at 2m	0.39	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
12 min	00 sec (720 sec)	Room 1	Outside
	Layer (m)	1.415	
	Upper Temp (C)	902.4	
	Lower Temp (C)	276.6	
	HRR (kW)	2181.4	
	Visibility (m) at 2m	0.39	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
12 min	36 sec (756 sec)	Room 1	Outside
	Layer (m)	1.414	
	Upper Temp (C)	911.6	
	Lower Temp (C)	278.0	
	HRR (kW)	2179.8	
	Visibility (m) at 2m	0.39	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
13 min	12 sec (792 sec)	Room 1	Outside
	Layer (m)	1.413	
	Upper Temp (C)	920.8	
	Lower Temp (C)	277.3	
	HRR (kW)	2176.2	
	Visibility (m) at 2m	0.39	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
13 min	48 sec (828 sec)	Room 1	Outside
	Layer (m)	1.413	
	Upper Temp (C)	929.0	
	Lower Temp (C)	281.8	
	HRR (kW)	2177.1	
	Visibility (m) at 2m	0.40	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
14 min	24 sec (864 sec)	Room 1	Outside
	Layer (m)	1.414	
	Upper Temp (C)	936.8	
	Lower Temp (C)	287.8	
	HRR (kW)	2178.5	
	Visibility (m) at 2m	0.40	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
15 min	00 sec (900 sec)	Room 1	Outside
	Layer (m)	1.414	
	Upper Temp (C)	944.1	
	Lower Temp (C)	293.6	

	HRR (kW)	2179.7	
	Visibility (m) at 2m	0.40	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
15 min	36 sec		
	(936 sec)	Room 1	Outside
	Layer (m)	1.414	
	Upper Temp (C)	950.9	
	Lower Temp (C)	299.0	
	HRR (kW)	2180.8	
	Visibility (m) at 2m	0.40	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
16 min	12 sec		
	(972 sec)	Room 1	Outside
	Layer (m)	1.415	
	Upper Temp (C)	957.4	
	Lower Temp (C)	304.2	
	HRR (kW)	2181.8	
	Visibility (m) at 2m	0.41	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
16 min	48 sec		
	(1008 sec)	Room 1	Outside
	Layer (m)	1.415	
	Upper Temp (C)	963.4	
	Lower Temp (C)	309.1	
	HRR (kW)	2182.8	
	Visibility (m) at 2m	0.41	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
17 min	24 sec		
	(1044 sec)	Room 1	Outside
	Layer (m)	1.416	
	Upper Temp (C)	969.1	
	Lower Temp (C)	313.8	
	HRR (kW)	2183.6	
	Visibility (m) at 2m	0.41	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
18 min	00 sec		
	(1080 sec)	Room 1	Outside
	Layer (m)	1.425	
	Upper Temp (C)	973.1	
	Lower Temp (C)	317.3	
	HRR (kW)	2158.5	
	Visibility (m) at 2m	0.44	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
18 min	36 sec		
	(1116 sec)	Room 1	Outside
	Layer (m)	1.438	
	Upper Temp (C)	975.2	
	Lower Temp (C)	319.4	
	HRR (kW)	2127.2	
	Visibility (m) at 2m	0.49	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
19 min	12 sec		
	(1152 sec)	Room 1	Outside

	Layer (m)	1.452	
	Upper Temp (C)	975.9	
	Lower Temp (C)	320.6	
	HRR (kW)	2092.1	
	Visibility (m) at 2m	0.56	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
19 min	48 sec		
	(1188 sec)	Room 1	Outside
	Layer (m)	1.468	
	Upper Temp (C)	970.8	
	Lower Temp (C)	322.4	
	HRR (kW)	2054.7	
	Visibility (m) at 2m	0.63	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
20 min	24 sec		
	(1224 sec)	Room 1	Outside
	Layer (m)	1.486	
	Upper Temp (C)	956.8	
	Lower Temp (C)	316.3	
	HRR (kW)	1840.0	
	Visibility (m) at 2m	0.72	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
21 min	00 sec		
	(1260 sec)	Room 1	Outside
	Layer (m)	1.503	
	Upper Temp (C)	927.1	
	Lower Temp (C)	299.7	
	HRR (kW)	1600.0	
	Visibility (m) at 2m	0.81	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
21 min	36 sec		
	(1296 sec)	Room 1	Outside
	Layer (m)	1.523	
	Upper Temp (C)	888.3	
	Lower Temp (C)	278.4	
	HRR (kW)	1360.0	
	Visibility (m) at 2m	0.92	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
22 min	12 sec		
	(1332 sec)	Room 1	Outside
	Layer (m)	1.550	
	Upper Temp (C)	843.3	
	Lower Temp (C)	273.9	
	HRR (kW)	1120.0	
	Visibility (m) at 2m	1.05	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
22 min	48 sec		
	(1368 sec)	Room 1	Outside
	Layer (m)	1.576	
	Upper Temp (C)	791.5	
	Lower Temp (C)	248.4	
	HRR (kW)	880.0	
	Visibility (m) at 2m	1.21	
	FED gases on egress path =	1.000	

FED thermal on egress path = 1.000

23 min 24 sec
(1404 sec) Room 1 Outside

Layer (m) 1.608
Upper Temp (C) 736.1
Lower Temp (C) 222.7
HRR (kW) 640.0
Visibility (m) at 2m 1.44
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

24 min 00 sec
(1440 sec) Room 1 Outside

Layer (m) 1.651
Upper Temp (C) 673.0
Lower Temp (C) 196.7
HRR (kW) 400.0
Visibility (m) at 2m 1.83
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

24 min 36 sec
(1476 sec) Room 1 Outside

Layer (m) 1.724
Upper Temp (C) 600.0
Lower Temp (C) 176.9
HRR (kW) 160.0
Visibility (m) at 2m 2.77
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

25 min 12 sec
(1512 sec) Room 1 Outside

Layer (m) 1.992
Upper Temp (C) 570.6
Lower Temp (C) 164.7
HRR (kW) 0.0
Visibility (m) at 2m 4.97
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

25 min 48 sec
(1548 sec) Room 1 Outside

Layer (m) 2.015
Upper Temp (C) 542.1
Lower Temp (C) 155.3
HRR (kW) 0.0
Visibility (m) at 2m 20+
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

26 min 24 sec
(1584 sec) Room 1 Outside

Layer (m) 2.032
Upper Temp (C) 517.6
Lower Temp (C) 146.1
HRR (kW) 0.0
Visibility (m) at 2m 20+
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

27 min 00 sec
(1620 sec) Room 1 Outside

Layer (m) 2.045
Upper Temp (C) 496.6

	Lower Temp (C)	138.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
27 min	36 sec		
	(1656 sec)	Room 1	Outside
	Layer (m)	2.057	
	Upper Temp (C)	478.3	
	Lower Temp (C)	132.4	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
28 min	12 sec		
	(1692 sec)	Room 1	Outside
	Layer (m)	2.068	
	Upper Temp (C)	462.1	
	Lower Temp (C)	127.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
28 min	48 sec		
	(1728 sec)	Room 1	Outside
	Layer (m)	2.077	
	Upper Temp (C)	447.6	
	Lower Temp (C)	122.3	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
29 min	24 sec		
	(1764 sec)	Room 1	Outside
	Layer (m)	2.086	
	Upper Temp (C)	434.4	
	Lower Temp (C)	118.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
30 min	00 sec		
	(1800 sec)	Room 1	Outside
	Layer (m)	2.093	
	Upper Temp (C)	422.1	
	Lower Temp (C)	115.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
30 min	36 sec		
	(1836 sec)	Room 1	Outside
	Layer (m)	2.101	
	Upper Temp (C)	410.9	
	Lower Temp (C)	111.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
31 min	12 sec		

	(1872 sec)	Room 1	Outside
	Layer (m)	2.107	
	Upper Temp (C)	400.6	
	Lower Temp (C)	108.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
31 min	48 sec		
	(1908 sec)	Room 1	Outside
	Layer (m)	2.113	
	Upper Temp (C)	391.0	
	Lower Temp (C)	105.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
32 min	24 sec		
	(1944 sec)	Room 1	Outside
	Layer (m)	2.119	
	Upper Temp (C)	382.1	
	Lower Temp (C)	103.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
33 min	00 sec		
	(1980 sec)	Room 1	Outside
	Layer (m)	2.124	
	Upper Temp (C)	373.6	
	Lower Temp (C)	100.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
33 min	36 sec		
	(2016 sec)	Room 1	Outside
	Layer (m)	2.129	
	Upper Temp (C)	365.8	
	Lower Temp (C)	100.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
34 min	12 sec		
	(2052 sec)	Room 1	Outside
	Layer (m)	2.134	
	Upper Temp (C)	358.4	
	Lower Temp (C)	99.3	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
34 min	48 sec		
	(2088 sec)	Room 1	Outside
	Layer (m)	2.138	
	Upper Temp (C)	351.4	
	Lower Temp (C)	97.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	

	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
35 min	24 sec		
	(2124 sec)	Room 1	Outside
	Layer (m)	2.142	
	Upper Temp (C)	344.8	
	Lower Temp (C)	95.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
36 min	00 sec		
	(2160 sec)	Room 1	Outside
	Layer (m)	2.146	
	Upper Temp (C)	338.5	
	Lower Temp (C)	93.9	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
36 min	36 sec		
	(2196 sec)	Room 1	Outside
	Layer (m)	2.150	
	Upper Temp (C)	332.5	
	Lower Temp (C)	92.2	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
37 min	12 sec		
	(2232 sec)	Room 1	Outside
	Layer (m)	2.153	
	Upper Temp (C)	326.7	
	Lower Temp (C)	90.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
37 min	48 sec		
	(2268 sec)	Room 1	Outside
	Layer (m)	2.157	
	Upper Temp (C)	321.2	
	Lower Temp (C)	89.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
38 min	24 sec		
	(2304 sec)	Room 1	Outside
	Layer (m)	2.160	
	Upper Temp (C)	315.9	
	Lower Temp (C)	87.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
39 min	00 sec		
	(2340 sec)	Room 1	Outside
	Layer (m)	2.163	

	Upper Temp (C)	310.8	
	Lower Temp (C)	86.2	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
39 min	36 sec		
	(2376 sec)	Room 1	Outside
	Layer (m)	2.166	
	Upper Temp (C)	305.9	
	Lower Temp (C)	84.9	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
40 min	12 sec		
	(2412 sec)	Room 1	Outside
	Layer (m)	2.169	
	Upper Temp (C)	301.1	
	Lower Temp (C)	83.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
40 min	48 sec		
	(2448 sec)	Room 1	Outside
	Layer (m)	2.172	
	Upper Temp (C)	296.6	
	Lower Temp (C)	82.4	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
41 min	24 sec		
	(2484 sec)	Room 1	Outside
	Layer (m)	2.174	
	Upper Temp (C)	292.2	
	Lower Temp (C)	81.3	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
42 min	00 sec		
	(2520 sec)	Room 1	Outside
	Layer (m)	2.177	
	Upper Temp (C)	287.9	
	Lower Temp (C)	80.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
42 min	36 sec		
	(2556 sec)	Room 1	Outside
	Layer (m)	2.180	
	Upper Temp (C)	283.8	
	Lower Temp (C)	79.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	

43 min	12 sec		
	(2592 sec)	Room 1	Outside
	Layer (m)	2.182	
	Upper Temp (C)	279.8	
	Lower Temp (C)	78.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
43 min	48 sec		
	(2628 sec)	Room 1	Outside
	Layer (m)	2.184	
	Upper Temp (C)	276.0	
	Lower Temp (C)	77.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
44 min	24 sec		
	(2664 sec)	Room 1	Outside
	Layer (m)	2.187	
	Upper Temp (C)	272.0	
	Lower Temp (C)	77.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
45 min	00 sec		
	(2700 sec)	Room 1	Outside
	Layer (m)	2.189	
	Upper Temp (C)	268.0	
	Lower Temp (C)	77.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
45 min	36 sec		
	(2736 sec)	Room 1	Outside
	Layer (m)	2.191	
	Upper Temp (C)	264.2	
	Lower Temp (C)	76.8	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
46 min	12 sec		
	(2772 sec)	Room 1	Outside
	Layer (m)	2.194	
	Upper Temp (C)	260.6	
	Lower Temp (C)	76.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
46 min	48 sec		
	(2808 sec)	Room 1	Outside
	Layer (m)	2.196	
	Upper Temp (C)	257.2	
	Lower Temp (C)	75.1	
	HRR (kW)	0.0	

	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
47 min	24 sec		
	(2844 sec)	Room 1	Outside
	Layer (m)	2.198	
	Upper Temp (C)	253.9	
	Lower Temp (C)	74.2	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
48 min	00 sec		
	(2880 sec)	Room 1	Outside
	Layer (m)	2.199	
	Upper Temp (C)	250.7	
	Lower Temp (C)	73.4	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
48 min	36 sec		
	(2916 sec)	Room 1	Outside
	Layer (m)	2.201	
	Upper Temp (C)	247.6	
	Lower Temp (C)	72.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
49 min	12 sec		
	(2952 sec)	Room 1	Outside
	Layer (m)	2.203	
	Upper Temp (C)	244.6	
	Lower Temp (C)	71.8	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
49 min	48 sec		
	(2988 sec)	Room 1	Outside
	Layer (m)	2.205	
	Upper Temp (C)	241.7	
	Lower Temp (C)	71.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
50 min	24 sec		
	(3024 sec)	Room 1	Outside
	Layer (m)	2.207	
	Upper Temp (C)	238.8	
	Lower Temp (C)	70.3	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
51 min	00 sec		
	(3060 sec)	Room 1	Outside

	Layer (m)	2.208		
	Upper Temp (C)	236.1		
	Lower Temp (C)	69.5		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
51 min	36 sec			
	(3096 sec)	Room 1	Outside	
	Layer (m)	2.210		
	Upper Temp (C)	233.3		
	Lower Temp (C)	68.8		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
52 min	12 sec			
	(3132 sec)	Room 1	Outside	
	Layer (m)	2.211		
	Upper Temp (C)	230.7		
	Lower Temp (C)	68.1		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
52 min	48 sec			
	(3168 sec)	Room 1	Outside	
	Layer (m)	2.213		
	Upper Temp (C)	228.1		
	Lower Temp (C)	67.5		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
53 min	24 sec			
	(3204 sec)	Room 1	Outside	
	Layer (m)	2.215		
	Upper Temp (C)	225.6		
	Lower Temp (C)	66.8		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
54 min	00 sec			
	(3240 sec)	Room 1	Outside	
	Layer (m)	2.216		
	Upper Temp (C)	223.1		
	Lower Temp (C)	66.2		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
54 min	36 sec			
	(3276 sec)	Room 1	Outside	
	Layer (m)	2.217		
	Upper Temp (C)	220.7		
	Lower Temp (C)	65.5		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		

55 min	12 sec		
	(3312 sec)	Room 1	Outside
	Layer (m)	2.219	
	Upper Temp (C)	218.4	
	Lower Temp (C)	64.9	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
55 min	48 sec		
	(3348 sec)	Room 1	Outside
	Layer (m)	2.220	
	Upper Temp (C)	216.1	
	Lower Temp (C)	64.4	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
56 min	24 sec		
	(3384 sec)	Room 1	Outside
	Layer (m)	2.222	
	Upper Temp (C)	213.8	
	Lower Temp (C)	63.8	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
57 min	00 sec		
	(3420 sec)	Room 1	Outside
	Layer (m)	2.223	
	Upper Temp (C)	211.6	
	Lower Temp (C)	63.2	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
57 min	36 sec		
	(3456 sec)	Room 1	Outside
	Layer (m)	2.224	
	Upper Temp (C)	209.5	
	Lower Temp (C)	62.7	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
58 min	12 sec		
	(3492 sec)	Room 1	Outside
	Layer (m)	2.225	
	Upper Temp (C)	207.4	
	Lower Temp (C)	62.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
58 min	48 sec		
	(3528 sec)	Room 1	Outside
	Layer (m)	2.227	
	Upper Temp (C)	205.3	
	Lower Temp (C)	61.6	

HRR (kW) 0.0
Visibility (m) at 2m 20+
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

59 min 24 sec
(3564 sec) Room 1 Outside

Layer (m) 2.228
Upper Temp (C) 203.3
Lower Temp (C) 61.1
HRR (kW) 0.0
Visibility (m) at 2m 20+
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

60 min 00 sec
(3600 sec) Room 1 Outside

Layer (m) 2.229
Upper Temp (C) 201.3
Lower Temp (C) 60.6
HRR (kW) 0.0
Visibility (m) at 2m 20+
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

=====
Event Log

=====
FED(thermal) Exceeded 0.3 at 118.0 Seconds.
FED(CO) Exceeded 0.3 at 215.0 Seconds.
321 sec. Ventilation Limit 1968 kW.
Fitted t2 alpha coefficient (kW/s2) = 0.023
243 sec. Flashover in Room 1.
93 sec. Visibility at 2m above floor reduced to 10 m in room 1
0 sec. Item 1 3 MW propane gas burner ignited.
Iteration 1

=====
Computer Run-Time = 2.8 seconds.
=====