

January 23, 2025 23:15:09

B-RISK Fire Simulator and Design Fire Tool (Ver 2024.3)

Input Filename : input1.xml

Base File : C:\Users\franc\CSTBGroup\These_Francois_Consigny - Documents\Calculs
Feu\Programmes\python\Brisk_pre_calculated\McGregor 1\basemodel_Iter0.xml

User Mode : Risk Simulator

Simulation Time = 7140.00 seconds.

Initial Time-Step = 1.00 seconds.

=====

Description of Rooms

=====

Room 1 : McGregor 1

Room Length (m) =	3.45
Room Width (m) =	4.45
Maximum Room Height (m) =	2.45
Minimum Room Height (m) =	2.45
Floor Elevation (m) =	0.000
Absolute X Position (m) =	0.000
Absolute Y Position (m) =	0.000
Room 1 has a flat ceiling.	
Shape Factor (A_f/H^2) =	2.6

Wall Surface is GYP1/2	
Wall Density (kg/m3) =	790.0
Wall Conductivity (W/m.K) =	0.160
Wall Specific Heat (J/kg.K) =	900
Wall Emissivity =	0.90
Wall Thickness (mm) =	25.4
SQROOT Thermal Inertia ($J.m-2.s-1/2.K-1$) =	337

Wall Substrate is CLT	
Wall Substrate Density (kg/m3) =	515.0
Wall Substrate Conductivity (W/m.K) =	0.130
Wall Substrate Specific Heat (J/kg.K) =	1600
Wall Substrate Thickness (mm) =	105.0

Ceiling Surface is GYP1/2	
Ceiling Density (kg/m3) =	790.0
Ceiling Conductivity (W/m.K) =	0.160
Ceiling Specific Heat (J/kg.K) =	900
Ceiling Emissivity =	0.90
Ceiling Thickness (mm) =	25.4
SQROOT Thermal Inertia ($J.m-2.s-1/2.K-1$) =	337

Ceiling Substrate is CLT	
Ceiling Substrate Density (kg/m3) =	515.0
Ceiling Substrate Conductivity (W/m.K) =	0.130
Ceiling Substrate Specific Heat (J/kg.K) =	1600
Ceiling Substrate Thickness (mm) =	105.0

Floor Surface is fibre cement sheet	
Floor Density (kg/m3) =	1490.0
Floor Conductivity (W/m.K) =	0.720
Floor Specific Heat (J/kg.K) =	840
Floor Emissivity =	0.88
Floor Thickness = (mm)	12.7
SQROOT Thermal Inertia ($J.m-2.s-1/2.K-1$) =	949

Floor Substrate is GYP1/2	
Floor Substrate Density (kg/m3) =	790.0
Floor Substrate Conductivity (W/m.K) =	0.160
Floor Substrate Specific Heat (J/kg.K) =	900
Floor Substrate Thickness (mm) =	15.9

=====

Wall Vents

```

=====
Vent 1 : McGregor 1_01
    From room 1 to 2
    Front face of room 1
    Offset (m) = 1.190
    Vent Width (m) = 1.069
    Vent Height (m) = 2.000
    Vent Sill Height (m) = 0.000
    Vent Soffit Height (m) = 2.000
    Opening Time (sec) = 0
    Closing Time (sec) = 0
    Discharge Coefficient (-) = 0.680

=====
Ceiling/Floor Vents
=====
Ambient Conditions
=====
Interior Temp (C) = 5.5
Exterior Temp (C) = 5.5
Relative Humidity (%) = 50

=====
Tenability Parameters
=====
Monitoring Height for Visibility and FED (m) = 2.00
Asphyxiant gas model = FED(CO) C/VM2
Visibility calculations assume: reflective signs
Egress path segments for FED calculations
1. Start Time (sec) 0
1. End Time (sec) 600
1. Room 1
2. Start Time (sec) 0
2. End Time (sec) 0
2. Room 0
3. Start Time (sec) 0
3. End Time (sec) 0
3. Room 0

=====
Sprinkler / Detector Parameters
=====
    Ceiling Jet model used is NIST JET.
    Sprinkler System Reliability 1.000
    Sprinkler Probability of Suppression 0.000
    Sprinkler Cooling Coefficient 1.000

=====
Smoke Detector Parameters
=====
    Smoke Detection System Reliability 1.000

=====
Mechanical Ventilation (to/from outside)
=====
Mechanical Ventilation not installed.
    Mech ventilation system reliability 1.000

=====
Description of the Fire
=====
CO Yield pre-flashover(g/g) = 0.040
Soot Alpha Coefficient = 2.50
Smoke Epsilon Coefficient = 1.20
Flame Emission Coefficient (1/m) = 13.32
Fuel - Carbon Moles 3.00
Fuel - Hydrogen Moles 8.00
Fuel - Oxygen Moles 0.00
Fuel - Nitrogen Moles 0.00
Stoichiometric air/fuel ratio 0.0

```

Burning objects are manually positioned in room.

Enhanced burning submodel is OFF

Burning Object No 1

3 MW propane gas burner

Located in Room	1
Energy Yield (kJ/g) =	43.7
CO2 Yield (kg/kg fuel) =	2.340
HCN Yield (kg/kg fuel) =	0.000
H2O Yield (kg/kg fuel) =	1.636
Soot Yield (kg/kg fuel) =	0.024
Heat Release Rate Per Unit Area (kW/m2) =	250.0
Radiant Loss Fraction =	0.30
Fire Elevation (m) =	0.000
Fire Object Length (m) =	1.700
Fire Object Width (m) =	1.300
Fire Object Height (m) =	0.000
Location, X-coordinate (m) =	2.150
Location, Y-coordinate (m) =	3.350
Fire Location (for entrainment)=	CORNER
Plume behaviour is	UNDISTURBED

Time (sec)	Heat Release (kW)
0	0
75	68
150	270
225	608
300	1080
375	1688
450	2430
525	3308
600	4320
675	0
750	0
825	0
900	0
975	0
1050	0
1125	0
1200	0
1275	68
1350	270
1425	608
1500	1080
1575	1688
1650	2430
1725	3308
1800	4247
1875	3000
1950	3000
2025	3000
2100	3000
2175	3000
2250	3000
2325	3000
2400	3000
2475	3000
2550	3000
2625	3000
2700	3000
2775	3000
2850	3000
2925	3000
3000	3000
3075	3000
3150	3000
3225	3000
3300	3000
3375	2750
3450	2500
3525	2250
3600	2000

3675	1750
3750	1500
3825	1250
3900	1000
3975	750
4050	500
4125	250
4200	0
4275	0
4350	0
4425	0
4500	0
4575	0
4650	0
4725	0
4800	0
4875	0
4950	0
5025	0
5100	0
5175	0
5250	0
5325	0
5400	0
5475	0
5550	0
5625	0
5700	0
5775	0
5850	0
5925	0
6000	0
6075	0
6150	0
6225	0
6300	0
6375	0
6450	0
6525	0
6600	0
6675	0
6750	0
6825	0
6900	0
6975	0
7050	0
7125	0
7200	0

=====

Postflashover Inputs

=====

Postflashover model is OFF.

=====

Results from Fire Simulation

=====

0 min	00 sec		
	(0 sec)	Room 1	Outside
	Layer (m)	2.446	
	Upper Temp (C)	5.5	
	Lower Temp (C)	5.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	0.000	
	FED thermal on egress path =	0.000	

1 min	11 sec		
	(71 sec)	Room 1	Outside

	Layer (m)	1.633		
	Upper Temp (C)	72.1		
	Lower Temp (C)	7.2		
	HRR (kW)	63.9		
	Visibility (m) at 2m	4.50		
	FED gases on egress path =	0.002		
	FED thermal on egress path =	0.012		
2 min	22 sec			
	(142 sec)	Room 1	Outside	
	Layer (m)	1.573		
	Upper Temp (C)	194.2		
	Lower Temp (C)	14.9		
	HRR (kW)	248.4		
	Visibility (m) at 2m	1.68		
	FED gases on egress path =	0.013		
	FED thermal on egress path =	0.498		
3 min	33 sec			
	(213 sec)	Room 1	Outside	
	Layer (m)	1.549		
	Upper Temp (C)	324.9		
	Lower Temp (C)	33.4		
	HRR (kW)	553.5		
	Visibility (m) at 2m	1.04		
	FED gases on egress path =	0.055		
	FED thermal on egress path =	1.000		
4 min	44 sec			
	(284 sec)	Room 1	Outside	
	Layer (m)	1.521		
	Upper Temp (C)	453.4		
	Lower Temp (C)	63.3		
	HRR (kW)	979.2		
	Visibility (m) at 2m	0.79		
	FED gases on egress path =	0.229		
	FED thermal on egress path =	1.000		
5 min	55 sec			
	(355 sec)	Room 1	Outside	
	Layer (m)	1.488		
	Upper Temp (C)	585.4		
	Lower Temp (C)	98.6		
	HRR (kW)	1525.5		
	Visibility (m) at 2m	0.62		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
7 min	06 sec			
	(426 sec)	Room 1	Outside	
	Layer (m)	1.459		
	Upper Temp (C)	714.9		
	Lower Temp (C)	150.9		
	HRR (kW)	2069.5		
	Visibility (m) at 2m	0.48		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
8 min	17 sec			
	(497 sec)	Room 1	Outside	
	Layer (m)	1.419		
	Upper Temp (C)	785.0		
	Lower Temp (C)	180.6		
	HRR (kW)	2186.9		
	Visibility (m) at 2m	0.36		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		

9 min	28 sec (568 sec)	Room 1	Outside
	Layer (m)	1.384	
	Upper Temp (C)	839.8	
	Lower Temp (C)	212.5	
	HRR (kW)	2293.1	
	Visibility (m) at 2m	0.27	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
10 min	39 sec (639 sec)	Room 1	Outside
	Layer (m)	1.472	
	Upper Temp (C)	853.7	
	Lower Temp (C)	233.7	
	HRR (kW)	2061.4	
	Visibility (m) at 2m	0.47	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
11 min	50 sec (710 sec)	Room 1	Outside
	Layer (m)	2.030	
	Upper Temp (C)	501.2	
	Lower Temp (C)	129.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
13 min	01 sec (781 sec)	Room 1	Outside
	Layer (m)	2.083	
	Upper Temp (C)	413.6	
	Lower Temp (C)	100.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
14 min	12 sec (852 sec)	Room 1	Outside
	Layer (m)	2.112	
	Upper Temp (C)	364.5	
	Lower Temp (C)	89.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
15 min	23 sec (923 sec)	Room 1	Outside
	Layer (m)	2.131	
	Upper Temp (C)	330.2	
	Lower Temp (C)	80.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
16 min	34 sec (994 sec)	Room 1	Outside
	Layer (m)	2.147	
	Upper Temp (C)	303.3	
	Lower Temp (C)	76.4	

	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
17 min	45 sec			
	(1065 sec)	Room 1	Outside	
	Layer (m)	2.158		
	Upper Temp (C)	283.0		
	Lower Temp (C)	71.3		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
18 min	56 sec			
	(1136 sec)	Room 1	Outside	
	Layer (m)	2.168		
	Upper Temp (C)	266.8		
	Lower Temp (C)	66.9		
	HRR (kW)	0.0		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
20 min	07 sec			
	(1207 sec)	Room 1	Outside	
	Layer (m)	2.095		
	Upper Temp (C)	227.4		
	Lower Temp (C)	63.4		
	HRR (kW)	6.3		
	Visibility (m) at 2m	20+		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
21 min	18 sec			
	(1278 sec)	Room 1	Outside	
	Layer (m)	1.766		
	Upper Temp (C)	232.9		
	Lower Temp (C)	56.9		
	HRR (kW)	75.6		
	Visibility (m) at 2m	3.95		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
22 min	29 sec			
	(1349 sec)	Room 1	Outside	
	Layer (m)	1.660		
	Upper Temp (C)	316.6		
	Lower Temp (C)	61.0		
	HRR (kW)	267.3		
	Visibility (m) at 2m	1.92		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
23 min	40 sec			
	(1420 sec)	Room 1	Outside	
	Layer (m)	1.592		
	Upper Temp (C)	420.7		
	Lower Temp (C)	77.0		
	HRR (kW)	585.0		
	Visibility (m) at 2m	1.18		
	FED gases on egress path =	1.000		
	FED thermal on egress path =	1.000		
24 min	51 sec			
	(1491 sec)	Room 1	Outside	

	Layer (m)	1.540	
	Upper Temp (C)	541.0	
	Lower Temp (C)	100.8	
	HRR (kW)	1023.3	
	Visibility (m) at 2m	0.87	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
26 min	02 sec		
	(1562 sec)	Room 1	Outside
	Layer (m)	1.500	
	Upper Temp (C)	673.1	
	Lower Temp (C)	143.7	
	HRR (kW)	1582.2	
	Visibility (m) at 2m	0.67	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
27 min	13 sec		
	(1633 sec)	Room 1	Outside
	Layer (m)	1.463	
	Upper Temp (C)	799.1	
	Lower Temp (C)	194.8	
	HRR (kW)	2098.8	
	Visibility (m) at 2m	0.51	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
28 min	24 sec		
	(1704 sec)	Room 1	Outside
	Layer (m)	1.425	
	Upper Temp (C)	863.9	
	Lower Temp (C)	239.2	
	HRR (kW)	2224.4	
	Visibility (m) at 2m	0.38	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
29 min	35 sec		
	(1775 sec)	Room 1	Outside
	Layer (m)	1.389	
	Upper Temp (C)	917.1	
	Lower Temp (C)	273.2	
	HRR (kW)	2316.4	
	Visibility (m) at 2m	0.29	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
30 min	46 sec		
	(1846 sec)	Room 1	Outside
	Layer (m)	1.403	
	Upper Temp (C)	947.4	
	Lower Temp (C)	277.1	
	HRR (kW)	2260.4	
	Visibility (m) at 2m	0.32	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
31 min	57 sec		
	(1917 sec)	Room 1	Outside
	Layer (m)	1.429	
	Upper Temp (C)	958.9	
	Lower Temp (C)	290.9	
	HRR (kW)	2218.1	
	Visibility (m) at 2m	0.41	
	FED gases on egress path =	1.000	

FED thermal on egress path = 1.000

33 min 08 sec
(1988 sec) Room 1 Outside

Layer (m) 1.430
Upper Temp (C) 977.3
Lower Temp (C) 306.1
HRR (kW) 2221.4
Visibility (m) at 2m 0.41
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

34 min 19 sec
(2059 sec) Room 1 Outside

Layer (m) 1.431
Upper Temp (C) 992.0
Lower Temp (C) 318.3
HRR (kW) 2223.1
Visibility (m) at 2m 0.42
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

35 min 30 sec
(2130 sec) Room 1 Outside

Layer (m) 1.431
Upper Temp (C) 1005.7
Lower Temp (C) 329.8
HRR (kW) 2224.7
Visibility (m) at 2m 0.42
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

36 min 41 sec
(2201 sec) Room 1 Outside

Layer (m) 1.432
Upper Temp (C) 1017.7
Lower Temp (C) 339.9
HRR (kW) 2226.1
Visibility (m) at 2m 0.43
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

37 min 52 sec
(2272 sec) Room 1 Outside

Layer (m) 1.432
Upper Temp (C) 1028.2
Lower Temp (C) 349.0
HRR (kW) 2227.2
Visibility (m) at 2m 0.43
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

39 min 03 sec
(2343 sec) Room 1 Outside

Layer (m) 1.433
Upper Temp (C) 1037.5
Lower Temp (C) 357.1
HRR (kW) 2228.1
Visibility (m) at 2m 0.43
FED gases on egress path = 1.000
FED thermal on egress path = 1.000

40 min 14 sec
(2414 sec) Room 1 Outside

Layer (m) 1.433
Upper Temp (C) 1045.8

	Lower Temp (C)	364.4	
	HRR (kW)	2228.9	
	Visibility (m) at 2m	0.44	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
41 min	25 sec		
	(2485 sec)	Room 1	Outside
	Layer (m)	1.433	
	Upper Temp (C)	1053.2	
	Lower Temp (C)	371.0	
	HRR (kW)	2229.6	
	Visibility (m) at 2m	0.44	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
42 min	36 sec		
	(2556 sec)	Room 1	Outside
	Layer (m)	1.432	
	Upper Temp (C)	1061.4	
	Lower Temp (C)	373.7	
	HRR (kW)	2225.0	
	Visibility (m) at 2m	0.44	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
43 min	47 sec		
	(2627 sec)	Room 1	Outside
	Layer (m)	1.433	
	Upper Temp (C)	1066.2	
	Lower Temp (C)	375.9	
	HRR (kW)	2227.6	
	Visibility (m) at 2m	0.44	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
44 min	58 sec		
	(2698 sec)	Room 1	Outside
	Layer (m)	1.432	
	Upper Temp (C)	1072.0	
	Lower Temp (C)	375.3	
	HRR (kW)	2225.5	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
46 min	09 sec		
	(2769 sec)	Room 1	Outside
	Layer (m)	1.432	
	Upper Temp (C)	1074.1	
	Lower Temp (C)	375.8	
	HRR (kW)	2225.7	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
47 min	20 sec		
	(2840 sec)	Room 1	Outside
	Layer (m)	1.432	
	Upper Temp (C)	1076.0	
	Lower Temp (C)	376.7	
	HRR (kW)	2225.9	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
48 min	31 sec		

	(2911 sec)	Room 1	Outside
	Layer (m)	1.430	
	Upper Temp (C)	1086.3	
	Lower Temp (C)	378.4	
	HRR (kW)	2221.8	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
49 min	42 sec		
	(2982 sec)	Room 1	Outside
	Layer (m)	1.431	
	Upper Temp (C)	1088.6	
	Lower Temp (C)	378.3	
	HRR (kW)	2222.5	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
50 min	53 sec		
	(3053 sec)	Room 1	Outside
	Layer (m)	1.430	
	Upper Temp (C)	1090.6	
	Lower Temp (C)	378.1	
	HRR (kW)	2221.9	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
52 min	04 sec		
	(3124 sec)	Room 1	Outside
	Layer (m)	1.429	
	Upper Temp (C)	1096.1	
	Lower Temp (C)	377.5	
	HRR (kW)	2219.4	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
53 min	15 sec		
	(3195 sec)	Room 1	Outside
	Layer (m)	1.429	
	Upper Temp (C)	1099.8	
	Lower Temp (C)	376.9	
	HRR (kW)	2217.3	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
54 min	26 sec		
	(3266 sec)	Room 1	Outside
	Layer (m)	1.429	
	Upper Temp (C)	1102.7	
	Lower Temp (C)	377.8	
	HRR (kW)	2217.3	
	Visibility (m) at 2m	0.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
55 min	37 sec		
	(3337 sec)	Room 1	Outside
	Layer (m)	1.435	
	Upper Temp (C)	1105.0	
	Lower Temp (C)	378.6	
	HRR (kW)	2201.9	
	Visibility (m) at 2m	0.47	

	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
56 min	48 sec		
	(3408 sec)	Room 1	Outside
	Layer (m)	1.447	
	Upper Temp (C)	1104.9	
	Lower Temp (C)	378.3	
	HRR (kW)	2171.4	
	Visibility (m) at 2m	0.53	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
57 min	59 sec		
	(3479 sec)	Room 1	Outside
	Layer (m)	1.461	
	Upper Temp (C)	1103.7	
	Lower Temp (C)	377.1	
	HRR (kW)	2137.6	
	Visibility (m) at 2m	0.59	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
59 min	10 sec		
	(3550 sec)	Room 1	Outside
	Layer (m)	1.477	
	Upper Temp (C)	1101.1	
	Lower Temp (C)	378.7	
	HRR (kW)	2101.8	
	Visibility (m) at 2m	0.66	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
60 min	21 sec		
	(3621 sec)	Room 1	Outside
	Layer (m)	1.493	
	Upper Temp (C)	1084.1	
	Lower Temp (C)	377.1	
	HRR (kW)	1930.0	
	Visibility (m) at 2m	0.75	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
61 min	32 sec		
	(3692 sec)	Room 1	Outside
	Layer (m)	1.513	
	Upper Temp (C)	1044.0	
	Lower Temp (C)	371.2	
	HRR (kW)	1693.3	
	Visibility (m) at 2m	0.85	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
62 min	43 sec		
	(3763 sec)	Room 1	Outside
	Layer (m)	1.531	
	Upper Temp (C)	998.6	
	Lower Temp (C)	338.6	
	HRR (kW)	1456.7	
	Visibility (m) at 2m	0.95	
	FED gases on egress path = 1.000		
	FED thermal on egress path = 1.000		
63 min	54 sec		
	(3834 sec)	Room 1	Outside
	Layer (m)	1.550	

	Upper Temp (C)	949.6	
	Lower Temp (C)	306.0	
	HRR (kW)	1220.0	
	Visibility (m) at 2m	1.08	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
65 min	05 sec		
	(3905 sec)	Room 1	Outside
	Layer (m)	1.575	
	Upper Temp (C)	892.7	
	Lower Temp (C)	277.6	
	HRR (kW)	983.3	
	Visibility (m) at 2m	1.23	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
66 min	16 sec		
	(3976 sec)	Room 1	Outside
	Layer (m)	1.605	
	Upper Temp (C)	831.7	
	Lower Temp (C)	259.9	
	HRR (kW)	746.7	
	Visibility (m) at 2m	1.45	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
67 min	27 sec		
	(4047 sec)	Room 1	Outside
	Layer (m)	1.641	
	Upper Temp (C)	766.0	
	Lower Temp (C)	226.9	
	HRR (kW)	510.0	
	Visibility (m) at 2m	1.80	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
68 min	38 sec		
	(4118 sec)	Room 1	Outside
	Layer (m)	1.694	
	Upper Temp (C)	689.7	
	Lower Temp (C)	195.2	
	HRR (kW)	273.3	
	Visibility (m) at 2m	2.54	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
69 min	49 sec		
	(4189 sec)	Room 1	Outside
	Layer (m)	1.817	
	Upper Temp (C)	605.3	
	Lower Temp (C)	176.9	
	HRR (kW)	36.7	
	Visibility (m) at 2m	6.21	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
71 min	00 sec		
	(4260 sec)	Room 1	Outside
	Layer (m)	2.007	
	Upper Temp (C)	630.8	
	Lower Temp (C)	176.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	

72 min	11 sec		
	(4331 sec)	Room 1	Outside
	Layer (m)	2.019	
	Upper Temp (C)	607.8	
	Lower Temp (C)	166.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
73 min	22 sec		
	(4402 sec)	Room 1	Outside
	Layer (m)	2.031	
	Upper Temp (C)	586.8	
	Lower Temp (C)	158.2	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
74 min	33 sec		
	(4473 sec)	Room 1	Outside
	Layer (m)	2.041	
	Upper Temp (C)	567.9	
	Lower Temp (C)	150.9	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
75 min	44 sec		
	(4544 sec)	Room 1	Outside
	Layer (m)	2.050	
	Upper Temp (C)	550.9	
	Lower Temp (C)	144.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
76 min	55 sec		
	(4615 sec)	Room 1	Outside
	Layer (m)	2.058	
	Upper Temp (C)	535.4	
	Lower Temp (C)	139.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
78 min	06 sec		
	(4686 sec)	Room 1	Outside
	Layer (m)	2.066	
	Upper Temp (C)	521.1	
	Lower Temp (C)	133.9	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
79 min	17 sec		
	(4757 sec)	Room 1	Outside
	Layer (m)	2.073	
	Upper Temp (C)	507.9	
	Lower Temp (C)	129.4	
	HRR (kW)	0.0	

	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
80 min	28 sec		
	(4828 sec)	Room 1	Outside
	Layer (m)	2.080	
	Upper Temp (C)	495.5	
	Lower Temp (C)	125.3	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
81 min	39 sec		
	(4899 sec)	Room 1	Outside
	Layer (m)	2.086	
	Upper Temp (C)	484.0	
	Lower Temp (C)	121.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
82 min	50 sec		
	(4970 sec)	Room 1	Outside
	Layer (m)	2.092	
	Upper Temp (C)	473.0	
	Lower Temp (C)	117.9	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
84 min	01 sec		
	(5041 sec)	Room 1	Outside
	Layer (m)	2.097	
	Upper Temp (C)	462.7	
	Lower Temp (C)	114.7	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
85 min	12 sec		
	(5112 sec)	Room 1	Outside
	Layer (m)	2.102	
	Upper Temp (C)	452.9	
	Lower Temp (C)	111.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
86 min	23 sec		
	(5183 sec)	Room 1	Outside
	Layer (m)	2.107	
	Upper Temp (C)	443.6	
	Lower Temp (C)	108.8	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
87 min	34 sec		
	(5254 sec)	Room 1	Outside

	Layer (m)	2.111	
	Upper Temp (C)	434.7	
	Lower Temp (C)	106.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
88 min	45 sec		
	(5325 sec)	Room 1	Outside
	Layer (m)	2.116	
	Upper Temp (C)	426.2	
	Lower Temp (C)	103.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
89 min	56 sec		
	(5396 sec)	Room 1	Outside
	Layer (m)	2.120	
	Upper Temp (C)	417.6	
	Lower Temp (C)	101.7	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
91 min	07 sec		
	(5467 sec)	Room 1	Outside
	Layer (m)	2.124	
	Upper Temp (C)	409.7	
	Lower Temp (C)	100.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
92 min	18 sec		
	(5538 sec)	Room 1	Outside
	Layer (m)	2.128	
	Upper Temp (C)	402.3	
	Lower Temp (C)	99.9	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
93 min	29 sec		
	(5609 sec)	Room 1	Outside
	Layer (m)	2.132	
	Upper Temp (C)	395.2	
	Lower Temp (C)	98.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
94 min	40 sec		
	(5680 sec)	Room 1	Outside
	Layer (m)	2.135	
	Upper Temp (C)	388.3	
	Lower Temp (C)	96.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	

95 min	51 sec		
	(5751 sec)	Room 1	Outside
	Layer (m)	2.138	
	Upper Temp (C)	381.6	
	Lower Temp (C)	94.7	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
97 min	02 sec		
	(5822 sec)	Room 1	Outside
	Layer (m)	2.142	
	Upper Temp (C)	375.1	
	Lower Temp (C)	92.8	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
98 min	13 sec		
	(5893 sec)	Room 1	Outside
	Layer (m)	2.145	
	Upper Temp (C)	368.8	
	Lower Temp (C)	91.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
99 min	24 sec		
	(5964 sec)	Room 1	Outside
	Layer (m)	2.148	
	Upper Temp (C)	362.7	
	Lower Temp (C)	89.3	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
100 min	35 sec		
	(6035 sec)	Room 1	Outside
	Layer (m)	2.151	
	Upper Temp (C)	356.7	
	Lower Temp (C)	87.7	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
101 min	46 sec		
	(6106 sec)	Room 1	Outside
	Layer (m)	2.154	
	Upper Temp (C)	351.0	
	Lower Temp (C)	86.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
102 min	57 sec		
	(6177 sec)	Room 1	Outside
	Layer (m)	2.157	
	Upper Temp (C)	345.4	
	Lower Temp (C)	84.6	

	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
104 min	08 sec		
	(6248 sec)	Room 1	Outside
	Layer (m)	2.159	
	Upper Temp (C)	339.9	
	Lower Temp (C)	83.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
105 min	19 sec		
	(6319 sec)	Room 1	Outside
	Layer (m)	2.162	
	Upper Temp (C)	334.6	
	Lower Temp (C)	81.7	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
106 min	30 sec		
	(6390 sec)	Room 1	Outside
	Layer (m)	2.164	
	Upper Temp (C)	329.5	
	Lower Temp (C)	80.3	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
107 min	41 sec		
	(6461 sec)	Room 1	Outside
	Layer (m)	2.167	
	Upper Temp (C)	324.5	
	Lower Temp (C)	79.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
108 min	52 sec		
	(6532 sec)	Room 1	Outside
	Layer (m)	2.169	
	Upper Temp (C)	319.6	
	Lower Temp (C)	77.7	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
110 min	03 sec		
	(6603 sec)	Room 1	Outside
	Layer (m)	2.172	
	Upper Temp (C)	314.6	
	Lower Temp (C)	77.1	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
111 min	14 sec		
	(6674 sec)	Room 1	Outside

	Layer (m)	2.174	
	Upper Temp (C)	309.5	
	Lower Temp (C)	77.0	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
112 min	25 sec		
	(6745 sec)	Room 1	Outside
	Layer (m)	2.177	
	Upper Temp (C)	304.3	
	Lower Temp (C)	76.9	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
113 min	36 sec		
	(6816 sec)	Room 1	Outside
	Layer (m)	2.179	
	Upper Temp (C)	299.7	
	Lower Temp (C)	75.8	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
114 min	47 sec		
	(6887 sec)	Room 1	Outside
	Layer (m)	2.181	
	Upper Temp (C)	295.3	
	Lower Temp (C)	74.6	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
115 min	58 sec		
	(6958 sec)	Room 1	Outside
	Layer (m)	2.184	
	Upper Temp (C)	291.0	
	Lower Temp (C)	73.5	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
117 min	09 sec		
	(7029 sec)	Room 1	Outside
	Layer (m)	2.186	
	Upper Temp (C)	286.8	
	Lower Temp (C)	72.4	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	
	FED thermal on egress path =	1.000	
118 min	20 sec		
	(7100 sec)	Room 1	Outside
	Layer (m)	2.188	
	Upper Temp (C)	282.7	
	Lower Temp (C)	71.3	
	HRR (kW)	0.0	
	Visibility (m) at 2m	20+	
	FED gases on egress path =	1.000	

FED thermal on egress path = 1.000

```
=====
Event Log
=====
FED(thermal) Exceeded 0.3 at 131.0 Seconds.
FED(CO) Exceeded 0.3 at 296.0 Seconds.
409 sec. Ventilation Limit 2024 kW.
Fitted t2 alpha coefficient (kW/s2) = 0.012
311 sec. Flashover in Room 1.
32 sec. Visibility at 2m above floor reduced to 10 m in room 1
0 sec. Item 1 3 MW propane gas burner ignited.
Iteration 1
```

```
=====
Computer Run-Time = 5.8 seconds.
=====
```