

DRAINAGE DETAILS

150mm CONCRETE SURROUND REQUIRED WHERE COVER TO PIPE SOFFIT IS BELOW 1200mm

ALL EXISTING SEWERS ON-SITE TO BE CONFIRMED.

TRENCHES UNDER HIGHWAYS BACKFILLED WITH DOT TYPE 1.

SECTION 38 AGREEMENT. SECTION 106.