

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

SECTION C-1: INTRODUCTION

1.0 Introduction

The Defense Logistics Agency (DLA) (i.e. the Government) is the largest logistics support agency in the United States (U.S.) Department of Defense (DoD). The DLA Director reports to the Under Secretary of Defense for Acquisition, Technology and Logistics (USD AT&L) through the Assistant Secretary of Defense for Logistics and Materiel Readiness (ASD L&MR). DLA provides worldwide logistics support, acquisition, and technical services to the military services, other federal and civilian agencies, and partner nations in peacetime and wartime. DLA Energy is the executive agent for the management of the DoD wholesale and retail fuels operations including accounting operations within the Defense Working Capital Fund (DWCF). DLA Information Operations (J62BG), Operational Energy Applications (OEA), is a key entity responsible for providing Information Technology (IT) and Operational Technology (OT) support to DLA Energy in its performance of worldwide supply chain management at numerous DoD fuel facilities including (but not limited to) defense fuel supply points (DFSPs).

As part of its mission, DLA OEA manages, installs, and maintains automated fuel systems (AFS) and equipment at DFSPs. DLA activities include standardizing, maintaining, or upgrading AFS, hydrant fueling automation maintenance (HFAM), automatic tank gauge (ATG), automated fuel handling equipment (AFHE), and other fuel related IT or OT solutions at DFSPs to improve fuel inventory accountability, monitoring, and control as well as preventing fuel spills and environmental hazards. Standardized, modernized, and sustainable IT/OT solutions at DFSPs enable DLA to provide real-time data acquisition and automated inventory management for capitalized fuel products. These IT/OT solutions are typically comprised of web-enabled application software and internet of things (IOT) technology stacks that are fully integrated with liquified petroleum fuel storage tanks and Industrial Control Systems (ICS) at the DFSPs. The purpose of these solutions is to provide worldwide access to mission essential commodities such as petroleum and fuel for the U.S. Armed Forces and North American Treaty Organization (NATO) Allies. Each ICS is unique to its deployed location and can consist of Supervisory Control and Data Acquisition (SCADA) computers, Programmable Logic Controllers (PLCs), Remote Terminal Units (RTUs), networked data communications, and graphical user interfaces (GUIs), systems/sub-systems, control modules, and sensors/probes. These ICS are typically fully integrated with liquid petroleum fuel facilities and provide the capabilities of active/passive monitoring and remote access.

The DLA OEA Hydrant Fueling Automation Maintenance (HFAM) program is component of

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

the agency's mission that provides comprehensive maintenance to sustain, support, modify, and repair the hydrant fueling systems at various DFSPs which use PLC automation and other control interfaces. The PLC automation reads inputs from the field devices, writes outputs for automated control of the hydrant systems, and is a mission critical component of the AFS that must be maintained.

1.1 Purpose / Objectives

The purpose of this Indefinite Delivery Indefinite Quantity (IDIQ) contract and accompanying Task Orders (TOs) is to achieve the following objectives:

- a. Acquire support services to successfully administer the HFAM program**
- b. Acquire a combination of supplies and services to successfully conduct sustainment, support, maintenance, modification, and repair of the HFAM solutions deployed worldwide.**

This contracting effort is part of a continuously improving Government approach to providing effective Operations and Support (O&S) of the various DLA OEA programs. The Government recognizes successful contract performance will be performed by an entity that takes responsibility for work performance of the tasks and subtasks identified in this PWS, executes continuous process improvement to increase efficiencies and reduce costs, and establishes a professional rapport with DLA Energy, the DLA program office, and various DoD fuel facility/DFSP representatives.

1.2 Current Incumbent Information

- Contractor: Kellog Brown & Root (KRC) Services, INC (3GJU9)
- Address: 601 Jefferson St., Houston TX 77002
- Contract #: SP4702-21-D-0002

SECTION C-2: SCOPE

2.0 Scope

To ensure the Government's objectives are met, the contractor will need to provide all necessary supplies and services for administering the HFAM program and supporting, maintaining, modifying, and repairing the HFAM solutions deployed worldwide. Supplies

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

or services that are unrelated to the HFAM program or its solutions as described in this PWS are NOT included within the scope of this contract.

The contractor's administration of the HFAM program will be comprised of all the necessary support services required to organize, orchestrate, monitor, report, travel, and sustain the program by successfully executing the tasks / subtasks described in this PWS.

The contractor's support, maintenance, modification, and repairing of the HFAM solutions deployed worldwide (i.e. regardless of geographical location) will include the overall technology stack consisting holistically of all current:

- | | |
|---|---|
| • Capabilities and applications | • SCADA computers |
| • Network Environments (NE) /
Computing Environments (CE) (i.e.
Development, Test, Stage, Production,
Fail/Cut Over, Recovery, etc.) | • PLCs |
| • IT/OT components | • RTUs |
| • Software, hardware, and firmware | • GUIs |
| • Coding, configuration, and scripts | • Interfaces and integrations |
| • Systems and sub-systems | • Networked data communications |
| • Batch programs | • Reports and reporting documentation |
| • Data and databases | • Technical artifacts/schematics |
| • Servers and machines | • Equipment, automation, and modules |
| | • Edge devices (sensors, actuators, etc.) |
| | • Cybersecurity controls |

As such, references to "HFAM" within this PWS are to be understood by the contractor as the HFAM program and the deployed HFAM solutions in their entirety unless otherwise explicitly stated.

The contractor must utilize the best available commercial practices (such as Information Technology Infrastructure Library (ITIL), Project Management Institute (PMI), etc.) to influence service delivery supporting HFAM and conform to all Government requirements described in this PWS. The contractor will be responsible for coordinating, managing, assigning resources, processes, and activities to successfully render all deliverables and services described within the PWS. As such, the contractor must provide all labor, management, supervision, Quality Control (QC)/Quality Assurance (QA), transportation, supplies, vehicles, tools, materials, facilities, equipment, and incidentals necessary to perform the work described in this PWS. Successful execution of this contract will necessitate the contractor to work as part of an integrated team with Government personnel and other third-party contractors throughout the period of

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

performance.

The contractor will be expected to provide a wide variety of supplies and services for successful contract performance. These supplies and services will require the contractor to possess expertise in sustaining, supporting, maintaining, modifying, and repairing petroleum facilities and petroleum systems to comply with applicable codes, criteria, and federal, state, local and/or host nation regulations. Contractor services will also include operational, technical, maintenance, network, infrastructure, help/service desk, end user, administrative, field/site, cybersecurity, IT, OT, hardware, and software assistance. The contractor will be expected to sustain interfaces between HFAM solutions and current DLA applications including (but not limited to) ATGs. The supplies and services rendered by the contractor will need to account for the significant geographical disbursement (i.e. within the continental United States (CONUS) and outside the continental United States (OCONUS)) of the DFSPs due to different military installations/areas of responsibility to perform the work described in this PWS.

2.1 HFAM Sites

The HFAM program is currently spread across 103 sites geographically disbursed between CONUS and OCONUS. A list of HFAM sites where solutions are deployed is identified in Attachment 1 List of HFAM Sites and Systems. The contractor will be expected to render all supplies and services to administer the HFAM program and perform support, maintenance, modification, and repair of the HFAM solutions based upon the sites listed in Attachment 1 - List of HFAM Sites and Systems.

The Government reserves the right to add, remove, update, or realign the HFAM sites identified in Attachment 1 - List of HFAM Sites and Systems as in scope modifications to the contract. If required, these additions, removals, updates, or realignments will be considered in scope and will be performed as a contract modification to be negotiated between the Government and contractor at the time of occurrence. During the life of the contract, the contractor should expect at least eight (8) HFAM sites added and two (2) HFAM sites decommissioned.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

2.2 Work Breakdown Structure (WBS)

Execution of this contract and breakdown of the HFAM program is comprised of nine (9) distinct parts as depicted in the below graphic and WBS. Detailed information on each of these parts of the HFAM program are described within this PWS. To achieve the Government’s desired objective for the scoped work effort, the supplies and services provided by the contractor must (at a minimum) be rendered to complete the following:




Figure 1 – Work Breakdown Structure

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Work Breakdown Structure (WBS)	
PWS #	Description
3.0	<u>HFAM Support Requirements</u>
3.1	Task 1: <u>Transition In</u>
3.2	Task 2: <u>Administrative Support & Program Management</u>
3.2.1	Subtask 2.1: <u>Program Management Plan & Quality Control Plan (QCP)</u>
3.2.2	Subtask 2.2: <u>Post Award Conference</u>
3.2.3	Subtask 2.3: <u>Weekly Updates & Weekly Activity Report (WAR)</u>
3.2.4	Subtask 2.4: <u>Monthly Status Report (MSR)</u>
3.2.5	Subtask 2.5: <u>In Progress Review (IPR)</u>
3.2.6	Subtask 2.6: <u>DoDM 8570.01/DoDD 8140.01 Report</u>
3.2.7	Subtask 2.7: <u>Contractor Personnel Roster, Common Access Card (CAC), & Alternate Token Report)</u>
3.2.8	Subtask 2.8: <u>Quarterly Inventory Report (QIR)</u>
3.2.9	Subtask 2.9: <u>Commercial Documents</u>
3.3	Task 3: <u>Preventive Maintenance (PM)</u>
3.3.1	Subtask 3.1: <u>PM Planning & Coordination</u>
3.3.2	Subtask 3.2: <u>PM Travel</u>
3.3.3	Subtask 3.3: <u>PM Services</u>
3.3.4	Subtask 3.4: <u>PM Documentation</u>
3.4	Task 4: <u>Technical Support</u>
3.4.1	Subtask 4.1: <u>Technical Support Team Resources & Availability</u>
3.4.2	Subtask 4.2: <u>Technical Support Team Communications</u>
3.4.3	Subtask 4.3: <u>Technical Support Team Services</u>
3.4.4	Subtask 4.4: <u>Technical Support Team CM/Repair Service Planning and Coordination</u>
3.5	Task 5: <u>Corrective Maintenance (CM)/Repair</u>
3.5.1	Subtask 5.1: <u>CM/Repair SNOW Case Prioritization</u>
3.5.2	Subtask 5.2: <u>CM/Repair Travel</u>
3.5.3	Subtask 5.3: <u>CM/Repair Services</u>
3.5.4	Subtask 5.4: <u>CM/Repair Documentation</u>
3.6	Task 6: <u>Site Support</u>
3.7	Task 7: <u>Cybersecurity Support</u>
3.8	Task 8: <u>Commercial Software Licensing</u>
3.9	Task 9: <u>Transition Out</u>

Table 1 – Work Breakdown Structure

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

SECTION C-3: HFAM SUPPORT REQUIREMENTS

3 HFAM Support Requirements

The contractor must provide adequate resources (i.e. competent, capable, professional, and qualified personnel with the necessary supplies) to manage, deliver, and ensure timely completion for:

3.1 Task 1: Transition In

If the awardee is NOT the incumbent identified in this PWS, the Government may require transition-in services for the contractor. All transition-in services rendered to complete this task will be performed on a Firm-Fixed-Price (FFP) basis. Contractor rendered services for this task will be documented within the Monthly Status Report (MSR) deliverable as described within this PWS. The Government Contracting Officer's Representative (COR) will perform evaluation and formal inspection and acceptance of the contractor's services in accordance with (IAW) the Quality Assurance Surveillance Plan (QASP).

To reduce the risks associated with contract performance, including decrements to productivity and/or possible negative impacts on additional services, the contractor will provide the necessary services to support a 90-calendar day transitional period.

During the transition-in period, the contractor will be expected to participate in knowledge (tacit and explicit) transfer and accept the responsibilities of contract performance working alongside existing third-party contractors. Throughout the transition-in period, existing third-party contractors will assist in transferring the duties of key personnel, services, and ServiceNow (SNOW) cases to the contractor. As the transition-in period progresses, work will continue to be performed by current third-party contractors IAW the terms and conditions of separate Government contractual obligations until confirmation is obtained by the Government that all key personnel responsibilities, services, and SNOW cases have been successfully transferred. As part of the transition-in services, the contractor's personnel will be expected to work on site with third-party contractors to gain familiarity with tools, processes, and organizational assets. The contractor will promptly notify the COR in writing of any problems/issues preventing their ability to accept responsibilities for key personnel, services, and SNOW cases as the transition-in progresses. To ensure uninterrupted operations and successful performance of this contract, the contractor's key personnel be fully engaged in and ensure the successful transfer of services from third-party contractors.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

The target date for the contractor's acceptance of the responsibilities for key personnel, services, and SNOW cases as described in this PWS is no later than (NLT) 30 calendar days prior to the end of the transition period. This will allow the Government adequate time to address any transition problems/issues between the contractor and any third-party contractors before the end of the transition period. No later than fifteen (15) calendar days before the end of the transition period, the COR will meet with the contractor to ensure all concerns and issues have been addressed. At the contractor's meeting with the COR, the contractor will submit a Transition-In Report to support Government oversight. The Transition-In Report will be utilized by the Government to confirm the contractor has formally transferred the responsibilities for key personnel, services, and SNOW cases to third party contractors. The contractor will be expected to have fully accepted responsibility for key personnel roles and successful performance of all work described throughout this PWS at the end of the 90-calendar day transition-out period.

3.1.1 Deliverable: Transition-In Report [CDRL A001]

- a. **Schedule:** No later than (NLT) fifteen (15) days before the end of the transition period.
- b. **Content:** At a minimum, the data product will include:
 - 1. Parts Statuses for HFAM solution sustainment based upon region (i.e. CONUS, Pacific, Europe, etc.).
 - 2. Open/Active Preventative Maintenance (PM), Corrective Maintenance (CM), and site support SNOW cases including the following information (for each case):
 - i. SNOW case #.
 - ii. Summary Description of work.
 - iii. SNOW case priority.
 - iv. Assigned technician / contractor personnel.
 - v. Status on work progress.
 - vi. Region of PM work (i.e. CONUS, Pacific, Europe, etc.).
 - vii. Site/Location of work.
 - viii. Latest version(s) of Plan of Actions & Milestones (POAMs) for work completion.
 - ix. Any POAM extensions/deferments requested with basis of logic/reasoning for Government review and approval.
 - 3. Confirmation all existing services to perform PM, CM, and site support activities have been transitioned from the previous contractor and identification of any

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

outstanding questions or concerns that are risks to successful performance.

- c. **Format: Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF**

3.2 Task 2: Administrative Support and Program Management

All Administrative Support and Program Management services rendered to complete this task (including subtasks) will be performed on a FFP basis. Contractor services rendered for this task (including all subtasks) will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

To meet the Government's objective of sustaining, maintaining, and administering the HFAM solution the contractor will be required to provide a wide variety of administrative support and program management services. These services will need to ensure all work performance is coordinated successfully, supplies and services rendered are delivered at an acceptable level of quality and grade IAW the contractor's Quality Control Plan (QCP), and records are well kept/maintained. The contractor will be responsible for the planning, orchestrating, executing, and monitoring the movement/travel of resources (supplies and personnel) to the various geographical disbursed locations (CONUS and OCONUS) where the HFAM solutions exist to perform the services described in this PWS. The contractor's administrative support and program management services will be expected to include all necessary activities to support Government oversight, evaluation, inspection, and acceptance of supplies and services rendered. This includes (but is not limited to) all necessary services required to ensure contractor conformance with all of the requirements described in this PWS.

To successfully render these services, the contractor will be required to assign a single point of contact (POC), also known as the Maintenance Program Manager (MPM), who will serve as the primary resource for coordination with the Government. The MPM will work closely with the Government Contracting Officer (KO), COR and (if designated) Technical Point of Contact (TPOC) to ensure all supplies and services are rendered at an acceptable level of quality and grade. The MPM will be key personnel on this contract as described in this PWS. The contractor's MPM will have the requisite authority for full control over company resources necessary for contract performance. As part of the contractor's administrative support and program management services, the contractor will perform the following:

3.2.1 Subtask 2.1: Program Management Plan (PMP) and Quality Control Plan (QCP)

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

The contractor must provide complete and appropriate plans that establish a creditable management approach and understanding of the methods necessary to successfully complete the tasks, subtasks, etc. identified within this PWS. As such, the Contractor must submit a Project Management Plan (PMP) and Quality Control Plan (QCP) demonstrating a comprehensive understanding of the PWS requirements and a robust management approach for successful work completion. While the QCP can be a subset artifact within the PMP, the combined documents must detail the Offeror's administrative oversight, including resources, processes, and controls to ensure adherence to the Government's Quality Assurance Surveillance Plan (QASP). Controls identified within the combined PMP and QCP must include the Offeror's quality control (QC) / quality assurance (QA) actions. These documents must also identify key personnel and demonstrate sufficient administrative risk mitigation strategies to render the supplies and services to successfully administer the HFAM program.

Initial versions of the PMP and QCP will be submitted to the Government at the time of proposal to support technical evaluation and determination of acceptability of the contractor's management approach. At the time of the award, the initial versions of the PMP and QCP will be considered accepted by the Government. The final versions of the contractor's PMP and QCP will be submitted to the Government within ten (10) business days after completion of the post award conference for inspection and acceptance. After the PMP and QCP are finalized, the contractor will be required to maintain these documents and ensure services rendered are compliant with them throughout the duration of the contract. These documents will be updated by the contractor as necessary, but any proposed changes to these documents must be approved in writing by the Government post-award. **The contractor must ensure the PMP and QCP do not contain Controlled Unclassified Information (CUI) including (but not limited to) Personally Identifiable Information (PII).**

3.2.1.1 Deliverable: Program Management Plan (PMP) and Quality Control Plan (QCP) – [CDRL A002]

- a. **Schedule**: Initial version submitted at time of contractor proposal to support evaluations for acceptability. Final versions submitted to the Government within ten (10) business days after completion of the post award conference.
- b. **Content**: The contractor's PMP and QCP in combination must clearly contain (at a minimum):
 1. **Organization**: A logical method for organizing all content such as a table of contents,

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

page numbers, etc.

2. Work Plan: A narrative description with sufficient details to provide a complete understanding of the contractor's management approach for rendering the necessary supplies and services to meet the Government's desired outcomes. The work plan must account for all requirements, tasks, subtasks, etc. contained within the PWS. Additionally, the work plan must (at a minimum) also identify:
 - i. All labor categories/labor types (i.e. both essential/key personnel and non-essential/non-key personnel) the contractor intends to use for successful work performance.
 - ii. The total number proposed contractor staff/personnel per labor category/labor type.
 - iii. All subcontractors, vendors, suppliers, etc.
 - iv. Which tasks, subtasks, etc. described in the PWS will be performed by the prime contractor, subcontractors, vendors, suppliers, etc.
 - v. Which labor categories/labor types will be on-site vs. virtual/remote throughout contract performance.
 - vi. For each essential/key personnel labor category or position, identification of which individual(s) are anticipated to be a full-time, part-time, matrixed, or a split resource (i.e. not a full-time equivalent (FTE)/dedicated to the performance of work described in the PWS).
 - vii. The methods the contractor will use to supplement resourcing if staff/personnel changes occur to ensure continuity of operations and successful work performance.
 - viii. The methods the contractor will use to maintain training and applicable certifications for staff/personnel.
3. Organizational Structure: A summary description with applicable figures or charts demonstrating an acceptable organizational structure that logically provides adequate resource planning with qualified personnel to perform all the tasks, subtasks, etc. in

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

this PWS. This description with applicable figures or charts must (at a minimum) also clearly identify:

- i. The logical hierarchy (including roles/responsibilities) proposed by the contractor to conduct oversight of their personnel in alignment to the PWS tasks, subtasks, etc. for all proposed labor categories/labor types (i.e. both essential/key personnel and non-essential/non-key personnel).
 - ii. Clear identification of the organizational structure and incorporation of essential/key personnel identified in the PWS.
 - iii. Identification of all labor categories/labor types by prime contractor, subcontractor, vendor, or supplier.
4. **Key Personnel**: The resumes and applicable supporting documentation (including but not limited to certifications) for all contractor proposed Key Personnel identified in the PWS to clearly demonstrate their capabilities and qualifications for Government determination of acceptability. **The contractor will ensure all Key Personnel resumes and applicable supporting documentation does not contain any CUI including (but not limited to) PII.**
- i. The resumes of Key Personnel must provide a clear demonstration that the proposed resources meet or exceed the education, qualification, and experience requirements described in the PWS.
 - ii. The Government reserves the right to use any available information to evaluate Key Personnel, including (but not limited to) verification of proposed Key Personnel performance on other Government contracts. The Government may contact references identified in Key Personnel resumes, query databases for certification validity, and inquire with end user representatives regarding the quality of Key Personnel experience and performance. The Offeror must provide, along with resumes, Letters of Intent (LOI)/Letters of Commitment (LOC) confirming Key Personnel selection and availability immediately on contract award. The Offeror must ensure that all Key Personnel possess eligibility for applicable personnel security clearance investigations and can obtain a Common Access Card (CAC).
5. **Risk/Issue Management**: A narrative description with applicable figures or charts on

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

how the contractor will identify, control, manage, and elevate to the Government risks or issues encountered during contract performance. This description must (at a minimum) also include:

- i. Methods to address any known constraints to contractor performance identified in the PWS
 - ii. Identification (including if/then statements with likelihood and consequences) of any critical risks known to the contractor at the time of proposal that could significantly impact successful contract performance.
 - iii. The methods the contractor will use to control cost, prevent scope creep during contract performance, and minimize requests for equitable adjustment (REAs).
6. Stakeholder Communications: A narrative description with applicable figures or charts of the methods the contractor will use for stakeholder identification, engagement, and communications. This description should include information on how communications will be disseminated between the contractor and the Government such as communication matrixes, integrated project teams (IPTs), group mailbox(es), etc.
7. Quality Control/Quality Assurance (QC/QA): A narrative description with applicable figures or charts of the plans, processes, and methods the contractor will use to meet the performance standards identified in the PWS. Additionally, this description needs provide details on how the contractor will support Government oversight and implement QC/QA processes to successfully complete the tasks, subtasks, etc. to deliver the Government's desired outcomes including (but not limited to):
- i. Any contractor key framing assumptions associated with contract performance.
 - ii. The contractor's methods of compliance with the Government QASP such as performance monitoring, Acceptable Quality Levels (AQLs), etc.
 - A. This information must include specific details on how the contractor will adhere to the performance standards, Key Performance Indicators (KPI), Key Performance Parameters (KPPs), etc.
 - iii. The contractor's approach to QC/QA that will identify, prevent, and ensure

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

non-recurrence of defective supplies or services including (but not limited to):

- A. Methods, tools, and techniques for QC/QA activities such as 100% inspection, random/periodic sampling, peer reviews, independent verification and validation (IV&V), auditing, management/second level reviews, etc.
 - B. Methods for addressing non-conformity of supplies or services identified by the Government.
8. **Additional Information:** Any additional relevant information associated with the contractor's management approach for the performance of the contract including (but not limited to) appendices, glossaries, definitions, enclosures, or attachments as applicable.
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF.

3.2.2 Subtask 2.2: Post Award Conference

The contractor will be required to participate in a single and/or multi-day post award conference that is intended to serve as orientation for contract execution compliant with FAR 42.5. At a minimum, all key personnel identified in this PWS must attend the post award conference. The post award conference may be held virtually (i.e. video teleconference) or face-to-face or at a specific location designated by the Government. The post award conference will aid both Government and contractor to achieve a clear and mutual understanding of all contractual requirements as well as identify and resolve any potential problems before they arise during contract performance. The post award conference is not a substitute for the contractor full understanding of the work requirements at the time their proposal was submitted, nor is it to be used to alter the final agreement arrived at in any negotiations leading to contract award. As part of the contractor's participation in the post award conference, the contractor will be expected to prepare and present an executive overview of their plan to manage the scope, schedule, and resources for the contract. An agenda for the post award conference will be provided to the contractor by the KO, COR, and/or TPOC before the conference date. The contractor will support the Government oversight of the post award conference by recording meeting minutes summarizing the events that transpired during the post award conference. All documentation generated by the contractor for the post award conference will be submitted to the COR/TPOC NLT ten (10) business days after the conclusion of the conference.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

3.2.2.1 Deliverable: Post Award Conference Presentation & Meeting Minutes [CDRL A003]

- a. **Schedule**: Within ten (10) business upon conclusion of the post award conference.
- b. **Content**: As determined by COR/TPOC in collaboration with the contractor based upon the requirement.
- c. **Format**: Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF.

3.2.3 Subtask 2.3: Weekly Updates and Weekly Activity Report (WAR)

To support Government oversight and monitoring of the contractor's performance, the contractor will provide reoccurring weekly updates to the COR/TPOC. The purpose of the weekly update is to provide a means for an informal interchange between the Government and contractor during the execution of the contract. The weekly updates will occur on a continuous basis throughout the duration of the contract on a business day (i.e. Monday, Tuesday, Wednesday, Thursday, or Friday) that is mutually agreed upon by the contractor and the COR/TPOC. Weekly updates that are scheduled to occur on Federal Holidays as identified in this PWS will be rescheduled at the discretion of the COR/TPOC. The weekly update should be intentionally designed so that it is short in duration (no longer than one (1) hour) and will consist of the following elements:

- a. **Weekly Virtual Teleconference** – The weekly teleconference will be scheduled by the contractor with the COR/TPOC and consist of a well-organized agenda to discuss topic(s) that will assist the Government with oversight and monitoring of the contractor's performance. The contractor will develop the agenda for the weekly virtual teleconference in collaboration with the COR/TPOC and include all areas of Government concern as needed. For example, the weekly virtual teleconference agenda should contain a summary review of all open/active SNOW cases within the ITSM solution assigned to the contractor. The weekly virtual teleconference should also review travel authorizations for upcoming services and SNOW cases to ensure smooth operations. During the weekly virtual teleconference, the Government will review work progress for the services rendered as described in this PWS as well as any major risks / issues identified that could be (or already is) an impediment or roadblock to successful contract performance. Additionally, during the weekly teleconference the contractor will be expected to identify SNOW cases in which services may exceed the Performance Standards identified in Section 7.2 of this PWS and request extension or deferment. Any requests for extension or deferment of SNOW cases must

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

include justification stating the reasoning, basis, and logic for not achieving timely completion of the work. The Government will review the justification provided and decide if an extension/deferment is warranted. Extensions/deferments for the timely completion of services is NOT automatic and will be reviewed and authorized by the Government on a case-by-case basis. The contractor will take meeting minutes of the weekly virtual teleconference summarizing attendees, the discussions/conversations held, action items, assigned action officers, corrective actions, and associated due dates. The contractor's meeting minutes from the weekly virtual teleconference will be provided to the COR/TPOC as part of the Weekly Activity Report (WAR).

- b. **Weekly Activity Report (WAR)** – NLT two (2) business days after completion of the weekly virtual teleconference (preferably within the same Monday through Friday week of occurrence), the contractor will provide to the COR/TPOC a WAR. The WAR will be logically organized to support expeditious Government review (i.e. it should not be excessive in page count or information) and contain the contractor's meeting minutes with any relevant data presented during the weekly virtual teleconference to support Government oversight of performance monitoring. **This deliverable is expected to contain CUI data that is controlled technical information and must be marked and handled appropriately.**

3.2.3.1 Deliverable: Weekly Activity Report (WAR) – CUI – [CDRL A004]

- a. **Schedule:** NLT two (2) business days after completion of the weekly virtual teleconference.
- b. **Content:** At a minimum, the following must be provided by the contractor in each WAR submission:
 - 1. Executive summary of upcoming weekly activities, milestones, and achievements.
 - 2. Meeting minutes of weekly virtual teleconference and action items, assigned action officers, and associated due dates.
 - 3. A summary list of deliverables (i.e. tasks, subtasks, work packages, action items, etc.) that are:
 - i. Past due / behind schedule
 - ii. Recently completed (within the past week)
 - iii. Upcoming (planned to be completed in the next week)

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

4. Reports on all open/active SNOW cases assigned to the contractor:
 - i. The report's data will contain (at a minimum) the following information:
 - A. SNOW case #
 - B. Summary Description of work
 - C. Priority of SNOW case
 - D. Region (i.e. CONUS, Pacific, Europe, etc.)
 - E. Specific site/location of work
 - F. Assigned contractor technician / personnel
 - G. SNOW Case age (based upon Performance Standards described in Section 7.2 of this PWS)
 - H. Brief summation of work progress status
 - I. Projected work finish/completion date
 1. At each WAR submittal, the contractor will clearly identify any changes to projected work finish/completion dates. Changes to the projected work finish/completion dates must include justification stating the reasoning, basis, and logic for the untimely rendering of services. The Government will review the contractor's justification during the weekly teleconference and decide if an extension/deferment is warranted. Extensions/deferments for services rendered is NOT automatic and will be reviewed and authorized by the Government on a case-by-case basis.
 - J. For site support SNOW cases the following additional information is required:
 1. Month and year the site support TO was awarded
 2. Month and year site support services started
 3. Last PM date for specific site
 - ii. The data will be grouped by SNOW case types (i.e. PM, CM, Technical Support, site support, etc.) and then by the following criteria:
 - A. All cases that are "Emergency" and "High" in Priority
 - B. All newly assigned cases and cases aged between 0 and 29 calendar days
 - C. All cases aged between 30 and 59 calendar days
 - D. All cases aged between 60 and 89 calendar days
 - E. All cases aged 90 calendar days or greater
5. Reports on all closed/completed SNOW cases since the last WAR submission:

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- i. The report's data will contain (at a minimum) the following information:
 - A. SNOW case #
 - B. Summary Description of work
 - C. Priority of SNOW case
 - D. Region (i.e. CONUS, Pacific, Europe, etc.)
 - E. Specific site/location of work
 - F. Total case age / duration (based upon assignment to contractor)
 - ii. The data will be grouped by SNOW case types (i.e. PM, CM, Technical Support, site support, etc.).
 6. A summary list of contractor travel organized by SNOW case types (i.e. PM, CM, site support, etc.) identifying:
 - i. SNOW Case #
 - ii. Travel location
 - iii. Travel dates (start and end)
 - iv. Name of contractor personnel assigned
 7. Additional data identified in writing by the COR as necessary to support Government oversight of contractor performance.
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF.

3.2.4 Subtask 2.4: Monthly Status Report (MSR)

To provide adequate documentation and support Government oversight, inspection, and acceptance of the supplies and services rendered, the contractor will provide reoccurring a Monthly Status Reports (MSR). The MSR will serve as formal documentation throughout the performance of the contract for Government inspection and acceptance on most supplies and services rendered by the contractor to meet the requirements identified in this PWS. The primary purpose of the MSR is to support Government surveillance, review, and evaluation of contractor work performance by providing status, update, and formal record on task, subtask, work effort, activity, and required data products/deliverables completion. The MSR intended to be summation of the contractor's preceding month's supplies and services rendered and will need to contain information on contractor travel, financial expenditures, data/metrics on contract performance, action items, staff changes, and any significant risks or issues encountered during

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

work performance.

The contractor will submit the first MSR to the Government within thirty (30) calendar days after contract award. Follow on MSRs will be provided by the contractor to the Government by no later than (NLT) the fifth (5th) business day of each month for the duration of the contract. Upon Government review of the MSR, the document will be formalized via signature of the contractor and Government to establish an auditable record of the supplies and services rendered for each month of contract performance. Finalized copies of each MSR must be distributed to the contractor and the COR/TPOC for retention.

The MSR must be submitted in the contractor's design unless otherwise agreed upon between the contractor and the Government. The documentation must be provided in a digital format, viewable using the latest version of Microsoft Office or Adobe PDF. **The contractor must ensure the MSR does not contain CUI.**

3.2.4.1 Deliverable: Monthly Status Report (MSR) – [CDRL A005]

- a. **Schedule:** Within thirty (30) calendar days after contract award and NLT the fifth (5th) business day of each month thereafter for the duration of contract performance.
- b. **Content:** Each MSR submitted will contain the following:
 1. Logical and methodical organization of all content such as a table of contents, page numbers, etc.
 2. Clear and concise identification of the supplies and services rendered to the Government for the preceding calendar month including tasks, subtasks, Government reviews, milestones, action items, or required data deliverables completed compliant to this PWS.
 3. Figures, graphics, and/or tables of current data/metrics (i.e. no older than two (2) business days from contractor MSR submission) identifying SNOW cases assigned to the contractor to perform the services described in this PWS. This data is intended to be a monthly roll up of the contractor WARs as described in this PWS to support Government oversight on the quality and timeliness of services rendered. The COR/TPOC may perform inspection (random or specific/targeted) on any SNOW case identified in the MSR to evaluate quality and timeliness of the contractor's rendered services. SNOW cases determined by the COR/TPOC to be in non-

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

conformance to quality and/or timeliness (for example, excessive in age and/or insufficiently supported by the contractor) may result in a performance evaluation below “Satisfactory” compliant to the Performance Standards described in this PWS. The contractor’s data/metrics is expected to include a monthly summation of all SNOW case data reported in the WARs as well as the following additional information:

- i. Open Active SNOW cases:
 - A. Total # of new SNOW cases assigned to the contractor for the month grouped by type (i.e. PMs, CMs, Technical Support, and site support).
 - B. Total # of active SNOW cases assigned to the contractor at the time of MSR submission.
 - C. Total # of SNOW cases for PMs currently behind schedule at the time of MSR submission.
 - D. Total # of SNOW cases for CM/Repairs aged 31 calendar days or greater from approval to execute CM/Repair services.
 - E. Average cumulative age of SNOW cases grouped by type (i.e. rolling average age of open/active PMs, CMs, Technical Support and site support SNOW cases).
- ii. Completed SNOW cases:
 - A. SNOW cases completed for the month by type (i.e. the total # of PMs, CMs, Technical Support and site support completed since last MSR submission).
 - B. Total # of SNOW cases completed during the PoP by type.
 - C. Total # of SNOW cases for PMs completed on time or ahead of schedule for the month.
 - D. Cumulative total # of SNOW cases completed during the PoP based upon region (i.e. CONUS, Europe, Pacific, etc.).
 - E. Average cumulative age during the PoP of SNOW cases completed (i.e. rolling average # of days to successfully complete PM, CM, Technical Support, and site support SNOW cases).
 - F. Monthly total # of SNOW cases resolved by Technical Support Team (i.e. problem resolved remotely).
 - G. Cumulative % of SNOW cases resolved during the PoP by Technical Support Team (i.e. problem resolved remotely).
- iii. Completed Site Support Projects SNOW cases: The contractor will provide a

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

summary of all completed Site Support Project SNOW cases with the following information:

- A. Total # of Site Support SNOW cases completed for the month/since last MSR submission.
 - B. Cumulative list of Site Support SNOW cases completed during the PoP based upon region (i.e. CONUS, Europe, Pacific, etc.).
 - C. Cumulative average age of Site Support SNOW cases.
- iv. Relevant contractor information justifying deferment/delay on the progress of SNOW cases (regardless of status) to support Government analysis on the quality or timeliness of contractor performance.
- v. Any additional SNOW case data identified by the COR as necessary to assist in Government oversight or contractor performance monitoring.
4. Description and supporting documentation (if necessary) of contractor travel completed in the preceding month and upcoming contractor travel.
5. Summary of all active risks or issues to contractor performance complaint with the Government's risk, issue, and opportunity management processes including:
- i. All risks categorized by likelihood and consequence (i.e. High, Medium, Low)
 - ii. All issues categorized by impact (i.e. High, Medium, Low)
 - iii. Mitigation / resolution strategies for each risk / issue with status of implementation.
6. Contract financial information (such as documentation identifying by funds expended and amounts remaining) for all CLINs.
- i. Included in this financial information, the contractor must include summary cost expenditure data associated with CM/Repair services rendered including:
 - A. Monthly total labor costs incurred
 - B. Monthly total supplies costs incurred
 - C. Monthly total travel costs incurred
 - D. Cumulative total labor costs
 - E. Cumulative total supplies costs
 - F. Cumulative total travel costs
 - G. Funds remaining for CM/Repair services CLIN(s)

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

7. Any additional information or documentation necessary to support successful Government surveillance (including identifying problem areas/issues requiring attention) and/or oversight.
8. A section reserved for the Government to provide input / feedback.
 - i. The COR will utilize this area/section in the MSR to provide formal comments to the contractor, document performance concerns, and identify the assigned monthly performance ratings for the contractor IAW the Performance Standards described in this PWS.
9. A signature page containing lines for:
 - i. Contractor Representative
 - A. The contractor will sign the MSR prior to its submission for Government review.
 - ii. Government Representative
 - A. The COR will review the MSR and if the deliverable is acceptable, provide input / feedback with assignment of monthly performance ratings. The COR will sign the MSR deliverable and provide a copy of the document to the contractor. The contractor will provide a response to the Government within five (5) business days if they do not agree with the COR's ratings as assigned. In the event of the contractor not agreeing with the COR's ratings, the KO will review the contractor's response and make the final rating determination
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

3.2.5 Subtask 2.5: In Progress Reviews (IPRs)

To meet the requirements described in this PWS, the contractor will need to participate in and provide administrative support services for IPRs on an as needed basis to assist with Government coordination, oversight, and surveillance of contractor work performance. Documentation

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

generated for IPRs will be identified by the contractor and the Government as to its content and format at the time of IPR. All documentation generated to support IPRs will be submitted to the Government COR for inspection, acceptance, and retention on an as needed basis.

The purpose of the IPR is to provide a means for a formal exchange between the Government and contractor during the execution of the contract. IPRs will be conducted as required and during the IPR the KO and COR will appraise the contractor of how the Government views the contractor's performance. In exchange, the contractor will be expected to identify to the Government any issues, problems, roadblocks, impediments, etc. that are preventing successful performance. Topics best suited for IPRs include formal discussion on risks or issues discovered; reoccurring updates on progress towards completing specific tasks, subtasks, work efforts, activities of Government or contractor concern; or other collaborative efforts that necessitate formal coordination. For example, if there is a specific contractor task requiring formal oversight or the Government has concerns regarding contractor performance, the IPR should be utilized to rapidly and effectively address those concerns. The Government or contractor may request to conduct an IPR at any point during contract performance but must do so in writing. IPRs should be infrequent and contain a pre-arranged, well-organized agenda to maximize their effectiveness. IPRs may be conducted virtually or in person as appropriate. Documentation generated for IPRs will be identified by the contractor and the Government as to its content and format at the time of IPR. All documentation generated to support IPRs will be submitted to the Government COR for inspection, acceptance, and retention NLT five (5) business days after completion of each IPR.

3.2.5.1 Deliverable: IPR Documentation [CDRL A006]

- a. **Schedule:** NLT five (5) business days after completion of each IPR.
- b. **Content:** As determined by COR/TPOC in collaboration with the contractor based upon the requirement.
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

3.2.6 Subtask 2.6: DoDM 8570.01/DoDD 8140.01 Report

The contractor will provide documentation supporting the information assurance certification status of personnel performing information assurance functions compliant with DoDM 8570.01/DoDD 8140.01 - Information Assurance Workforce Improvement Program. The contractor must provide reoccurring monthly reporting confirming adherence to the

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

cybersecurity requirements associated with personnel who require “privileged access” as described within this PWS. The purpose of the report is to identify all contractor personnel requiring “privileged access” to the Government NE or CE, verify certification(s) are not expired, and validate security clearance eligibilities.

The first Monthly DoDM 8570.01-M/DoDD 8140.01 Report will be a comprehensive document covering all contractor provided (i.e. prime or subcontractor, key or non-key) personnel. The contractor will then be required to report updates monthly thereafter (or report no changes). The contractor must submit the first DoDM 8570.01-M/DoDD 8140.01 Report to the within thirty (30) calendar days after contract award for inspection and acceptance.

Follow on DoDM 8570.01-M/DoDD 8140.01 Reports will be provided by the contractor NLT the fifth (5th) business day of each month for the duration of the contract. The follow-on reports must provide updated status on all data fields contained within the report and indicate any additions or removals of personnel requiring privileged access to the Government NE or CE.

This deliverable is expected to contain CUI data that is general privacy/PII and must be marked and handled appropriately.

3.2.6.1 Deliverable: DoDM 8570.01-M/DoDD 8140.01 Report - CUI – [CDRL A007]

- a. **Schedule**: Submitted with MSR within thirty (30) calendar days after contract award and NLT the fifth (5th) business day of each month thereafter for the duration of contract performance.
- b. **Content**: For all applicable contractor personnel, the DoDM 8570.01-M/DoDD 8140.01 Report will contain:
 1. Change Status
 2. Last Name
 3. First Name
 4. Middle Initial
 5. IA Category
 6. IA Level
 7. Company
 8. Contract Name/Description
 9. Contract #
 10. Contracting Officer Representative (COR)
 11. Primary/Baseline IA Certification Held
 12. Date of Primary/Baseline IA Certification

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

13. Date Primary/Baseline IA Certification Expires
14. Primary CE Certification Held
15. Date Primary CE Certification Received
16. Primary IA Certification Status (Current or Past Due)
17. Primary CE Certification Status (Current or Past Due)

- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

3.2.7 Subtask 2.7: Contractor Personnel Roster, Common Access Card (CAC), & Alternate Tokens Report

To support Government monitoring of Government Property (GP), the contractor will be required to submit reoccurring reports identifying all employees working on the contract. This report will include all contractor personnel (regardless of whether Prime or Subcontractor). The report will also identify which contractor personnel have been issued CACs and/or alternate tokens for privileged access to the Government NE or CE. The contractor will provide at the time of each report submission confirmation the employees listed are still working on the contract and/or require CACs and alternate tokens. The report must note where changes have occurred (i.e. any additions or deletions) since the previous month at the time of each submission. contractor employees who already have a CAC or alternate token related to another DLA or DoD contract must be included in the monthly report. The contractor will note the issuing organization and the expiration date for all CACs and alternate tokens. The contractor will be responsible for notifying the KO and COR in writing, within 24 hours when any of their personnel are no longer working under the contract. At the time of contractor personnel departure/roll-off, the contractor will be responsible for ensuring (at no additional cost to the Government) the collection and turn-in of any CAC or alternate token issued to their personnel (regardless of whether Prime or Subcontractor). **This deliverable is expected to contain CUI data that is general privacy/PII and must be marked and handled appropriately.**

3.2.7.1 Deliverable: Contractor Personnel Roster, Common Access Card (CAC), & Alternate Tokens Report [CDRL A008]

- a. **Schedule:** Submitted with MSR within thirty (30) calendar days after contract award and NLT the fifth (5th) business day of each month thereafter for the duration of contract performance.
- b. **Content:** At a minimum the contractor Personnel Roster & CAC Report will include the

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

following data:

1. For all contractor personnel (regardless of whether Prime or Subcontractor):
 - i. Full name (first, middle, and last)
 - ii. Roll-On Date
 - iii. DLAH 1728 Submission Date
 - iv. Roll-Off Date
 2. For all contractor personnel (regardless of whether Prime or Subcontractor) who have been issued a CAC:
 - i. CAC/alternate token issuance date
 - ii. CAC/alternate token expiration date
 - iii. CAC/alternate token EDIPI #
 - iv. CAC/alternate token turn-in date
 - v. CAC/alternate token turn-in location
 - vi. Government POC for CAC/alternate token turn-in
 3. An additional text field for notes/comments
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

3.2.8 Subtask 2.8: Quarterly Inventory Report (QIR)

The QIR is a continuously maintained list of all Government products and equipment deployed or utilized. The Government will provide an initial QIR as Government Furnished Information (GFI) during the transition-in period as described in this PWS. After receipt of the initial QIR, the contractor will be expected to maintain the inventory, listing all deployed products and equipment throughout the duration performance. The QIR will need to be updated by the contractor as work is performed and an updated version will be submitted to the Government on a reoccurring basis (i.e. every three (3) months/quarterly). The QIR will include information used by the Government to monitor and track deployed inventory, downtime, site/system locations, and system types. **This deliverable is expected to contain CUI data that is controlled technical information and must be marked and handled appropriately.**

3.2.8.1 Deliverable: Quarterly Inventory Report (QIR) – CUI – [CDRL A009]

- a. **Schedule:** Quarterly (every three (3) months) after the start of contract performance and

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

by NLT the last calendar day of month

- b. **Content:** Data product will include an inventory list (separated by region such as CONUs, Pacific, Europe, etc.) with the following information:
 - 1. DODAAC
 - 2. Site Name
 - 3. Configuration Item Name
 - 4. Configuration Item Description
 - 5. Status
 - 6. Part Number
 - 7. Serial Number
 - 8. Program
 - 9. System
 - 10. Manufacturer
 - 11. Location/Floor
 - 12. Last known PM date
 - 13. System Type
 - 14. Quantities
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

3.2.9 Subtask 2.9: Commercial Documents

The contractor will provide applicable commercial documentation for supplies rendered to support the HFAM program throughout the performance of this contract. This commercial documentation is expected to include (but is not limited to) equipment manuals, publications, manufacturers' descriptive literature of cataloged products, equipment drawings, diagrams, performance and characteristic curves, catalog cuts, warranty periods, etc. to the Government for supplies rendered. All commercial documentation will be uploaded electronically into the Government NE as directed by the COR for retention and support of the HFAM program. The contractor will submit all commercial documents to the Government NLT ten (10) business days after identification of each requirement.

3.2.9.1 Deliverable: Commercial Documents [CDRL A010]

- a. **Schedule:** NLT ten (10) business days after identification of each requirement.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- b. **Content:** Determined based upon supplies rendered such as equipment manuals, publications, manufacturers' descriptive literature of cataloged products, equipment drawings, diagrams, performance and characteristic curves, catalog cuts, warranty periods, etc.
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

3.3 Task 3: Preventive Maintenance (PM)

All PM support supplies and services rendered to complete this task (including subtasks) will be performed on a FFP basis. Contractor services rendered for this task (including all subtasks) will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

To meet the Government's objectives identified in this PWS, the contractor will be required to provide preventative maintenance (PM) (i.e. recurring maintenance) support services for the deployed HFAM solutions. PM focuses on regularly scheduled inspections, inventorying, maintenance activities, and component replacements to prevent equipment failures before they occur. This is a proactive approach that aims to keep assets in optimal condition with the goal of maximizing equipment up time, extending asset lifespan, and reducing the likelihood of unexpected breakdowns requiring CM/Repair. **As a general principle, the contractor will ensure PM support services will be completed compliant with the planned maintenance cycles (see Attachment 4 - PM Frequency Listing) to ensure the Government does not have sites with overdue PM activities.**

The contractor's PM support services for the HFAM solutions will follow Unified Facilities Criteria (UFC) 3-460-03, general inspection and maintenance criteria for military land-based liquid petroleum fuel facilities. The PM process will also follow guidance for the equipment manufacture recommend PM processes and any additional PM processes or guidance aligned with DLA PM guidance (SOP). These criteria are applicable to all branches of the DoD (including DLA). The contractor PM support services require personnel experienced in repair, maintenance, and operation of federal petroleum facilities and petroleum systems to ensure compliance with codes, criteria, regulations, and laws of the United States/host nation (local and national). UFC 3-460-03 applies to all real property facilities used for storing, distributing, and dispensing fuels for reciprocating and jet engine aircraft, automotive fuels, lubricating oils, and diesel fuel. As part of these PM support services, the contractor will be expected to generate

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

detailed reports documenting the on-site conditions as encountered, testing verification of functionality, and identification of any deficiencies discovered.

PM support services rendered by the contractor will be based upon the unique configuration of each HFAM site and deployed solution. The contractor's PM support services will be expected to include activities such as inspection, testing, maintenance, verification, validation, inventory, and documentation of the HFAM solution at each site listed in Attachment 1 - List of HFAM Sites and Systems. The contractor's PM support services will also include drafting or revising applicable drawings/schematics for the HFAM solutions at each site. The contractor's PM support services will be conducted compliant with the Government's SOPs outlined in Appendix A – Guidance/Reference Documents. The contractor's PM support services will be required to also support specific HFAM sites with Independent Alarm Systems (IAS) attached to the hydrant system operating tanks. Contractor PM support at sites with IAS will include validation of the level alarms function as intended and fully interface with the SCADA, ICS, PLCs, and any other applicable AFS components on-site.

Contractor performance of PM support services requires their personnel to possess the capability of traveling worldwide to the various DFSPs (i.e. performance of the work requires physical presence and PM support services cannot be done remotely). All contractor personnel performing PM support services at the DFSPs will have at least a basic level of technical knowledge on the operations of AFS and petroleum facilities/petroleum systems, including the physical hardware / equipment, communication protocols, testing and calibration, system of systems integration, etc. All contractor services rendered at the DFSPs will strictly observe all safety/security protocols and comply with applicable codes, criteria, and federal, state, local and/or host nation regulations.

The contractor will ensure all PM support services are logged and monitored within the Government's ITSM solution (i.e. SNOW cases). All PM support must have at least one (1) SNOW case for each instance of services rendered. Inquiries to combine any SNOW cases will be directed to the COR on a case-by-case basis. The contractor will be responsible for logging into each SNOW case within the Government's NE to actively log, monitor, update, maintain, and record all PM support services. All contractor personnel assigned the duties for logging into the Government's NE will be required to have a valid CAC for access. The contractor will immediately inform the COR if their personnel no longer requires access to the Government NE due to termination of employment or for any reason.

All PM support services rendered by the contractor must meet the Government's expectations for the timely completion of the work compliant with Section 7.2 – Performance Standards of this

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

PWS.

In the performance of PM support services, the Contactor will be required to complete:

3.3.1 Subtask 3.1: PM Planning and Coordination

Contractor services rendered for this subtask will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

Based upon Government PM frequency listing described in Attachment 4, the contractor will conduct all planning and coordination for PM support services of the HFAM solutions deployed at the various DFSPs. This includes (but is not limited to) orchestration of contractor personnel travel and delivery of supplies to the DoD fuel facility/DFSP site. Each PM support service will be tracked on an individual basis via SNOW cases in the ITSM solution. The contractor will be required to perform all advance coordination with the various DFSPs site personnel to ensure all inspections and maintenance efforts can be accomplished during a site visit for PM. The Government will not be responsible for reimbursement of travel or lost time due to a lack of advance coordination with the DFSPs prior to site visits for PM. Confirmation of contractor coordination with the DFSPs prior to personnel travel will be documented in writing and logged by the Contactor within each SNOW case as applicable. As part of the planning and coordination for PM support services, the Contactor will also need to develop a Plan of Action and Milestones (POAM) to complete the work. While the complete POAM is not a formal deliverable, at the completion of PM planning and coordination the contractor will ensure the SNOW case clearly identifies the contractor personnel assigned to perform the work with the projected dates for travel and completion of PM support services.

3.3.2 Subtask 3.2: PM Services

Contractor services rendered for this subtask will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

The contractor's personnel will be expected to initiate PM support services within 48 hours of arrival at the specific site location. The contractor will be expected perform all coordination for equipment, supplies, and incidentals (i.e. pre-planning/pre-positioning) to support PM support services in advance of their execution as described in this PWS. The Government will not be responsible for any delays in work performance or time lost by the contractor for their failure to

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

pre-plan or coordinate in advance of executing PM support services such as inability to access the HFAM solution or non-delivery of supplies. Delays, extensions, or deferments requested by the contractor to perform PM support services will be handled by the Government on a case-by-case basis as described in this PWS. The contractor's PM support services will perform the following complaint to the Government's SOPs outlined in Appendix A – Guidance/Reference Documents. All contractor PM services will be expected to meet or exceed the performance standards described in this PWS.

All contractor personnel rendering PM support services must have seamless coordination with the contractor's Technical Support Team to ensure SNOW cases are updated in near real time. While on site, the contractor will be expected to proceed with performing the PM support services such as HFAM solution inspection, maintenance, calibration, adjustment/fine tuning, testing, and documenting of conditions as they exist. The contractor's PM support services must include all necessary incidental and consumable supplies to perform regular / re-occurring maintenance of the deployed HFAM solution at no additional cost to the Government. Common supplies the Government anticipates the contractor will need to provide to perform PM support services include (but is not limited to) items such as cleaning materials, batteries, fuses, desiccant pads, corrosion inhibitors, lubricants, o-rings, gaskets, diaphragms, calibration tools, anti-seize materials, etc. If the contractor discovers a significant deficiency or fault with the deployed HFAM solution during execution of PM services (i.e. a component, hardware, equipment, etc. failure that jeopardizes or has affected the operability of the HFAM solution), the contractor will ensure seamless coordination occurs between on-site personnel and their Technical Support Team to generate a new SNOW case identifying a need for CM/Repair services. In these circumstances, the contractor will follow the procedures described in Section 3.4.2 Subtask 4.2: Technical Support Team CM/Repair and Site Support Planning and Coordination as described in this PWS. Issues discovered on site by contractor personnel that clearly fall outside the scope of PM support services will be logged the SNOW case as appropriate and escalated to the Government for action.

While not all-inclusive, the Government anticipates the contractor will need to successfully complete the following to render PM support services:

3.3.2.1 PM Travel

Upon completion of PM planning and coordination as described in this PWS, the contractor will authorize their personnel to travel to the specific DoD fuel facility/DFSP identified in the SNOW case to perform PM support services. The contractor will be responsible for all pre-planning, coordination, organization, and orchestration of PM support services (including travel) at no

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

additional cost to the Government. The contractor will not authorize travel of personnel to perform PM support services without a SNOW case. The contractor will coordinate with the COR when it is identified during planning and coordination that escort, SOFA status/orders, or other unique security or safety requirements exist at the site which may impact the performance of PM support services.

3.3.2.2 PM Information Gathering and Inspection

The contractor will perform PM information gathering and inspection of the HFAM solution at the DoD fuel facility/DFSP. This PM inspection will be performed by the contractor prior to conducting any HFAM solution testing and will review existing equipment, conduit, and wire for the hydrant fueling systems to ensure these components are still operable and in satisfactory condition. As part of the PM inspection, if the Government does not have a record of a PM performed at the specific site the contractor's will be required to document the as-found condition of the HFAM solution discovered. This documentation will include a brief report as to the condition of the HFAM solution including its components, what the outputs of the HFAM solution controls are (if applicable), and site configuration drawings. For the information gathering, the contractor will collect the information that is required in equipment installation details as described in SENS-D-GEN-SOP-01 Sections 3 and 4. The contractor will obtain all equipment information compliant with SENS-D-GEN-SOP-01 Sections 1.0, 2.0, 3.0, and 4.0.

3.3.2.3 PM Adjustment and Fine Tuning

After the initial inspection is complete, the contractor will proceed with performing PM support activities including (but not limited to) regular service of the HFAM solution. For example, the contractor will be expected to perform routine maintenance of the equipment, hardware, sensors, devices, etc. of the HFAM solution. This routine maintenance will include cleaning or change-out / replacement of common consumable components (i.e. batteries, fuses, desiccant pads, corrosion inhibitors, lubricants, o-rings, gaskets, diaphragms, etc.) using contractor furnished supplies. As PM support services are rendered, the contractor will be required coordinate with onsite Government personnel and perform calibration, adjustment, and fine tuning of the HFAM solution. The contractor will adjust set point values, timing values, and program logic as required to provide a properly tuned hydrant fueling system. A properly maintained and adjusted HFAM solution aligns system performance, reliability, and operates effectively to meet the site-specific needs (i.e. varying onsite mission availability and fuel fill rates of the ship, aircraft, vehicle, etc.). Proper calibration, adjustment, and fine tuning provides smooth system operation, prevents CM/Repairs, and helps eliminate/reduce destructive surge pressure spikes. The critical nature of the end use of fuel demands the dependability and safety of each HFAM solution to perform

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

mission while insuring the protection of fuel quality. HFAM solution adjustments and fine tuning may require privileged access to the Government NE or CE as described in this PWS.

3.3.2.4 PM Testing

During PM support services, the contractor will need to perform onsite HFAM solution testing. All testing activities conducted by the contractor will be coordinated with the DoD fuel facility/DFSP site personnel. Testing by the contractor will be conducted with intention to show the HFAM solution operates as intended, that every device (lights, switches, personal computer display screens, alarms, etc.) associated with the Pump Control Panel (PCP) and NE/CE is in working order, and that the PLC program controls the system per specifications as shown in the fueling system standard design. When directed by the COR, the contractor will develop and/or revise test inspection procedures to keep this activity current. The test procedures will be developed/revised based on the applicable sections of the Unified Facilities Guide Specification (UFGS), Section 33 08 53, Aviation Fuel Distribution System Start-Up.

3.3.2.5 PM Independent Alarm System (IAS)

HFAM sites with an IAS will include PM support services for the IAS attached to the hydrant system operating tanks. The IAS PM will include validation of the level alarms function as well as the interface with the PLC automation. Some older fueling systems may not meet the current updated specifications and are not required to be brought up to current standards under PM support services. Programming changes conducted as part of the contractor's PM support services to ensure IAS functionality will meet the latest standard design to the maximum extent practicable.

3.3.2.6 PM Default Values

Once the HFAM solution has been fine-tuned and passed testing, the contractor will ensure the system default values are loaded into the PLC Electrical Erasable Programmable Read Only Memory (EEPROM) and adjust the CE screens for the Human Machine Interface (HMI) to indicate the new values.

3.3.2.7 Notifications to the Government for PM Services

While not all inclusive, the contractor will immediately notify the COR/TPOC if there are any significant problems / issues encountered during the execution of PM services as well as:

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- a. **Significant Delays:** If the contractor encounters severe impact towards completion of services, the contractor will need to provide sufficient justification to the Government for deferment/extension during the weekly updates and WAR described in this PWS. Significant delays can include (but are not limited to) issues encountered that impact work performance, incomplete activities requiring extensions, Government caused deferrals, etc. In situations where significant delays are expected or have already occurred, the contractor will summarize the situation with a full explanation of their logic, reasoning, and basis for extension of services. Once complete, this information will be provided to the Government for review and decision on the appropriate course of action via the weekly teleconference and WAR described in this PWS. The Government retains unilateral authority for decision on extensions / deferrals and authorizations to extend services will NOT be assumed by the contractor as automatic. All requests for extensions / deferrals of services will be reviewed by the Government and authorized on a case-by-case basis.
- b. **Inadequate Personnel:** If the Government discovers or the contractor determines unskilled or inadequate personnel are assigned to perform services, the contractor will be required to thoroughly document the circumstances surrounding why unacceptable personnel were utilized and provide a resolution strategy.

3.3.3 Subtask 3.3: Technical Documentation

Contractor services rendered for this subtask will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

As services are rendered, the contractor will be required to generate evidentiary matter documenting completion of work. This documentation will vary depending upon the services rendered to support the site-specific HFAM solution deployed. As such, the documentation described within this subtask may apply to PM, Technical Support, CM/Repair, or Site Support services rendered by the contractor and is not repeated within this PWS to eliminate redundancy. All documentation generated for services rendered will be submitted by the contractor into the applicable SNOW case and uploaded into a Government designated NE database for the HFAM program. The contractor will submit to the Government for inspection and acceptance all applicable documentation within ten (10) business days of on-site services completion for each PM, CM/Repair, or Site Support activity performed at the specific DoD fuel facility/DFSP site. The Government will perform a review of the documentation submitted compliant to the QASP. If the documentation is found to contain errors, they will be returned to

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

the contractor for correction compliant to the QASP. The following documentation are the known deliverables associated with support services to be rendered by the contractor, but will vary based upon the DoD fuel facility/DFSP requirements:

3.3.3.1 Deliverable: HFAM Site Documentation [CDRL A011]

The contractor will submit a Testing Site Overview Sign-Off Form (SENS-D-GEN-TEP-02, Section 1.2) for support services rendered. The Sign-Off Form will be used as a cover page for the completed test forms. Upon completion of on-site services, the contractor will sign this sheet and have the site representative sign the sheet. A copy of the signed sheet will be left with the site representative prior to departure. The contractor will ensure copies of this documentation are retained within the SNOW case and the designated DLA asset database.

- a. **Schedule**: Within ten (10) business days of on-site service completion.
- b. **Content**: Per SENS-D-TEP-02 sections 1.2, 1.5, 2.8.1, 2.8.2, 2.8.3, 3.5, 3.10.1, 3.10.1.2, 3.10.2, 3.10.3, 3.10.4, 4.0, and 5.5. Combine into one report. Additional content may be required compliant to the Government's SOPs outlined in Appendix A – Guidance/Reference Documents depending upon services rendered.
- c. **Format**: Electronic copies viewable using the latest version of Adobe PDF.

3.3.3.2 Deliverable: HFAM Test and Inspection Documentation [CDRL A012]

The contractor will accomplish Test and Inspection procedures for the HFAM solutions in conjunction with the services rendered. The contractor will complete the information required in the Test Inspection Procedures & Report compliant with SENS-D-GEN-TEP-02, Section 3.10. The contractor will ensure copies of this documentation are retained within the SNOW case and the designated DLA asset database.

- a. **Schedule**: Within ten (10) business days of on-site service completion.
- b. **Content**: Per SENS-D-TEP-02 Section 3.10 – Hydrant System (HFAM) Testing and Inspection. Additional content may be required compliant to the Government's SOPs outlined in Appendix A – Guidance/Reference Documents depending upon services rendered.
- c. **Format**: Electronic copies viewable using the latest version of Adobe PDF.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

3.3.3.3 Deliverable: HFAM Information Gathering and Equipment Data [CDRL A013]

The contractor will accomplish information gathering and equipment data creation/updating for HFAM solutions in conjunction with the services rendered. For the information gathering, the contractor will collect the information that is required in equipment installation details compliant with SENS-D-GEN-SOP-01 Sections 3 and 4. The contractor will also obtain all equipment information compliant with SENS-D-GEN-SOP-01 Sections 1.0, 2.0, 3.0, and 4.0. The contractor will ensure copies of this documentation are retained within the SNOW case and the designated DLA asset database.

- a. **Schedule**: Within ten (10) business days of on-site service completion.
- b. **Content**: Equipment installation details per SENS-D-GEN-SOP-01 Sections 3 and 4. Equipment information per SENS-D-GEN-SOP-01 Sections 1.0, 2.0, 3.0, and 4.0. Additional content may be required compliant to the Government's SOPs outlined in Appendix A – Guidance/Reference Documents depending upon services rendered.
- c. **Format**: Electronic copies viewable using the latest version of Adobe PDF.

3.3.3.4 Deliverable: HFAM Configuration Drawings [CDRL A014]

The contractor will verify the configuration drawings for HFAM sites. The contractor will accomplish this drawing verification for all PM, CM/Repair, or site support services rendered. The contractor will obtain the site-specific AutoCAD drawing and verify the correctness and accuracy of the drawing as part of the PM, CM/Repair, or site support services. The contractor will mark any changes or additions to the drawings based upon their observations of the HFAM solution at the site. If existing HFAM configuration drawings do not exist for the DoD fuel facility/DFSP, the contractor will develop configuration drawings compliant with SENS-D-GEN-SOP-15, Section 2.3. The contractor will ensure copies of this documentation are retained within the SNOW case and the designated DLA asset database.

- a. **Schedule**: Within ten (10) business days of on-site service completion.
- b. **Content**: Per SENS-D-GEN-SOP-15, Section 2.3. Additional content may be required compliant to the Government's SOPs outlined in Appendix A – Guidance/Reference Documents depending upon services rendered.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- c. **Format:** Electronic copies viewable using the latest version of AutoCAD and Adobe PDF.

3.3.3.5 Deliverable: HFAM Configuration Files [CDRL A015]

The contractor will extract configuration files from each HFAM solution PLC or RTU compliant with SENS-D-GEN-SOP-01 Sections 2.0 and 2.4. The contractor will ensure copies of this documentation are retained within the SNOW case and the designated DLA asset database.

- a. **Schedule:** Within ten (10) business days of on-site service completion.
- b. **Content:** Per SENS-D-GEN-SOP-01 Sections 2.0 and 2.4. Additional content may be required compliant to the Government's SOPs outlined in Appendix A – Guidance/Reference Documents depending upon services rendered.
- c. **Format:** Electronic copies viewable using the latest version of Adobe PDF.

3.3.3.6 Deliverable: HFAM Digital Photographs [CDRL A016]

The contractor will obtain a "Photography Authorization" prior to taking any photographs. Photographs of any kind must be authorized by the installation commander. Authorized forms are site specific and can be obtained by the HFAM site representative as part of the contractor's planning and coordination activities for services. Contractor personnel must have a copy of a photography authorization whenever they are onsite taking photographs. The contractor will ensure all digital photographs do not contain CUI or classified information prior to capture. After obtain proper authorization from the local site, the contractor will take digital photographs as evidentiary matter for services rendered. If requested by the COR, additional photographs may be requested depending upon the discrepancy discovered. All digital photographs should be a minimum of 4-megapixel resolution in .jpg or .pdf format. The contractor will ensure copies of all digital pictures are retained within the SNOW case and the designated DLA asset database.

- a. **Schedule:** Within ten (10) business days of on-site service completion.
- b. **Content:** Per SENS-D-GEN-SOP-01 Sections 2.0 and 2.4. Additional content may be required compliant to the Government's SOPs outlined in Appendix A – Guidance/Reference Documents depending upon services rendered.
- c. **Format:** Electronic copies viewable using the latest version of Adobe PDF.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

3.4 Task 4: Technical Support

All technical support services rendered to complete this task (including subtasks) will be performed on a FFP basis. Contractor services rendered for this task (including all subtasks) will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

To meet the Government's objective, the contractor will be required to provide remote (i.e. off-site) Technical Support services for the HFAM solutions deployed worldwide at the various DoD fuel facilities and DFSPs. This type of support will be the second (2nd) level of a three (3) tiered technical support model. Terms associated with the type of services the Government requires include "level 2 support", "support line 2", and various other headings denoting "advanced technical troubleshooting and analysis". As such, the Contractor's Technical Support Team will be expected to not be just a "Help Desk". It will be required to provide effective customer support by leveraging their knowledge of AFE, petroleum facilities, petroleum systems, and hydrant fueling systems to identify and resolve problems with the HFAM solutions. For example, if DLA's Tier I Initial Response Support receives contact from a customer requesting technical support for a specific HFAM solution deployed at a DoD fuel facility/DFSP and is unable to assist the customer/user or resolve a problem, it would be elevated to the contractor's provided Technical Support Team. However, the contractor's Technical Support Team occasionally may receive contact directly from customers/users at the DFSPs requesting troubleshooting and support (i.e. bypassing Tier I). Problems encountered with the HFAM solutions must be expected to vary in complexity and can impact mission readiness or hinder operations at the DoD fuel facility/DFSP, requiring the contractor's Technical Support Team to possess a wide variety of technical analysis capabilities to resolve them. For example, problems typically elevated to the contractor's Technical Support Team can be expected to consist of HFAM solution modules, components, hardware, software, IT/OT, etc. that are not operating as intended. The contractor's Technical Support Team will also be required to perform planning and preparation for the contractor to conduct on-site support CM/Repair services as described in this PWS such as developing initial work plans / POAMs, cost projections, travel coordination, etc. The contractor's Technical Support Team must provide sufficient staffing of personnel who are knowledgeable on AFE, petroleum facilities, petroleum systems, and hydrant fueling systems that can assist with customer/user requests for support.

The contractor's Technical Support Team will need to be regularly available for providing technical support services during normal Government Duty Hours as described in this

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

PWS based upon Eastern Standard Time (EST)/Coordinated Universal Time (UTC) – 4.

This requirement for regular availability of the Technical Support Team during EST/UTC-4 is intentional to ensure coordination with the contractor's key personnel and maximize the likelihood of effective services to the Government. However, the contractor's Technical Support Team will need to provide the capability of providing communications outside of EST/UTC-4 Government Duty Hours to support SNOW cases for technical support services at the various DFSPs worldwide. For example, if the contractor's Technical Support Team is assigned a SNOW case requiring assistance at a DoD fuel facility/DFSP in Yokosuka, Japan (located in Japan Standard Time (JST)/UTC+9), the contractor may (on a SNOW case-by-case basis) need to communicate with the customer/user outside of EST/UTC-4 Government Duty Hours to provide effective technical support services.

The contractor's Technical Support Team will need to be able to effectively and efficiently communicate worldwide with the customers/users of the HFAM solutions requiring remote assistance. The following are the methods the Government anticipates the contractor will need to utilize for communications with the Technical Support Team:

- a. Electronic Communications (Primary): The primary method the Government will utilize for interaction with the Contractor's Technical Support Team will be via electronic communications. These communications will typically occur via Government E-mail, Instant Messenger, and SNOW cases assigned within the ITSM solution. Regardless of electronic medium utilized for communications, the contractor's Technical Support Team will ensure all written communications are logged within the applicable SNOW case assigned to record services rendered.
- b. Telephone Communications (Secondary): The secondary method the Government will utilize for interaction with the contractor's Technical Support Team will be commercial telephone communications. The contractor's Technical Support Team will ensure all verbal communications are summarized and logged within the applicable SNOW case assigned to record services rendered. To support these communications, the contractor will provide at least one (1) toll-free commercial telephone number (but may provide more) for the following purposes:
 1. Standard Technical Support: The contractor will provide a telecommunications method for the Government to contact the Technical Support Team, report routine problems or issues with the HFAM solutions deployed at the various DFSPs, and request technical assistance during EST/UTC-4 Government Duty Hours. The Technical Support Team must be capable of generating SNOW cases on behalf of

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

customers/users who call into their commercial toll-free phone number, but this will not be the normal method for requesting technical assistance. The contractor's Technical Support Team will not be expected to actively monitor this method of communication outside of EST/UTC-4 Government Duty Hours.

2. Emergency Technical Support: The contractor will provide a telecommunications method for the Government to contact the Technical Support Team and request emergency technical assistance with the HFAM solutions deployed at the various DFSPs. This method of communication will be expected maintain operational availability twenty-four (24) hours a day, seven (7) days a week, three-hundred and sixty-five (365) days a year for emergency assistance. Government contact to request emergency assistance may originate from the KO, COR, Government OEA PMO, or other cognizant Government entities (such as the DLA Information Technology Operations Center (ITOC)). Government requests for emergency technical support services will be kept to a minimum and only conducted on an as-needed, case-by-case basis. As such, the Government will NOT have an expectation for habitually re-occurring requests for contractor emergency response. For planning purposes, the contractor should expect less than six (6) Government requests for emergency technical support to occur in any given year of contract performance (i.e. highly infrequent). In the event of Government request for emergency response, the contractor will be expected to provide technical support services as soon as possible (i.e. regardless of time zone or Government Duty Hours) and continue them until the emergency problem is resolved or the Government determines the contractor's emergency technical support services are no longer necessary. The contractor will maintain continuous reporting on the status of emergency technical support services as they are performed. While it is impossible to fully anticipate the Government's needs when emergency technical support services are requested, the general expectations for these services include the contractor to:

- i. Evaluate and review the reported catastrophic system outage or critical safety hazard.
- ii. Investigate and identify critical failures (i.e. system, subsystem, application, etc. that is affected), users, and sites / locations.
- iii. Coordinate with the Government or third-party Contractors, discover root cause(s) for problem statements, develop plans to restore mission capability or operational availability, and implement approved resolution strategies.

Commented [JJ1]: Check with Ken and verify

Commented [KP2R1]: verified

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- iv. Create and submit a technical Root Cause Analysis (RCA) within ten (10) business days after confirmed resolution of critical failure.
- c. Virtual Meetings (Tertiary): The third method the Government will utilize for interaction with the contractor's Technical Support Team will be virtual meetings. Virtual meetings with the entire contractor's Technical Support Team is expected to be unnecessary, but key POCs from the group may be requested by the Government to attend meetings such as the weekly updates to provide status on specific SNOW cases.

To sustain and support the HFAM solutions deployed at the various DFSPs throughout the world, the contractors will need to perform the following:

3.4.1 Subtask 4.1: Technical Support Team Services

The contractor's Technical Support Team will be required to render services using the Government's provided ITSM solution (i.e. ServiceNow (SNOW)). All contractor Technical Support Team activities, documentation, and customer interactions will be logged within SNOW and the Government will establish SNOW case dashboards that query real time data to ensure active oversight. The contractor will ensure their Technical Support Team is able to support the performance of all tasks and subtasks described in this PWS. For example, the contractor's Technical Support Team will need to be fully integrated and able to assist in the performance of PM, CM, site support, etc. to ensure SNOW cases are updated with progress reporting.

Successful performance of the contractor's technical support services will require the contractor to remotely aid customers (i.e. Government personnel, end users, third-party contractors, etc. regardless of the customer's geographical location) with the HFAM solutions deployed at the various DFSPs. The Technical Support Team will be required to conduct a wide variety of HFAM solution technical support services to assist customers/users such as generating and investigating problem statements, performing basic diagnostics, resolving issues, assisting with system checks and testing, identifying root causes, error code analysis, guided troubleshooting, etc. The Technical Support Team will be required to access and research existing Government Furnished Information (GFI) / documentation associated with the HFAM program contained in the Government NE to assist with troubleshooting and problem solving. This GFI / documentation consists of artifacts such as SOPs, HFAM solution specific technical schematics/drawings, etc.

As the contractor renders technical support, the contractor technician assigned to the SNOW case

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

may determine the root cause of a problem cannot be resolved without sending supplies to the HFAM site (i.e. the customer can resolve the problem without on-site support, but they need materials or supplies) or contractor technician physical on-site presence is required to further investigate or resolve the problem. In these instances, the contractor will utilize the processes outlined in Section 3.4.4. Subtask 4.4: Technical Support Team CM/Repair Planning and Coordination and *may* be authorized to execute services compliant with Section 3.5 Task 5: CM/Repair or Section 3.6 Task 6: Site Support.

3.4.1.1 Technical Support Team Service Level Requirements

The contractor's Technical Support Team will be expected to meet or exceed the performance standards described in Section 7.2 – Performance Standards of this PWS and the following service level requirements based upon EST/UTC-4 Government Duty Hours:

- a. Assignment: The Technical Support Team must be capable of monitoring the ITSM solution for new SNOW cases and self-assigning (i.e. without Government intervention) resources for technical assistance. The contractor will ensure a contractor technician is assigned to each SNOW case within the ITSM solution based upon the timetables identified in this PWS for effective rendering of technical support services.
- b. Initial Review & Contact: Compliant with the timetables identified in this PWS, the Technical Support Team must complete an initial review of the reported information in the SNOW case and attempt to establish responsive contact with the customer/user to initiate technical assistance (i.e. verifiably demonstrate efforts to communicate with the customer/user). **For the purposes of these service level requirements, responsive contact is the ability for the contractor to actively, fluidly, and dynamically communicate with the customer/ user to render technical support services.** Responsive contact with the customer/user may be performed by the contractor exclusively using electronic communications, so long as they are an effective method for providing technical assistance and meets the service level requirements described in this PWS. For “emergency” or “high” priority SNOW cases, if the contractor is unsuccessful in obtaining responsive contact with the customer/user, they will immediately notify the COR of the issue for resolution on a case-by-case basis. For “medium” or “low” priority SNOW cases, if the contractor is unsuccessful in obtaining responsive contact with the customer/user within three (3) business days of SNOW case assignment, the contractor will document the efforts undertaken within SNOW case and escalate the issue to the COR via the next weekly status update for resolution.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- c. Technical Support: After establishing responsive contact with the customer/user, the contractor technician will provide technical assistance for each SNOW case. All technical assistance will be conducted in a professional manner, using English as the primary language for communication, until the reported customer/user problem/issue is resolved **or** until the Government determines the contractor's technical support services are no longer necessary. All determinations by the Government that the contractor's technical support services are no longer necessary will be verifiable and fully documented within each SNOW case as applicable. The contractor is not authorized to change the status of SNOW cases to "closed" without confirmation the customer/user problem/issue is resolved, or the Government determines the contractor's technical support services are no longer necessary. The contractor will not change or shift SNOW cases to other technical support teams to circumvent the timetables identified in this PWS.
1. Escalation: If the Technical Support Team is unable to effectively resolve the problem/issue reported by the customer/user (such as the root cause(s) require CM/Repair, the solution requires services are outside of the scope of services for this contract, etc.) the contractor will document the SNOW case and, when appropriate, promptly escalate the issue to the Government for review / assistance. These escalations will be situationally based and the contractor will be expected to logically assess the unresolved problem's mission impact to determine the expediency of Government review. For example, SNOW cases determined identified as "low" priority and routine in nature may be reported to the Government through the re-occurring weekly updates as described Subtask 2.3 of this PWS, whereas "emergency" or "high" priority problems will need to be escalated immediately. Upon notification of escalation for a SNOW case, the Government will coordinate with the contractor, perform an analysis of the problem statement, and determine the appropriate action as required. All Technical Support Team escalations to the Government must occur within the timelines identified within the performance standards of this PWS for the contractor's services to be considered fully successful.

3.4.1.1.1 Technical Support Team SNOW Case Prioritization and Timetables / Timeliness

The contractor's Technical Support Team will prioritize their work based upon the mission impact of SNOW cases to DLA Energy described as follows:

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

HFAM ServiceNow (SNOW) Case Prioritization	
Priority	Description
Emergency	Government contacts contractor requesting emergency services due to a catastrophic system outage or critical safety hazard impacting fueling operations, posing a severe risk or issue to mission, personnel, assets, or the environment.
High	A significant system malfunction or performance degradation impacting fueling operations, mission, personnel, or assets with available workarounds or redundancies.
Medium	A non-critical system malfunction or performance degradation causing minor impact or disruptions to fueling operations, mission, personnel, or assets.
Low	General, routine, or minor system adjustments, requests, or non-urgent repairs that do not impact fueling operations, mission, personnel, or assets.

Table 2 – HFAM SNOW Case Prioritization

All timetables for the successful performance of the contractor’s Technical Support Team will be based upon the SNOW case prioritization. The contractor will not reprioritize assigned SNOW cases without Government approval. A detailed description of the performance standards for the contractor’s Technical Support Team with timetables / timeliness based upon SNOW case prioritization is identified in Section 7.2 – Performance Standards of this PWS.

3.4.1.1.2 Technical Support Team SNOW Case Reassignments

In situations where a SNOW case is reassigned from the contractor’s Technical Support Team (such as transitions to CM/Repair or Site Support services), the timeliness metrics associated with the SNOW case will reset to a new performance standard as described in this PWS. The reset of performance standards associated with timeliness will be based upon the prioritization and the approval date for reassignment as documented within each SNOW case. A graphic depicting this process is as follows:

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**




Figure 2 – Example of SNOW Case Reassignment Performance Standards Change

3.4.1.1.3 Technical Support Team SNOW Case Reprioritization

As work progresses and Technical Support services are rendered, the contractor must anticipate some assigned SNOW cases will require reprioritization. Due to the dynamics associated with customer service and the unpredictability of problem statements, the Government reserves the unilateral right to reprioritize SNOW cases at any time and for any reason. In situations of reprioritization, the Government will identify the applicable SNOW case(s) and coordinate with the contractor to log re-prioritization of the SNOW case within the ITSM solution as appropriate.

In situations where a SNOW case is re-prioritized, the timeliness metrics associated with the SNOW case will reset to a new performance standard. The reset of performance standards associated with timeliness will be based upon the re-prioritization date documented within each SNOW case. A graphic depicting this process is as follows:




Figure 3 – Example of SNOW Case Re-Prioritization Performance Standards Change

3.4.2 Subtask 4.2: Technical Support Team CM/Repair and Site Support Planning and Coordination

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Performance of this subtask is contingent upon the individual problem statement encountered by the contractor's Technical Support Team as services are rendered. In situations where the contractor's Technical Support Team has reviewed a SNOW case problem statement and identified CM/Repair or site support services described in this PWS *may* be required, the contractor will be required to perform planning and coordination as described in this subtask.

The contractor will NOT circumvent the review process and thresholds described in this PWS for CM/Repair by separating, splitting, etc. requirements into different SNOW cases.

The Technical Support Team will need to ensure CM/Repair and site support planning incorporates all advanced coordination with the various DFSPs site personnel to ensure services can be accomplished. For example, the Technical Support Team may determine via responsive contact with the customer that supplies are needed, but the customer can perform the on-site work necessary to resolve the problem statement identified in the SNOW case. Conversely in situations where contractor technicians need to have an on-site / physical presence to further investigate / resolve the problem, the Technical Support Team needs to ensure the DFSP is aware of the travel dates, has resources available to support the on-site presence of contractor technicians, etc. All records confirming the Technical Support Team's coordination with the DFSPs will be documented and logged by the contractor within each SNOW case as applicable.

Services rendered to complete this subtask will require the contractor's Technical Support Team planning and coordination to generate *initial* projections for CM/Repair service duration and costs. The initial projections generated by the contractor's Technical Support Team need have a reasonable degree of accuracy and the Government's total costs for CM/Repair services needs to be effectively controlled. However, the Government acknowledges CM/Repair services are highly unpredictable / dynamic and anticipates *some* contractor revisions to the initial projections will need to occur as work progresses. As such, the initial projections for CM/Repair services generated by the contractor need to be accurate enough to establish a high level of confidence (i.e. greater than 80%) the work can be successfully completed within estimated duration / total costs. If the contractor's CM/Repair initial projections for cost or duration are determined to be consistently inaccurate or incapable of establishing a high level of confidence CM/Repair services can be successfully completed within the estimated duration / total costs, the Government may elect to implement additional reviews, approvals, or controls prior to CM/Repair service execution as appropriate

A description of the expected services rendered by the contractor for this subtask are as follows:

3.4.2.1 CM/Repair Supplies Planning and Coordination

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

In situations where the contractor's Technical Support Team has identified resolution of the SNOW case problem statement requires the procurement and shipment of supplies to the HFAM site, but there is no need for on-site support (i.e. CM/Repair supplies ONLY), the contractor may be authorized to purchase and ship supplies to the customer compliant with Section 3.5 Task 5: CM/Repair of this PWS. In these circumstances, the contractor's Technical Support Team will conduct market research on the supplies to identify their procurement costs (including shipping) and sources of supply. The contractor will NOT add any service costs, profit, or fee to any CM/Repair supplies. Documentation for all CM/Repair supplies will be uploaded into each SNOW case with summation of costs incurred provided by the contractor via the MSR as described in this PWS. To effectively control costs and conduct oversight of the contractor's planning and coordination for CM/Repair supplies ONLY requirements, the Government will utilize the following logical review process:

- a. CM/Repair supplies less than \$5,000.00: CM/Repair supplies to resolve a SNOW case that are projected to be less than a total cost of \$5,000.00 (including procurement and shipping) will generally not require Government review and written authorization prior to procurement by the contractor unless funding for CM/Repair is low or depleted. In circumstances where the Government does not perform review in advance of CM/Repair supplies procurement and shipment to the customer, the contractor will be expected to conform with all QA/QC processes outlined in their QCP as described in this PWS. If during the execution of this contract the Government determines the contractor is not effective in cost controls (i.e. is consistently wasteful or abusive causing increased costs beyond initial projections), the Government may require review and authorization prior to CM/Repair supplies procurement.
- b. CM/Repair supplies greater than \$5000.00: CM/Repair supplies that are projected to be at or exceed a total cost of \$5,000.00 (including procurement and shipping) will require Government review with written authorization provided for each SNOW case prior to procurement. In these situations, the contractor must ensure CM/Repair supplies are either sourced directly from the Government (i.e. obtained on a National Stock Number (NSN) basis) or multiple quotes (preferably 3 or more) are obtained from different sources of supply to support cost reasonableness. Copies of quotes to support cost reasonableness for CM/Repair supplies will be uploaded in each SNOW case prior to requesting Government review. The maximum total amount the Government may review and approve for any individual CM/Repair associated with a SNOW case is \$50,000.00. **For supplies with a total cost exceeding \$5,000.00, the contractor will not execute procurement compliant with Section 3.5 Task 5: CM/Repair until written Government authorization is provided.**

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

1. Emergency / High Priority CM/Repairs Waiver: The requirement for Government review of CM/Repair supplies with a projected cost at or greater than \$5,000.00 may be waived by the Government on a case-by-case basis for emergency or high priority SNOW cases as described in this PWS. In these unique situations, the COR will provide written notification to contractor which will be logged by their Technical Support Team within the applicable SNOW case.

A depiction of this logical review is described via the following graphic:




Figure 4 – CM/Repair Supplies Only Planning & Coordination Government Review Process

3.4.2.2 CM/Repair Services or Site Support Planning and Coordination

In situations where the contractor identified the SNOW case requires on-site / physical presence to further investigate or resolve the problem statement associated with the HFAM solution (regardless if supplies are or are not needed), the contractor *may* be authorized to perform work compliant with Section 3.5 Task 5: CM/Repair on at time and material (T&M) basis or the Government may need to generate a Task Order (TO) to definitize the work compliant with Section 3.6 Task 6: Site Support of this PWS. **In these circumstances, the contractor will be required to perform sufficient planning and coordination for CM/Repair or Sites Support services prior to Government authorization of their execution.**

This planning and coordination by the contractor's Technical Support Team will require the contractor to establish an initial POAM (i.e. applicable tasks to complete, travel days, etc.) for the on-site work to identify projected work duration as well as an initial cost estimate for the services (i.e. labor, supplies, travel, incidentals, etc.). These projections will be used by the contractor and the Government to support the decision on whether CM/Repair are appropriate. If escorts, SOFA status/orders, or other unique security or safety requirements exist on-site that may impact the performance of services, the contractor will ensure this information is fully described within the SNOW case. All CM/Repair or site support services planning and coordination performed by the contractor's Technical Support Team will be documented within

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

each SNOW case.

To effectively control costs and conduct oversight of the contractor's planning and coordination for CM/Repair and sites support services, the Government will utilize the following risk-based logical review process for each SNOW case:

- a. Low Risk – CM/Repair Services less than 14 days and \$5,000.00: CM/Repair services that are initially projected to be completed in less than 14 calendar days (from the time CM/Repair service is authorized until either the SNOW case is resolved or the investigation to determine root cause is finished) **and** less than a total cost of \$5,000.00 (including all supplies, services, travel, etc.) will be considered “low” risk. These types of CM/Repair services will generally not require Government review and written authorization prior to supplies procurement and travel by contractor personnel unless funding for CM/Repair is low or depleted. If the Government does not perform review in advance CM/Repair services execution, the contractor will be expected to conform with all QA/QC processes outlined in their QCP as described in this PWS for the CM/Repair planning and coordination. If during the execution of this contract the Government determines the contractor is not effective in cost controls (i.e. is consistently wasteful or abusive causing increased costs beyond initial projections), the Government may require review and authorization prior to CM/Repair service execution.
- b. Moderate Risk – CM/Repair Services between 15 - 45 days or \$5,000.00 - \$25,000.00: CM/Repair services that are initially projected take between 15 - 45 calendar days to complete (from the time CM/Repair service is authorized until either the SNOW case is resolved or the investigation to determine root cause is finished) **or** have an initial projected total cost between \$5,000.00 - \$25,000.00 (including all supplies, services, travel, etc.) will be considered “moderate” risk. These types of CM/Repair services require Government review and authorization prior to execution (including contractor personnel traveling to the HFAM site). In these circumstances, the contractor's Technical Support Team will be expected to have documented within each applicable SNOW case the *initial* POAM and costs for the services to be rendered. Additionally in these situations, the contractor must ensure supplies are either sourced directly from the Government (i.e. obtained on a National Stock Number (NSN) basis) or the Technical Support Team obtained multiple quotes (preferably 3 or more) from different sources of supply to support cost reasonableness. **When the CM/Repair services are initially projected to take between 15 – 45 calendar days or \$5,000.00 - \$25,000.00 to complete, the contractor will not execute any services compliant with Section 3.5 Task 5: CM/Repair until written Government authorization is provided.**

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

1. Emergency or High Priority Waiver/Modification: The Government may waive the requirement for review of CM/Repair service planning and coordination on a case-by-case basis for “emergency” or “high” priority SNOW cases as described in this PWS. In these unique situations, the COR will provide written notification to contractor which will be logged by their Technical Support Team within the applicable SNOW case.
- c. High Risk – CM/Repair Services are unknown in duration / cost, longer than 45 days, or exceed \$25,000.00: CM/Repair services in which the contractor cannot identify an initial projected total duration / cost **or** are initially projected take longer than 45 calendar days to complete (from the time CM/Repair service is authorized until either the SNOW case is resolved or the investigation to determine root cause is finished) **or** the total cost is initially projected to exceed \$25,000.00 (including all supplies, services, travel, etc.) will be considered “high” risk. **These types of SNOW cases require a higher level of scrutiny by the Government prior to authorization of CM/Repair services because they may quickly exceed the thresholds as described in this PWS and likely need definitized into a separate TO compliant with Section 3.6 Task 6: Site Support of this PWS.**

In these circumstances, if the costs or duration to resolve the SNOW case problem statement are unknown, the contractor will provide a complete and detailed narrative with justifying information to assist the Government in understanding the totality of the circumstances. Request for CM/Repair services in which the contractor cannot project initial costs or durations will be heavily scrutinized by the Government for validity.

Conversely in these circumstances if the costs or duration are known and exceed 45 calendar days or \$25,000.00, the contractor’s Technical Support Team will be expected to have documented within each applicable SNOW case the *initial* POAM and costs for the services to be rendered. Additionally in these situations, the contractor must ensure supplies are either sourced directly from the Government (i.e. obtained on a National Stock Number (NSN) basis) or the Technical Support Team obtained multiple quotes (preferably 3 or more) from different sources of supply to support cost reasonableness. **When the initial total projected duration / cost for CM/Repair services is unknown or is expected to exceed 45 calendar days / \$25,000.00 to complete, the contractor will not execute any services compliant with Section 3.5 Task 5: CM/Repair until written Government authorization is provided.**

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

1. Emergency or High Priority Waiver/Modification: The Government may waive the requirement for review of CM/Repair service planning and coordination on a case-by-case basis for “emergency” or “high” priority SNOW cases as described in this PWS. In these unique situations, the COR will provide written notification to contractor which will be logged by their Technical Support Team within the applicable SNOW case.

A depiction of the Government’s review process is described via the following graphic:




Figure 5 – CM/Repair Services Planning & Coordination Government Review Process

3.4.3 Subtask 4.3: Technical Support Team Documentation

3.4.3.1 Deliverable: Root Cause Analysis (RCA) [CDRL A017]

- a. Schedule: Within ten (10) business days after confirmed resolution of critical failure.
- b. Content: RCA must contain (at minimum):
 1. An overview of the critical failure and mission / business impact to the Government that includes chronological summary of event(s) date(s) and time(s) as well as resource(s) involved.
 2. Identification of critical failure causation(s).
 3. Description step(s) taken to restore mission capability and/or operational availability.
 4. Recommendation(s) to prevent reoccurrence of critical failure.
 5. Likelihood the critical failure would reoccur if the Contractor’s recommendations were not undertaken by the Government.
- c. Format: Electronic copies within applicable SNOW case of the Government’s ITSM solution viewable using the latest version of MS Office products and/or Adobe PDF.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

3.4.3.2 Deliverable: CM/Repair Supplies Planning and Coordination [CDRL A018]

- a. **Schedule**: As required based upon SNOW case priority and Service Level Agreement (SLA).
- b. **Content**: The documentation must identify the supplies required (i.e. manufacturer, part number (P/N), unit of issue, quantity, etc.) and cost of the supplies (including procurement, shipping, etc). CM/Repair supplies that are projected to be at or exceed a total cost of \$5,000.00 (including procurement and shipping) must be sourced directly from the Government (i.e. obtained on a National Stock Number (NSN) basis) or multiple quotes (preferably 3 or more) from different sources of supply provided.
- c. **Format**: Electronically within each SNOW case of the Government's ITSM solution. Copies of the POAM should be viewable using the latest version of MS Office products and/or Adobe PDF

3.4.3.3 Deliverable: CM/Repair Services or Site Support Planning & Coordination Documentation [CDRL A019]

- a. **Schedule**: As required based upon SNOW case priority and Service Level Agreement (SLA).
- b. **Content**: The CM/Repair documentation must summarize the contractor's projected work elements (i.e. tasks, subtasks, work packages, activities, travel, etc.) that are necessary to successfully complete the work in a logical fashion. This should include a POAM that clearly identifies the critical path to work completion (i.e. the longest sequence of work elements required to successfully render the PM support services) and identify the interdependencies (i.e. the relationships and dependences between work elements such as Finish to Start (FS), Finish to Finish (FF), Start to Finish (SF), or Start to Start (SS)) of the work elements. If interdependencies are identified, the POAM must contain only one (1) work element that does not have a predecessor (i.e. the starting task or milestone) and one (1) work element that does not have a successor (i.e. the final task or milestone). This documentation must also include initial cost projections (i.e. all supplies, services, travel, etc.) to assist the Government in determining whether to authorize execution of CM/Repair services. CM/Repair supplies that are projected to be at or exceed a total cost of \$5,000.00 (including procurement and shipping) must be sourced directly from the Government (i.e. obtained on a National Stock Number (NSN) basis) or multiple quotes (preferably 3 or more) from different sources of supply

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

provided.

- c. **Format:** Electronically within each SNOW case of the Government's ITSM solution. Copies of the POAM should be viewable using the latest version of MS Office products and/or Adobe PDF

3.5 Task 5: Corrective Maintenance (CM)/Repair

All CM/Repair support supplies and services to complete this task (including subtasks) will be performed on a Time and Material (T&M) basis. Contractor services rendered for this task (including all subtasks) will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

To control costs and effectively conduct oversight, the Government will review and provide written authorization for all CM/Repair supplies and services that have an unknown duration / cost, have an initial projected total duration exceeding 14 calendar days (from the time CM/Repair service is authorized until either the SNOW case is resolved or the investigation to determine root cause is finished), or have an initial projected total cost exceeding \$5,000.00 (including all supplies, services, travel, etc.) as described in Section 3.4.4. Subtask 4.4 Technical Support Team CM/Repair and Site Support Service Planning and Coordination of this PWS.

The Government's threshold for total cost and duration of any single CM/Repair occurrence (i.e. each SNOW case) is \$50,000.00 and 90 calendar days. This threshold requirement is to prevent waste, abuse, unnecessarily prolonging the duration of CM/Repairs, or utilizing these services as a substitute for definitizing requirements compliant with Section 3.6 Task 6: Site Support as described in this PWS. If any Government approved CM/Repair service (per SNOW case) is identified to exceed a total cost of \$50,000.00 or has CM/Repair services rendered that exceed 90 calendar days in duration, the COR will notify the KO, document the totality of the circumstances that resulted in the Government's threshold being breached, and implement controls to prevent re-occurrence. All costs associated with CM/Repair supplies and services must be determined as allowable, reasonable, and allocable compliant to FAR 31.201-2 through FAR 31.201-4.

CM/Repair for the HFAM program is intended to provide the Government with a method to obtain break/fix support of HFAM deficiencies at the various DFSPs to ensure the safe and reliable accomplishment of DLA Energy's delivery mission. As such, supplies acquire or services rendered under this task involves CM/Repairs of the HFAM solution after it has failed,

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

broken down, or a deficiency has been discovered via customer/user reporting and/or falls outside the scope of a PM repair activity. It is essentially a reactive approach to maintenance, requiring on-site investigation, assessment, and addressing of problems as they arise that are unique to the deployed HFAM solution. The Government anticipates the requirements for CM/Repair services to be dynamic and highly unpredictable. Regardless of the requirements for each occurrence, **the primary goal for CM/Repair services will be to restore the specific HFAM solution to its operational state as quickly as possible to minimize downtime, production losses, and Government costs.** Due to their dynamic requirements, each occurrence of CM/Repair will require the contractor to actively manage service expectations and (when necessary) coordinate with the Government for approvals as described in Section 3.4.4. Subtask 4.4 Technical Support Team CM/Repair and Site Support Service Planning and Coordination of this PWS. However, the Government's general expectation is that the contractor will investigate and resolve the problems reported for CM/Repair in a safe, prompt, and efficient manner by continuously utilizing appropriate resources that are geographically advantageous to perform the work. The contractor personnel rendering CM/Repair services must have an advanced level of knowledge of AFE, petroleum facilities, petroleum systems, and hydrant fueling systems including:

- Capabilities and applications
- Network Environments (NE) / Computing Environments (CE) (i.e. Development, Test, Stage, Production, Fail/Cut Over, Recovery, etc.)
- IT/OT components
- Software, hardware, and firmware
- Coding, configuration, and scripts
- Systems and sub-systems
- Batch programs
- Data and databases
- Servers and machines
- SCADA computers
- PLCs
- RTUs
- GUIs
- Interfaces and integrations
- Networked data communications
- Reports and reporting documentation
- Maintenance and repair

To ensure effective oversight of this task, the contractor will coordinate CM/Repair work performance in a seamless manner with the contractor's Technical Support Team as described in this PWS. All CM/Repair costs incurred will be summarized by the contractor on a regular basis within the MSR deliverable described in this PWS. The contractor will assist the Government in maintaining active oversight, cost controls, and prevent waste as CM/Repair services are rendered. All contractor CM/Repair work, activities, documentation, and customer interactions will be logged and monitored within the applicable SNOW case assigned. The contractor will not be authorized to perform any CM/Repair work without an assigned SNOW case. Inquiries to combine or split requirements associated with any SNOW case will be directed to the COR on a

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

case-by-case basis. The contractor will be responsible for logging into SNOW within the Government's NE to actively log, monitor, update, maintain, and record all CM/Repair cases. All contractor personnel assigned the duties for logging into the Government's NE will be required to have a valid CAC for access. The contractor will immediately inform the COR if their personnel no longer require access to the Government NE due to termination of employment or for any reason.

To successfully complete this task, the contractor will be required to perform the following:

3.5.1 Subtask 5.1: CM/Repair Supplies

As described in Section 3.4.2 Subtask 4.2: Technical Support Team CM/Repair and Site Support Planning and Coordination of this PWS, the contractor may be authorized to procure supplies to assist in the resolution of faults discovered with an HFAM solution. In these circumstances, the contractor's Technical Support Team will be required to conduct market research, procurement planning, etc. on an FFP basis, but the actual supplies will be purchased (including their freight, insurance, etc.) on a T&M basis. The contractor will NOT include any additional costs (i.e. General and Administrative (G&A), profit, fee, etc.) to the procurement of CM/Repair supplies. For CM/Repair supplies that exceed a total cost of \$5,000.00, the contractor must ensure Government reviews are completed prior to procurement. This includes ensuring CM/Repair supplies are either sourced directly from the Government (i.e. obtained on a National Stock Number (NSN) basis) or multiple quotes (preferably 3 or more) are obtained from different sources of supply to support cost reasonableness. After CM/Repair supplies are procured by the contractor, they will be shipped to the specific HFAM site identified in the SNOW case. The contractor will be responsible for all CM/Repair supplies until they are successfully utilized (i.e. freight, insurance, tracking, monitoring, delivery, and expenditure / installation confirmation). The contractor will bear exclusive responsibility for all CM/Repair supplies that are unaccounted for, lost in transit, or lack written evidentiary matter confirming their use. All CM/Repair supplies procured must have accompanying receipts, invoices, etc. to support cost voucher submission for contractor reimbursement. Copies of these documents will be uploaded into each SNOW case and also submitted to the Government via cost reimbursement vouchers compliant with the requirements described in this PWS.

3.5.2 Subtask 5.2: CM/Repair Services

Contractor performance of CM/Repair services will require their personnel to possess the capability of traveling worldwide to the various DFSPs (i.e. performance of the work requires physical presence and CM/Repair services cannot be done remotely). All contractor personnel

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

performing CM/Repair services at the DFSPs will have an advanced level of technical knowledge in the operations of AFS and petroleum facilities/petroleum systems, including the physical hardware / equipment, communication protocols, testing and calibration, system of systems integration, etc. All contractor services rendered at the DFSPs will strictly observe all safety/security protocols and comply with applicable codes, criteria, and federal, state, local and/or host nation regulations. The contractor's CM/Repair services for the HFAM solutions will follow UFC 3-460-03, general inspection and maintenance criteria for military land-based liquid petroleum fuel facilities. These criteria are applicable to all branches of the DoD (including DLA). The contractor's CM/Repair services will require personnel experienced in repair, maintenance, and operation of federal petroleum facilities and petroleum systems to ensure compliance with codes, criteria, regulations, and laws of the United States/host nation (local and national). UFC 3-460-03 applies to all real property facilities used for storing, distributing, and dispensing fuels for reciprocating and jet engine aircraft, automotive fuels, lubricating oils, and diesel fuel. Some older fueling systems may not meet the current updated specifications and might not be required to be brought up to current standards as part of the CM/Repair services. In these situations, the contractor (in concert with their Technical Support Team) will investigate problem statements, identify solutions, and (when necessary) request Government review or approval on courses of action (COAs) available to resolve the HFAM deficiency. Any CM/Repair services requiring programming changes will meet the latest standard design of United States Army Corps of Engineers (USACE) 078-24-28 and USACE 078-24-29 unless deviation is authorized by the Government. The contractor's CM/Repair services will be required to also support specific HFAM sites with IAS attached to the hydrant system operating tanks. Contractor CM/Repair services at sites with IAS will include validation of the level alarms function as intended and fully interface with the SCADA, ICS, PLCs, and any other applicable AFS components on-site.

The contractor's CM/Repair services will be expected to include on-site activities such as response, investigation, inspection, troubleshooting, analysis, diagnosis, supply procurement / logistical support, testing, verification, validation, resolution, and restoration of operational availability of the HFAM solution identified in the SNOW case. For example, the contractor may need to provide CM/Repair services by traveling to a specific DFSP to locate causes of faults, order and replace defective components, make necessary adjustments, complete testing / verification, and restore HFAM solution operational availability. The contractor's CM/Repair services needs to include the capability of drafting or revising applicable documentation and drawings/schematics as applicable based upon the CM/Repair services rendered. All contractor's CM/Repair services will be conducted compliant with the Government's SOPs outlined in Appendix A – Guidance/Reference Documents. See Attachment 1 - List of HFAM Sites and Systems for the complete list of possible locations where the contractor's CM/Repair

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

requirements could originate from.

The contractor's personnel will be expected to initiate CM/Repair services within 24 hours of arrival at the specific site location. While on site at the DoD fuel facility/DFSP, the contractor will be expected to perform all applicable CM/Repair services for the HFAM solution based upon the dynamic requirements identified in the SNOW case. The contractor will ensure seamless coordination between personnel performing CM/Repair services and the Technical Support Team to update SNOW cases in near real time. This includes (but is not limited to) the on-going efforts to investigating, inspecting, troubleshooting, analyzing, diagnosing, resolving, testing, verifying, validating, and restoring the HFAM solution. The contractor's CM/Repair services will also include equipment, supplies, and materials necessary to restore the specific HFAM solution to its operational state as quickly as possible by minimizing downtime, production losses, and Government costs. Issues discovered on site by contractor personnel that clearly fall outside the scope of CM/Repair services will be logged the SNOW case as appropriate and escalated to the Government for action. The contractor's CM/Repair services will be performed complaint to the Government's SOPs outlined in Appendix A – Guidance/Reference Documents.

While not all-inclusive, the Government anticipates the contractor will need to successfully complete the following to render CM/Repair services:

3.5.2.1 CM/Repair SNOW Case Prioritization and Timetables / Timeliness

The contractor's CM/Repair services will be rendered in a prioritized manner utilizing the same SNOW case prioritization requirements as their Technical Support Team described in this PWS. All timetables for the successful performance of the contractor's CM/Repair services will be based upon the SNOW case prioritization. The contractor will not reprioritize assigned SNOW cases without Government approval. A detailed description of the performance standards for the contractor's CM/Repair services with timetables / timeliness based upon SNOW case prioritization is identified in Section 7.2 – Performance Standards of this PWS.

3.5.2.1.1 CM/Repair SNOW Case Reprioritization

As work progresses and CM/Repair services are rendered, the contractor must anticipate some assigned SNOW cases will require reprioritization. Due to the dynamics associated with customer service and the unpredictability of problem statements, the Government reserves the unilateral right to reprioritize SNOW cases at any time and for any reason. In situations of reprioritization, the Government COR will identify the applicable SNOW case(s) and

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

coordinate with the contractor to log re-prioritization of the SNOW case within the ITSM solution as appropriate.

In situations where a SNOW case is re-prioritized, the timeliness metrics associated with the SNOW case will reset to a new performance standard. The reset of performance standards associated with timeliness will be based upon the re-prioritization date documented within each SNOW case. A graphic depicting this process is as follows:



Figure 6 – Example of SNOW Case Re-Prioritization Performance Standards Change

3.5.2.2 CM/Repair Travel

Upon completion of CM/Repair services planning and coordination by the contractor's Technical Support Team as described in this PWS, the contractor will receive authorization to execute CM/Repair services. Authorization to execute CM/Repair services will be the formal approval for the contractor's personnel to the HFAM site identified in the SNOW case and perform work.

The contractor WILL NOT authorize their personnel to travel to the DoD fuel facility/DFSP for CM/Repair services without completing the requirements for CM/Repair Services Planning and Coordination as described in this PWS. If the contractor fails to perform and document within the SNOW case sufficient planning or coordination for CM/Repair services, the Government may determine the costs associated with the contractor's CM/Repair services are un-allowable compliant with FAR 31.202-2(a)(4). For example, if the contractor did not adequately coordinate with the HFAM site and post-travel the Government discovers CM/Repair services cannot be successfully performed (such as the contractor technician cannot access the HFAM solution), the Government may determine the CM/Repair labor hours and travel is unallowable for failure to meet the contractual requirements.

When traveling, the contractor must utilize the most reasonable means of transportation to arrive quickly and efficiently at the destination. Depending on travel destination, the contractor should plan to arrive as expeditiously as possible with an absolute maximum arrival at the DFSP no

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

more than 48 hours from the initial departure. All contractor CM/Repair services travel must comply with the DoD Joint Travel Regulations (JTR). CM/Repair travel will not be authorized for a duration that is any longer than necessary to perform the work as documented in the SNOW case, based upon the dynamic requirements unique to each occurrence. Whenever CM/Repair services travel is required, the contractor will notify the HFAM site of their Estimated Time of Arrival (ETA) and provide updates as applicable. The contractor will ensure the ETA is logged and updated within the applicable SNOW case, including if the ETA changes.

3.5.2.2.1 CM/Repair Travel Extensions

The contractor will be expected to provide consistently accurate travel planning for CM/Repair services via their Technical Support Team as described in this PWS. However, the Government acknowledges CM/Repair services are intentionally reserved for problems that are dynamic and unpredictable. As such, if the contractor is unable to resolve or investigate and determine root cause of the SNOW case problem statement within the initial POAM timeframe for travel to the site, the contractor will promptly notify the Government and (if necessary) request travel extension authorization. All travel extension authorizations must identify the basis/reasoning with updated projections on labor hours, costs, etc. The Government will review the extension request and provide written authorization for all travel extensions beyond the contractor's initial projections. Depending upon the totality of circumstances, the Government may authorize an extension of CM/Repair services if the cost maximum threshold of \$50,000.00 or duration of 90 calendar days has not been exceeded. All extensions to CM/Repair travel will be authorized on a case-by-case basis. All travel extensions and authorizations will be logged and updated within the applicable SNOW case.

3.5.2.2.2 Emergency or High Priority CM/Repair Travel

In the event of a SNOW case assignment with "emergency" or "high" priority for CM/Repair services, the Government may pre-authorize expeditious travel to address the problem statement expeditiously (i.e. there is an immediate need for contractor technicians on-site and time is of the essence). In these situations, the contractor will coordinate with the Government for immediate CM/Repair service travel to resolve the critical fault and/or restore the mission capability / operational availability of the HFAM solution as soon as possible. Depending upon the totality of the circumstances surrounding the SNOW case, the Government may waive the requirements associated with CM/Repair planning and coordination as described in this PWS. These situations will be handled on a case-by-case basis between the COR and the contractor.

3.5.2.3 CM/Repair Information Gathering, Inspection, and Analysis

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

CM/Repair information gathering, inspection, and analysis will be performed to the maximum extent practicable by the contractor's Technical Support Team in a remote manner prior to travel and documented in the SNOW case. However, upon arrival at the DoD fuel facility/DFSP where the HFAM solution is deployed, the contractor will likely need to perform additional research to fully determine root cause(s) and problem statements. This additional information gathering, inspection, and analysis will be dynamic based upon the requirements of the site with the objective of answering key CM/Repair service questions such as "what are the problem(s) incurred?", "what are root cause(s) of these problems?", "what can be done to fix the HFAM solution in the most effective manner?", etc.

3.5.2.3.1 Generate Statements of Work (SOWs) for Site Support

Based upon the dynamic situations and unpredictability of CM/Repair services, the Government anticipates some of the problems or issues encountered by the contractor on-site will exceed the Government's thresholds for CM/Repair (i.e. resolution of the SNOW case is projected to have a total cost exceeding \$50,000.00 or duration to complete longer than 90 calendar days). In these situations, the Government will determine these types of CM/Repair services to be 'complex' and must be definitized into an individual TO complaint with Section 3.6 Task 6: Site Support of this PWS. To assist with definitizing the complex CM/Repair, the contractor will be expected to fully investigate the HFAM solution problem statement within the SNOW case, identify the root cause(s), document the applicable requirements (i.e. what must be done to resolve the problem statement and restore the HFAM solution to mission capability / operational availability), update the SNOW case cost / duration projections, and generate complete SOWs that can be utilized by the Government to issue a TO against the HFAM IDIQ contract. SOWs generated by the contractor will be reviewed by the Government for completeness and will not automatically become binding authorizations to perform site support services as described in this PWS without issuance of an individual TO.

3.5.2.4 Execution of CM/Repairs

Based upon the results of the information gathering, inspection, and analysis, the contractor will execute the CM/Repair of the HFAM solution. These services are expected to include all the necessary services, supplies, equipment, materials, etc. necessary to perform the CM/Repair of the HFAM solution unique to the situation on-site. The contractor will coordinate CM/Repairs with the specific DoD fuel facility/DFSP customer/user throughout the performance of work, including (but not limited to) the pre-positioning or shipment of supplies to the site. As work is performed on-site (especially if there are changes to travel requirements), the contractor will update the information within the SNOW case.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

While not all-inclusive, execution of CM/Repair services is anticipated to include:

- a. Type III - Hydrant fueling system is an automated constant pressure system that is controlled by PLCs. The system uses a piping design that makes fuel readily available to aircraft on a refueling loop and then routes the unused fuel back to the operating tanks. The fuel is supplied to aircraft from hydrant pits via a hydrant servicing vehicle
- b. Type IV - Hydrant fueling system is an on-demand automated system that is controlled by PLCs. The system is started manually by the operator then controlled automatically by the PLCs. The Type IV piping design uses a refueling loop to supply fuel to aircraft via a pantograph with flexible piping joints and then routes the unused fuel back to the operating tanks
- c. Type V - Type V fueling system is the same as the Type IV with the exception of the pantograph refueling points are located in hardened aircraft shelters
- d. HFAM Equipment: The contractor will perform CM/Repairs on HFAM Equipment and subsystems that varies at each site based upon the deployed solution such as:
 1. PLC/Control Panels
 2. PLC Inputs/Outputs
 3. PLC Logic
 4. Modems
 5. Comptrol Communication device and associated software
 6. Operator Interface (Chart Recorders, Graphic Displays, Operator Interface Devices) and associated software
 7. Power Supplies, surge suppressors, Uninterruptable Power Supply (UPS)
 8. Audible/Visual Alarms
 9. Flow Meters
 10. Flow Switches
 11. Flow Transmitters
 12. Pressure Transmitters
 13. Level Transmitters
 14. Valve Position Switches
 15. Motor Operated Valve (MOV) Controls (associated electronics and minor mechanical repairs only)
 16. Level Switches

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

17. Hydraulic Control Valves (associated electronics and minor mechanical repairs only)
18. Emergency Stop Stations (associated with the PLC system)

3.5.2.4.1 Notifications to the Government for CM/Repair Services

While not all inclusive, the contractor will immediately notify the COR/TPOC if there are any significant problems / issues encountered during the execution of CM/Repair services as well as:

- a. Significant Delays: If the contractor encounters severe impact towards completion of services, the contractor will need to provide sufficient justification to the Government for deferment/extension during the weekly updates and WAR described in this PWS. Significant delays can include (but are not limited to) issues encountered that impact work performance, incomplete activities requiring extensions, Government caused deferrals, etc. In situations where significant delays are expected or have already occurred, the contractor will summarize the situation with a full explanation of their logic, reasoning, and basis for extension of services. Once complete, this information will be provided to the Government for review and decision on the appropriate course of action via the weekly teleconference and WAR described in this PWS. The Government retains unilateral authority for decision on extensions / deferrals and authorizations to extend services will NOT be assumed by the contractor as automatic. All requests for extensions / deferrals of services will be reviewed by the Government and authorized on a case-by-case basis.
- b. Inadequate Personnel: If the Government discovers or the contractor determines unskilled or inadequate personnel are assigned to perform services, the contractor will be required to thoroughly document the circumstances surrounding why unacceptable personnel were utilized and provide a resolution strategy.
- c. Significant Increase in Duration / Total Cost: If the contractor discovers during work performance the duration or total costs to perform CM/Repair services will exceed greater than twenty percent (20%) of their initial projections, the contractor will summarize the basis for the increase, generate new projections within the applicable SNOW case, and notify the Government. This information will be reviewed and evaluated by the Government to determine if continuation of the CM/Repair services is appropriate. Government decisions to continue CM/Repair services with significant cost increases will be documented by the contractor within each SNOW case as applicable.
The contractor will NOT automatically presume authorization to continue CM/Repair services that exceed twenty percent (20%) of the initial projections

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

without Government written authorization to prevent cost overruns.

- d. Inability to Perform: If the contractor discovers they are unable to fully investigate the root cause(s) or resolve the problem(s) identified in the SNOW case for the specific HFAM solution for any reason, the contractor will summarize the situation with a full explanation of their logic, reasoning, basis, and provide recommendations to the Government on how to proceed.
- e. Unrelated to HFAM: The contractor will notify the Government when they are assigned SNOW cases that are non-related to the HFAM solution for CM/Repair services to prevent unnecessary costs. This is especially important when HFAM site personnel may think that a problem is related to CM/Repair services. These situations will be handled by the COR on a case-by-case basis and may result in a request for the contractor to assist in isolating an unrelated problem. For example, if during the performance of CM/Repair services it is discovered there is an actual fuel leak, the contractor's personnel may be asked to assist in isolating the location of the leak or reviewing archive tests, confirming the system calibration, and explaining the results of the findings.

3.5.3 Subtask 5.3: CM/Repair Documentation

As CM/Repair services are performed, the contractor will be required to generate evidentiary matter documenting services rendered and completion of work. This documentation will vary depending upon the problem statement contained within the SNOW case for the site-specific HFAM solution. All documentation generated from CM/Repair services will be submitted by the contractor into the applicable SNOW case and uploaded into a Government designated NE database for the HFAM program. The contractor will submit to the Government for inspection and acceptance all CM/Repair documentation within ten (10) business days of on-site service completion for each activity performed. The Government will perform a review of the documentation submitted compliant to the QASP. If the documentation is found to contain errors, they will be returned to the contractor for correction compliant to the QASP.

Most of the CM/Repair services documentation requirements and applicable data products/deliverables are described in Section 3.3. Task 3: Preventative Maintenance of this PWS and are not re-listed to prevent redundancy. However, the following are additional deliverables unique to CM/Repair services:

3.5.3.1 Deliverable: HFAM CM/Repair Trouble Call Out Briefing [CDRL A020]

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

The contractor will perform out briefs on-site for the HFAM solution with the supervisor or the Responsible Officer (RO) detailing what CM/Repair services were rendered, what equipment/supplies were provided, and confirming the problem(s) reported were fully resolved, partially resolved, or unresolved. The contractor will prepare a copy of the “Trouble Call/Out brief” Form 1.3 as provided in SENS-D-GEN-TEP-02 and review it with the supervisor or RO. The contractor will prepare a “Trouble Call/Out brief” form for every CM/Repair service visit performed to a HFAM site. After conducting the out brief, the contractor will obtain the supervisor’s or RO’s signature on the form. The contractor will leave a copy of the signed form with the supervisor or RO. The contractor will upload a copy of the completed “Trouble Call/Out brief” form to the SNOW case within the ITSM solution.

- a. **Schedule:** Within ten (10) business days of on-site service completion.
- b. **Content:** Per SENS-D-GEN-TEP-02 Form 1.3. Additional content may be required compliant to the Government’s SOPs outlined in Appendix A – Guidance/Reference Documents depending upon services rendered.
- c. **Format:** Electronic copies viewable using the latest version of Adobe PDF.

3.5.3.2 Deliverable: HFAM CM/Repair Test Inspection Procedures & Report [CDRL A021]

The contractor will complete the Test Inspection Procedures & Report from SENS-D-GEN-TEP-02 Section 1.3 for the CM/Repair services performed. The contractor will ensure copies of this documentation are retained within the SNOW case, the designated DLA asset database, and the site personnel.

- a. **Schedule:** Within ten (10) business days of on-site service completion.
- b. **Content:** Per SENS-D-GEN-TEP-02 Section 1.3. Additional content may be required compliant to the Government’s SOPs outlined in Appendix A – Guidance/Reference Documents depending upon services rendered.
- c. **Format:** Electronic copies viewable using the latest version of Adobe PDF.

3.5.3.3 Deliverable: HFAM Site Support Statement of Work (SOW) [CDRL A022]

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

To assist with definitizing the complex CM/Repair work into Site Support projects, the contractor will be expected to generate SOWs for CM/Repair services that are projected to exceed the Government's thresholds (i.e. resolution of the SNOW case is projected to have a total cost exceeding \$50,000.00 or duration to complete longer than 90 calendar days). To assist with definitizing the complex CM/Repair, the contractor will be expected to fully investigate the HFAM solution problem statement within the SNOW case, identify the root cause(s), document applicable requirements, update the SNOW case cost / duration projections, and generate complete SOWs that can be utilized by the Government to issue a Task Order (TO) against the HFAM IDIQ contract.

- a. **Schedule:** Within ten (10) business days of on-site service completion.
- b. **Content:** A complete outline of all supplies, services, activities, deliverables, requirements, and timelines for a specific CM/Repair service to be performed as an individual Task Order (TO) Site Support project issued against the HFAM IDIQ contract.
- c. **Format:** Electronic copies viewable using the latest version of Adobe PDF.

3.6 Task 6: Site Support

All site support supplies and services rendered to complete this task will be performed on a FFP basis. Contractor services rendered for this task will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

Site support projects are roughly defined as complex corrective maintenance, modifications, improvements, or modernization of existing Energy OT systems deployed at DSFPs. However, site support projects may also include increases in HFAM solution capability at an existing site as well as required work to bring newly constructed systems up to specifications for continuous maintenance support under the HFAM program. Some examples (while not all inclusive) of site support projects are:

- a. Definitizing complex HFAM solution CM/Repairs that are anticipated to exceed the Government's threshold of \$50,000.00 / greater than 90 calendar days to complete.
- b. Implementing HFAM solution upgrades that were determined by the Government to require a dedicated project for successful completion.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- c. Upgrading or replacing PLCs for deployed HFAM solutions.
- d. Expensive enhancements to HFAM automation on existing site infrastructure or integrating new HFAM site infrastructure that was installed by others.
- e. HFAM solution salvage/recovery in support of military construction operations.

All site support projects will be awarded as individual Task Orders (TOs). Each site support project TO will have unique requirements described on an individual basis with an established period of performance that may be different from the HFAM IDIQ contract period of performance. Deliverables for site support projects will be defined within each TO awarded. Site support services rendered by the contractor will be documented within each applicable SNOW case and be conducted compliant with the Government's SOPs outlined in Appendix A – Guidance/Reference Documents. Successful execution of site support services will require the contractor to seamlessly coordinate and collaborate with their Technical Support Team as described in this PWS. The contractor performance of site support project TOs will be compliant with Section 7.2 – Performance Standards of this PWS.

3.6.1 Complex CM/Repairs

Based upon the dynamic requirements and unpredictability of CM/Repair described in this PWS, the Government anticipates it is highly likely some of the problems or issues encountered will be highly complicated or take significant amounts of time and cost to resolve and exceed the Government's thresholds for CM/Repair services. In these situations, the Government will determine these types of CM/Repairs to be 'complex'. Complex CM/Repairs will often include tasks, subtasks, work packages, activities, etc. that are long in duration (i.e. may take longer timeframes to complete due to their difficulty, excessive procurement lead times for supplies, etc.), requiring the Government and contractor to definitize them via an individual TO for site support services to ensure work completion in the timeliest and most cost-effective manner. For example, if the contractor initiates a SNOW case problem statement investigation for a CM/Repairs and discovers resolution of the issue has a projected total cost exceeding \$50,000.00 or duration to complete longer than 90 calendar days, the Government will request the contractor to generate a SOW so the CM/Repair work can be converted into site support services by awarding an individual TO.

3.6.2 PLC Upgrades/Replacements

Another type of site support project the Government anticipates is highly likely to be needed

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

during the execution of this contract are PLC upgrades/replacements. PLC upgrades/replacements are defined as a type of complex maintenance support service to replace or enhance one (1) or more PLCs at a HFAM solution to improve machine reliability, uptime, and productivity. PLC upgrades/replacement typically target antiquated hydrant equipment to ensure future HFAM solution sustainability and operational capability. These types of support services are almost certain to require the contractor to complete tasks, subtasks, work packages, activities, etc. that, when combined, are extremely long in duration. PLC upgrades/replacements will also require the contractor to procure supplies that have excessive lead times. While not inclusive, typical requirements for site support projects for PLC upgrades/replacements may include:

- Provisioning of an upgraded PLC system and associated equipment
- Integration with the existing pump control panel
- System installation and testing
- Electrical work
- Software installation and configuration
- Interfacing with existing systems
- Operational control requirements for PLC equipment.
- Training on-site HFAM personnel
- Delivery of specific documentation / deliverables unique to PLC upgrades

3.7 Task 7: Cybersecurity Support

All cybersecurity support services rendered to complete this task will be performed on a FFP basis. Contractor services rendered for this task will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

Recognizing the evolving nature of cybersecurity threats and the potential for future regulatory changes for the HFAM program, the Government may require the contractor to provide cybersecurity support services that are unique to the HFAM program. Typical cybersecurity support services would be related to ensuring HFAM program compliance with the following key cybersecurity related publications:

- [DOD Instruction \(DoDI\) 8510.01 Risk Management Framework \(RMF\) for DOD Systems](#)
- [DOD Manual \(DoDM\) 8140.03 Cyberspace Workforce Qualification and Management Program](#)

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- [The National Institute of Standards and Technology \(NIST\) Special Publication \(SP\) 800-82 Guide to Operational Technology \(OT\)](#),
- [NIST SP 800-53 Security and Privacy Controls for Information Systems and Organizations](#)
- [NIST SP 800-160 Engineering Trustworthy Secure Systems](#)

For example, the contractor may be requested to participate and support the Government's execution of the process defined within DoDI 8501.01 – RMF for DOD systems such as system categorization, selection of security controls, implementation of security controls, system authorization, and monitoring for cybersecurity compliance. Cybersecurity services could include assisting with scanning of the HFAM solution for cybersecurity vulnerabilities, implementing Security Technical Information Guides (STIGs)/Security Requirements Guides (SRGs), generating cybersecurity documentation, etc. However, the Government's specific cybersecurity requirements are currently unknown and cannot be fully definitized but must be accounted for as potential in-scope services. As such, HFAM program requests for cybersecurity support services that fall outside general system configuration and functionality data will be awarded as individual TOs.

All TOs awarded for cybersecurity support services will have the unique Government requirements described within their PWS with an established period of performance that may be different from the contract period of performance. The required deliverables for cybersecurity support services will be defined within each TO awarded. Rendering of cybersecurity support will require the contractor to fully document services within SNOW cases utilizing the Government ITSM solution and be conducted compliant with the Government's SOPs outlined in Appendix A – Guidance/Reference Documents. Successful execution of cybersecurity support services will require the contractor to seamlessly coordinate and collaborate with their Technical Support Team as described in this PWS.

3.8 Task 8: Commercial Software Licensing

All commercial software licensing supplies and services rendered to complete this task will be performed on a FFP basis. Contractor services rendered for this task will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

The HFAM program currently utilizes the following known commercial software to conduct technical support for the deployed HFAM solutions and their components (such as PLCs):

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- General Electric (GE) Proficy Machine Edition (ME) software
- GE MaxOn Redundancy software
- Cimplicity software
- Wonderware HMI software

Use of these commercial software products is essential to the overall capability for conducting sustainment, support, maintenance, modification, and repair of the HFAM solutions deployed worldwide. As such, the Contractor may be required to acquire and provide supplies in the form of additional and/or replacement commercial software licensing (i.e. assignable “permitted licenses”) to successfully render the services described in this PWS. All requests to acquire and provide commercial software licensing will be awarded as individual TOs under this IDIQ with the unique requirements and deliverables such as End User License Agreements (EULAs) that outline the use authorizations and accompanying data rights described within their PWS.

Upon completion of commercial software licensing purchase by the Contractor under an individual TO, the Government will re-issue the commercial software permitted licenses to the Contractor as Government Furnished Property (GP)/Government Furnished Material (GFM) to maintain the existing HFAM solutions. When required, the Contractor will utilize these software licenses compliant with applicable EULAs to render services throughout the duration of the contract performance. The Government will retain decisional authority for the use of the commercial software and permitted licenses procured under this IDIQ compliant to end user licensing rights including the physical or virtual machine(s) for installation regardless of their location and ownership (i.e. Government or contractor CE). Any modifications made to the commercial software paid for by the Government will be for sole use by the Government and may not be redistributed or otherwise re-sold by the Contractor. The Contractor will immediately notify the COR/TPOC if there are any problems or issues encountered with using, installing, maintaining validity of the commercial software licenses acquired for supporting the HFAM solutions.

3.9 Task 9: Transition Out

Due to the Government’s objectives for this procurement, it is possible the requirements for the services described in this PWS will continue to exist after the performance period of this contract. As such, if the follow-on contract awardee is NOT the same entity awarded for the services described in this PWS, the Government may require transition-out services. All transition-in services rendered to complete this task will be performed on a Firm-Fixed-Price (FFP) basis.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Contractor services rendered for this task will be documented within the MSR deliverable as described within this PWS. The Government COR will perform evaluation and formal inspection and acceptance of the contractor's services IAW the QASP.

To reduce the risks associated with follow-on contract performance, including decrements to productivity and/or possible negative impacts on additional services, the contractor will provide the necessary planning and services to support a 90-calendar day transitional period at the end of contract performance. The contractor will develop a Transition-Out Plan within 120 calendar days of contract start date and assist DLA in planning, preparing, and implementing any transition or change services. The contractor's Transition-Out Plan will not be a formal deliverable to the Government, but must consider economies of scale, complexity of services rendered, roles / responsibilities for key personnel, reporting requirements, operational tempo / mission performance, etc. and be ready for execution significantly in advance of the end of contract performance.

During the transition-out period, the contractor will be expected to participate in knowledge (tacit and explicit) transfer for their services rendered by working alongside existing third-party contractors. The transition-out period may require the contractor to generate documentation / artifacts to support this knowledge transfer that cannot be identified in advance (such as job aids, checklists, etc.). Throughout the transition-out period, the contractor will work with third-party contractors and assist in transferring all services rendered as well as ServiceNow (SNOW) cases. However, work will continue to be performed by the contractor during the transition-out period as described in this contract until confirmation is obtained by the Government that all key personnel responsibilities, services, and SNOW cases have been successfully transferred to the new contractor. During the transition-out period, the contractor's personnel will be expected to work with third-party contractors to transfer familiarity of tools, processes, and organizational assets. The contractor will promptly notify the COR in writing of any problems/issues preventing their ability to transfer responsibilities for key personnel, services, and SNOW cases as the transition-out period progresses. It is essential the contractor's key personnel provide transition-out services associated with the consolidation or divestiture of DoD and/or DLA workload to ensure uninterrupted operations.

The target date for the contractor's transfer of the responsibilities for key personnel, services, and SNOW cases as described in this PWS is no later than (NLT) 30 calendar days prior to the end of the transition period. This will allow the Government adequate time to address any transition problems/issues between the contractor and any third-party contractors before the end of the transition period. No later than fifteen (15) calendar days before the end of the transition period, the COR will meet with the contractor to ensure all concerns and issues have been addressed. At

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

the contractor's meeting with the COR, the contractor will submit a Transition-Out Report to support Government oversight. The Transition-Out Report will be utilized by the Government to confirm the contractor has formally transferred the responsibilities for key personnel, services, and SNOW cases to third party contractors. The contractor will be expected to have fully transferred responsibility for key personnel and successful performance of all work described throughout this PWS at the end of the 90-calendar day transition-out period.

3.9.1 Deliverable: Transition-Out Report [CDRL A023]

- a. **Schedule:** NLT fifteen (15) calendar days before the end of the transition period.
- b. **Content:** At a minimum, the data product will include:
 - 1. Parts Statuses for HFAM solution sustainment based upon region (i.e. CONUS, Pacific, Europe, etc.).
 - 2. Open/Active Preventative Maintenance (PM), Corrective Maintenance (CM), and site support SNOW cases including the following information (for each case):
 - i. SNOW case #.
 - ii. SNOW case priority.
 - iii. Assigned technician / contractor personnel.
 - iv. Summary Description of work.
 - v. Status on work progress.
 - vi. Region of PM work (i.e. CONUS, Pacific, Europe, etc.).
 - vii. Site/Location of work.
 - viii. Latest version(s) of Plan of Actions & Milestones (POAMs) for work completion.
 - ix. Any POAM extensions/deferments requested with basis of logic/reasoning for Government review and approval.
 - 3. Confirmation all existing services to perform PM, CM, and site support activities have been transitioned from the previous contractor and identification of any outstanding questions or concerns that are risks to successful performance.
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)

SECTION C-4: GENERAL PERFORMANCE REQUIREMENTS

4.0 General Performance Requirements

The following section outlines general contractual performance requirements for this PWS.

4.1 Period of Performance

The Period of Performance will be a twelve (12) month base period, and four (4) 12-month option periods to be exercised at the Government's discretion.

4.2 Place of Performance

The primary place of performance will be at the contractor's specified site and/or off-site. Contractor personnel may be required to periodically support meetings at HQ DLA (Fort Belvoir, VA) and/or other field locations based on project needs. The contractor's facility can be located anywhere, provided it does not impede the timely and effective completion of work. The contractor will establish real-time communication between its personnel and Government personnel once the contract is awarded.

The contractor is responsible for performing the services required under this contract at various locations specified in Attachment 1 - List of HFAM Sites and Systems. **The Government reserves the right to add, remove, update, or realign the HFAM sites identified as described in this PWS.** When there is a need for contractor performance on-site, utilities in the Government facility will be available for the contractor's use in performance of duties outlined in this PWS. In such situations the contractor must instruct employees in utilities conservation practices and will be responsible for operating under conditions that preclude the waste of utilities.

4.2.1 Government Duty Hours/Working Hours

In general, when working at DLA or other Government locations the contractor must work the Government Duty Hours of that location. The standard Government Duty Hours for the performance of this contract will be between 07:30 and 17:30 hours local time, Monday through Friday, exclusive of Federal holidays. However, contractor key personnel identified in this PWS must be regularly available during Eastern Standard Time (EST) to maximize coordination with the Government for oversight and coordination on performance. Contractor services may be required outside the Government Duty Hours on given days and/or weekends, depending on

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

operational needs and contingencies to complete the tasks described within this PWS.

4.2.2 Contractor Alternate Worksite Authorization

The Contractor will provide its own worksite throughout the duration of IDIQ execution. If there is a need for the contractor to change the location of its worksite, a contract authorization for an alternate worksite must be obtained from the KO. If authorization is given, the KO will state when the contractor can begin working at the alternate worksite and all existing contract performance outcomes / metrics, deliverables and contract terms or conditions will remain in effect. The contractor must have an approved Corporate Alternate Worksite plan on file with the KO and COR/TPOC prior to any work being performed at the contractor's alternate worksite.

Working at an alternate worksite will only be authorized if the KO can adequately determine that the following conditions exist for the contractor:

- a. **Organizational Need:** There must be a predefined need, in keeping with the organization's mission, for the contractor to work at an alternate worksite. For example, in case of inclement weather or Federal Government closure, contractor employees may be authorized to perform tasks under this contract from their alternate worksite.
- b. **Contractor Contingency of Operations Plan (COOP):** The contractor may be authorized to perform tasks under this contract/task order at a contractor alternate worksite, upon declaration of a COOP or Pandemic situation by the Government.

The Government is not responsible for any costs associated with meeting the above requirements.

4.2.3 Contractor Worksite/Remote Access Requirements

The contractor will ensure all contractor Furnished Equipment (CFE) provided for work performance by their personnel off-site (i.e. computers, hardware, software, etc.) that requires remote access to the Government's networks, systems, applications, and databases meet the minimal configuration requirements set forth in the DLA Virtual Desktop Guide. The guide can be obtained via the following URL:

<https://dla.dod.afpims.mil/Portals/104/Documents/RemoteVDI/VDIVirtualDesktopUserGuideFebruary2024.pdf?ver=zHGDFBFySm1orMscyGX5yA%3d%3d>

All CFE is strictly prohibited from connecting to the DLA Virtual Private Network. The Government is not responsible for any costs associated with providing, maintaining, or meeting

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

contractor requirements associated with CFE. Computer equipment, to include network hardware, computers (desktop, laptop, and server), CAC readers, printers, and software intended for use in a contractor facility will be furnished by the contractor at no additional cost to the Government. The contractor will provide all utilities used in the performance of duties outlined in this PWS for personnel located in contractor facilities.

All liability for issues and troubleshooting CFE is the responsibility of the equipment owner. The Government will not provide support for issues with hardware/software not provided by DLA, including but not limited to CFE hardware, non-DLA networks (e.g., home routers, public hot spots), and non-DLA software compatibility issues with Citrix. However, the Government's DISA Global Service Desk will support troubleshooting issues that are not related to the CFE, including but not limited to accounts, DLA applications, and server-side issues. Contact 844-DISA-HLP (844-347-2457) for remote assistance.

a. It's recommended that the CFE minimally install:

1. Windows 7, Windows 8/8.1, Windows 10, or Windows 11 Operating Systems
2. Applicable Security Technical Implementation Guides (STIGs)/checklists for operating systems.
3. Anti-virus, Anti-Spyware, and Host Based Intrusion Prevention software that is updated daily (i.e. software revisions, virus definitions). The Host Based Intrusion Prevention Software firewall should be configured to permit traffic by exception only, and dropping all other traffic.
4. Vulnerability scanning (at a minimum of every 15 days) with remediation of vulnerability findings.
5. Government approved CAC readers and middleware.

The Government is not responsible for any costs associated with meeting the above requirements.

4.3 Federal Holidays

The DoD recognizes the following Federal holidays, which are applicable to the local DLA Government workforce:

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

OBSERVED FEDERAL HOLIDAYS	
New Year's Day	Labor Day
Birthday of Martin Luther King Jr.	Columbus Day
Washington's Birthday	Veterans Day
Memorial Day	Thanksgiving Day
Juneteenth National Independence Day	Christmas Day
Independence Day	

4.4 Travel Requirements

The Contractor will be required by the Government to perform travel in performance of the resulting contract. The Contractor must plan for requirements necessitating travel to CONUS and OCONUS locations to support the HFAM solutions deployed worldwide for PM, CM, and site support services as described in this PWS. A complete list of the locations where the HFAM solutions exist is included in Attachment 1 List of HFAM Sites and Systems. When pre-authorizations / country clearance is required, travel reviews and approvals will be performed by the COR. Selection for contractor travel assignments will be based on PWS necessity and qualifications of the individual to best perform the service required. All contractor travel must be conducted compliant with the DoD Joint Travel Regulations and utilize the most cost and geographically advantageous resources for services rendered.

4.4.1 Preventative Maintenance (PM) & Site Support Travel

All contractor travel for PM and site support services as described in this PWS will be conducted on a FFP basis at no additional cost to the Government.

4.4.2 Corrective Maintenance (CM) / Repair Travel

All contractor travel for CM/Repair services described in this PWS will be conducted on a Time and Materials (T&M) basis. Travel reimbursement for CM/Repair services will be IAW the FAR 31.205-46. When traveling, the Contractor must utilize the most reasonable means of ground transportation (i.e. taxi, bus, car rental) to arrive quickly and efficiently to the destination. Depending on travel destination, the Contractor should plan to arrive as expeditiously as possible with an absolute maximum of no more than 48 hours from initial departure. **Contractor travel for CM/Repair services must be documented within the applicable SNOW case prior initiation. Travel for CM/Repair services with an initial projected total duration exceeding 14 calendar days or a total cost greater than \$5,000.00 must be pre-approved by the COR. Failure to obtain Government pre-approval prior to travel for CM/Repair services may result in non-reimbursement.**

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

To obtain approval, the Contractor must generate travel information within the applicable SNOW case which will be reviewed and authorized by the COR. Following COR travel approval, the Contractor will conduct final travel bookings. All travel related expenses (per diem, airfare, transportation etc.) will be reimbursed to the Contractor IAW FAR 31.205-46. Upon completion of travel, the Contractor is required to submit supporting documentation. This supporting documentation needs to contain receipts and information for the reimbursable costs associated with each trip. Contact the COR for additional details regarding required data elements to meet this requirement. All travel documentation must be submitted to the Government no later than (NLT) ten (10) business days following completion of travel. A culmination of all travel completed for CM/Repair services will be generated by the Contractor and submitted with the Monthly Status Report (MSR) identified within this PWS to support cost reimbursement. This culmination of information must contain monthly copies of expense reports, receipts, and supporting documentation within the MSR. See Section 4.12 of this PWS for details on invoicing, vouchers, and payment.

4.4.3 OCONUS Immunization Requirements

The contractor will be required to travel to locations OCONUS. Contractor employees who deploy to locations that require immunizations will do so IAW DoDI 6205.4, DoD, Instructions, Immunizations of Other Than U.S. Forces (OTUSF) for Biological Warfare Defense.

4.4.4 Letter of Authorization

Some travel will require a Letter of Authorization (LOA) to comply with Status of Forces Agreements (SOFAs) or other military requirements. An LOA is necessary to enable a contractor employee to process through a deployment processing center; to travel to, from, and within a theater of operations; and to identify any additional authorizations and privileges. When required for OCONUS travel, the contractor will initiate a LOA for each prospective traveler. The contractor will use the Synchronized Pre-deployment & Operational Tracker (SPOT) web-based system, at <https://spot.dmdc.mil/default.aspx>, to enter and maintain data with respect to traveling/deployed personnel, and to generate LOAs. When necessary and if in the Government's interest, the contractor may also initiate a LOA request to provide an official traveler access to Government facilities and to take advantage of travel discount rates IAW Government contracts and/or agreements. All privileges, services, and travel rate discount access are subject to availability and vendor acceptance. LOAs will be signed/approved by the Government whenever they are required.

Commented [P(3): Fix white space

4.5 Government Property (GP), Government Furnished Equipment (GFE), Government Furnished Material (GFM), and Government Furnished Information (GFI)

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Authorization for contractor use of GP, GFE, GFM, and/or GFI at the sole discretion of the Government. The Government will **NOT** automatically provide GP, GFE, and/or GFM to all contractor personnel working under this contract. When necessary, the Government may provide GP, GFE, and GFM such as Common Access Cards (CAC), Smart Card tokens, computers, mobile devices, or software to specific identified contractor personnel who require access to the Government network in the performance of the work efforts described within this PWS. For example, contractor personnel continuously traveling to perform field/site services at Government facilities or requiring privileged access compliant with DoDM 8570.01/DoDD 8140.01 are expected to require issuance of GP, GFE, and/or GFM. However, contractor personnel who do not require physical access to Government facilities and/or do not require privileged access will be expected to use Contractor Furnished Equipment (CFE) for all off-site work performed. Contractor personnel leveraging CFE will be expected to access the Government network by using DLA's Remote Access System (VDI). Contractors accessing the Government network remotely should go to <https://dla.dod.afpims.mil/Remote-VDI/> for access. See contractor Worksite/Remote Access Requirements within this PWS for additional details.

All GFE computers must be scanned by the contractor with the appropriate DLA vulnerability scanner (or current approved DoD scanner solution) at a minimum of every 30 days. All vulnerabilities must be remediated and reported to the cognizant IAM.

4.5.1 Government Furnished Property (GFP)

As defined in Federal Acquisition Regulation (FAR) Part 45.102, GFP is property in the possession of, or directly acquired by the Government, and subsequently furnished to the contractor for performance of a contract. GFP includes, but not limited to, spares and property furnished for repair, maintenance, overhaul, or modification. GFP includes Government-Furnished Equipment (GFE) and Government-Furnished Material (GFM)). The contractor will be responsible for safeguarding all Government property provided for contractor use. At the time of PWS creation, the Government does not anticipate the contractor will require any GFP for successful contract performance. All materials needed to meet the requirements of the PWS will be determined, acquired and owned by the contractor. No space, storage or facility will be provided at any HFAM site during the performance of this contract.

4.5.2 Government Furnished Information (GFI)

GFI is Government owned intellectual property provided to contractors for performance on a contract. For the purposes of this contract, GFI includes manuals, technical specifications, maps, building designs, schedules, drawings, test data, etc that the Government will provide the

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

contractor access to achieve the objectives described in this PWS. Depending on the information contained in a document, the contractor may be required to comply with additional controls (e.g., completion of a Non-Disclosure Agreements, etc.) for access and distribution IAW a ‘need to know’ and the DoDM 5200.01 Volume 4 (DoD Information Security Program: Controlled Unclassified Information (CUI)). The Contractor will ensure appropriate data security protocols and procedures are in place to protect GFI and prevent its unauthorized disclosure and/or public release.

4.5.3 Issuance of GP, GFE, GFM, and GFI

The contractor will need to coordinate with the COR to obtain issuance for any GP, GFE, GFM, and GFI.

Contractor personnel travel required to pick up or drop off GP, GFE, GFM, and GFI including CACs, Smart Card tokens, mobile devices, phones, hardware, software, etc., will be accomplished at no additional cost to the Government and is not directly reimbursable under this contract. Title and data rights to all GP, GFE, GFM, and GFI will remain vested with the Government throughout the duration of this contract. The contractor must safeguard the custody of, maintain proper care for, and provided quantitative and physical control over all GP, GFE, GFM, and GFI. **All GP, GFE, GFM, and GFI provided to the contractor will be returned to the Government upon completion or termination of the contract.**

4.5.3.1 Deliverable: GP Report [CDRL A024]

If required, based upon issuance of GP, GFE, and GFM by the Government, the contractor must provide the Government with a GP Report within thirty (30) calendar days after contract award and by the fifth (5th) business day each month thereafter for the duration of the contract. The first Monthly GP Report will be a comprehensive document covering all previously issued GP, GFE, and/or GFM currently in the possession of the contractor (regardless of prime or subcontractor status). This includes (but is not limited to) all computers, mobile devices, software, etc. support the HFAM program. The contractor will then be required to report updates on a monthly basis thereafter (or report no changes). The contractor must submit the first GP Report to the within thirty (30) calendar days after contract award for inspection and acceptance.

Follow on GP Reports will be provided by the contractor by no later than (NLT) the fifth (5th) business day of each month for the duration of the contract. The follow-on reports must provide updated status on all data fields contained within the report and indicate any additions or removals of GP, GFE, and/or GFM from the contractor’s custody

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- a. **Schedule:** Submitted with MSR within thirty (30) calendar days after contract award and NLT the fifth (5th) business day of each month thereafter for the duration of contract performance.
- b. **Content:** At a minimum, the data product will include:
1. Contract #
 2. Company Name
 3. CAGE
 4. Custodian Last Name
 5. Custodian First Name
 6. Custodian Phone #
 7. Physical Location (City & State)
 8. Asset Description
 9. Asset Type (i.e. computer, mobile device, software, etc.)
 10. Asset ID #, Unique ID #, or Serial # (if applicable)
 11. Model Number (M/N) or Part Number (P/N) (if applicable)
 12. Quantity
 13. Condition
 14. Warranty Information (if applicable)
 15. Assigned COR
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

4.6 Data Rights

The contractor will observe all copyright agreements and will be held liable for any infringement of copyrighted software licensing agreements and will compensate the appropriate contractor for each instance of copyright violation. In the interest of protecting Government systems from computer viruses, the contractor will not use public domain software nor will contractor personnel download software from public bulletin boards. Unless otherwise noted, the contractor will only use Commercial Off the Shelf (COTS), contractor-developed or Government furnished software in performance of the contractual effort. If the contractor uses public domain software, code, or other data, or uses software, code or data from a public bulletin board, and such use results in damage (including but not limited to introduction of a computer virus or malicious software), the contractor will repair the damage, at no cost to the Government, in a timely manner as required by the delivery schedule. Further, such use will be considered a default under

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

the contract.

With the exception of existing commercial software End User License Agreements (EULAs) and copyrights, the Government will retain data ownership / rights for all data, data products, deliverables, information, etc. generated in the performance of this contract. This includes (but is not limited to) details of all security countermeasures the contractor may design or develop. All data, deliverables, documents, files, records, and schedules must be turned over to the Government upon termination or completion of the contract. All data, data products, deliverables, information, etc. generated under this contract will not be disclosed or released to the public without prior written consent from the Government. The Contractor will not allow access or disclosure of classified information, CUI, or information regarding the operations of DLA to any outside Government agency, non- Government agency, or individual unless specifically authorized. The contractor will not repackage, reutilize, or resell any of the data, data products, deliverables, information, etc. generated in the performance of this contract for financial gain. All documentation, records, and schedules generated by this contract are subject to 5 U.S.C. § 552 Freedom of Information Act and 5 U.S.C. § 552a Privacy Act of 1974. The contractor will ensure the accuracy and completeness of all deliverables IAW referenced DoD policy, regulations, laws, and directives. Errors, misleading statements, and/or incomplete information will be considered defects and will be subject to correction by the contractor at no additional cost to the Government.

The following clauses apply to data and software rights: DFARS 252.227-7013, 252.227-7014, 252.227- 7015. The Government will have software and data rights as described in the referenced clauses for all data and software developed under this contract.

Information given to the contractor during the life of this contract will only be used for the purpose of carrying out the provisions of this contract. Agency information marked “CUI” or bearing other sensitivity markings will be handled IAW Agency information security program regulations and will not be divulged or disclosed without Agency permission. Requests for disclosure will be addressed to the COR. All contractor (including prime and subcontractor) personnel performing work on this contract will be required to sign and adhere to the terms of the Government’s Non- Disclosure Agreements.

4.7 Contractor Furnished Equipment (CFE)

The Government anticipates the Contractor will need to provide the following CFE at no additional cost to the Government to meet the objectives of this contract:

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- a. The contractor will need to provide computer equipment, scanners, readers, and software applications to conduct technical support, monitor SNOW cases as well as diagnose, configure, and calibrate the components associated with the HFAM program. Some of this CFE will need to be portable so that it can be taken to a specific DoD fuels facility or DFSP to perform technical support, PM, CM, etc. on the HFAM solutions as described in this PWS.
- b. The contractor will need to provide wireless communication equipment to enable contractor personnel access to the contractor's network environment. The contractor will not use radio transmission or wireless devices on-site at DoD fuel facilities or DFSPs unless they are approved by the Government. CFE wireless communication equipment needs to provide coverage at all sites listed in Attachment 1 (List of HFAM Sites and Systems). The contractor's CFE wireless communication equipment must be rated as intrinsically safe and/or non-incendiary, if it is used in hazardous environments.
- c. The contractor will provide the capability of obtaining digital recordings / images to aid in the diagnosing and troubleshooting of the HFAM program. Contractor personnel onsite at the various DoD fuel facilities and DFSPs will be expected to use take digital recordings / images of HFAM equipment and transmit this data as deliverables compliant to the requirements described in this PWS. The contractor will coordinate with the local site POCs to ensure authorization has been obtained for all digital recordings / images, and will take adequate measures to protect them from unauthorized disclosure or public release.

4.8 Security Requirements

Security requirements described within this PWS apply to the prime contractor, any sub-contractors, third party agreements, and any temporary employees that may be hired by the contractor. The Government retains the right to request removal of contractor personnel whose actions, while assigned to this contract, are determined by the KO to conflict with the interests of the Government. If such removal occurs, the contractor will assign qualified personnel to fulfill any vacancy.

All contractor personnel accessing the Government's NE will observe local Automated Information Systems policies and procedures directed by the Information System Security Officer (ISSO). The contractor will notify the KO and the COR within 24 hours, when for reasons of personnel resignations, reassignments, terminations, or completion of portions of the contract, named contractor personnel no longer require access to the Government NEs.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Contractor personnel will be required to complete the Government's security background check documentation, Standard form 85P (National Agency Check (NAC)) and be fingerprinted to obtain a Common Access Card (CAC). Instructions on how to obtain a CAC be provided by the COR. The security background check documentation must be electronically submitted to the DES Personnel Security Office prior to the COR signing off on the Badge and ID Request Form (DLAH Form 1728), if applicable. A hard copy of the security background check documentation questionnaire must be attached to the Badge and ID Request Form, to include the employee's signature, prior to submitting the package to DES Personnel Security. The employee must receive a favorable background investigation. If the background investigation finding shows that the employee has a criminal or drug problem, DLA HQ CAAS (Command Security) will make the determination whether to allow employee access to the Headquarters Complex (HQC) or not. Once issued, the CAC Card must be always displayed while working at the HQC.

Contractor personnel will always conduct themselves in an acceptable business decorum. The contractor will remove any individual from the site or project whose continued presence or employment is deemed by the KO to be contrary to the public interest or inconsistent with the best interest of national security. Should the Government deny access to Government facilities for any of the contractor's personnel for security or personal conduct reasons, or request removal of contractor employees, such removal will not relieve the contractor of the requirements in this PWS.

4.8.1 Physical Security Requirements

The contractor will be responsible for safeguarding all Government property provided for contractor use. At the close of each work period, the Contractor will ensure all Government facilities, equipment, and materials are clean, maintained in an orderly fashion, and locked / protected from unnecessary hazard, damage, etc.

4.8.1.1 Government Facility Access

Prior to gaining access to any DLA facility, contractor personnel must be vetted through the local security office. Due to DoD security requirements, any individual who has an unlawful immigration status, outstanding warrants, or certain convictions not be permitted access to any DLA facility. Contractor personnel must ensure they have the appropriate identification required to access DLA facilities. Contractor personnel entering a DLA facility should anticipate their vehicle will undergo a security check by DLA Security, and should ensure that no drugs, alcohol, or weapons of any kind are found within the vehicle. It is the contractor's responsibility to ensure

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

the personnel performing under this contract can and will meet these requirements for accessing DLA facilities. Names of contractor personnel will be provided to the local POC for vetting purposes no less than one week prior to the scheduled work. If contractor is unable to obtain Security Requirements for any site, they can contact the COR/TPOC for assistance. While on-site at Government facilities, contractor personnel will be expected to continuously display CACs in a manner that is easily seen using physical devices such as ID card lanyards. These physical devices will be provided by the contractor at no additional cost to the Government.

4.8.1.2 Site Specific Security Requirements

When contractor personnel are at any Government site, installation, or facility, they will follow all security procedures and processes of the installation as stated and directed by the Government personnel at the site. For example, the contractor will ensure they control access by locking or unlocking the areas or facilities used by their personnel in the performance of work. The contractor will lock all internal overhead doors, cages, vaults, warehouse doors, windows, etc. before leaving an area unattended and prior to the conclusion of any working day. This includes locking up all external cargo and personnel doors when not in use.

Security requirements for work in foreign countries will be based on the requirements set by the combatant commander of the particular Area of Responsibility (AOR) in which the work will be performed. If contractor is unable to obtain the specific security requirements for any site, they should contact the COR/TPOC for assistance. The items that are covered will include but are not limited to transportation into and out of the operating area, required clothing and equipment, movements while onsite, specific employee training prior to entering the operating area, etc.

4.8.2 Authorized Visitor Control

Depending on the tasks to be completed, the contractor may be required to sponsor or escort subcontractors, suppliers, vendors, or other one-time or occasional visitors to Government sites in order to successfully perform the work described in this PWS. Visitors on official business related to the contract must obtain approval from the host installation law enforcement security office, or the COR prior to authorization for entrance to the Government site. The Contractor may be required to submit documentation such as DLA Form 1818 Visitor Request Form (or equivalent) to the COR in advance for all planned off-base visitors needing access. When authorized, the contractor will follow host installation specific security controls, Government policies and procedures for visitor identification, and maintain responsibility, accountability, and custody of all contractor sponsored visitors.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

The contractor will not allow visits from foreign nationals to any Government site without the written approval from the host installation law enforcement security office, or the COR. A foreign national is defined as a person who is not a citizen or national of the United States. If approval is obtained, the contractor must follow the instructions for coordinating the visit IAW DLA I 4303 Foreign Visits and Disclosure Program.

The contractor's procedures for authorized visitors to Government sites will include:

- a. Positive identification of all visitors by means of personal recognition, visitor security badge, visitor permit, or other identifying credentials. The contractor must contact the employee, supervisor, or officer in charge to ascertain the validity of the visit and submit documentation to the COR as necessary.
- b. Using DLA Form 584, Visitor Register or contractor equivalent form to provide a record of the identity of the visitor, the time and the duration of the visit, and other pertinent control data. The contractor may use an automated system instead of DLA Form 584 provided the system records, at a minimum, provide the same data included on DLA Form 584. The contractor will establish procedures for recovering any visitor security badges, visitor permits, or other identifying credentials at the completion of the visit.

4.8.3 Personnel Security Requirements

The contractor will ensure that personnel accessing the Government's NE and CE have the proper and current information assurance certification to perform functions IAW DoD 8570.01-M, Information Assurance Workforce Improvement Program. Contractor personnel supporting IA functions as described in Chapters 3, 4, 10, and 11 of DoDD 8570 will be appropriately certified prior to being engaged. Additional mandatory training on local or system procedures may be provided by DLA Information Operations. The TPOC will ensure that contractor personnel are appropriately certified and provide verification to the Defense Eligibility Enrollment System (DEERS) or other appropriate Defense Manpower Data Center (DMDC) database. <https://www.dmdc.osd.mil/>. All contractor personnel provided with access to Information Systems will observe local and host Automated Information Systems policies and procedures directed by the Information System Security Manager (ISSM) or Information System Security Officer (ISSO).

Contractor personnel who perform work on sensitive IT systems or applications will be required to obtain and maintain the appropriate investigation and adjudication or suitability determination commensurate with the information contained within the application or system. Sensitive

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

information access positions are designated based on access to government networks and IT systems. Note that sensitive information access does not imply or convey access to classified information. **There will be no access to classified information for any TO issued under this IDIQ.** The Government requires that all Contractor personnel assigned to this project will have attained a favorable outcome to the investigative requirement and be available to initiate work immediately upon award. The contractor will ensure all individuals assigned to the performance of work as described in this PWS possess the proper security clearance eligibility as required by DoDM 5200.02 – Procedures for the DoD Personnel Security Program (PSP).

For sensitive information access positions, the required investigation must be completed or interim access granted for individuals assigned to sensitive duties. The personnel security requirements described herein apply to the prime contractor and any subcontractors during the course of this contract. For Non-Key Personnel described in this PWS, in lieu of the correct investigations being completed when contract employees start the Government may authorize an interim waiver for personnel security clearance investigations on a case-by-case basis. This waiver interim clearance may be submitted if no issues exist within the e-QIP Questionnaire for Public Trust Positions or Questionnaire for National Security Positions. The contractor will have the e-QIP form filled out, with any other requirements (fingerprints taken and, if required, an OF306), and reviewed by DLA Intelligence before officially hiring any contractor employee into sensitive information access positions. Foreign Nationals are only eligible to perform non-sensitive duties and will not be authorized to perform non-critical sensitive or critical sensitive duties, nor will they be investigated by the Government for personnel security clearance eligibility.

The following table describes the Government’s investigation standards based upon the position sensitivity and assigned duties.

Tiered Investigation Standards					
Position	Low-Risk	Moderate Risk		High Risk	
		Confidential	Secret	Top Secret	SCI
Position Sensitivity	Non-Sensitive	Non-Critical Sensitive		Critical Sensitive	Special Sensitive
Investigation	Tier 1/NACI	Tier 3/NACLC/ANACI		Tier 5/SSBI	
Formerly Known As	IT-III or IT-3	IT-II or IT-2		IT-I or IT-1	

Table 3 – Personnel Security Tiered Investigation Standards

4.8.4 Controlled Unclassified information (CUI)

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

[DoDI 5200.48 – Controlled Unclassified Information \(CUI\)](#) provides instruction and direction for marking, protecting, and preventing unauthorized disclosure and/or public release of CUI. During contract execution, the contractor will be required to draft, revise, or finalize deliverables that contain CUI. The contractor will ensure compliance with DoDI 5200.48 by properly marking, safeguarding, and ensuring adequate security measures are undertaken to protect CUI from unauthorized disclosure and/or public release.

4.8.5 Classified Information

Contractor personnel will not require access to classified information to perform work on this contract. If marked classified information is encountered during the performance of this contract, the contractor will notify the Government security personnel immediately follow their instructions to prevent unauthorized disclosure or release, and notify the KO or COR classified information was encountered. The contractor will comply with all instructions and steps identified by Government security personnel to prevent unauthorized disclosure or release of classified information.

4.8.6 Information Security Requirements

Equipment and Fuel Systems associated with this contract are considered by the Government to be providing Operational Critical Support (OCS) as defined in Defense Federal Acquisition Regulation Supplement (DFARS) 252.204-7012 Safeguarding Covered Defense Information (CDI) and Cyber Incident Reporting. Information provided to the contractor and developed in support of this contract will be considered CDI as defined in DFARS 252.204-7012 Safeguarding CDI and Cyber Incident Reporting. The contractor will provide adequate security IAW FAR and DFARS requirements for all covered contractor information systems. Some of the work and deliverables generated under this contract will be marked as CUI when appropriate.

4.8.6.1 DODM 8570.01/DODD 8140.01 Information Assurance Workforce Improvement Program

The DODM 8570.01/DODD 8140.01, Information Assurance Workforce Improvement Program, requires training and certification for Information Assurance (IA) duties performed. All contract employees performing IA functions (i.e. regardless of whether the personnel are prime or subcontractor and key or non-key personnel) must meet the requirements IAW DOD/DLA guidance. Additionally, contractor employees performing System Administration (SYSADMIN) or other “privileged access” duties as described in this PWS must complete applicable personnel security clearance investigations and be certified in the specific operating systems for which these duties are performed. Proof of certification must be provided before privileged access is

Commented [P(5)]: Fix White space below

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

granted and (for key personnel) must be provided by the contractor at time of proposal submission (i.e. via key personnel resumes). For example, the requirements for DODM 8570.01/DODD 8140.01 and “privileged access” does include (but is not limited to) system administration access, network administration access, router/switch access, firewall access, Intrusion Detection System (IDS) access, Programmable Logic Controller (PLC) access, and Supervisory Control and Data Acquisition (SCADA) access. All documentation required for security certification will be maintained by the contractor with active reporting provided to the Government as described within this PWS. The certification requirements associated with are not based on position title; they are based on assigned duties. As such, the contractor will ensure that all personnel accessing information systems, including network or system components, either during provisioning or post award, have the proper and current information assurance certification to perform functions IAW the latest edition or successor publication of DoD 8570.01-M - Information Assurance Workforce Improvement Program and DoDD 8140.01 - Cyberspace Workforce Management.

Contractor personnel requiring IA certification must have their security and industry competency certifications compliant with DODM 8570.01/DODD 8140.01 prior to starting work and will be required to maintain these certifications so long as they are performing duties requiring “privileged access” throughout the life of the contract. If a certification becomes obsolete during the life of the contract, the contractor will be responsible for ensuring applicable personnel obtain a replacement certification that is acceptable to the Government prior to the continuation of work on the contract. The contractor will immediately inform the COR if a contractor personnel’s clearance is revoked or otherwise changed or called into question. Contractor employees must have personnel security clearance investigation that has been favorably adjudicated at the level appropriate for the required system access. As personnel are replaced or added during contract performance, the contractor will provide only those employees with an active security investigation that has been favorably adjudicated at the level appropriate for the required system access.

Contractor personnel who have not completed the proper personnel security clearance investigations or do not possess valid certifications will be denied access to DoD information systems for the purpose of performing information assurance functions as described in DoDM 8570.01. Newly hired contractor personnel may be authorized by the Government to shadow current personnel with a valid certification but must be authorized in writing by the COR on a case-by-case basis. However, all new contractor personnel will obtain their certification within 6 months from their official start date on the contract. A monthly status on certification qualification will be provided for all new hires and current employees whose certifications will expire in the next 6 months.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

All contractor personnel provided with access to Information Systems will observe local and host Automated Information Systems policies and procedures directed by the Information System Security Manager (ISSM) or Information System Security Officer (ISSO). All security ratings for this Performance Work Statement are Non-Critical Sensitive, ADP I or II.

The Government will provide additional information for the current list of DODM 8570.01/DODD 8140.01 Approved Baseline Certifications and Computing Environment Certifications upon written request.

Note: Additional mandatory training on local or system procedures may be required by DLA Information Operations prior to authorization of privileged access. If required, the Government provided training will be held virtually or in person at DLA Fort Belvoir, VA and coordinated as appropriate.

4.8.6.2 Privileged Access

For certain Key and Non-Key Personnel, obtaining privileged access to the Government network / computing environment may be required for successful contractor performance to complete the work described in this PWS. In this context, “privileged access” is defined in accordance with DoDM 8570.01-M, Appendix 1, AP1.22 as an authorized user who access to the system/subsystem with the capability of control, monitoring, and/or administration functions. These authorized users include (but are not limited to) system administrators, database administrators, etc. This definition includes (but is not limited to) an authorized user who:

- Has access to configure and/or update the control functions of the information system beyond a normal user level (IE: software/firmware configuration, administration of user accounts, etc)
- Has access to change the control parameters (IE: routing tables, path priorities, addresses) of key information system equipment or software.
- Has the ability and authority to control and change program files and other users’ access to data.
- Has direct access to operating system level functions (also called unmediated access) that would permit system controls to be bypassed or changed.
- Has access and authority for installing, configuring, monitoring, or troubleshooting the security monitoring functions of information systems.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Contractor personnel requiring “privileged” access must possess appropriate cybersecurity certifications in line with DoD 8570.01/8140.01 standards, relevant to their roles. Personnel with “privileged access” must adhere to least-privilege principles, receiving elevated permissions only as needed for their job functions, and access reviews must be conducted quarterly. The contractor will implement a continuous training program to ensure all personnel are aware cybersecurity threats, policies, and procedures. Additionally, personnel must complete annual training on secure handling of CUI and case reporting protocols. The contractor will maintain an Access Control List (ACL) and track this information on a regular basis to maintain accountability for their personnel. While the ACL is not a formal deliverable, the Government may request to review this document at any time to verify access rights are current and appropriate based on role requirements.

Commented [P(6)]: Updated to state 8570/8140

All contractor personnel requiring elevated/privileged access to any network or system components will complete either a Tier 3/NACLC/ANACI or Tier 5/SSBI investigation and meet DoD 8570.01-M IA Technical (IAT) II baseline and computing environment certifications. The contractor will provide a copy of all current certifications to the KO and COR at time of award and the contractor will ensure assigned personnel performing duties requiring elevated/privileged access remain in good standing during the contract period of performance. The contractor will immediately inform the COR of any contractor personnel whose security clearance is revoked or otherwise changed or called into question.

4.8.7 Contact of a Suspicious Nature

Contractor personnel who have been contacted under suspicious circumstances must report that contact immediately, either verbally or in writing, to their supervisor who must report it within two (2) hours to the KO and COR. For reporting purposes, examples of suspicious contact includes (but is not limited to):

- a. Contact with an individual (regardless of nationality) that suggests to the contractor employee that an intelligence gathering or terrorist organization may have targeted him or her for possible intelligence exploitation.
- b. A request by anyone (regardless of nationality) for illegal or unauthorized access to classified or unclassified sensitive information.
- c. Contact with a known or suspected intelligence officer from any country.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- d. Contact with a foreign diplomatic establishment, whether in the U.S. or abroad, for personal or official reasons. Certain contractor personnel in positions designated as “sensitive” by the Government may also be required to inform their chain of command in advance of the nature and reason for contacting a foreign diplomatic establishment or travel to countries on the State Department list whose interests may be adverse to the United States.

Additionally, contractor personnel who have information about activities pertaining to espionage, terrorism, unauthorized technology transfer, sabotage, sedition, subversion, spying, treason, unauthorized release of classified or unclassified controlled information, or unauthorized intrusions into automated information systems will report that information to the KO and COR.

4.9 Common Access Cards (CACs)

All contractor personnel (including subcontractor personnel), requiring access to Government NE, CE or facilities will be required to obtain a CAC. The Government will verify proof of the appropriate investigative requirement/background check through the Joint Personnel Adjudication System (JPAS). When proof of a background check cannot be verified, the DLA Headquarters security personnel will obtain the appropriate background check for the contractor employee. Contact the COR or KO for additional information on obtaining CACs. All CACs must be returned to the Government prior to completion of the Transition-Out services described in this PWS.

For OCONUS sites, contractors must be able to obtain either a CAC, or other applicable/official base entry means that have been agreed upon by the Host Nation and the US. Government/COMCOM for each site. Lost or stolen contractor employee badges must be reported to COR immediately upon discovery and replacement CACs will be issued solely at the Government’s discretion.

4.9.1 Identification of Contractor Employees

All contractor personnel attending meetings and working in other situations where their contractor status is not obvious to third parties are required to identify themselves as such to avoid creating an impression in the minds of members of the public that they are Government officials. They must also ensure that all documents or reports produced by contractors are suitably marked as contractor products or that contractor participation is appropriately disclosed.

4.10 Safety and Occupational Health (SOH) Requirements

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

It is the responsibility of the contractor to be aware of the safety requirements of personnel, equipment, and products leveraged throughout the performance of the contract. All necessary protective equipment, coverings, shields, protective barriers, warning signs, etc., must be worn or furnished and installed by the contractor where a hazard or potential hazard exists. The contractor will coordinate with the KO or COR as appropriate prior to installing protective coverings, shields, barriers, signs and barricades for concurrence and approval. The contractor must comply with all pertinent provisions of OSHA standards 29 CFR 1910 and 29 CFR 1926 when applicable. The contractor will not be excused from requirements of all generally accepted safety standards, practices, rules and regulations as well as those established by this PWS and/or the KO, COR, or Government representative/designee. Government and Host Installation Safety and Health office personnel may inspect the contractor's worksite at any time for compliance of SOH requirements.

4.10.1 Deliverable: Accident/Incident Report [CDRL A025]

The contractor will immediately notify the KO, COR, and Government/Host Installation Safety and Health office personnel of any major workplace accident or incident that results in personal injury/illness, loss of life, Lost Workday (LWD), Restricted Duty (RD), or property damage greater than \$5,000. The contractor will generate a report and submit it to the KO, COR, and Government/Host Installation Safety and Health office personnel within five (5) business days following the accident/incident. This requirement applies to all contractors, subcontractor, site support, and anything that can be charged to the Government for the rendering of the supplies and services described within this contract.

- a. **Schedule**: Within five (5) business days following the accident/incident.
- b. **Content**: Must (at a minimum) include
 1. The names of personnel involved in the accident/incident
 2. Contact information of personnel involved in the accident/incident
 3. Names of witness(es) to accident/incident
 4. Location of accident/incident
 5. Date/time of accident/incident
 6. Description of the injuries/damages incurred due to accident/incident
 7. Summation of the event(s) leading up to the accident/incident
 8. Photographic evidence of property damage
 9. A complete description in chronological order of the accident/incident

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

4.11 Personnel Requirements

Upon award, all Labor Categories of personnel as defined below will be required to obtain and maintain the appropriate investigation and adjudication or suitability determination commensurate with the information within the application or system. Most work to be performed under this requirement is unclassified, however, a security clearance may be required. All contractor personnel, if not specifically defined below will require (at a minimum) a Tier 1 National Agency Check with Inquiries (NACI) personnel security clearance investigation, prior to commencing work.

All contractor personnel requiring elevated/privileged access as described in this PWS, either during provisioning or post award, will be required to complete a Tier 3 National Agency Check with Law and Credit (NACLC) / Access National Agency Check and Inquiries (ANACI) or Tier 5 Single Scope Background Investigation (SSBI) personnel security clearance for a Non-Critical Sensitive position, meet DoD 8570.1-M IA Technical (IAT) II baseline and computing environment certifications, and provide copies of certification documentation to the Government prior to commencing work. Contractor personnel performing elevated/ privileged access duties must remain in good standing for personnel security clearance eligibility and applicable certifications throughout contract period of performance.

4.11.1 Labor Categories – Key Personnel

Certain skilled, experienced, professional and/or technical personnel are essential for successful accomplishment of the work to be performed under this contract and are defined herein as "Key Personnel".

The contractor must submit resumes and applicable supporting documentation (such as certifications) for all Key Personnel and all personnel proposed as Key Personnel substitutions. Resumes and required certifications for Key Personnel will be utilized by the Government to support evaluation and determination of technical acceptability. These resumes and certifications will be included as part of the contractor's proposal as described in this PWS. The contractor is responsible for providing Key Personnel approved by the Government based upon the resumes and certifications submitted and will bear all costs associated with meeting this requirement. The contractor will be responsible for bearing all costs associated with training for Key Personnel and the Government will not reimburse training costs. Except for mandatory

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Government training, the training of Key Personnel will not be allowed on Government time. The contractor will ensure Key Personnel maintain valid certification(s) and credential(s) for the duration of the contract. These Key Personnel provisions will be fully applicable to all subcontracts.

For Key Personnel not currently under the contractor's/subcontractor's employment, the resume will indicate pending. At a minimum, for any Key Personnel who do not currently work for the contractor/subcontractor, the contractor will provide documentary evidence of the individual's availability to support these requirements in the form of a signed letter of intent with an agreed upon start date and salary. Only contingency hires with letters of intent will be considered as technically acceptable for Government evaluation purposes. For follow-on efforts where the contractor is not the incumbent, a proposed plan to hire incumbent personnel is not acceptable without letters of intent.

The nomenclature/position name associated with key/essential personnel is notional. The contractor may propose alternative/substitute labor categories or nomenclature for identified Key Personnel positions, so long as the offered candidate meets the qualifications identified herein.

Key Personnel Labor Categories for this contract are:

4.11.1.1 Maintenance Program Manager (MPM)

The contractor must designate a specific individual (i.e. identify a person by name) to serve as the MPM who will serve as the principle point of contact to the KO, COR, and TPOC throughout the duration of contractual performance. The MPM will be responsible for managing, coordinating, and overseeing successful completion of all contractor work performed to render the supplies and services described within this PWS (including any TOs issued against the IDIQ). The contractor may identify an alternate MPM when the primary individual is unavailable, but this person must meet the requirements described herein and have the authority to act on the contractor's behalf when communicating with the Government in all performance matters related to the contract.

The MPM must possess excellent managerial skillsets with outstanding verbal and written communication abilities to ensure successful contract performance. For example, the MPM must be able to effectively communicate with KO, other Contractor Project Managers, the Government Program Manager, Government personnel, and customer agency representatives to address performance concerns, coordinate work, and ensure activities throughout the duration of contract execution are successfully completed. Additionally, the MPM will be responsible for

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

maintaining contractor oversight on all activities to render the required supplies and services as described within this PWS. As such, the MPM will be responsible for overall contractor-based monitoring and controlling of work performed, including all tasks, subtasks, work efforts, activities, action items, etc. necessary to render the required supplies and services identified within this PWS. As part of the monitoring and controlling activities, the MPM must be competent in risk and issue management with strong ability to identify and rapidly resolve problems/issues as they arise to ensure fully successful contractor performance. Monitoring and controlling work by the MPM will also require this individual to ensure internal contractor quality controls are met by implementing and tracking management reviews of documentation, plans, status reports, and deliverables. These reviews must verify compliance with the contractor's QCP that will check the supplies and services for completeness, precision, grade, and/or content prior to submission to the Government for final inspection and acceptance. The MPM will also be expected to spearhead coordination for all contractor resources (supplies and personnel, including travel) to ensure successful performance throughout the duration of the contract. This coordination will include (but is not exclusive to) ensuring seamless integration of the contractor's Technical Support Team as services are rendered to complete the tasks and subtasks described in this PWS. The MPM will be responsible for ensuring all personnel assigned to the contract are fully qualified, competent, and possess the necessary credentials (including but not limited to DoDM 8570/8140 certifications to support privileged access) prior to task, subtask, work effort, activity, and/or action item assignment.

The MPM will be expected to provide remote sustainment support (i.e. offsite/at contractor place of performance) on a regular basis for the HFAM program but may be required to travel to specific geographical locations to meet with the Government KO, COR, and/or TPOC as required. Working hours for the MPM must be aligned to Eastern Standard Time (EST) to maximize sustainment coordination with the contractor's Technical Support Team as well as the Government KO, COR, and TPOC.

Desired Certifications:

- Should possess a valid Project Management certification (i.e. Project Management Professional (PMP) Certification or other equivalent nationally recognized program management certification, etc.).

Minimum Experience:

- Must possess at least six (6) years of relevant management experience of progressively higher responsibility in the public and/or private sector that clearly demonstrates leadership

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

in operations, maintenance, and sustainment of information technology (IT) and/or operational technology (OT) systems, preferably with experience managing fuel industry related solutions.

Minimum Education:

- Must possess a Bachelor of Science (BS) or a Bachelor of Arts (BA) degree from a nationally accredited and recognized institution of higher learning **or** four (4) additional years of relevant experience beyond the minimum experience requirement (IE: a total of ten (10) years of relevant management experience or greater).

Additional Qualifications & Required Skills:

- Must be available for work during normal Government business hours (08:00 – 16:30 EST) to maximize coordination with the Government KO, COR, and TPOC and ensure the operational sustainment of the HFAM program.
- Must possess eligibility for a Non-Sensitive position (i.e. completed a Tier 1 National Agency Check with Inquiries (NACI) (or higher) personnel security clearance investigation) at time of proposal submission. The Government will not authorize a Tier I NACI personnel security clearance investigation for the contractor's identified MPM upon or after award of the contract. This requirement exists to ensure the contractor's assigned resource to perform the duties of the MPM are capable of immediately performing work at the time of award.
- Proven interpersonal skills with the ability to work effectively in a team setting in areas such as teamwork, facilitation, and negotiation.
- Exceptional verbal and written communication skills.
- Expert in sustaining complex IT/OT systems with demonstrated ability to provide acceptable support services in a timely manner.
- Excellent planning and organizational skills.
- Strong understanding of contract management and contractual obligations.
- Well versed in risk management, issue identification, and problem resolution.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- Proficiency in basic analytical software products such as Adobe, Microsoft Excel, Access, Word, Office, Project, Visio, and PowerPoint.

4.11.1.2 Chief Engineer (CEE)

The contractor must designate a specific individual (i.e. identify a person by name) to serve as the CEE who will serve as the lead engineer for the entire HFAM program and act as their technical subject matter expert (SME). The CEE will be responsible for a wide variety of technical support services. For example, the CEE will work with the system security engineer to fully integrate cybersecurity into overall engineering efforts for the HFAM program. The contractor may identify an alternate CEE when the primary individual is unavailable, but this person must meet the requirements described herein and have the same capabilities to serve as the contractor's technical SME for the HFAM program.

The CEE will be expected to provide remote sustainment support (i.e. offsite/at contractor place of performance) on a regular basis for the HFAM program but may be required to travel to specific geographical locations to meet with the Government KO, COR, and/or TPOC as required. Working hours for the CEE must be aligned to Eastern Standard Time (EST) to maximize sustainment coordination with the contractor's Technical Support Team as well as the Government KO, COR, and TPOC.

Desired Certifications:

- Should possess a valid Professional Engineering (PE) registration.

Minimum Experience:

- The contractor's CEE must be a SME and technically adept in the operations of Automated Fuel Systems (AFS) and petroleum facilities/petroleum systems. As such, the contractor's CE must possess at least ten (10) years of experience in the electrical / mechanical engineering field working with complex and integrated Industrial Control Systems (ICS). Holistically, this experience needs to demonstrate the contractor's CEE has performed electrical / mechanical engineering work such as technology assessments; systems analysis; system design; systems architecture; system testing and evaluation; and system integration. At least five (5) of the total ten (10) years of the contractor's CEE experience must be clearly affiliated with AFS or petroleum related ICS including (but not limited to) their Supervisory Control and Data Acquisition (SCADA) computers; Programmable Logic Controllers (PLCs); Remote Terminal Units (RTUs); networked data communications; graphical user

Commented [KP7]: Add Non Key personnel verbiage

Commented [P8]: Fix White space

Commented [P9]: Fix white space

Commented [P10]: Add Non Key personnel verbiage

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

interfaces (GUIs); control modules; sensors/probes; communication protocols; and safety procedures.

- Additional experience desired (but not required) includes previous work with complex electrical/electronic systems such as Command, Control, Communications, Computers, Intelligence, Surveillance and Reconnaissance (C4ISR); Cybersecurity; Customer-Driven Technical Support Services

Minimum Education:

- Must have a bachelor's degree in engineering from an accredited university or college.

Additional Qualifications & Required Skills:

- Must be available for work during normal Government business hours (08:00 – 16:30 EST) to maximize coordination with the Government KO, COR, and TPOC and ensure the operational sustainment of the HFAM program.
- Must possess eligibility for a Non-Critical Sensitive position (i.e. completed a Tier 3 National Agency Check with Law and Credit (NACLC) / Access National Agency Check and Inquiries (ANACI) or Tier 5 Single Scope Background Investigation (SSBI) personnel security clearance investigation) at time of proposal submission. The Government will not authorize a Tier 3 NACLC/ANACI or Tier 5 SSBI personnel security clearance investigation for the contractor's identified CEE upon or after award of the contract. This requirement exists to ensure the contractor's assigned resource to perform the duties of the CEE are capable of immediately performing work at the time of award.
- Must possess DoD 8570.1-M Information Assurance Technical (IAT) II baseline and computing environment certifications.
- Proven interpersonal skills with the ability to work effectively in a team setting in areas such as teamwork, facilitation, and negotiation.
- Exceptional verbal and written communication skills.
- Excellent planning and organizational skills.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- Capable of reviewing and revising technical drawings and schematics using electronic software such as AutoCAD.
- Proficiency in basic analytical software products such as Adobe as well as Microsoft Excel, Access, Word, Office, Project, Visio, and PowerPoint.

4.11.2 Changes to Key Personnel

The contractor will use key personnel as identified in its proposal during the performance of this contract and will request Government approval prior to any changes. Requests for approval of any changes will be in writing with a detailed explanation of the circumstances necessitating the change. The request must contain a complete resume for the new key personnel and any other pertinent information, such as degrees, certifications, and work history.

The contractor will not substitute Key Personnel assigned to perform work under this contract without prior approval of the Government. Contractors may propose alternative/substitute Key Personnel in the identified Labor Categories, if the candidate meets the qualifications identified for the Key Personnel position. Requests for approval of substitutions will be in writing and will provide for a detailed explanation of the circumstances necessitating the proposed substitution(s). Requests will contain a complete resume for the proposed substitute, and any other information as requested by the Government. Proposed substitutions will have qualifications that are equal to or higher than the key personnel being augmented and will be able to immediately perform assigned duties. The Government will evaluate such requests and promptly notify the contractor, in writing, whether the proposed substitution is acceptable. If the Government determines that a suitable and timely replacement of Key Personnel who have been reassigned, terminated or have otherwise become unavailable for the contract work is not reasonably forthcoming or the resultant substitution would be so substantial as to impair the successful completion of the contract or contract IAW the proposal accepted by the Government at the time of contract award, the KO may pursue appropriate termination procedures and/or equitably adjust the contract price downward to compensate the Government for any resultant delay, loss or damage.

4.11.3 Labor Categories - Non-Key Personnel

To successfully meet the Government's objective, meet the requirements described in this PWS, and render the necessary supplies and services, the contractor will need to provide various skilled, experienced, professional and/or technical non-key personnel. The nomenclature/position name associated with non-key personnel is notional and is intended to represent the labor categories anticipated as necessary to successfully render the required supplies and services

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

identified in the PWS. As part of the contractor's proposal, the contractor will need to describe their anticipated non-key personnel labor mix to support Government evaluation of the proposed technical and management approach for acceptability. Contractors are permitted to propose a labor mix of higher or lower complexity from the Government's notional estimate if their proposed approach enables them to successfully perform the requirements described in this PWS. Regardless of labor mix proposed, the contractor will be responsible for fully describing their technical and management approach to support Government evaluation and determination of acceptability. The contractor is the sole entity responsible for performing oversight non-key personnel (including but not limited to) ensuring all non-key personnel are trained, competent, capable, and possess the necessary skillsets to complete the tasks, subtasks, work efforts, activities, and/or deliverables assigned.

The contractor is responsible for providing qualified non-key personnel to render the required supplies and services described in this PWS and will bear all costs for training its personnel. The Government will not reimburse the contractor for the cost of training contractor personnel. Training of non-key personnel will not be allowed on Government time. The contractor will ensure non-key personnel maintain valid certification(s) and credential(s) for the duration of the contract (including but not limited to DoDM 8570/8140 certifications to support privileged access).

The Government anticipates Non- Key Personnel for the HFAM Support contract (and any issued task order) are as follows:

- **Wage Determination No.: 2015-4427 (Sam.gov) and LCAT GS35F553AA**

4.11.4 Language Requirements

The contractor will ensure all personnel performing on this contract are capable of communicating with the Government employees by fluently speaking, reading, writing, and understanding the English language including unique technical terminology required for the performance of assigned duties and functions.

4.11.5 Non-U.S. Citizens

This requirement applicable to contractor and subcontractor employees that do not work on Government systems (i.e. access to the Government's network environment (NE) or computing environment (CE)). The Headquarters (HQ) DLA Intelligence Foreign Disclosure Officer will approve foreign nationals working on a DLA contract or task order before beginning work on the

Commented [JJ11]: You will need to identify the non-key labor categories based upon your IGCE that you anticipate the Contractor will need here.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

contract or task order. This approval requirement also includes Subcontractor employees. The contractor will submit, in writing, to the KO the names of all foreign nationals proposed for performance under this contract, along with documentation to verify that he or she is legally admitted into the United States and has authority to work. The contractor must forward this information to the HQ DLA Security Officer for background check and for approval. The contractor will complete all requirements IAW DLA Instruction 5200.02, "Personnel Security Program," November 30, 2018.

4.11.6 Mandatory Provided Training

The contractor will ensure all contractor employees requiring access to the Government NE receive training for Personally Identifiable Information (PII), DLA Privacy Safeguards, Cyber Awareness Challenge, Controlled Unclassified Information (CUI) within 7 calendar days after the employee is granted access to the DLA Network. Contractor personnel not requiring access to the Government NE or systems will **NOT** be required to meet this requirement. The contractor will access the training at <https://j6enterprise.skillport.com>.

The contractor will ensure all contractor employees requiring access to the Government NE or systems receive training for DLA Annual Security & Counterintelligence Awareness Training within 7 calendar days after the employee is granted access to the DLA Network. The contractor will access the training at <https://dla-hcm04.ns2.apps.mil/icontent/CUSTOM/DLAHCM04P/NoCompat/SEC-ASCA/>. All five modules must be complete to receive credit. Once the contractors completes the training, they will save a screenshot of the final page for each module in PDF format, digitally sign the document (acknowledging they have fully completed the training) and provide to the COR. Required annually, per DLAM 3606.01, for contractors who have an Active Directory/Email account • <https://issuances.dla.mil>.

Specific contractor personnel (including subcontractors) may be required to complete additional safety, Information Assurance (IA), security, or other Government mandated training. In these situations, the COR will notify the contractor of additional training requirements on a case-by-case basis. If additional safety, security, or other Government mandated training is required, the contractor will ensure assigned personnel successfully participate in and complete the training.

For all mandatory Government provided training, the contractor will provide copies of course completion certificates to the COR for retention within the Government contract file. An employee failure to complete mandatory Government provided training may result in a request of removal by the KO for any contractor personnel and/or denial of their access to the DLA IT

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

systems.

To ensure the contractor complies with all the mandatory Government provided training requirements described herein, the contractor will provide to the COR a monthly contractor Personnel Training Compliance (CPTC) Report. The purpose of the CPTC Report is to ensure all contractor personnel have successfully completed and maintained compliance with mandatory Government provided training requirements. The first Monthly CPTC Report will be a comprehensive document covering all contractor provided personnel (i.e. prime or subcontractor, key or non-key). The contractor will then be required to report updates monthly thereafter (or report no changes). The contractor must submit the first CPTC Report to the COR within thirty (30) calendar days after the contract award for inspection and acceptance. Follow on CPTC Report will be provided by the contractor by no later than (NLT) the fifth (5th) business day of each month for the duration of the contract. The follow-on reports must provide updated status on all data fields contained within the report and indicate any additions or removals of personnel from contractor staff.

**4.11.6.1 Deliverable: Contractor Personnel Training Compliance (CPTC) Report
[CDRL A026]**

- a. **Schedule:** Submitted with MSR within thirty (30) calendar days after contract award and NLT the fifth (5th) business day of each month thereafter for the duration of contract performance.
- b. **Content:** At a minimum, the data product will include:
 - 1. Contractor Name
 - 2. Company
 - 3. CAGE
 - 4. COR
 - 5. Contract #
 - 6. Course Title
 - 7. Date of Course Completion
 - 8. Expiration of Course Certification/Required Renewal Date
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

4.12 Invoicing, Vouchers, and Payment

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

The Contractor will submit invoices, vouchers, and applicable supporting documentation for Government processing **no more frequently than MONTHLY** and by **NLT the 10th business day each month** after Government inspection and acceptance of the MSR. This requirement of no more frequent than monthly and by NLT the 10th business day is to maximize the effective use of Government resources and prevent unnecessary continuous submission by the contractor. Cost vouchers for supplies or services rendered on a time and materials (T&M) basis will be submitted to the COR for review prior to submission in Wide Area Work Flow (WAWF) as described in this PWS. Cost vouchers will be analyzed by the COR to determine allowability compliant to FAR 31.201-2, reasonableness compliant to FAR 31.201-3, and allocability compliant to FAR 31.201-4. Cost vouchers for travel reimbursement on a T&M basis must contain location and dates, and items must be identified by subject (i.e. incidentals, meals, rental car, and airfare). All contractor travel billable on a T&M basis must be performed compliant with the DoD Joint Travel Regulations (JTR). The Contractor will be responsible for any costs incurred because of authorized travel which were more than that allowed under FAR 31.205-46. Travel vouchers should be compiled and submitted for processing as soon as possible upon trip completion (i.e. the next available monthly submission). All cost vouchers must clearly identify the specific contract line items (CLINs) for services or supplies rendered with associated burndowns (i.e. amounts billed and amounts on CLINs remaining) for the month. Other invoice requirements are set forth in FAR 52.232-25 and DFARS 252.232-7003.

Upon receipt of invoices and vouchers, the Government's target to complete review and processing is within five (5) business days. However, the Government may take as long as twenty (20) business days to perform invoice and voucher reviews depending on submission complexity and resource availability (i.e. COR workload volume). Government reviews will validate invoices and cost vouchers for accuracy, confirm delivery of services and supplies, and verify travel meets the Government's requirements for reimbursement. Invoices or cost vouchers that are identified by the COR to contain inaccuracies will be returned to the Contractor for correction and re-submittal. The contractor will be required to correct any invoice or voucher issues identified by the Government prior to re-submittal.

4.12.1 Deliverable: Invoices and Cost Voucher Documentation [CDRL A027]

- a. **Schedule**: No more frequently than monthly and NLT the fifth (5th) business day of each month.
- b. **Content**: Invoices must include supporting documentation (i.e. the MSR) identifying services rendered for billable month. Cost vouchers for supplies and services must include all supporting documentation to support Government determination monthly

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

costs billed are costs are allowable, reasonable, and allocable compliant to FAR 31.201-2 through FAR 31.201-4.

- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

4.13 Non-Disclosure Agreements (NDAs)

All contractor personnel working on this contract are required to sign a Non-Disclosure Agreement (NDA) of Non-Public Information Form located at Appendix B no later than (NLT) five (5) business days after roll-on or assignment to support the work efforts described within this PWS. The contractor will ensure a signed copy of each contractor personnel's NDA is kept on file and provided to the KO and COR as appropriate.

4.13.1 Deliverable: Non-Disclosure Agreements (NDAs) [CDRL A028]

- a. **Schedule:** No later than (NLT) five (5) business days after contractor personnel roll-on or assignment.
- b. **Content:** See Appendix D.
- c. **Format:** Electronic copies viewable using the latest version of Microsoft Office or Adobe PDF

SECTION C-5: CONTRACT LINE ITEM (CLIN) STRUCTURE

5.0 Contract Line Item (CLIN) Structure

All deliverables and CDRLs will not be separately priced (NSP). All CLINs except CLIN 0005 will be funded on a Firm, Fixed Price (FFP) basis. CLIN 0005 will be on a Time and Material (T&M) basis. Services and supplies rendered for CLINs 0006, 0007, and 0008 will be awarded as individual Task Orders (TOs) as needed.

This requirement includes the following periods of performance (PoP):

- Transition In – 3 Months
- Base PoP – 9 Months
- Option 1 PoP – 12 Months
- Option 2 PoP – 12 Months

Commented [JJ12]: Ken will need to work on cleaning up Sections 5, 6, and 7 and then update the attachments and appendices as appropriate.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

- Option 3 PoP – 12 Months
- Option 4 PoP – 12 Months
- Transition Out – 3 Months

5.1 Transition In (3 Months)

Transition In PoP (3 Months)	
CLIN	PWS Reference
CLIN 0001 – Transition In	3.1

5.2 Base Period (9 Months)

Base PoP (9 Months)	
CLIN	PWS Reference
CLIN 0002 – Admin Support & Program Management	3.2
CLIN 0003 – Preventative Maintenance (PM)	3.3
CLIN 0004 – Technical Support	3.4
CLIN 0005 – Corrective Maintenance (CM)/Repair	3.5
CLIN 0006 – Site Support	3.6
CLIN 0007 – Cybersecurity Support	3.7
CLIN 0008 – Commercial Software Licensing	3.8

5.3 Option 1 PoP (12 Months)

Option 1 PoP (12 Months)	
CLIN	PWS Reference
CLIN 1002 – Admin Support & Program Management	3.2
CLIN 1003 – Preventative Maintenance (PM)	3.3
CLIN 1004 – Technical Support	3.4
CLIN 1005 – Corrective Maintenance (CM)/Repair	3.5
CLIN 1006 – Site Support	3.6

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Option 1 PoP (12 Months)	
CLIN	PWS Reference
CLIN 1007 – Cybersecurity Support	3.7
CLIN 1008 – Commercial Software Licensing	3.8

5.4 Option 2 PoP (12 Months)

Option 2 PoP (12 Months)	
CLIN	PWS Reference
CLIN 2002 – Admin Support & Program Management	3.2
CLIN 2003 – Preventative Maintenance (PM)	3.3
CLIN 2004 – Technical Support	3.4
CLIN 2005 – Corrective Maintenance (CM)/Repair	3.5
CLIN 2006 – Site Support	3.6
CLIN 2007 – Cybersecurity Support	3.7
CLIN 2008 – Commercial Software Licensing	3.8

5.5 Option 3 PoP (12 Months)

Option 3 PoP (12 Months)	
CLIN	PWS Reference
CLIN 3002 – Admin Support & Program Management	3.2
CLIN 3003 – Preventative Maintenance (PM)	3.3
CLIN 3004 – Technical Support	3.4
CLIN 3005 – Corrective Maintenance (CM)/Repair	3.5
CLIN 3006 – Site Support	3.6
CLIN 3007 – Cybersecurity Support	3.7
CLIN 3008 – Commercial Software Licensing	3.8

5.6 Option 4 PoP (12 Months)

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Option 4 PoP (12 Months)	
CLIN	PWS Reference
CLIN 4002 – Admin Support & Program Management	3.2
CLIN 4003 – Preventative Maintenance (PM)	3.3
CLIN 4004 – Technical Support	3.4
CLIN 4005 – Corrective Maintenance (CM)/Repair	3.5
CLIN 4006 – Site Support	3.6
CLIN 4007 – Cybersecurity Support	3.7
CLIN 4008 – Commercial Software Licensing	3.8

5.7 Transition Out (3 Months)

Transition In PoP (3 Months)	
CLIN	PWS Reference
CLIN 0009 – Transition Out	3.9

SECTION C-6: DELIVERABLES & CDRLS

6.0 Deliverables & Contract Data Requirements List (CDRL)

The contractor must use the best commercial practices for formatting all deliverables under this contract. All deliverables containing CUI will be marked as appropriate compliant with the requirements described in this PWS. All deliverables identified herein will be not separately priced (NSP) and will be included as part of the services rendered by the contractor as described in this PWS. The Contractor will provide deliverables in the approved format identified in the PWS or as requested by the COR. All completed deliverables will be submitted to the COR/TPOC for inspection compliant to the Government's QASP. Electronic copies will be delivered via official DLA issued e-mail with attachment or other media specified by the COR. If a deliverable exceeds email size limitations, the Contractor must notify the COR for alternative means of delivery (such as DoD SAFE available at the following URL: <https://safe.apps.mil/>). The electronic copies will be compatible with the current DLA software products or other applications as appropriate and specified by the COR.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

The primary method for the contractor to document successful completion of services rendered and Government inspection and acceptance of these services will be the MSR as described in this PWS.

The following table (below) identifies the known formal deliverables resulting from the requirements described in this PWS:

DELIVERABLES / CDRLs				
CDRL #	Deliverable Title	PWS Ref #s	Quantity/ Frequency	Deliverable Due Date
A001	Transition-In Report	3.1.1	One (1)	No later than (NLT) fifteen (15) days before the end of the transition period.
A002	Program Management Plan (PMP) and Quality Control Plan (QCP)	3.2.1.1	One (1)	Initial version submitted at time of contractor proposal to support evaluations for acceptability. Final versions submitted to the Government within ten (10) business days after completion of the post award conference.
A003	Post Award Conference Presentation & Meeting Minutes	3.2.2.1	One (1)	Within ten (10) business upon conclusion of the post award conference.
A004	Weekly Activity Report (WAR) – CUI	3.2.3.1	Weekly	NLT two (2) business days after completion of the weekly virtual teleconference.
A005	Monthly Status Report (MSR)	3.2.4.1	Monthly	Within thirty (30) calendar days after contract award and NLT the fifth (5 th) business day of each month thereafter for the duration of contract performance.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

DELIVERABLES / CDRLs				
CDRL #	Deliverable Title	PWS Ref #s	Quantity/ Frequency	Deliverable Due Date
A006	IPR Documentation	3.2.5.1	As Required	NLT five (5) business days after completion of each IPR.
A007	DoDM 8570.01-M/DoDD 8140.01 Report - CUI	3.2.6.1	Monthly	Submitted with MSR within thirty (30) calendar days after contract award and NLT the fifth (5 th) business day of each month thereafter for the duration of contract performance.
A008	Contractor Personnel Roster, Common Access Card (CAC), & Alternate Tokens Report	3.2.7.1	Monthly	Submitted with MSR within thirty (30) calendar days after contract award and NLT the fifth (5 th) business day of each month thereafter for the duration of contract performance
A009	Quarterly Inventory Report (QIR)	3.2.8.1	Quarterly	Quarterly (every three (3) months) after the start of contract performance and by NLT the last calendar day of month
A010	Commercial Documents	3.2.9.1	As Required	NLT ten (10) business days after identification of each requirement
A011	HFAM Site Documentation	3.3.3.1	As Required	Within ten (10) business days of on-site service completion
A012	HFAM Test and Inspection Documentation	3.3.3.2	As Required	Within ten (10) business days of on-site service completion
A013	HFAM Information Gathering and Equipment Data	3.3.3.3	As Required	Within ten (10) business days of on-site service completion

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

DELIVERABLES / CDRLs				
CDRL #	Deliverable Title	PWS Ref #s	Quantity/ Frequency	Deliverable Due Date
A014	HFAM Configuration Drawings	3.3.3.4	As Required	Within ten (10) business days of on-site service completion
A015	HFAM Configuration Files	3.3.3.5	As Required	Within ten (10) business days of on-site service completion
A016	HFAM Digital Photographs	3.3.3.6	As Required	Within ten (10) business days of on-site service completion
A017	Root Cause Analysis (RCA)	3.4.3.1	As Required	Within ten (10) business days after confirmed resolution of critical failure
A018	CM/Repair Supplies Planning and Coordination	3.4.3.2	As Required	As required based upon SNOW case priority and Service Level Agreement (SLA)
A019	CM/Repair Services or Site Support Planning & Coordination Documentation	3.4.3.3	As Required	As required based upon SNOW case priority and Service Level Agreement (SLA)
A020	HFAM CM/Repair Trouble Call Out Briefing	3.5.3.1	As Required	Within ten (10) business days of on-site service completion.
A021	HFAM CM/Repair Test Inspection Procedures & Report	3.5.3.2	As Required	Within ten (10) business days of on-site service completion.
A022	HFAM Site Support Statement of Work (SOW)	3.5.3.3	As Required	Within ten (10) business days of on-site service completion.
A023	Transition-Out Report	3.9.1	One (1)	NLT fifteen (15) calendar days before the end of the transition period

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

DELIVERABLES / CDRLs				
CDRL #	Deliverable Title	PWS Ref #s	Quantity/ Frequency	Deliverable Due Date
A024	GP Report	4.5.3.1	Monthly	Submitted with MSR within thirty (30) calendar days after contract award and NLT the fifth (5 th) business day of each month thereafter for the duration of contract performance
A025	Accident/Incident Report	4.10.1	As Required	Within five (5) business days following the accident/incident
A026	Contractor Personnel Training Compliance (CPTC) Report	4.11.6.1	Monthly	Submitted with MSR within thirty (30) calendar days after contract award and NLT the fifth (5 th) business day of each month thereafter for the duration of contract performance
A027	Invoices and Cost Voucher Documentation	4.12.1	Monthly	No more frequently than monthly and NLT the tenth (10 th) business day of each month after inspection and acceptance of MSR
A028	Non-Disclosure Agreements (NDAs)	4.13.1	As Required	No later than (NLT) five (5) business days after contractor personnel roll-on or assignment.

Table 4 – Contract Data Requirements Listing (CDRL) & Deliverables

SECTION C-7: QUALITY CONTROLS & PERFORMANCE STANDARDS

7.0 Quality Controls & Performance Standards

The following section outlines the general quality controls and performance standards associated

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

with this contract. Additional details and information regarding the methods for Government surveillance is described in the QASP.

7.1 Quality Control Plan (QCP)

The purpose of the contractor's QC program is to provide an assurance the work performed is compliant to the Government QASP, complete, timely, and meets the requirements of the contract. As such, the contractor will be required to implement a QC program throughout the duration of contract performance by developing and utilizing a QCP as described in Section 3.2.1 - Subtask 2.1: Program Management Plan (PMP) and Quality Control Plan (QCP) of this PWS.

7.2 Performance Standards

All products and services rendered will be prepared compliant with the performance standards described in this PWS. The contractor is required to perform all functions in a professional manner. The Contractor is permitted to use subcontractors as appropriate to conduct the work (i.e. tasks, subtasks, etc.) described in the PWS. However, use of subcontractor(s) does not relieve or alleviate the prime contractor of the responsibility for ensuring successful performance.

7.2.1 General Inspection & Acceptance Criteria

Unless specified, the contractor must report on all activities performed IAW this PWS to the COR. The COR has the responsibility to monitor the progress of the work of the Contractor throughout the duration of contract performance. The contractor will submit all work products, deliverables, etc. to the COR for inspection compliant to this QASP. The COR may coordinate with the Government Program Management Office (PMO), Technical Points of Contact (TPOCs), or Designated Technical Support Representatives (DTSRs) to assist with inspection and obtain recommendations on the acceptability of supplies, services, deliverables, etc. rendered on the contract.

In terms of all work products and deliverables (whether formal or informal), a "day" means (unless otherwise specified) a business day or workday. Additionally, in the absence of other agreements negotiated with respect to the time provided for Government review, work products or deliverables will be inspected and the Contractor notified of the COR's findings within ten (10) workdays of submission or requested review. During the review, the Government will inspect the submittals and provide comments back to the Contractor with approval or disapproval of the work product or deliverable. Defective work products or deliverables with deficiencies

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

will be remedied by the Contractor prior to an agreed upon date as determined by the Government. In the absence of an agreed upon date for corrective actions, the Contractor will have a maximum of ten (10) working days from the day the Government's comments are received regarding defective work products or deliverable with deficiencies to incorporate all changes and re-submit to the Government.

The Government will conduct inspection of the quality and timeliness of services, supplies, work products, deliverables, etc. by verifying and validating their accuracy, clarity, format, and conformance to contractual requirements. The basis for acceptance of Contractor deliverables will be compliance with the requirements in the PWS, the Contractor's proposal, and other terms and conditions of the contract. Final acceptance of all work, reports, and other deliverables will be performed at the place of delivery by the COR based upon recommendations from the Government PMO, TPOC, or DTSR. At the discretion of the Government, inspection may include random sampling or testing for validation of data, reports, deliverables, etc. identified in the PWS. Inspections may be performed by the Government using automated tools (such as software to conduct testing and validation).

- a. **Non-Conforming Services:** If Government inspections of services rendered determine the contractor's performance does not meet the AQLs or negative customer feedback is validated, the COR will notify the Contractor of the deficiencies for correction. The Contractor will then be expected to take corrective actions to address deficiencies or validated negative customer feedback and resolve any performance problems to the Government's satisfaction. If deficiencies are not corrected by the Contractor within a specified period of time, the COR will notify the KO for action. If the Contractor disagrees with the performance discrepancy or an agreement with the COR for remedy cannot be reached, the COR will notify the KO for a final decision.
- b. **Non-Conforming Supplies, Work Products, Deliverables, etc:** If Government inspections determine supplies, work products, deliverables, etc. do not meet the AQLs (such as non-conformance to contractual requirements, faults, failures, discrepancies, inaccuracies, incompleteness, spelling / grammatical errors, improper format, etc.), it may be immediately rejected without further review and the COR will notify the Contractor of the deficiencies for correction. The Contractor will then be expected to take corrective actions to address the identified deficiencies prior to resubmission. Corrected supplies, work products, deliverables, etc. will be resubmitted by the contractor prior to an agreed upon date as determined by the Government. If the additional Government guidance is required to produce acceptable supplies, work products, deliverables, etc., the contractor must request a meeting with the COR. Draft versions of deliverables inspected by the

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Government may be determined as acceptable with feedback, revisions, or comments provided for incorporation into the final version. All the Government's comments must be incorporated in the succeeding version unless directed to correct in the current version of the deliverable. All supplies, work products, deliverables, etc. that do not meet the AQLs will not be accepted until discrepancies, deficiencies, etc. identified have been corrected to the Government's satisfaction

The following is an outline of the Government's general acceptance criteria:

General Acceptance Criteria	
Criterion	Element / Description
Quality	<u>Accuracy</u> – Work products will be accurate in presentation, complete in content, and contain objective measurements / data that is verifiable
Quality	<u>Clarity</u> – Work products will be clear, concise, and legible. Diagrams will be designed in a manner that is easy to understand and relevant to the supporting narrative.
Quality	<u>Conformance to Requirements</u> – Work products will satisfy the requirements of the PWS and contain all required content. Identified defective work products / deficiencies and negative customer feedback is remedied effectively.
Quality	<u>Format</u> – Work products will be logical in structure and submitted in an acceptable manner as described in the PWS or in a manner mutually agreed upon prior to submission. Documents will be free of spelling, grammatical, or format errors. All text and diagrammatic files will be editable by the Government unless otherwise requested.
Timeliness	Work products and milestones are completed on or before the due dates. Identified defective work products / deficiencies and negative customer feedback are remedied prior to an agreed upon date as determined by the Government.

Table 5 – General Acceptance Criteria

7.2.2 Performance Ratings and Acceptable Quality Levels (AQLs)

The Government will assign performance ratings for supplies and services rendered monthly for each Task Order (TO) issued against this IDIQ contract. The following information describes the Government's performance ratings and decrements that will be utilized throughout the duration

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

of this contract compliant to the QASP. These ratings enable the Government to determine whether contractor performance is acceptable and if not, what decrements to payment are appropriate. The Government does not have an expectation of perfection in the performance of this contract and the target performance rating / AQL is “Satisfactory” or greater. However, the contractor must ensure consistent qualitative and timely performance is rendered. Inconsistent performance or failure to meet the “Satisfactory” rating constitutes “Marginal” or “Unsatisfactory” contract performance and may result in a decrement or withholding of payment, depending upon the degree to which the “Satisfactory” rating has been breached. Exceeding the “Satisfactory” rating constitutes “Very Good” or “Exceptional” contract performance, but only if the Government realizes specific benefits such as services or work products without any defects, accelerated deliveries of supplies or deliverables, etc. Exceeding the “Satisfactory” rating will not result in any additional payment or incentives. Assessment and assignment of performance ratings will be performed monthly by the Government for each CLIN at the Task Order (TO) level. For example, in the monthly review of the contractor’s services for a specific TO, the Government may assign a rating of “Satisfactory” for CLIN 0001, “Marginal” for CLIN 0002, “Exceptional” for CLIN 0003, etc. Any decrements or payment withholdings associated with a rating below “Satisfactory” will be applied at the CLIN level throughout the duration of contract performance until performance is validated as improved. The COR will analyze the monthly individual performance ratings assigned for all CLINs to generate an overall contractor performance rating for the month. The overall monthly performance rating will be assigned by the COR based upon the lowest individual performance ratings assigned to the CLINs for the month. For example, if the contractor receives “Satisfactory” for CLIN 0001, “Marginal” for CLIN 0002, and “Exceptional” for CLIN 0003, the overall performance rating will be “Marginal” because it is the lowest rating for the month.

Upon the contractor submission of the MSR deliverable described in this PWS for inspection and acceptance, the COR will evaluate the contractor’s monthly performance, document their monthly rating assignments in the MSR, and provide a copy to the contractor. The contractor will provide a response to the Government within five (5) business days if they do not agree with the COR’s ratings as assigned. In the event of the contractor not agreeing with the COR’s ratings, the KO will review the contractor’s response and make the final rating determination.

7.2.2.1 General Performance Ratings

The following general performance ratings will be utilized by the Government for all services, supplies, work products, deliverables, etc. rendered by the contractor. All deliverables must be submitted compliant with the timelines identified in this PWS. Assessment and assignment these performance ratings will be performed by the Government at the Task Order (TO) level

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

for each of the following CLINs:

- CLIN 0001 – Transition In
- CLIN 0002, 1002, 2002, 3002, 4002 – Admin Support & Program Management
- CLIN 0006, 1006, 2006, 3006, 4006 – Site Support
- CLIN 0007, 1007, 2007, 3007, 4007 – Cybersecurity Support
- CLIN 0008, 1008, 2008, 3008, 4008 – Commercial Software Licensing
- CLIN 0009 – Transition Out

General Performance Ratings / AQLs	
Rating	Description
Exceptional	<u>Quality</u>: Services, supplies, work products, deliverables, etc. clearly exceed contractual requirements and achieved Government acceptance with no defects, deficiencies, negative customer feedback, or problems requiring corrective action reported. <u>Timeliness</u>: The contractor consistently rendered services, supplies, work products, deliverables, etc. before due dates and there are no action items, tasks, subtasks, activities, etc. past due. The COR will recommend the contractor be paid 100% of the invoice amount.
Very Good	<u>Quality</u>: Services, supplies, work products, deliverables, etc. met or exceeded contractual requirements and achieved Government acceptance with minor defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address defects, deficiencies, or negative customer feedback have clearly resolved any performance problems to the Government's satisfaction. <u>Timeliness</u>: The contractor rendered services, supplies, work products, deliverables, etc. on or before due dates and there are no action items, tasks, subtasks, activities, etc. past due. Corrective actions taken by the contractor were implemented prior to an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 100% of the invoice amount.
Satisfactory	<u>Quality</u>: Services, supplies, work products, deliverables, etc. met contractual requirements or achieved Government acceptance with defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address defects, deficiencies, or negative customer feedback appear to have resolved any performance problems to the Government's satisfaction. <u>Timeliness</u>: The contractor rendered services, supplies, work products, deliverables, etc. on or slightly after due dates (no later than 1 – 5 business days past due) or there are action items, tasks, subtasks, activities, etc. slightly past due (no later than 1 – 5 business days). Delays associated with performance were verified to not have caused impact to fuels operations or DLA

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

General Performance Ratings / AQLs	
Rating	Description
	Energy mission. Corrective actions taken by the contractor were implemented on or before an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 100% of the invoice amount.
Marginal	<u>Quality</u>: Services, supplies, work products, deliverables, etc. may not have met contractual requirements, narrowly meets contract requirements, or achieved Government acceptance with significant defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address significant defects, deficiencies, or negative customer feedback appear to be marginally effective at resolving performance problems to the Government's satisfaction. <u>Timeliness</u>: The contractor rendered services, supplies, work products, deliverables, etc. after due dates (between 6 – 10 business days past due) or there are action items, tasks, subtasks, activities, etc. past due (between 6 – 10 business days). Delays associated with performance may have caused a slight impact to fuels operations or DLA Energy mission. Corrective actions taken by the contractor were not fully implemented prior to an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 80% of the invoice amount.
Unsatisfactory	<u>Quality</u>: Services, supplies, work products, deliverables, etc. clearly did not meet contractual requirements or failed to achieve Government acceptance. Serious defects, deficiencies, or negative customer feedback was reported and corrective actions taken by the contractor appear to be or were confirmed as ineffective at resolving performance problems to the Government's satisfaction. <u>Timeliness</u>: The contractor did not render services, supplies, work products, deliverables, etc. or rendered them significantly behind schedule (greater than 6 business days past due) or recovery is not likely in a timely manner. Delays associated with performance have impacted fuels operations or DLA Energy mission. Corrective actions were not implemented prior to an agreed upon date as determined by the Government. Possible issues include, but are not limited to: missed deliverables / milestones, low quality documents requiring multiple reviews and rewrites, significant or serious complaints submitted by the customers, services do not comply with PWS requirements, or one or more cure notices have been issued. The COR will recommend withholding contractor payment and notify the Contracting Officer (KO) immediate remedy is needed.

Table 6 – General Performance Ratings / AQLs

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Example: The contractor rendered their services and delivered work products on time and met contractual requirements by achieving Government acceptance with some defects requiring corrective action. The contractor implemented corrective actions for the defective services and work products on or before the Government an agreed upon date, which appear to have resolved performance problems to the Government’s satisfaction. The contractor would receive a “Satisfactory” rating for the month and the COR would recommend payment of 100% for the applicable CLIN.

7.2.2.2 Preventative Maintenance (PM) Performance Ratings

The performance ratings for Preventive Maintenance (PM) will be evaluated based on the quality and timeliness of the contractor’s services. As part of the evaluation of services rendered, the Government will review the percentage of PM actions overdue each month (first day-last day of the month). All PM services will be pre-designated each month by the contractor derived from the HFAM PM schedule. The contractor will provide data on the timeliness and percentage of PMs completed for each month in the MSR to assist the Government in the evaluation of PM services and performance. Assessment and assignment these performance ratings will be performed by the Government at the Task Order (TO) level for the following CLINs:

- CLIN 0003, 1003, 2003, 3003, 4003 – Preventative Maintenance (PM)

Preventative Maintenance (PM) Performance Ratings / AQLs	
Rating	Description
Exceptional	<u>Quality:</u> Services, supplies, work products, deliverables, etc. clearly exceed contractual requirements and achieved Government acceptance with no defects, deficiencies, negative customer feedback, or problems requiring corrective action reported. <u>Timeliness:</u> 100% of scheduled PM’s were completed for the month. The COR will recommend the contractor be paid 100% of the invoice amount.
Very Good	<u>Quality:</u> Services, supplies, work products, deliverables, etc. met or exceeded contractual requirements and achieved Government acceptance with minor defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address defects, deficiencies, or negative customer feedback have clearly resolved any performance problems to the Government’s satisfaction. <u>Timeliness:</u> 95%-99% of scheduled PM’s were completed for the month. Corrective actions taken by the contractor were implemented prior to an agreed upon date as determined by the Government.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Preventative Maintenance (PM) Performance Ratings / AQLs	
Rating	Description
	The COR will recommend the contractor be paid 100% of the invoice amount.
Satisfactory	<u>Quality</u>: Services, supplies, work products, deliverables, etc. met contractual requirements or achieved Government acceptance with defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address defects, deficiencies, or negative customer feedback appear to have resolved any performance problems to the Government's satisfaction. <u>Timeliness</u>: 90%-94% of scheduled PM's were completed for the month. Delays associated with performance were verified to not have caused impact to fuels operations or DLA Energy mission. Corrective actions taken by the contractor were implemented on or before an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 100% of the invoice amount.
Marginal	<u>Quality</u>: Services, supplies, work products, deliverables, etc. may not have met contractual requirements, narrowly meets contract requirements, or achieved Government acceptance with significant defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address significant defects, deficiencies, or negative customer feedback appear to be marginally effective at resolving performance problems to the Government's satisfaction. <u>Timeliness</u>: 80%-89% of scheduled PM's were completed for the month. Delays associated with performance may have caused a slight impact to fuels operations or DLA Energy mission. Corrective actions taken by the contractor were not fully implemented prior to an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 80% of the invoice amount.
Unsatisfactory	<u>Quality</u>: Services, supplies, work products, deliverables, etc. clearly did not meet contractual requirements or failed to achieve Government acceptance. Serious defects, deficiencies, or negative customer feedback was reported and corrective actions taken by the contractor appear to be or were confirmed as ineffective at resolving performance problems to the Government's satisfaction. <u>Timeliness</u>: Less than 80% of scheduled PM's were completed for the month. Delays associated with performance have impacted fuels operations or DLA Energy mission. Corrective actions were not implemented prior to an agreed upon date as determined by the Government. Possible issues include, but are not limited to: missed deliverables / milestones, low quality documents requiring multiple reviews and rewrites, significant or serious complaints submitted by the customers, services do not comply with PWS requirements, or one or more cure notices have been issued.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Preventative Maintenance (PM) Performance Ratings / AQLs	
Rating	Description
	The COR will recommend withholding contractor payment and notify the Contracting Officer (KO) immediate remedy is needed.

Table 7 – Preventative Maintenance (PM) Performance Ratings / AQLs

Example: The contractor achieved Government acceptance with no defects reported for eight (8) out of ten (10) total PM services scheduled for the month (i.e. timeliness of 8/10 for SNOW cases or 80%). During weekly status reporting, the contractor failed to provide an acceptable justification for extension / deferment of untimely PM services. The contractor would receive a “Marginal” rating for the month and the COR would recommend payment of 80% for the applicable CLIN.

7.2.2.3 Technical Support Performance Ratings

The performance ratings for the contractor’s Technical Support will be evaluated based on the quality and timeliness of the contractor’s services. As part of the evaluation of services rendered, the Government will review the percentage of SNOW cases completed compliant with the service level requirements and Service Level Agreement (SLA) described herein based upon EST/UTC-4 Government Duty Hours. The Government will utilize this SLA in conjunction with the performance standards identified as follows to assess and assign performance ratings at the Task Order (TO) level for the following CLINs:

- CLIN 0004, 1004, 2004, 3004, 4004 – Technical Support

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Technical Support Service Level Agreement (SLA)				
Priority	Description	Assignment	Initial Review & Contact	Target Resolution / Escalation Timetable
Emergency	Government contacts contractor requesting emergency services due to a catastrophic system outage or critical safety hazard impacting fueling operations, posing a severe risk or issue to mission, personnel, assets, or the environment.	SNOW case assigned to technician within one (1) hour (regardless of time zone)	Verifiable attempt to establish responsive contact with the customer/user within two (2) hours (regardless of time zone) of SNOW case assignment to technician	Contractor maintains continuous status reporting until problem/issue resolved and SNOW case closed within one (1) calendar day of assignment to contractor support group. <u>or</u> Contractor maintains continuous status reporting until problem/issue resolved and SNOW case closed within a Government approved timetable. <u>or</u> Contractor maintains continuous status reporting until SNOW case problem/issue investigated, root cause(s) identified, and escalated for CM/Repair approval within a Government approved timetable.
High	A significant system malfunction or performance degradation impacting fueling operations, mission, personnel, or assets with available workarounds or redundancies.	SNOW case assigned to technician within one (1) business hour	Verifiable attempt to establish responsive contact with the customer/user within two (2) business hours of SNOW case assignment to technician	Problem/issue resolved and SNOW case closed within three (3) business days of assignment to contractor support group. <u>or</u>

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Technical Support Service Level Agreement (SLA)				
Priority	Description	Assignment	Initial Review & Contact	Target Resolution / Escalation Timetable
				SNOW case problem/issue investigated, root cause(s) identified, and escalated to the Government for CM/Repair approval within three (3) business days of assignment to contractor support group.
Medium	A non-critical system malfunction or performance degradation causing minor impact or disruptions to fueling operations, mission, personnel, or assets.	SNOW case assigned to technician within two (2) business hours	Verifiable attempt to establish responsive contact with the customer/user within four (4) business hours of SNOW case assignment to technician	Problem/issue resolved and SNOW case closed within ten (10) business days of assignment to contractor support group. <u>or</u> SNOW case problem/issue investigated, root cause(s) identified, and escalated to the Government for CM/Repair approval within ten (10) business days of assignment to contractor support group.
Low	General, routine, or minor system adjustments, requests, or non-urgent repairs that do not impact fueling operations, mission, personnel, or assets.	SNOW case assigned to technician within four (4) business hours	Verifiable attempt to establish responsive contact with the customer/user within eight (8) business hours of SNOW case assignment to technician	Problem/issue resolved and SNOW case closed within fifteen (15) business days of assignment to contractor support group. <u>or</u>

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Technical Support Service Level Agreement (SLA)				
Priority	Description	Assignment	Initial Review & Contact	Target Resolution / Escalation Timetable
				SNOW case problem/issue investigated, root cause(s) identified, and escalated to the Government for CM/Repair approval within fifteen (15) business days of assignment to contractor support group.

Table 8 – Technical Support Team SLA

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Utilizing SNOW case metrics reported in the WAR and MSR deliverables in comparison to the SLA, the following criteria will be applied by the Government for evaluation of the contractor's Technical Support Team services:

Technical Support Performance Ratings / AQLs	
Rating	Description
Exceptional	<u>Quality:</u> Technical support services, work products, deliverables, etc. clearly exceed contractual requirements and achieved Government acceptance with no defects, deficiencies, negative customer feedback, or problems requiring corrective action reported. <u>Timeliness:</u> 100% of SNOW cases assigned to contractor technical support were successfully addressed within the SLA timeline based upon priority levels. The COR will recommend the contractor be paid 100% of the invoice amount.
Very Good	<u>Quality:</u> Technical support services, work products, deliverables, etc. met or exceeded contractual requirements and achieved Government acceptance with minor defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address defects, deficiencies, or negative customer feedback have clearly resolved any performance problems to the Government's satisfaction. <u>Timeliness:</u> 95% - 99% of SNOW cases assigned to contractor technical support were successfully addressed within the SLA timeline based upon priority levels. Corrective actions taken by the contractor were implemented prior to an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 100% of the invoice amount.
Satisfactory	<u>Quality:</u> Technical support services, work products, deliverables, etc. met contractual requirements or achieved Government acceptance with defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address defects, deficiencies, or negative customer feedback appear to have resolved any performance problems to the Government's satisfaction. <u>Timeliness:</u> 90% - 94% of SNOW cases assigned to contractor technical support were successfully addressed within the SLA timeline based upon priority levels. Delays associated with performance were verified to not have caused impact to fuels operations or DLA Energy mission. Corrective actions taken by the contractor were implemented on or before an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 100% of the invoice amount.
Marginal	<u>Quality:</u> Technical support services, work products, deliverables, etc. may not have met contractual requirements, narrowly meets contract requirements, or achieved Government acceptance with significant defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address significant defects, deficiencies, or negative

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Technical Support Performance Ratings / AQLs	
Rating	Description
	customer feedback appear to be marginally effective at resolving performance problems to the Government's satisfaction. <u>Timeliness:</u> 85% - 89% of SNOW cases assigned to contractor technical support were successfully addressed within the SLA timeline based upon priority levels and/or contractor technical support performance borders on unacceptability in terms of timeliness. Delays associated with performance may have caused a slight impact to fuels operations or DLA Energy mission. Corrective actions taken by the contractor were not fully implemented prior to an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 80% of the invoice amount.
Unsatisfactory	<u>Quality:</u> Technical support services, work products, deliverables, etc. clearly did not meet contractual requirements or failed to achieve Government acceptance. Serious defects, deficiencies, or negative customer feedback was reported and corrective actions taken by the contractor appear to be or were confirmed as ineffective at resolving performance problems to the Government's satisfaction. <u>Timeliness:</u> Less than 85% of SNOW cases assigned to contractor technical support were successfully addressed within the SLA timeline based upon priority levels and/or contractor technical support performance has been less than acceptable in terms of timeliness. Delays associated with performance have impacted fuels operations or DLA Energy mission. Corrective actions were not implemented prior to an agreed upon date as determined by the Government. Possible issues include, but are not limited to: missed deliverables / milestones, low quality documents requiring multiple reviews and rewrites, significant or serious complaints submitted by the customers, services do not comply with PWS requirements, or one or more cure notices have been issued. The COR will recommend withholding contractor payment and notify the Contracting Officer (KO) immediate remedy is needed.

Table 9 – Technical Support Performance Ratings / AQLs

7.2.2.4 Corrective Maintenance (CM) / Repair Services Performance Ratings

The performance ratings for the contractor's CM/Repair Services will be evaluated based on the quality and timeliness of the contractor's services. As part of the evaluation of services rendered, the Government will review the percentage of SNOW cases completed compliant with the SLA described herein based upon EST/UTC-4 Government Duty Hours. The Government will utilize

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

this SLA in conjunction with the performance standards identified as follows to assess and assign performance ratings at the Task Order (TO) level for the following CLINs:

- CLIN 0005, 1005, 2005, 3005, 4005 – CM/Repair

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

CM/Repair Service Level Agreement (SLA)		
Priority	Description	Target Resolution / Escalation Timetable
Emergency	Government contacts contractor requesting emergency services due to a catastrophic system outage or critical safety hazard impacting fueling operations, posing a severe risk or issue to mission, personnel, assets, or the environment.	Contractor maintains continuous status reporting until problem/issue resolved and SNOW case closed within five (5) calendar days of authorization to execute CM/Repair services. <u>or</u> Contractor maintains continuous status reporting until problem/issue resolved and SNOW case closed within a Government approved timetable for execution of CM/Repair services. <u>or</u> Contractor maintains continuous status reporting until SNOW case problem/issue investigated, root cause(s) identified, and escalated with appropriate documentation to assist with conversion into site support project within a Government approved timetable.
High	A significant system malfunction or performance degradation impacting fueling operations, mission, personnel, or assets with available workarounds or redundancies.	Problem/issue resolved and SNOW case closed within ten (10) calendar days of authorization to execute CM/Repair services. <u>or</u> Problem/ issue resolved and SNOW case closed within a Government approved timetable for execution of CM/Repair services. <u>or</u> SNOW case problem/issue investigated, root cause(s) identified, and escalated with appropriate documentation to assist with conversion into site support project within a Government approved timetable.

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

CM/Repair Service Level Agreement (SLA)		
Priority	Description	Target Resolution / Escalation Timetable
Medium	A non-critical system malfunction or performance degradation causing minor impact or disruptions to fueling operations, mission, personnel, or assets.	Problem/issue resolved and SNOW case closed within twenty (20) calendar days of authorization to execute CM/Repair services. <u>or</u> Problem/ issue resolved and SNOW case closed within a Government approved timetable for execution of CM/Repair services. <u>or</u> SNOW case problem/issue investigated, root cause(s) identified, and escalated with appropriate documentation to assist with conversion into site support project within a Government approved timetable.
Low	General, routine, or minor system adjustments, requests, or non-urgent repairs that do not impact fueling operations, mission, personnel, or assets.	Problem/issue resolved and SNOW case closed within thirty (30) calendar days of authorization to execute CM/Repair services. <u>or</u> Problem/ issue resolved and SNOW case closed within a Government approved timetable for execution of CM/Repair services. <u>or</u> SNOW case problem/issue investigated, root cause(s) identified, and escalated with appropriate documentation to assist with conversion into site support project within a Government approved timetable.

Table 10 – CM/Repair SLA

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Utilizing SNOW case metrics reported in the WAR and MSR deliverables in comparison to the SLA, the following criteria will be applied by the Government for evaluation of the contractor's CM/Repair services:

Corrective Maintenance (CM) / Repair Performance Ratings / AQLs	
Rating	Description
Exceptional	<u>Quality:</u> CM/Repair services, work products, deliverables, etc. clearly exceed contractual requirements and achieved Government acceptance with no defects, deficiencies, negative customer feedback, or problems requiring corrective action reported. <u>Timeliness:</u> 100% of SNOW cases assigned to contractor CM/Repair services were successfully addressed within the SLA timeline based upon priority levels. The COR will recommend the contractor be paid 100% of the invoice amount.
Very Good	<u>Quality:</u> CM/Repair services, work products, deliverables, etc. met or exceeded contractual requirements and achieved Government acceptance with minor defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address defects, deficiencies, or negative customer feedback have clearly resolved any performance problems to the Government's satisfaction. <u>Timeliness:</u> 95% - 99% of SNOW cases assigned to contractor CM/Repair services were successfully addressed within the SLA timeline based upon priority levels. Corrective actions taken by the contractor were implemented prior to an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 100% of the invoice amount.
Satisfactory	<u>Quality:</u> CM/Repair services, work products, deliverables, etc. met contractual requirements or achieved Government acceptance with defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address defects, deficiencies, or negative customer feedback appear to have resolved any performance problems to the Government's satisfaction. <u>Timeliness:</u> 90% - 94% of SNOW cases assigned to contractor CM/Repair were successfully addressed within the SLA timeline based upon priority levels. Delays associated with performance were verified to not have caused impact to fuels operations or DLA Energy mission. Corrective actions taken by the contractor were implemented on or before an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 100% of the invoice amount.
Marginal	<u>Quality:</u> CM/Repair services, work products, deliverables, etc. may not have met contractual requirements, narrowly meets contract requirements, or achieved Government acceptance with significant defects, deficiencies, or negative customer feedback reported. Corrective actions taken by the contractor to address significant defects, deficiencies, or negative customer feedback appear to be marginally effective at resolving performance problems to the

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

Corrective Maintenance (CM) / Repair Performance Ratings / AQLs	
Rating	Description
	Government's satisfaction. <u>Timeliness</u>: 85% - 89% of SNOW cases assigned to contractor CM/Repair services were successfully addressed within the SLA timeline based upon priority levels and/or contractor CM/Repair services performance borders on unacceptability in terms of timeliness. Delays associated with performance may have caused a slight impact to fuels operations or DLA Energy mission. Corrective actions taken by the contractor were not fully implemented prior to an agreed upon date as determined by the Government. The COR will recommend the contractor be paid 80% of the invoice amount.
Unsatisfactory	<u>Quality</u>: CM/Repair services, work products, deliverables, etc. clearly did not meet contractual requirements or failed to achieve Government acceptance. Serious defects, deficiencies, or negative customer feedback was reported and corrective actions taken by the contractor appear to be or were confirmed as ineffective at resolving performance problems to the Government's satisfaction. <u>Timeliness</u>: Less than 85% of SNOW cases assigned to contractor CM/Repair services were successfully addressed within the SLA timeline based upon priority levels and/or contractor CM/Repair services performance has been less than acceptable in terms of timeliness Delays associated with performance have impacted fuels operations or DLA Energy mission. Corrective actions were not implemented prior to an agreed upon date as determined by the Government. Possible issues include, but are not limited to: missed deliverables / milestones, low quality documents requiring multiple reviews and rewrites, significant or serious complaints submitted by the customers, services do not comply with PWS requirements, or one or more cure notices have been issued. The COR will recommend withholding contractor payment and notify the Contracting Officer (KO) immediate remedy is needed.

Table 11 – CM/Repair Performance Ratings / AQLs

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

SECTION C-8: DEFINITIONS & ACRONYMS

8.0 Definitions and Acronyms

This section provides a general outline of the definitions and acronyms used in this PWS. The DOD Dictionary of Military and Associated Terms is available on the Internet at http://www.dtic.mil/doctrine/dod_dictionary. Acronyms utilized throughout the base IDIQ and subsequent TOs are defined within each PWS. Inquiries to clarify use of acronyms may be sent to the KO or COR.

A&A	Assessment and Authorization
ADA	American Disabilities Act
AFS	Automated Fuel Systems
AFSS	Automated Fuel Service Stations
A&I	Assessment and Incorporate
ANSI	American National Standards Institute
AOR	Area of Responsibility
API	American Petroleum Institute
ATC	Authority to Connect
ATG	Automated Tank Gauging
ATO	Authority to Operate
C4ISR	Control, Communications, Computers, Intelligence, Surveillance and Reconnaissance
CAC	Common Access Card
CAP	Contractor Acquired Property
CCR	California Code of Regulations
CDI	Covered Defense Information
CDRL	Contract Data Requirements List
CE	Computing Environment
CEE	Chief Engineer
CFE	Contractor Furnished Equipment
CFM	Contractor Furnished Material
CFR	Code of Federal Regulations
C-I-A	Confidentiality, Integrity, and Availability
CM	Corrective Maintenance
CONUS	Continental United States
COR	Contracting Officer's Representative
CPARS	Contractor Performance Assessment Reporting
CPI	Critical Program Information

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

CS	Cybersecurity
CUI	Controlled Unclassified Information
CY	Calendar Year
DAG	Defense Acquisition Guidebook
DCP	Document Change Request
DCS	Distributed Control Systems
DD	Defense Directive
DFARS	Defense Federal Acquisition Regulation Supplement
DISA	Defense Information Systems Agency
DLA	Defense Logistics Agency
DLAH	Defense Logistics Agency Handbook
DoD	Department of Defense
DoDD	Department of Defense Directive
DoDI	Department of Defense Instruction
DoDM	Department of Defense Manual
DTM	Directive-Type Memorandum
DTSR	Designated Technical Support Representative → SEE TPOC
EAOTS	Energy Automation Operational Technology
EEPROM	Electrical Erasable Programmable Read Only
Memory EPA	Environmental Protection Agency
ETA	Estimated Time of Arrival
FAR	Federal Acquisition Regulation
FFP	Firm Fixed Price
FIPS	Federal Information Processing Standards
FISMA	Federal Information Security Management
FOUO	For Official Use Only
FY	Fiscal Year
GFE	Government Furnished Equipment
GFI	Government Furnished Information
GFP	Government Furnished Property
HFAM	Hydrant Fueling Automation Maintenance
HMI	Human Machine Interface
HPSD	Homeland Security Presidential Directive
HQDLA	Headquarters Defense Logistics Agency
IA	Information Assurance
IAS	Independent Alarm System
IAT	Information Assurance Technical
IAW	In Accordance With
ICS	Industrial Control Systems

Controlled Unclassified Information (CUI)
Source Selection Sensitive Information - See FAR 2.101 & 3.104
Page 131 of 134

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

IDIQ	Indefinite Delivery Indefinite Quantity
IP	Internet Protocol
IPR	In-Process Review
IT	Information Technology
ITSM	Information Technology Service Management
JPAS	Joint Personnel Adjudication System
KO	Contracting Officer
LOA	Letter of Authorization
LWD	Lost Workday
MIL HDBK	Military Handbook
MOV	Motor Operated Valves
MP ICAM	Mission Partner Identity, Credential, Access Management
MPM	Maintenance Program Manager
MPMS	Manual of Petroleum Measurement Standards
MR&E	Maintenance, Repair and Environmental
NACLC	National Agency Check with Law and Credit
NFPA	National Fire Protection Association
NISPOM	National Industrial Security Program Operating
NIST	National Institute of Standards and Technology
NIWC	Naval Information Warfare Center
NLT	No Later Than
NSS	National Security System
OCNUS	Outside Continental United States
OCS	Operationally Critical Support
OMB	Office of Management and Budget
OPE	Overfill Protection Equipment
OT	Operational Technology
OTUSF	Other Than U.S. Forces
PCP	Pump Control Panel
PE	Professional Engineer
PIV	Personal Identification Verification
PLC	Program Logic Controller
PM	Preventive Maintenance
PMP	Program Management Professional
POC	Point of Contact
PoP	Period of Performance
PRD	Project Requirements Document
PWS	Performance Work Statement
QC	Quality Control

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**

QCP	Quality Control Plan
RAPIDS	Real-Time Automated Personnel Identification
System RD	Restricted Duty
RFP	Request for Proposal
RMF	Risk Management Framework
RO	Responsible Officer
RTU	Remote Terminal Unit
SAAR	System Authorization Access Request
SAFE	Secure Access File Exchange
SATOC	Single Award Task Order Contract
SCADA	Supervisory Control and Data Acquisition
SCI	Sensitive Compartmented Information
SI	Systems Integrator
SLA	Service Level Agreement
SME	Subject Matter Expert
SO	Security Officer
SOP	Standard Operating Procedure
SOFA	Status of Forces Agreement
SPOT	Synchronized Pre-deployment & Operational Tracker
SSBI	Single Scope Background Investigation
STIG	Secure Technical Implementation Guide
TPOC	Technical Point of Contact
UFC	Unified Facilities Criteria
UFGS	Unified Facilities Guide Specification
UL	Underwriter Laboratories
UPS	Uninterruptable Power Supply
U.S.	United States
USACE	United States Army Corps of Engineers
U.S.C	United States Code
TASS	Trusted Associate Sponsorship System
TO	Task Order
WAC	Washington Administrative Code
WBS	Work Breakdown Structure

**ENERGY AUTOMATION OPERATIONAL TECHNOLOGY SUSTAINMENT (EAOTS)
HYDRANT FUELING AUTOMATION MAINTENANCE (HFAM) SUPPORT
INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ)
PERFORMANCE WORK STATEMENT (PWS)**