

Q&A- 36C77025Q0129 Lancaster Fan Replacement-Site Visit 5/7/2025

- Is there funding available for this project?
 - Yes the approvals have been granted.
- How long can we park our lifts?
 - Park as early and stay as late as you want. You are paying for the rental. We will give you an area to park them.
- What hours will they need to work?
 - Off hours Saturday and Sunday
- Will we be able to take the old fans? The solicitation states that.
 - **I just talked to our logistics manager, and he informed me that they will need to dismantle and leave onsite. Our team will need to access this equipment. We may need to mod the solicitation on this one.**
- Do we have access to 120-volt power?
 - Yes
- Who will be the site contact?
 - I will be your site contact Bill Byrd. If I am not available, Alice Hernandez will be available.
- What voltage are the fans?
 - 208 volt three phase.
- Will new controllers be needed?
 - Yes, all new equipment.