

SUPPLEMENTAL QUALITY ASSURANCE PROVISION (SQAP)					Prescribed by: eSOP 4155.05-001 Sponsor: J3	
REVISIONS						
REV	DESCRIPTION			DATE		APPROVED
1	ENERGY QAP C16.08-2			01/16/2025		
C16.08-2 TURBINE FUEL, AVIATION (JET A1) (INTO-PLANE) (DLA ENERGY JAN 2025)						
See below for Details.						
SUPPLEMENTAL QUALITY ASSURANCE PROVISION (SQAP)				DEFENSE LOGISTICS AGENCY, ENERGY 8725 JOHN J. KINGMAN RD FORT BELVOIR, VIRGINIA 22060-6222		
DISTRIBUTION STATEMENT - A	PREPARED BY MACLANE.SKYLAR.BRYANNA.1252141827 Digitally signed by MACLANE.SKYLAR.BRYANNA.1252141827 Date: 2025.01.16 15:53:01 +05'00'		DATE 1/16/2025	ITEM ENERGY QAP C16.08-2		
	APPROVED FOR PUBLIC RELEASE		REVIEWED BY ROSE.JAMAAL.R.1050293366 Digitally signed by ROSE.JAMAAL.R.1050293366 Date: 2025.01.21 13:19:58 +05'00'	DATE 01/21/2025	NSN 9130-01-305-4096	CODE ID NO. 52838
DISTRIBUTION IS "UNLIMITED"	APPROVED BY BANISZEWSKI.DANIEL.J.1287388698 Digitally signed by BANISZEWSKI.DANIEL.J.1287388698 Date: 2025.01.22 11:09:50 +05'00'		DATE 01/22/2025	SIZE A	SCALE 1:1	DRAWING NUMBER

C16.08-2 TURBINE FUEL, AVIATION (JET A1) (INTO-PLANE) (DLA ENERGY JAN 2025)

NATIONAL STOCK NUMBER	PRODUCT NOMENCLATURE	DLA ENERGY PRODUCT CODE
9130-01-305-4096	Turbine Fuel, Aviation, Jet A-1	IA1

Supplies delivered under this contract shall conform to all in-country environmental requirements applicable to the geographic location of the receiving activity on the date of delivery. In the event the in-country environmental requirement is more stringent than the specification contained in this contract, the Contractor shall deliver product that complies with the more stringent requirement. Product that fails to meet the more stringent requirement will be considered to be a nonconforming supply.

(a) **PERFORMANCE REQUIREMENTS.** Aviation turbine fuel shall conform to the requirements of the most recent version of ASTM D1655. Standard Specification for Aviation Turbine Fuels.

(b) **European, Middle Eastern and Asian Locations Only:** Aviation turbine fuel for European locations shall conform to the latest revision of Defence Standard 91-091.

(c) **ADDITIVES.**

(1) **FUEL SYSTEM ICING INHIBITOR (FSII).** When FSII is required by contract line item—

(i) The fuel shall contain 0.04 to 0.15 percent by volume FSII.

(ii) The FSII shall conform to the requirements of the latest version of specification MIL-DTL-85470C dated March 5, 2024, Inhibitor, Icing, Fuel System, High Flash NATO Code Number S-1745, found in the Acquisition Streamlining and Standardization Information System (ASSIST) database quick search (<https://quicksearch.dla.mil/qsSearch.aspx>), or ASTM D4171, Standard Specification for FSII's, Type III.

(iii) When using the 20-ounce aerosol can to introduce FSII during over the wing refueling, determine the fuel quantity and calculate the amount of additive required. The additive shall be added gradually during filling to permit proper blending in the fuel. One can of aerosol additive will inhibit 180 gallons of fuel to 0.087 percent by volume. The use of aerosol FSII is not permitted for U.S. Navy aircraft refueling.

(2) **CORROSION INHIBITOR / LUBRICITY IMPROVER (CI/LI).** When CI/LI is required by contract line item

(i) The additive shall conform to the latest revision of MIL-PRF-25017H with amendment 1 dated August 4, 2011, revalidated May 25, 2021, and be listed in Qualified Products List (QPL)-25017. In order to obtain dosage data for QPL-25017 additives, access the Qualified Products Database (QPD) <https://qpldocs.dla.mil/>, do a search for QPL number 25017, and click the MIL-PRF-25017 Category 1 link. The dosage information is located in the "source notes" for each qualified additive as minimum effective and maximum allowable concentrations in grams per cubic meter (g/m3).

(3) **STATIC DISSIPATER ADDITIVE (SDA).** When required by contract line item-

(i) SDA shall be added to the fuel and the conductivity limits of 50 to 600 picosiemens per meter (pS/m) at ambient temperature or 29.4°C (85°F), whichever is lower, unless otherwise directed by the procuring activity

(4) **METAL DEACTIVATOR (MDA).** MDA shall not be used unless the supplier has obtained PRIOR written consent from the procuring activity

(5) The Kerojet Aquarius additive, also known as just Aquarius, is neither authorized nor approved for use on these contracts.

(d) **SYNTHETIC BLEND COMPONENT (SBC) and CO-HYDROPROCESSED SYNTHESIZED KEROSENE**

(1) If fuel containing an SBC or a co-hydroprocessed synthesized kerosene is present at the location either at time of offer or any time after award, notification shall be made to the contracting point of contact with submission of relevant details regarding the blend percentage and which Annex of ASTM D7566 for the synthetic blend component used, and which feedstocks and co-processing percentage for co-hydroprocessed synthesized kerosene. Only synthetic blend components approved in ASTM D7566, MIL-DTL-83133, and MIL-DTL-5624 and co-hydroprocessed synthesized kerosene produced from approved feedstock and percentage in ASTM D1655, MIL-DTL-83133, and MIL-DTL-5624 shall be acceptable to the government.