

JUSTIFICATION REVIEW DOCUMENT – JUSTIFICATION AND APPROVAL (J&A)			
CONTROL #	[REDACTED]		
Program/Equipment	Johnson Controls Incorporated (JCI) Metasys Energy Management and Control Systems (EMCS) a proprietary system that operates approximately 5% of Brooke Army Medical Center (BAMC)		
Authority:	10 U.S.C 3204(a)(1) as implemented by FAR 6.302-1(c)	AMOUNT	[REDACTED]
Prepared by:	Name: La Rhonda Archie	Phone: 251-441-5539	
	Title: Contract Specialist		
Contracting Officer (See Sections 13-14 Below)	Name: Robert McAllister	Phone: 251-690-2912	
	Title: Contracting Officer		
Technical Rep (See Section 11 Below)	Name: Milan Portis	Phone: 251-721-4675	
	Title: Technical Manager		
Requirements Rep (See Section 12 Below)	Name: Amber Houston	Phone: 251-694-4016	
	Title: Lead Technical Manager		
Signatures Are Required Below:			
<i>I have reviewed this justification and find it adequate to support other than full and open competition</i>			
Deputy for Small Business	Signature: RODGERS.SONYA A.D. [REDACTED] Digitally signed by RODGERS.SONYA Date: 2025.03.14 09:35:45 -05'00'	Date: (See Signature)	
	Name: (See Signature)	Phone: [REDACTED]	
Project Manager (If no PM, use N/A)	Signature: DOWDY.STANLEY Y.F. [REDACTED] Digitally signed by DOWDY.STANLEY Date: 2025.03.13 16:16:59 -05'00'	Date: (See Signature)	
	Name: Stanley Dowdy	Phone: [REDACTED]	
Office of Counsel (OC)	Signature: ANGUS.KALEY.ELIZ ABETH [REDACTED] Digitally signed by ANGUS.KALEY Date: 2025.03.13 13:38:41 -05'00'	Date: (See Signature)	
	Name: (See Signature)	Phone: (See Signature)	
Business Oversight Branch (BOB) Chief	Signature: [REDACTED] Date: 2025.03.20 14:02:23 -05'00'	Date: (See Signature)	
	Name: James K. Kiesling	Phone: [REDACTED]	
Chief of Contracting Office (CoCO)	Signature: [REDACTED] 2025.03.21 09:12:50 -05'00'	Date: (See Signature)	
	Name: Carl Wade	Phone: [REDACTED]	

**Justification and Approval (J&A)
For
Other Than Full and Open Competition**

1. Contracting Activity: U.S. Army Corps of Engineers (USACE), Directorate of Contracting, Mobile Regional Contracting Center, P.O. Box 2288, Mobile, Alabama 36628-0001.

2. Description of Action: This Justification and Approval (J&A) is to specify Johnson Controls, Incorporated (JCI) METASYS Energy Management and Control Systems (EMCS) brand name specification to be included in Solicitation W9127824R0122, which is an Indefinite Delivery Indefinite Quantity (IDIQ) Multiple Award Task Order Contract (MATOC); specifically, this J&A is for the seed project at Brooke Army Medical Center (BAMC) and outlying buildings at Joint Base San Antonio (JBSA), Texas in support the Defense Health Agency (DHA) program. The seed project (first task order) will be an operation and maintenance (O&M) with repair and minor construction firm fixed price task order, using DHA Fiscal Year (FY) 2025 O&M funds. The period of performance for the BAMC seed project is a one year base period with four one year options. This brand name J&A is limited to the seed project task order and is not applicable to the base contracts or any subsequent task orders expected under this MATOC.

3. Description of Supplies/Services: The U.S. Army Corps of Engineers, Mobile District (SAM) intends to place a brand name specification under a new O&M with incidental Repair and Minor Construction task order at BAMC, JBSA, Texas.

The installed Metasys Field Devices and Centrifugal Chillers are JCI items and are maintained under O&M contracts at BAMC and outlying buildings by the O&M contractor (awardee). Based on historical data of similar requirements, the total estimated dollar value is over five years, annually.

Item	Brand	Facility
Chiller System/Field Devices maintenance	JCI	Main Hospital
HVAC Equipment, Fire Detection, Fire Suppression, and Digital Solutions, Controls	JCI	Outlying Buildings – System operates approximately 5% of the facility.

4. Authority Cited: The statutory authority permitting acquisition of this requirement by other than full and open competition is 10 U.S.C 3204(a)(1), as implemented by FAR 6.302-1 “Only One Responsible Source and No Other Supplies or Services Will Satisfy Agency Requirements”.

5. Reason for Authority Cited: As set forth in FAR 6.302-1(a)(2), when the supplies or services required by the agency are available from one source, or for DoD, National Aeronautics and Space Administration, and the Coast Guard, from only one or a limited number of sources, and no other types of supplies or services will satisfy agency requirements, full and open competition need not be provided. This authority is applicable to the brand-name descriptions in accordance with FAR 6.302-1(c). Additionally, FAR 6.302-1(c)(ii)(A) & (B) state the J&A approval/threshold requirements are only applicable to the portion of the acquisition specific to the brand-name specification, and the J&A should indicate that the use of such descriptions in the

applicable portion of the acquisition is essential to the Government's requirements, which precludes consideration of products from other manufacturers.

- a. Background: The O&M with incidental repair and minor construction mission at BAMC is a new requirement. BAMC is the United States Army and DoD's only Continental United States (CONUS) ten story Level I Trauma Center at approximately 4M square feet with a rooftop and a ground level Heliport. BAMC is home to the DoD's Burn Center; Bone Marrow Transplant Center; Traumatic Brain Injury (TBI) Research; 34 Operating Rooms (28 trauma and general surgery), 2 Oral Maxillofacial Surgery (OMFS) Suites, 2 Labor & Delivery (L&D) Suites, and 2 Burn Center Suites; 66 Critical Care Beds; a Cardiac Catheter Center; 2 Central Energy Plants/Central Utility Plants (CEPs/CUPs); Nine Clinical Pharmacies with Compounding Rooms; 2 Medical Linear Accelerators (LINAC); 3 Magnetic Resonance Imaging (MRI) units; 4 Computed Tomography (CT); a Computerized Axial Tomography (CAT) unit; 2 Clinical Labs; a Nutritional Medicine Dining Facility with outlying cafeterias and 3rd Party concession areas; and Center for the Intrepid (CFI) pioneering cutting-edge Limb Salvage, Prosthetics and rehabilitation procedures. BAMC is not a single contiguous facility. It is comprised of geographically separated facilities within the Medical Facilities Annex, Fort Sam Houston, Camp Bullis, and other Joint Base San Antonio Installations. There are two outpatient pharmacies, two outpatient clinics and two dental clinics on Fort Sam Houston (FSH). The BAMC Central Energy Plants consume approximately 14,000 tons of chilled water per minute; approximately 4,000 kilowatt (kW) per feeder per second, and over 80,000 British Thermal Units (BTUs) per hour from four boilers in the winter months.
- b. Justification: The JCI METASYS brand name specification is essential to this procurement as BAMC's EMCS systems all use JCI METASYS EMCS and its components. JCI has provided maintenance and upgrades to its METASYS software since the system was installed base-wide beginning in 1986. The EMCS is critical to the mission and sustainment of BAMC operations. JCI Chillers are proprietary systems that require parts and services from a licensed service technician. Since JCI retains its proprietary rights to the METASYS software, JCI is the only brand for the building service and components necessary to perform all necessary O&M requirements at BAMC. In order to replace, install, or modify this system, the subcontractor will need to be a JCI Controls Partner and use JCI components/equipment. Continued maintenance and operability of these critical systems have a direct impact on the hospital's functionality, directly impacting to the life, health, and safety for patients at BAMC.
- c. Alternative: JCI alone possesses the proprietary equipment necessary to integrate with the current system in place at BAMC. Application of JCI METASYS EMCS's is essential to meeting the Government's requirements, thereby precluding consideration of another product. The only alternative would be utilizing a different brand. However, this would require not only purchasing the component(s) but also purchasing a new EMCS and all related equipment, which would then be specific to that brand name. This is not a feasible approach. Use of the JCI METASYS EMCS offers the only solution that will meet the project requirements while also allowing the user to meet their mission requirements.

- [REDACTED]
- [REDACTED]
- d. Impact: If this J&A is not approved, USACE's O&M mission at BAMC will not be executed in accordance with user requirements. Other areas of concern include introduction of incompatible components/hardware, accessibility of local service, compatibility of software/hardware upgrades, and availability of spare parts. Any other controls provider is unable to provide the required software/hardware upgrades, training of day-to-day operations, manuals, and extended warranty of parts. Manufacturer support from JCI is a major concern and may be compromised if parts/services were sought through a third-party vendor.

6. Efforts to Obtain Competition:

- a. Effective competition: The Contracting Officer published the notice required by FAR 5.201, as described below. In accordance with FAR 5.2, Synopses of Proposed Contract Action, a Notice of Intent under Notice ID W9127822R0122 for NAICS 236220, Commercial and Institutional Building Construction, to include the brand name specifications for JCI METASYS EMCS equipment was posted to SAM.gov on 12 February 2025 with a response date of 27 February 2025. No responses were received.
- b. Subcontracting competition: JCI Metasys EMCS equipment is commercially available off-the-shelf equipment. The equipment will be purchased by subcontract of the competitively selected prime contractor for the continued O&M coverage at BAMC and its outlying buildings.

7. Actions to Increase Competition: There are no known actions to be taken to increase competition for similar future procurements that would not result in increased project costs, reduced efficiencies and increased overhead costs from installation and maintenance of an entirely different EMCS equipment system.

8. Market Research: A special notice under Notice ID W9127824R0122 was posted to SAM.gov on 12 February 2025 and requested responses by 27 February 2025. The special notice stated the intent was to use a brand name specification for the EMCS equipment and requested interested parties to submit their qualifications. No responses were received to this special notice.

9. Interested Sources: This J&A will be posted with the issuance of the solicitation in accordance with FAR 5.102(a)(6).

10. Other Facts: Reasonable efforts to retrieve the following items from computer records, contract files, competition advocate office files or other sources to support the use of other than full and open competition as follows:

- a. Procurement history:

- (1) This is a new procurement. It will be competed as the seed project via a MATOC solicitation.

- b. Other Facts: There are no additional facts to add in support of the JCI J&A.

11. **Technical Certification:** I certify that the supporting data under my cognizance which are included in the justification are accurate and complete to the best of my knowledge and belief.

Name: Milan Portis
Title: Technical Manager

PORTIS.MILAN.ELLIS [Redacted]
Digitally signed by PORTIS.MILAN.ELLIS [Redacted]
Date: 2025.03.13 08:17:32 -05'00'

Date: See Signature

Signature

12. **Requirements Certification:** I certify that the supporting data under my cognizance which are included in the justification are accurate and complete to the best of my knowledge and belief.

Name: Aimee McCormick
Title: Program Manager

MCCORMICK.AIMEE.ELI [Redacted]
ZABETH [Redacted]
Digitally signed by MCCORMICK [Redacted]
Date: 2025.03.13 16:09:48 -05'00'

Date: See Signature

Signature

13. **Fair and Reasonable Cost Determination:** I hereby determine that the anticipated cost to the Government for this contract action will be fair and reasonable based on analysis that includes comparison with the Government Estimate. In accordance with FAR 15.403-1(b)(1), Certified Cost & Pricing Data will not be required for this action.

Name: Robert S. McAllister
Title: Contracting Officer

MCALLISTER.ROBER [Redacted]
T.S. [Redacted]
Digitally signed by MCALLISTER.ROBERT.S [Redacted]
Date: 2025.03.14 10:14:33 -05'00'

Date: See Signature

Signature

14. **Contracting Officer Certification:** I certify that this justification is accurate and complete to the best of my knowledge and belief.

Name: Robert S. McAllister
Title: Contracting Officer

MCALLISTER.ROBER [Redacted]
T.S. [Redacted]
Digitally signed by MCALLISTER.ROBERT.S [Redacted]
Date: 2025.03.14 10:15:28 -05'00'

Date: See Signature

Signature

[REDACTED]

[REDACTED]

Approval

Based on the foregoing justification, I hereby approve the procurement of JCI METASYS EMCS equipment on an other than full and open competition basis pursuant to the authority of FAR 6.302-1 and 10 U.S.C. 3204(a)(1). The approval is subject to availability of funds, and provided that the services and property herein described have otherwise been authorized for acquisition.

Approved By:

MCALLISTER.ROB

Digitally signed by
MCALLISTER.ROBERT [REDACTED]

ERT.S. [REDACTED]

Date: 2025.03.14 10:18:02 -05'00'

Date: See Signature

ROBERT S. MCALLISTER

Contracting Officer

U.S. Army Corps of Engineers, Mobile District