

FAN COIL UNIT SCHEDULE

TRAIN COIL UNIT SCHEDULE																					
UNIT NO.	CFM		O.A. CFM	EXTERNAL STATIC PRESSURE (IN. WG)	CHILLED WATER COOLING COIL										HOT WATER HEATING COIL				MAX. MOTOR INPUT (H.P.TS)	FILTER ACCESS	NOTES
	NOMINAL	ACTUAL			MIN. TOTAL CAPACITY (BTU/HR)	MIN. SENS. CAPACITY (BTU/HR)	EAT (DB / WB)	LAT (DB / WB)	APPROX. WATER TEMP. RISE (°F)	GPM	MAX. PD (FT. WG)	MIN. CAPACITY (BTU/HR)	EAT (DB)	GPM	MAX. PD (FT. WG)						
FCU-1	800	640	105	0.30	22,310	16,335	80 / 61	56.7 / 56.0	10	4.5	8.2	16,344	60	1.6	4.4	240	BOTTOM				
FCU-2	800	100	110	0.30	22,108	16,130	80 / 61	56.7 / 56.0	10	4.5	8.2	16,242	60	1.7	11.0	240	BOTTOM				
FCU-3	800	510	105	0.30	20,719	14,825	80 / 61	55.5 / 54.4	10	4.2	7.2	15,943	60	1.4	7.8	250	BOTTOM				
FCU-4	800	530	80	0.30	14,714	10,671	80 / 61	56.7 / 56.0	10	3.0	3.5	12,543	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-5	600	530	140	0.30	17,300	10,744	80 / 61	56.7 / 56.0	10	3.0	3.5	12,543	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-6	600	530	80	0.30	15,338	10,841	80 / 61	57.8 / 57.2	10	3.0	3.5	12,543	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-7	800	510	130	0.30	20,423	13,130	80 / 61	55.5 / 54.4	10	4.2	7.2	15,943	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-8	800	530	40	0.30	14,714	9,744	80 / 61	57.8 / 57.2	10	3.0	3.5	12,543	60	1.4	7.8	250	BOTTOM	MEDIUM SPEED			
FCU-9	400	440	100	0.30	14,712	8,482	80 / 61	57.4 / 56.8	10	2.4	3.3	11,642	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-10	800	515	40	0.30	9,084	6,885	80 / 61	56.6 / 56.1	10	1.8	5.5	7,484	60	1.2	5.0	220	BOTTOM	MEDIUM SPEED			
FCU-11	600	530	0	0.30	11,942	11,242	80 / 61	54.2 / 50.5	10	2.3	2.1	12,543	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-12	800	530	60	0.30	16,332	9,466	80 / 61	58.4 / 57.1	10	2.7	2.4	12,543	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-13	1000	715	115	0.30	27,264	14,936	80 / 61	55.4 / 54.8	10	3.4	13.0	10,414	60	1.8	14.4	310	BOTTOM	MEDIUM SPEED			
FCU-14	800	120	80	0.30	17,641	12,454	80 / 61	55.4 / 50.7	10	3.4	13.0	10,414	60	1.8	14.4	310	BOTTOM	MEDIUM SPEED			
FCU-15	800	510	85	0.30	20,448	14,952	80 / 61	56.5 / 55.1	10	3.6	5.4	17,107	60	1.7	10.4	240	BOTTOM	MEDIUM SPEED			
FCU-16	800	510	85	0.30	20,448	14,952	80 / 61	56.5 / 55.1	10	3.6	5.4	17,107	60	1.7	10.4	240	BOTTOM	MEDIUM SPEED			
FCU-17	800	605	140	0.30	16,648	10,837	80 / 61	57.1 / 56.4	10	4.1	6.9	13,543	60	1.4	7.8	250	BOTTOM	MEDIUM SPEED			
FCU-18	1000	440	115	0.30	21,264	14,936	80 / 61	56.9 / 56.1	10	3.4	3.4	14,975	60	1.4	6.5	260	BOTTOM	MEDIUM SPEED			
FCU-19	800	530	100	0.30	15,334	11,201	80 / 61	57.1 / 57.0	10	3.1	3.7	12,534	60	1.5	10.4	445	BOTTOM				
FCU-20	800	530	100	0.30	15,053	11,116	80 / 61	54.5 / 58.0	10	3.1	3.7	13,068	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-21	800	530	100	0.30	15,406	9,788	80 / 61	57.1 / 57.0	10	3.1	3.7	12,543	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-22	800	530	100	0.30	14,728	10,744	80 / 61	54.6 / 58.2	10	3.0	3.5	13,068	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-23	800	530	100	0.30	14,586	10,744	80 / 61	54.6 / 58.2	10	3.0	3.5	13,068	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-24	800	530	100	0.30	14,586	10,744	80 / 61	54.6 / 58.2	10	3.0	3.5	13,068	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-25	800	510	120	0.30	20,611	9,257	80 / 61	54.6 / 58.2	10	3.0	3.5	13,068	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-26	800	640	130	0.30	22,258	14,666	80 / 61	55.6 / 55.1	10	4.1	6.9	13,662	60	1.4	7.8	250	BOTTOM	MEDIUM SPEED			
FCU-27	600	530	40	0.30	16,582	11,332	80 / 61	57.4 / 56.7	10	4.4	7.4	16,344	60	1.6	4.4	240	BOTTOM	MEDIUM SPEED			
FCU-28	600	530	80	0.30	14,644	10,196	80 / 61	58.0 / 57.3	10	3.5	4.1	12,543	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-29	400	380	80	0.30	15,034	8,445	80 / 61	56.5 / 55.9	10	2.6	10.6	10,241	60	1.0	3.6	220	BOTTOM	MEDIUM SPEED			
FCU-30	600	530	50	0.30	11,265	11,265	80 / 61	57.8 / 57.2	10	3.0	3.5	10,241	60	0.4	2.3	185	BOTTOM				
FCU-31	800	100	70	0.30	20,712	15,443	80 / 61	57.1 / 56.4	10	4.1	6.9	16,832	60	1.3	5.1	220	BOTTOM	MEDIUM SPEED			
FCU-32	800	380	80	0.30	13,366	9,242	80 / 61	56.1 / 55.1	10	2.7	2.4	10,241	60	1.7	11.0	240	BOTTOM				
FCU-33	600	640	140	0.30	17,381	9,241	80 / 61	58.5 / 57.6	10	3.5	4.6	15,206	60	0.9	3.0	170	BOTTOM	LOW SPEED			
FCU-34	800	100	0	0.30	14,751	14,751	80 / 61	58.6 / 57.4	10	3.0	3.4	16,632	60	1.7	11.0	240	BOTTOM				
FCU-35	400	350	0	0.30	7,380	7,380	80 / 61	58.5 / 57.8	10	1.5	3.4	9,316	60	0.8	1.4	185	BOTTOM				
FCU-36	200	230	0	0.30	4,523	4,523	80 / 61	60.0 / 58.5	10	0.4	6.7	5,465	60	0.5	0.6	120	BOTTOM				
FCU-37	1200	1150	0	0.30	24,550	24,550	80 / 61	58.0 / 57.2	10	6.0	8.4	21,324	60	1.7	15.5	475	BOTTOM				
FCU-38	1000	440	0	0.30	20,305	20,305	80 / 61	58.0 / 57.3	10	4.1	7.8	22,334	60	1.5	10.4	445	BOTTOM				
FCU-39	400	380	60	0.30	11,817	8,753	80 / 61	56.8 / 56.1	10	2.4	4.2	10,241	60	0.4	2.3	185	BOTTOM				

- NOTES:
- UNITS SHALL BE THE HORIZONTAL CONCEALED TYPE WITH DIRECT DRIVE FAN.
 - PROVIDE AUXILIARY DRAIN PAN UNDER UNIT VALVES.
 - UNIT COOLING CAPACITIES BASED ON 45° F. ENT. WATER TEMP., THROUGHWAY FILTER, NET COIL, AND HIGH FAN SPEED OPERATION UNLESS INDICATED OTHERWISE.
 - UNIT HEATING CAPACITY BASED ON 180° F. ENT. WATER TEMP., THROUGHWAY FILTER, AND HIGH FAN SPEED OPERATION UNLESS INDICATED OTHERWISE.
 - 120 VOLTS, SINGLE PHASE POWER REQUIREMENT.
 - PROVIDE UNIT WITH A UNIT-MOUNTED FAN SPEED SWITCH.
 - FCU-18, 31, 38 - HX FLOW BASED ON 30° MTD.

AIR-COOLED CHILLER SCHEDULE

AIR-COOLED CHILLER SCHEDULE														
UNIT NO.	MIN. CAPACITY (TONS)	EVAPORATOR				AIR ENT. COND. (°F)	NO. REFRIG. CIRCUITS	MIN. NO. STEPS UNLOADING	ELECTRICAL DATA			MAX. FULL-LOAD KW/TON	REMARKS	
		GPM	ENT (°F)	LHT (°F)	MAX PD (FT. HG.)				FOULING FACTOR	MINIMUM CIRCUIT AMPS	VOLTS			PHASE
AC-1	53.0	133.2	55	45	15	0.00025	45	2	4	323.3	208	3	115	(1)

- NOTES:
- PROVIDE WITH FLOW SWITCH, HOT GAS BY-PASS, CONDENSER GRILLES, CONTROLS TRANSFORMER, PRESSURE GAGES, OIL PRESSURE SWITCH AND DDC CONTROLLER.

PUMP SCHEDULE

UNIT NO.	SERVICE	TYPE	GPM	HEAD (FT. WG)	RPM	MIN. EFF. (%)	HP	VOLTS	PHASE	NEMA STARTER SIZE	REMARKS
P-1 & 1A	CHILLED WATER	BASE MOUNTED CENTRIFUGAL	133.2	70	1750	60.2	5	208	3	1	(1)
P-2 & 2A	HOT WATER	IN-LINE CENTRIFUGAL	58.6	48	1750	44.9	2	208	3	0	
ACP-1	A/C CONDENSATE	AUTOMATIC CONDENSATE PUMP	20 GPM	4	-	1/50	-	115	1	-	(2)

- NOTES:
- PROVIDE WITH SUCTION DIFFUSER.
 - MINIMUM TANK SIZE: 7' x 4' x 4.5', PROVIDE WITH SAFETY SWITCH.

STEAM-TO-HOT WATER CONVERTOR SCHEDULE

UNIT NO.	MIN. CAPACITY (BTU/HR)	TUBE SIDE		SHELL SIDE	REMARKS
		GPM	ENT. (°F)		
CONV-1	586,000	58.6	180	0.4	615

HOT WATER CONVERTOR SCHEDULE

UNIT NO.	MIN. CAPACITY (BTU/HR)	GPM	LENGTH (IN.)	HEIGHT (IN.)	REMARKS
CONV-1	5000	0.5	36	18	

- NOTES:
- CAPACITIES BASED ON 180° F. ENT. WATER TEMP. AND 65° F. ENT. AIR TEMP.
 - PROVIDE WITH INTEGRAL THERMOSTAT AND CONTROL VALVE.

GRILLE, REGISTER & DIFFUSER SCHEDULE

MARK	TYPE	SERVICE	CFM RANGE	NECK SIZE	MAX. PD.	REMARKS
(A)	LINEAR DIFFUSER	SUPPLY	10-105	6"ø	.07"	4'-0" LONG, 2 - 3/4" SLOTS SEE NOTE 1
(B)	CEILING DIFFUSER	SUPPLY	10-125	6' x 6'	.05"	FIXED PATTERN 24" x 24" LAY-IN PANEL
(C)	CEILING DIFFUSER	SUPPLY	135-220	8' x 8'	.05"	FIXED PATTERN 24" x 24" LAY-IN PANEL
(D)	CEILING DIFFUSER	SUPPLY	235-320	10' x 10'	.05"	FIXED PATTERN 24" x 24" LAY-IN PANEL
(E)	LINEAR DIFFUSER	SUPPLY	140	8"ø	.07"	4'-0" LONG, 3 - 3/4" SLOTS SEE NOTE 1
(F)	CEILING REGISTER	RETURN	130-300	10' x 14'	.05"	LOUVER FACE, 45° DEFLECTION 3/4" SPACING, 24" x 24" LAY-IN
(G)	CEILING REGISTER	RETURN	310-515	12' x 20'	.05"	LOUVER FACE, 45° DEFLECTION 3/4" SPACING, 24" x 24" LAY-IN
(H)	CEILING REGISTER	RETURN	530-680	14' x 22'	.05"	LOUVER FACE, 45° DEFLECTION 3/4" SPACING, 24" x 24" LAY-IN
(J)	CEILING GRILLE	EXHAUST	100-200	8' x 8'	.05"	1/2" x 1/2" x 1/2" EGG-CRATE
(K)	LINEAR DIFFUSER	SUPPLY	385-410	10"ø	.10"	4'-0" LONG, 4 - 3/4" SLOTS SEE NOTE 1
(L)	CEILING REGISTER	RETURN	50-105	6' x 8'	.05"	LOUVER FACE, 45° DEFLECTION 3/4" SPACING
(M)	CEILING DIFFUSER	SUPPLY	370-345	12' x 12'	.04"	FIXED PATTERN 24" x 24" LAY-IN PANEL
(N)	CEILING GRILLE	TRANSFER	80-170	10' x 8'	.05"	LOUVER FACE
(P)	CEILING REGISTER	RETURN	835	16' x 22'	.06"	LOUVER FACE, 45° DEFLECTION 3/4" SPACING, 24" x 24" LAY-IN
(R)	CEILING GRILLE	EXHAUST	385	12' x 12'	.05"	1/2" x 1/2" x 1/2" EGG-CRATE
(S)	CEILING GRILLE	TRANSFER	200	12' x 12'	.05"	LOUVER FACE, 45° DEFLECTION 3/4" SPACING

THE FOLLOWING NOTES ARE TYPICAL UNLESS OTHERWISE NOTED.

- PROVIDE DIFFUSERS AND REGISTERS WITH VOLUME DAMPERS.
- PROVIDE BAKED OFF-WHITE ENAMEL FINISH, INCLUDING HEADS OF SCREWS.
- PROVIDE 4-WAY PATTERN CEILING DIFFUSERS, DOWN ON PLANS OR SCHEDULE.
- PROVIDE MAXIMUM NC-25 AT HIGHEST CFM.
- MAXIMUM PRESSURE DROP SHALL INCLUDE VOLUME DAMPER WHERE DAMPER IS PROVIDED.
- PROVIDE SQUARE TO ROUND TRANSITION AS REQUIRED.
- CONTRACTOR FABRICATED PLENUM (SEE DETAIL, SHEET M-5).

HOT WATER UNIT HEATER SCHEDULE

UNIT NO.	APPROX. CFM	MIN.
----------	-------------	------