

Post site visit Questions and Answers:

1. What if parts are missing?

Answer: The contractor is responsible for any missing hardware and parts. This will be addressed as a cost-plus modification.

2. Are AutoCAD files available for the 56-2700 wing furniture designated for disposal, and for 56-2600 swing space?

Answer: Yes, AutoCAD files are available.

3. Is there disposal facilities on site?

Answer: No, the contractor will be responsible for the disposal processes and containers.

4. Is the contractor responsible for demoing the old data lines?

Answer: Yes, the contractor is responsible for demoing the old data lines from the suite to the closet.

5. Is the contractor wiring the data from the cubes to the data closet?

Answer: Yes, there will be two data ports per cube.

6. Is the contractor responsible for installing power whips to the cubes?

Answer: Yes, the contractor will be responsible for this installation.