

FAN COIL UNIT SCHEDULE																		
UNIT NO.	CFM		O.A. CFM	EXTERNAL STATIC PRESSURE (IN. WG.)	CHILLED WATER COOLING COIL						HOT WATER HEATING COIL				MAX. MOTOR INPUT (WATTS)	FILTER ACCESS	NOTES	
	NOMINAL	ACTUAL			MIN. TOTAL CAPACITY (BTU/HR)	MIN. SENS. CAPACITY (BTU/HR)	EAT (DB / WB)	LAT (DB / WB)	APPROX. WATER TEMP. RISE (°F)	GPM	MAX. PD (FT. WG.)	MIN. CAPACITY (BTU/HR)	EAT (DB)	GPM				MAX. PD (FT. WG.)
FCU-1	800	640	105	0.30	22,310	16,335	80 / 67	56.7 / 56.0	10	4.5	8.2	16,344	68	1.6	9.9	240	BOTTOM	
FCU-2	800	700	110	0.30	22,705	16,730	80 / 67	56.7 / 56.0	10	4.5	8.2	16,632	68	1.7	11.0	240	BOTTOM	
FCU-3	800	570	105	0.30	20,718	14,803	80 / 67	55.5 / 54.9	10	4.2	7.2	13,543	68	1.4	7.8	250	BOTTOM	MEDIUM SPEED
FCU-4	600	530	80	0.30	14,719	10,671	80 / 67	57.8 / 57.2	10	3.0	3.5	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-5	600	530	140	0.30	17,300	10,744	80 / 67	56.7 / 56.0	10	3.8	5.4	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-6	600	530	80	0.30	15,338	10,847	80 / 67	57.8 / 57.2	10	3.0	3.5	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-7	800	570	130	0.30	20,423	13,130	80 / 67	55.5 / 54.9	10	4.2	7.2	13,543	68	1.4	7.8	250	BOTTOM	MEDIUM SPEED
FCU-8	600	530	90	0.30	14,797	9,744	80 / 67	57.8 / 57.2	10	3.0	3.5	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-9	600	440	100	0.30	14,272	8,482	80 / 67	57.4 / 56.8	10	2.9	3.3	11,642	68	1.2	5.0	220	BOTTOM	MEDIUM SPEED
FCU-10	400	315	40	0.30	9,084	6,985	80 / 67	56.6 / 56.1	10	1.8	5.5	7,484	68	0.7	1.5	150	BOTTOM	MEDIUM SPEED
FCU-11	600	530	0	0.30	11,342	11,342	80 / 67	54.2 / 58.5	10	2.3	2.1	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-12	600	530	60	0.30	13,632	9,968	80 / 67	58.4 / 57.7	10	2.7	2.9	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-13	1000	775	115	0.30	27,264	19,936	80 / 67	55.4 / 54.8	10	5.4	13.0	18,414	68	1.8	14.9	370	BOTTOM	MEDIUM SPEED
FCU-14	800	720	80	0.30	17,641	12,954	80 / 67	54.5 / 58.1	10	3.6	5.4	17,107	68	1.7	10.9	240	BOTTOM	
FCU-15	800	570	85	0.30	20,448	14,952	80 / 67	55.5 / 54.9	10	4.2	7.2	13,543	68	1.4	7.8	250	BOTTOM	MEDIUM SPEED
FCU-16	800	570	85	0.30	20,448	14,952	80 / 67	55.6 / 55.1	10	4.1	6.9	13,543	68	1.4	7.8	250	BOTTOM	MEDIUM SPEED
FCU-17	600	605	140	0.30	18,648	10,837	80 / 67	57.7 / 56.9	10	3.8	5.4	14,375	68	1.4	6.5	260	BOTTOM	
FCU-18	1000	440	115	0.30	27,264	19,936	80 / 67	56.8 / 56.1	10	5.4	13.0	22,334	68	1.5	10.9	445	BOTTOM	
FCU-19	600	530	70	0.30	15,739	11,801	80 / 67	57.7 / 57.0	10	3.1	3.7	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-20	600	550	70	0.30	15,053	11,116	80 / 67	54.5 / 58.0	10	3.1	3.7	13,068	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-21	600	530	100	0.30	15,406	9,788	80 / 67	57.7 / 57.0	10	3.1	3.7	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-22	600	550	70	0.30	14,728	10,744	80 / 67	54.6 / 58.2	10	3.0	3.5	13,068	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-23	600	550	70	0.30	14,728	10,744	80 / 67	54.6 / 58.2	10	3.0	3.5	13,068	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-24	600	550	100	0.30	14,556	8,935	80 / 67	54.6 / 58.2	10	3.0	3.5	13,068	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-25	800	570	120	0.30	20,611	13,857	80 / 67	55.6 / 55.1	10	4.1	6.9	13,662	68	1.4	7.8	250	BOTTOM	MEDIUM SPEED
FCU-26	800	640	130	0.30	22,258	14,968	80 / 67	56.8 / 56.1	10	4.4	7.9	16,344	68	1.6	9.9	240	BOTTOM	
FCU-27	600	530	90	0.30	16,582	11,532	80 / 67	57.4 / 56.7	10	3.3	4.1	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-28	600	530	80	0.30	14,699	10,146	80 / 67	58.0 / 57.3	10	2.9	3.3	12,543	68	1.0	3.6	220	BOTTOM	MEDIUM SPEED
FCU-29	400	380	80	0.30	13,039	8,945	80 / 67	56.5 / 55.8	10	2.6	10.6	9,029	68	0.9	2.3	185	BOTTOM	
FCU-30	600	530	50	0.30	15,068	11,265	80 / 67	57.8 / 57.2	10	3.0	3.5	12,543	68	1.3	5.7	220	BOTTOM	MEDIUM SPEED
FCU-31	800	700	70	0.30	20,172	15,943	80 / 67	57.1 / 56.4	10	4.1	6.9	16,632	68	1.7	11.0	240	BOTTOM	
FCU-32	600	380	80	0.30	13,386	9,292	80 / 67	56.1 / 55.7	10	2.7	2.9	9,029	68	0.9	3.0	170	BOTTOM	LOW SPEED
FCU-33	600	640	140	0.30	17,381	9,241	80 / 67	58.5 / 57.6	10	3.5	4.6	15,206	68	1.5	7.4	260	BOTTOM	
FCU-34	800	700	0	0.30	14,757	14,757	80 / 67	58.6 / 57.9	10	3.0	3.9	16,632	68	1.7	11.0	240	BOTTOM	
FCU-35	400	350	0	0.30	7,380	7,380	80 / 67	58.5 / 57.8	10	1.5	3.9	8,316	68	0.8	1.9	185	BOTTOM	
FCU-36	200	230	0	0.30	4,523	4,523	80 / 67	60.0 / 58.5	10	0.9	6.7	5,465	68	0.5	0.6	120	BOTTOM	
FCU-37	1200	1150	0	0.30	29,550	29,550	80 / 67	58.0 / 57.2	10	6.0	8.4	27,324	68	1.7	15.5	475	BOTTOM	
FCU-38	1000	440	0	0.30	20,305	20,305	80 / 67	58.0 / 57.3	10	4.1	7.8	22,334	68	1.5	10.9	445	BOTTOM	
FCU-39	400	380	60	0.30	11,817	8,753	80 / 67	56.8 / 56.1	10	2.4	9.2	9,029	68	0.9	2.3	185	BOTTOM	

- NOTES
1. UNITS SHALL BE THE HORIZONTAL CONCEALED TYPE WITH DIRECT DRIVE FAN.
 2. PROVIDE AUXILIARY DRAIN PAN UNDER UNIT VALVES.
 3. UNIT COOLING CAPACITIES BASED ON 45° F. ENT. WATER TEMP., THROWAWAY FILTER, WET COIL, AND HIGH FAN SPEED OPERATION UNLESS INDICATED OTHERWISE.
 4. UNIT HEATING CAPACITY BASED ON 180° F. ENT. WATER TEMP., THROWAWAY FILTER, AND HIGH FAN SPEED OPERATION UNLESS INDICATED OTHERWISE.
 5. 120 VOLTS, SINGLE PHASE POWER REQUIREMENT.
 6. PROVIDE UNIT WITH A UNIT-MOUNTED FAN SPEED SWITCH.
 7. FCU-18, 37, 38 - H.M. FLOW BASED ON 30° WTD.

AIR-COOLED CHILLER SCHEDULE														
UNIT NO.	MIN. CAPACITY (TONS)	EVAPORATOR					AIR ENT. COND. (°F)	NO. REFRIG. CIRCUITS	MIN. NO. STEPS UNLOADING	ELECTRICAL DATA			MAX. FULL-LOAD KW/TON	REMARKS
		GPM	ENT (°F)	LWT (°F)	MAX. PD (FT. WG.)	FOULING FACTOR				MINIMUM CIRCUIT AMPS	VOLTS	PHASE		
AC-1	53.0	133.2	55	45	13	0.00025	95	2	4	323.3	208	3	1.15	(1)

- NOTES: ① PROVIDE WITH FLOW SWITCH, HOT GAS BY-PASS, CONDENSER GRILLES, CONTROLS TRANSFORMER, PRESSURE GAGES, OIL PRESSURE SWITCH AND DDC CONTROLLER.

PUMP SCHEDULE											
UNIT NO.	SERVICE	TYPE	GPM	HEAD (FT. WG.)	RPM	MIN. EFF. (%)	HP	VOLTS	PHASE	NEMA STARTER SIZE	REMARKS
P-1 & 1A	CHILLED WATER	BASE MOUNTED CENTRIFUGAL	133.2	70	1750	60.2	5	208	3	1	①
P-2 & 2A	HOT WATER	IN-LINE CENTRIFUGAL	58.6	48	1750	44.9	2	208	3	0	
ACP-1	A/C CONDENSATE	AUTOMATIC CONDENSATE PUMP	30 GPH	9	-	-	1/50	115	1	-	②

- NOTES: ① PROVIDE WITH SUCTION DIFFUSER.
② MINIMUM TANK SIZE: 7'H x 4'L x 4.5'W, PROVIDE WITH SAFETY SWITCH.

STEAM-TO-HOT WATER CONVERTOR SCHEDULE							
UNIT NO.	MIN. CAPACITY (BTU/HR)	TUBE SIDE			SHELL SIDE		REMARKS
		GPM	EAT (°F)	LWT (°F)	ENT. STEAM PRESSURE (PSIG)	LBS/HR	
CONV-1	586,000	58.6	160	180	0.9		

HOT WATER CONVECTOR SCHEDULE					
UNIT NO.	MIN. CAPACITY (BTU/HR)	GPM	LENGTH (IN)	HEIGHT (IN)	REMARKS
CONV-1	5,000	0.5	36	18	

- NOTES:
- ① CAPACITIES BASED ON 180°F ENT. WATER TEMP. AND 65°F ENT. AIR TEMP.
 - ② PROVIDE WITH INTEGRAL THERMOSTAT AND CONTROL VALVE.

GRILLE, REGISTER & DIFFUSER SCHEDULE						
MARK	TYPE	SERVICE	CFM RANGE	NECK SIZE	MAX. P.D.	REMARKS
(A)	LINEAR DIFFUSER	SUPPLY	70-105	6"φ	.07"	4'-0" LONG, 2 - 3/4" SLOTS SEE NOTE 7
(B)	CEILING DIFFUSER	SUPPLY	70-125	6" x 6"	.05"	FIXED PATTERN 24" x 24" LAY-IN PANEL
(C)	CEILING DIFFUSER	SUPPLY	135-220	8" x 8"	.05"	FIXED PATTERN 24" x 24" LAY-IN PANEL
(D)	CEILING DIFFUSER	SUPPLY	235-320	10" x 10"	.05"	FIXED PATTERN 24" x 24" LAY-IN PANEL
(E)	LINEAR DIFFUSER	SUPPLY	140	8"φ	.07"	4'-0" LONG, 3 - 3/4" SLOTS SEE NOTE 7
(F)	CEILING REGISTER	RETURN	130-300	10" x 14"	.05"	LOWER FACE, 45° DEFLECTION, 3/4" SPACING, 24" x 24" LAY-IN
(G)	CEILING REGISTER	RETURN	310-515	12" x 20"	.05"	LOWER FACE, 45° DEFLECTION, 3/4" SPACING, 24" x 24" LAY-IN
(H)	CEILING REGISTER	RETURN	530-680	14" x 22"	.05"	LOWER FACE, 45° DEFLECTION, 3/4" SPACING, 24" x 24" LAY-IN
(J)	CEILING GRILLE	EXHAUST	100-200	8" x 8"	.05"	1/2" x 1/2" x 1/2" EGG-CRATE
(K)	LINEAR DIFFUSER	SUPPLY	385-470	10"φ	.10"	4'-0" LONG, 4 - 3/4" SLOTS SEE NOTE 7
(L)	CEILING REGISTER	RETURN	50-105	6" x 8"	.05"	LOWER FACE, 45° DEFLECTION, 3/4" SPACING
(M)	CEILING DIFFUSER	SUPPLY	370-345	12" x 12"	.04"	FIXED PATTERN 24" x 24" LAY-IN PANEL
(N)	CEILING GRILLE	TRANSFER	80-170	10" x 8"	.05"	LOWER FACE
(P)	CEILING REGISTER	RETURN	835	16" x 22"	.06"	LOWER FACE, 45° DEFLECTION, 3/4" SPACING, 24" x 24" LAY-IN
(R)	CEILING GRILLE	EXHAUST	385	12" x 12"	.05"	1/2" x 1/2" x 1/2" EGG-CRATE
(S)	CEILING GRILLE	TRANSFER	200	12" x 12"	.03"	LOWER FACE, 45° DEFLECTION, 3/4" SPACING

THE FOLLOWING NOTES ARE TYPICAL UNLESS OTHERWISE NOTED:

1. PROVIDE DIFFUSERS AND REGISTERS WITH VOLUME DAMPERS.
2. PROVIDE BAKED OFF-WHITE ENAMEL FINISH, INCLUDING HEADS OF SCREWS.
3. PROVIDE 4-WAY PATTERN CEILING DIFFUSERS, U.O.N. ON PLANS OR SCHEDULE.
4. PROVIDE MAXIMUM NG=35 AT HIGHEST CFM.
5. MAXIMUM PRESSURE DROP SHALL INCLUDE VOLUME DAMPER WHERE DAMPER IS PROVIDED.
6. PROVIDE SQUARE TO ROUND TRANSITION AS REQUIRED.
7. CONTRACTOR FABRICATED PLENUM (SEE DETAIL, SHEET M-5)

HOT WATER UNIT HEATER SCHEDULE											
UNIT NO.	APPROX. CFM	MIN. CAPACITY (BTU/HR)	GPM	EAT (°F)	EAT (°F)	MAX. PD (FT. WG.)	MAX. HP	VOLTS	PHASE	REMARKS	
UH-1	340	8500	0.9	180	55	0.5	1/60	115	1	①	

- NOTES: ① PROVIDE WITH INTEGRAL FAN STARTER AND THERMOSTAT.

FAN SCHEDULE									
UNIT NO.	TYPE	CFM	EXTERNAL STATIC PRESSURE (IN. WG.)	MAX. MOTOR HP	MAX. SONES	VOLTS	PHASE	DRIVE TYPE	REMARKS
EF-1	IN-LINE CENTRIFUGAL	850	50	1/4	11.6	115	1	BELT	① ②
EF-2	IN-LINE CENTRIFUGAL	400	50	1/4	14.6	115	1	BELT	↓ ↓
EF-3	IN-LINE CENTRIFUGAL	770	50	1/4	12.2	115	1	BELT	↓ ↓
EF-4	IN-LINE CENTRIFUGAL	400	375	1/4	10.2	115	1	BELT	↓ ↓
EF-5	WALL PROPELLER	350	30	1/6	-	115	1	DIRECT	↓ ↓
SF-1	IN-LINE CENTRIFUGAL	980	50	1/4	9.2	115	1	BELT	②
SF-2	IN-LINE CENTRIFUGAL	890	50	1/4	9.2	115	1	BELT	↓ ↓
SF-3	IN-LINE CENTRIFUGAL	1,170	50	1/4	15.0	115	1	BELT	↓ ↓