

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 11 PAGES	
2. AMENDMENT/MODIFICATION NUMBER 0001		3. EFFECTIVE DATE 03/19/2025		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable)	
6. ISSUED BY NAVFACYSCOM MID-ATLANTIC PWD NORFOLK FACILITIES ENGINEERING & ACQ DIV 9324 VIRGINIA AVENUE NORFOLK, VA 23511-3095		CODE N40085		7. ADMINISTERED BY (If other than Item 6)		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				☒ (X)		9A. AMENDMENT OF SOLICITATION NUMBER	
				☒ (X)		N4008525R2603	
				☐		9B. DATED (SEE ITEM 11)	
						10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
CODE				FACILITY CODE		10B. DATED (SEE ITEM 13)	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended. ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

N4008524R2603; NH-16 Replace Air Cooled Chiller at Naval Support Activity (NSA), Norfolk, Virginia

See continuation pages:

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Previous edition unusable

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

AMENDMENT 0001

The purpose of this amendment is to provide the following:

1. Provide responses to Pre-Proposal Inquiries (PPI).
2. Update Wage Determination to VA20250160 02/26/25 (See Attachment "WD VA20250160 02.28.2025.pdf").
3. Provide Site Visit Log (see Attachment "Site Visit Log 022625.pdf").
4. Provide Mechanical Drawings (see Attachments "15060m7.pdf", "15060m8.pdf", "15060m9.pdf").
5. Extend the proposal due date from 20 March 2025 at 1400 local time to 27 March 2025 at 1400 local time. **LATE PROPOSALS WILL NOT BE CONSIDERED.**

1. PRE-PROPOSAL INQUIRY (PPI) RESPONSES:

PPI #	QUESTION	RESPONSE
1	Due to the ordering and manufacturing timeline (40 weeks) of the new 60-Ton Chiller, a 180-day duration for this contract will not be sufficient. We would recommend at least a 300 day duration, will this be acceptable?	Excessive material lead times will be justification for a no cost time extension.
2	When will the temporary Chiller need to be installed? (Within 30-60 days of award? Once New Chiller is placed on order? etc?) We need to know this in order to calculate rental costs of Temporary Chiller.	At the same time that the existing chiller is taken down.
3	Will the Superintendent be allowed to perform the roles of QCM and SSHO?	Project can be triple hat. Superintendent can perform QC and SSHO roles but must be qualified for each.
4	Will the crane lift(s) have to be performed after hours or on a weekend, since a parking lot (just south of the Chiller) will most likely need to be cleared out for the crane to maneuver?	Yes, the crane lift will need to be performed after hours or on a weekend.
5	Will compaction testing of the soil for the concrete slab extension be required?	Yes
6	Will concrete testing be required for the concrete placement?	Yes
7	Will TAB be required for Temp Chiller, for New Chiller?	TAB should be conducted to verify proper equipment function.
8	Will the contractor be required to provide any new Control work required? If so, who is the current Controls Contractor the base utilizes?	Contractor responsible for chiller controls. Controlled by Automated Logic.
9	Does the existing Chiller's refrigerant become property of the contractor or is the recovered refrigerant turned over to the government?	Recovered refrigerant is property of the contractor and must be handled and disposed of following all applicable regulations.
10	Can Mechanical drawings be provided showing what the existing Chiller is feeding?	Yes, they can be sent as .pdf's. See attachments "15060m7.pdf", "15060m8.pdf", "15060m9.pdf"
11	At the site visit it was mentioned about other possible locations for the Temporary Chiller. Since the current contract documents specify the location (walkway near NH-39), will any other optional locations be promulgated to all bidders so we're all bidding the same situation?	At the Pre-Bid meeting, it was discussed that if a different temporary chiller location works better, please specify and bid accordingly.
12	Can this project be supervised with a "Triple Hat", (combined SSHO/QC/Superintendent) due to its simplicity and short duration?	Project can be triple hat. Superintendent can perform QC and SSHO roles but must be qualified for each.

13	The BOD Trane chiller utilizes traditional copper tube / aluminum fin construction for the condenser coils. Are micro-channel condenser coils an acceptable alternative to the BOD copper tube / aluminum fin construction?	Yes, micro-channel is acceptable
14	General Requirements state the Time for completion to be 180 days from the award of the task order. The BOD chiller is 26 weeks + holidays + 1 week for delivery. Can the CCD be extended to 240 days from award to allow for approval and release of chiller to include lead time for delivery? Or will this be addressed as a NTCE after award once the timeframes are established?	Excessive material lead times will be justification for a no cost time extension.
15	Demolition requires the removal of the existing isolation valves and replaced with new to allow for installation of temporary connections. This will require an extended outage and draining down the system anyway. If the replacement of the chiller can be accomplished from a Friday to Sunday to include start-up can the requirements for temporary cooling be deleted?	Yes
16	BOD chiller requires an independent 115V, 20 amp circuit for the heaters. Please advise if there is an available circuit spare and its location since the existing chiller does not have this provision.	Circuit is existing
17	Work tasks require the system to be drained down to accomplish the work. Has the water been tested to allow for discharge down the nearest HRSD location? Or will the water need to be captured and disposed of/or re-introduced into the system?	Discharge will need to be captured and disposed of properly.
18	Please advise which DDC system is incumbent to the chiller under the CJ&A for controls for this building.	Must be field verified.
19	A crane will be utilized to set both the temp chiller and the new chiller. The crane plan will require FAA approval with actual dates the work will be done. Recently that has taken up to two months to receive. Will a NCTE be issued should that approval delay affect the CCD?	Due to equipment lead time this should not impact the project schedule. Contractor to submit the crane plan for approval while awaiting equipment fabrication and delivery.
20	Do the Superintendent, SSHO and QC Manager need to be 3 separate individuals?	Project can be triple hat. Superintendent can perform QC and SSHO roles but must be qualified for each.
21	If the building remains occupied, how many people will be in the building?	Bid as shown
22	Can the period of performance be extended after award once the material/equipment lead times are confirmed due to current market conditions for the equipment for this project?	See PPI #1
23	If any underground piping is required to be replaced, are soil boring reports available? If not, it will be assumed that excavation will be clear of rocks and obstructions.	Bid as shown
24	Please advise if third-party commissioning is required? If this is a requirement, please advise who is responsible for hiring the commissioning agent.	Contractor is responsible for any third-party commissioning.
25	Please provide the contact information for the building controls contractor.	Automated Logic Controls are currently.
26	Please advise if the controls need to be upgraded or if the changeout is as simple as a disconnect / reconnect of existing controls.	New chiller should tie-in to existing controls.
27	Please provide the contact information for the building	Bid as shown

	fire alarm company.	
28	Please provide the site visit attendee sign-in sheet.	See Attachment "Site Visit Log 022625"
29	Please provide photos of the job site and existing conditions.	Bid as shown
30	Are as-built drawings available for review?	Yes, see attachments "15060m7.pdf", "15060m8.pdf", "15060m9.pdf"
31	How can the temporary chiller be set? Should it remain on a trailer or is the intent it is set on the sidewalk? Will the sidewalk be able to handle the weight of the temporary chiller? If no, will the contractor be responsible for any damage due to the temporary unit?	Contractor to determine weight of temporary chiller and determine if it should remain on trailer or placed on sidewalk. Sidewalk is not to be damaged.
32	Please confirm the current measurement, including thickness, of the existing chiller pad.	Match the existing concrete pad thickness; Minimum 6" thick.; Drill and epoxy grout # 6 @ 24" o.c to existing pad. ; 8" embedment depth + 2'6 typ. Length for dowel bar; continuous 3/4" chamfer typ. at slab top edges
33	Please confirm the best path for the crane to enter to set up for the installation of the temporary chiller. If temp. chiller is to remain on a trailer, this request is not applicable.	See PPI #31
34	Please confirm the best path for the crane to enter to set up for the removal of the existing chiller and installation of the new chiller.	Crane will need to enter the base through Gate A.
35	Please confirm a temporary chiller is required as it was mentioned on the site visit the changeout for the new chiller could be accomplished without the temporary unit.	Temporary chiller is contingent on lead time for new chiller. Temp or New chiller to be in place before outdoor temperatures lead to overtemp inside building.
36	Is Trane the only approved equipment manufacturer for both the temporary and new chiller or will approved equals be allowed? If yes, please provide a list of approved manufacturers.	Contractor responsible for supplying approved equal chiller equipment.
37	Please confirm the hours of operation for this project.	Bid as shown
38	Please advise if a pre-test and balance is required of the existing chiller.	Negative
39	Please advise if test and balance is required after the installation and startup of the new chiller? If yes, please provide an equipment schedule and design parameters that need to be tested.	Yes, equipment schedules and design parameters to follow
40	Will the temporary chiller need to be connected after normal working hours?	No
41	Can the temporary chiller water lines be routed over the top of the sidewalk canopy?	Yes, a temporary stand may be required to prevent damage to the canopy.
42	Can the Temporary Chiller, if there is room, be located in the grass area closer to the existing chiller?	Yes
43	Will we be able to lift equipment over the building while it is occupied?	No
44	Will afterhours and weekend be allowed if proper notice is given and requested?	Bid per executable scope. After hour work requests can be submitted for consideration after award.
45	Just to clarify, all conduit, including any underground conduit will be replaced?	The conduit from the existing disconnect to the chiller is to be replaced.
46	Just to clarify, the existing 400A disconnect remains and does not get replaced?	The existing 400A disconnect is to remain.
47	At the site visit, we discussed setting up the crane in the parking lot on the other side of the building, what special	See response to PPI #4

	arrangements are needed if any for customer parking during the crane lift?	
48	Contractor Parking, can we cone off an area near the work site during working hours?	Yes
49	Chiller Controls: How is this chiller controlled? I see a BACnet card required, who is responsible for any control work needed, if any?	Contractor responsible for chiller controls. Controlled by Automated Logic.
50	Concrete extension, will there be any testing required for the concrete or ground?	Ensure minimum concrete compressive strength, $f_c = 3000$ psi for concrete pad on 6" layer of #57 stone on compacted earth or structural fill
51	What is the thickness of the concrete pad and will the pad require a turn down edge and doweling into the existing pad?	Match the existing concrete pad thickness; Minimum 6" thick.; Drill and epoxy grout # 6 @ 24" o.c to existing pad. ; 8" embedment depth + 2'6 typ. Length for dowel bar; continuous 3/4" chamfer typ. at slab top edges
52	The Solicitation Page 3 Under Special Scheduling Requirements/Work Procedures Item 3.7 refers to removing the existing roof system. Please confirm that there are not any roofing requirements for this project.	Confirming there are no roofing requirements
53	Due to the cost of a Crane Plan, please confirm that a Crane Plan will be required so each KTR will have the cost covered in their estimates.	Yes
54	Please confirm that one person can fill the positions of Superintendent, QCM and SSHO	Project can be triple hat. Superintendent can perform QC and SSHO roles but must be qualified for each.

2. WAGE DETERMINATION (VA20250160)

"General Decision Number: VA20250160 02/28/2025

Superseded General Decision Number: VA20240160

State: Virginia

Construction Type: Building

County: Norfolk* County in Virginia.

* INDEPENDENT CITY OF NORFOLK

BUILDING CONSTRUCTION PROJECTS (does not include single family homes or apartments up to and including 4 stories).

Note: Contracts subject to the Davis-Bacon Act are generally required to pay at least the applicable minimum wage rate required under Executive Order 14026 or Executive Order 13658. Please note that these Executive Orders apply to covered contracts entered into by the federal government that are subject to the Davis-Bacon Act itself, but do not apply to contracts subject only to the Davis-Bacon Related Acts, including those set forth at 29 CFR 5.1(a)(1).

If the contract is entered	. Executive Order 14026	
into on or after January 30,	generally applies to the	
2022, or the contract is	contract.	
renewed or extended (e.g., an	. The contractor must pay	
option is exercised) on or	all covered workers at	

after January 30, 2022:	least \$17.75 per hour (or
	the applicable wage rate
	listed on this wage
	determination, if it is
	higher) for all hours
	spent performing on the
	contract in 2025.
If the contract was awarded on	Executive Order 13658
or between January 1, 2015 and	generally applies to the
January 29, 2022, and the	contract.
contract is not renewed or	The contractor must pay all
extended on or after January	covered workers at least
30, 2022:	\$13.30 per hour (or the
	applicable wage rate listed
	on this wage determination,
	if it is higher) for all
	hours spent performing on
	that contract in 2025.

The applicable Executive Order minimum wage rate will be adjusted annually. If this contract is covered by one of the Executive Orders and a classification considered necessary for performance of work on the contract does not appear on this wage determination, the contractor must still submit a conformance request.

Additional information on contractor requirements and worker protections under the Executive Orders is available at <http://www.dol.gov/whd/govcontracts>.

Modification Number	Publication Date
0	01/03/2025
1	01/10/2025
2	02/21/2025
3	02/28/2025

ASBE0024-006 10/01/2024

	Rates	Fringes
ASBESTOS WORKER/HEAT & FROST INSULATOR - MECHANICAL (Duct, Pipe & Mechanical System Insulation).....	\$ 40.77	20.17+a

a. PAID HOLIDAYS: New Year's Day, Martin Luther King Day, Memorial Day, Independence Day, Labor Day, Veterans' Day, Thanksgiving Day, the day after Thanksgiving and Christmas Day provided the employee works the regular work day before and after the paid holiday.

* BOIL0045-003 01/01/2025

	Rates	Fringes
BOILERMAKER.....	\$ 38.97	27.39

BRVA0008-001 05/01/2022

	Rates	Fringes
BRICKLAYER.....	\$ 22.44	10.23

ELEC0080-010 12/01/2021

	Rates	Fringes
ELECTRICIAN (Includes Low Voltage Wiring and Alarm Installation).....	\$ 30.55	11.51

a. Workmen shall take off 1 hour with pay, at the discretion of the employer, on State and National Election days; Tuesday following the first Monday in November, provided they are qualified and vote.

ELEV0052-005 01/01/2025

	Rates	Fringes
ELEVATOR MECHANIC.....	\$ 52.06	38.435+a+b

a. PAID HOLIDAYS: New Year's Day, Memorial Day, Independence Day, Labor Day, Veterans' Day, Thanksgiving Day, the Friday after Thanksgiving Day and Christmas Day.

b. VACATIONS: 6% men under 5 years based on regular hourly rate and 8% men over 5 years based on regular hourly rate for all hours worked.

ENGI0147-019 05/01/2022

	Rates	Fringes
POWER EQUIPMENT OPERATOR Cranes 90 tons & over capacity; Tower & Climbing Cranes with Controls 100 ft. above ground.....	\$ 34.17	15.21
Cranes under 90 tons.....	\$ 33.26	15.12

IRON0028-006 05/01/2023

	Rates	Fringes
IRONWORKER, RIGGER.....	\$ 30.22	11%+14.24

IRON0028-007 05/01/2024

	Rates	Fringes
IRONWORKER, STRUCTURAL AND ORNAMENTAL.....	\$ 31.00	18.28

PLUM0110-008 11/01/2024

	Rates	Fringes
PIPEFITTER (Includes HVAC Pipe, Unit and Temperature Controls Installations).....	\$ 35.42	17.75
PLUMBER.....	\$ 35.42	17.75

* SUVA2013-043 01/11/2016

	Rates	Fringes
CARPENTER, Includes Acoustical Ceiling Installation, Drywall		

Hanging, and Form Work.....	\$ 19.80	3.98
CAULKER.....	\$ 18.49	1.33
CEMENT MASON/CONCRETE FINISHER...	\$ 20.02	2.00
GLAZIER.....	\$ 19.36	4.68
IRONWORKER, REINFORCING.....	\$ 27.18	4.13
LABORER: Mason Tender - Brick...	\$ 14.82 **	3.34
LABORER: Mason Tender - Cement/Concrete.....	\$ 12.96 **	3.12
LABORER: Pipelayer.....	\$ 12.40 **	1.86
LABORER: Common or General, Including Demolition.....	\$ 11.28 **	1.89
OPERATOR: Backhoe/Excavator/Trackhoe.....	\$ 18.57	1.19
OPERATOR: Bobcat/Skid Steer/Skid Loader.....	\$ 18.95	4.03
OPERATOR: Bulldozer.....	\$ 18.07	3.50
OPERATOR: Forklift.....	\$ 19.40	7.00
OPERATOR: Loader.....	\$ 21.28	3.17
OPERATOR: Roller.....	\$ 16.25 **	4.88
PAINTER (Brush and Roller).....	\$ 16.92 **	0.00
PAINTER: Spray.....	\$ 18.10	5.43
ROOFER.....	\$ 18.40	2.31
SHEET METAL WORKER, Includes HVAC Duct Installation.....	\$ 20.98	2.62
SPRINKLER FITTER (Fire Sprinklers).....	\$ 18.91	4.67
TILE FINISHER.....	\$ 23.40	0.00
TILE SETTER.....	\$ 27.80	10.25
TRUCK DRIVER: Dump Truck.....	\$ 15.50 **	0.75

WELDERS - Receive rate prescribed for craft performing
operation to which welding is incidental.

=====

** Workers in this classification may be entitled to a higher minimum wage under Executive Order 14026 (\$17.75) or 13658 (\$13.30). Please see the Note at the top of the wage determination for more information. Please also note that the minimum wage requirements of Executive Order 14026 are not currently being enforced as to any contract or subcontract to which the states of Texas, Louisiana, or Mississippi, including their agencies, are a party.

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave

for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at <https://www.dol.gov/agencies/whd/government-contracts>.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (iii)).

The body of each wage determination lists the classifications and wage rates that have been found to be prevailing for the type(s) of construction and geographic area covered by the wage determination. The classifications are listed in alphabetical order under rate identifiers indicating whether the particular rate is a union rate (current union negotiated rate), a survey rate, a weighted union average rate, a state adopted rate, or a supplemental classification rate.

Union Rate Identifiers

A four-letter identifier beginning with characters other than ""SU"", ""UAVG"", ?SA?, or ?SC? denotes that a union rate was prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2024. PLUM is an identifier of the union whose collectively bargained rate prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. The date, 07/01/2024 in the example, is the effective date of the most current negotiated rate.

Union prevailing wage rates are updated to reflect all changes over time that are reported to WHD in the rates in the collective bargaining agreement (CBA) governing the classification.

Union Average Rate Identifiers

The UAVG identifier indicates that no single rate prevailed for those classifications, but that 100% of the data reported for the classifications reflected union rates. EXAMPLE: UAVG-OH-0010 01/01/2024. UAVG indicates that the rate is a weighted union average rate. OH indicates the State of Ohio. The next number, 0010 in the example, is an internal number used in producing the wage determination. The date, 01/01/2024 in the example, indicates the date the wage determination was updated to reflect the most current union average rate.

A UAVG rate will be updated once a year, usually in January, to

reflect a weighted average of the current rates in the collective bargaining agreements on which the rate is based.

Survey Rate Identifiers

The ""SU"" identifier indicates that either a single non-union rate prevailed (as defined in 29 CFR 1.2) for this classification in the survey or that the rate was derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As a weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SUFL2022-007 6/27/2024. SU indicates the rate is a single non-union prevailing rate or a weighted average of survey data for that classification. FL indicates the State of Florida. 2022 is the year of the survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. The date, 6/27/2024 in the example, indicates the survey completion date for the classifications and rates under that identifier.

?SU? wage rates typically remain in effect until a new survey is conducted. However, the Wage and Hour Division (WHD) has the discretion to update such rates under 29 CFR 1.6(c)(1).

State Adopted Rate Identifiers

The ""SA"" identifier indicates that the classifications and prevailing wage rates set by a state (or local) government were adopted under 29 C.F.R 1.3(g)-(h). Example: SAME2023-007 01/03/2024. SA reflects that the rates are state adopted. ME refers to the State of Maine. 2023 is the year during which the state completed the survey on which the listed classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. The date, 01/03/2024 in the example, reflects the date on which the classifications and rates under the ?SA? identifier took effect under state law in the state from which the rates were adopted.

----- WAGE DETERMINATION APPEALS PROCESS

1) Has there been an initial decision in the matter? This can be:

- a) a survey underlying a wage determination
- b) an existing published wage determination
- c) an initial WHD letter setting forth a position on a wage determination matter
- d) an initial conformance (additional classification and rate) determination

On survey related matters, initial contact, including requests for summaries of surveys, should be directed to the WHD Branch of Wage Surveys. Requests can be submitted via email to davisbaconinfo@dol.gov or by mail to:

Branch of Wage Surveys
Wage and Hour Division
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

Regarding any other wage determination matter such as conformance decisions, requests for initial decisions should be directed to the WHD Branch of Construction Wage Determinations.

Requests can be submitted via email to BCWD-Office@dol.gov or by mail to:

Branch of Construction Wage Determinations
Wage and Hour Division
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

2) If an initial decision has been issued, then any interested party (those affected by the action) that disagrees with the decision can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Requests for review and reconsideration can be submitted via email to dba.reconsideration@dol.gov or by mail to:

Wage and Hour Administrator
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210.

=====

END OF GENERAL DECISION"

(End of Summary of Changes)