

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.	1. CONTRACT ID CODE	PAGE	OF	PAGES
2. AMENDMENT/MODIFICATION NUMBER 0001		3. EFFECTIVE DATE 03-14-2025	4. REQUISITION/PURCHASE REQ. NUMBER 693-25-2-539-0031		5. PROJECT NUMBER (if applicable) None	
6. ISSUED BY CODE Department of Veterans Affairs Network Contracting Office 4 Services 2 2907 Pleasant Valley Blvd Altoona PA 16602		36C244	7. ADMINISTERED BY (If other than Item 6) CODE Department of Veterans Affairs Network Contracting Office 4 Services 2 2907 Pleasant Valley Blvd Altoona PA 16602		36C244	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders			(X)	9A. AMENDMENT OF SOLICITATION NUMBER 36C24425Q0424		
			☒	9B. DATED (SEE ITEM 11)		
			☐	10A. MODIFICATION OF CONTRACT/ORDER NUMBER		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
☐						
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
☐	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to post all vendor questions with answers. All quote submissions must include a signed copy of this amendment.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)			15C. DATE SIGNED		16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	
					16C. DATE SIGNED	

1. The Statement of Work specifies that the generator must be trailer-mounted, but can you confirm whether it must remain on the trailer during operation or if placement on the ground is allowed?
 - Placement on the ground will be allowed if it is stabilized. Note that rigging of the equipment is at the vendor's expense.
2. In reference to the Solicitation , could you please confirm that who will be responsible for supply and installation/connecting the piping, electrical wiring, and insulation of the lines?
 - The contractor is responsible. The VA will make sure that all tie in points are ready and will operate the internal valving necessary along with energizing the shore power.
3. Can you confirm whether both 500-ton air-cooled rental chillers are required to be installed and operational on April 1, 2025, or if one will remain on standby for later deployment during the rental period?
 - Both will be required to be installed and operational upon delivery.
4. Is There a planned site visit date(s)?
 - There will not be a site visit for this requirement

End of Document