

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.		1. CONTRACT ID CODE		PAGE 1		OF PAGES 3	
2. AMENDMENT/MODIFICATION NUMBER 0001		3. EFFECTIVE DATE 03/24/2025		4. REQUISITION/PURCHASE REQ. NUMBER			5. PROJECT NUMBER (if applicable)		
6. ISSUED BY Department of Veterans Affairs NCO 17 North Texas Healthcare System Regional Procurement Office West (RPO-W) 124 E. Hwy 67, Suite 100 Duncanville TX 75137		CODE 36C257		7. ADMINISTERED BY (If other than Item 6) NCO 17 Department of Veterans Affairs North Texas Veterans Health Care Center 124 E. Hwy 67, Suite 100 Duncanville TX 75137			CODE 36C257		
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NUMBER 36C25725Q0334			
				☒		9B. DATED (SEE ITEM 11)			
				☐		10A. MODIFICATION OF CONTRACT/ORDER NUMBER			
				☐		10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE							
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS									
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.									
12. ACCOUNTING AND APPROPRIATION DATA (If required) See CONTINUATION Page									
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.									
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.								
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).								
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:								
☐	D. OTHER (Specify type of modification and authority)								
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.									
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to post questions and answers for solicitation 36C25725Q0334. See Continuation page.									
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.									
15A. NAME AND TITLE OF SIGNER (Type or print)					16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)				
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)					15C. DATE SIGNED		16B. UNITED STATES OF AMERICA _____ (Signature of Contracting Officer)		16C. DATE SIGNED

CONTINUATION PAGE

Question 1

Is the contractor to remove and disconnect the duct detectors?

Answer: Yes, contractor is responsible for demolition of induct smoke detectors.

Question 2

Is the contractor to disconnect the electrical and does it need to be demolished back to the panel it is fed from?

Answer: Contractor is responsible for demolition of electrical back to main panel.

Question 3

What type of duct is allowed to tie back into the existing from the removal of the 5-ton units?

Answer: Rigid duct/plenums within 5 feet of the register. The remaining distance to the register is allowed to be flex duct.

Question 4

What level ICRA will this project be?

Answer: Level 3.

Question 5

What are the working hours for this project?

Answer: After 1700 until 0600 and weekends starting Friday at 1700 through Monday 0600.

Question 6

Please provide any asbuilt drawings (existing)

Answer: There are no as built drawings for current configuration.

Question 7

On the site visit walk it was mentioned the VA would provide the VFD's and installed by proposed contractor.

Answer: Two Eaton VS3-7d5-4-N1B-2 7.5 hp drives

Question 8

Provide what vendor or brand of controls are currently installed

Answer: The controls for the AHU's is Metasys Controls on the MSTP protocol and must remain under Metasys Control.

Question 9

Provide updated SOW if any

Answer: None

Question 10

Provide site visit sign in sheet-

Answer: No, for internal use only

End of Document