

WebAIM Short Form TASK GROUP INSTRUCTION

05-MAR-2025 1644

20.14.15.2.9020 (September 2024)

ICN: 3819P22115 KeyOp: A06

TGI NO:	COMPONENT NAME: 1B BLR FO BNR LD PPG	TYPE: AY	PHASE: A	REPEAT: 0	CHG/VER: 0/0
SHIP/HULL NO: LCC-19	SHIP/HULL NAME: USS BLUE RIDGE	PROJECT: 19P	SYSTEM:	PLANT ID:	CASREP CAT:
CU PHASE TITLE: *(K37A-02) F/O - ACCOMPLISH HYDRST TEST OF 1B BLR FO BURNER LEAD PP IN 8-76-0-E					
PREPARING ACTIVITY:		STATUS: APP		WORKING STATUS:	
PREPARED BY: NAGASHIMA, TETSU		CODE: 234	PHONE: 3152434527	DATE: 24-FEB-2025	
APPROVED BY: SHINMEI, HIDEKUNI		CODE: 234	PHONE: 3152432371	DATE: 24-FEB-2025	
CONCURRED BY:		CODE:	PHONE:	DATE:	
REASON FOR WORK/NEED FOR CHANGE: EM02L192					
JCN: EM02-L192					
SPECIAL REQUIREMENTS: TGI Short Form					
CU PHASE DESCRIPTION: 1. SCOPE/PURPOSE: 1.1 Title: Hydrostatic Test of 1B Boiler Fuel Oil (FO) Burner Lead Piping; accomplish 1.2 Location of Work: 1.2.1 Fire Room (8-76-0-E) 1.3 Identification: 1.3.1 Quantity (One AY), No. One FO Burner Lead Piping including FO Valve Actuator (1B-BIS-F-1) for 1B Boiler, from FO Manifold Root Valve No. 23 to No. One Burner Size: 1/2 Inch IPS Material: Carbon Steel Specification: MIL-T-20157C, SCH 40 Remarks: See Sheet One (Zone 11-A and Zone 11-B) of Ref. No. 3 for detail.					
ZONE MANAGER: YAGINUMA, TAKEHIDE		ZONE:	COMPARTMENT:	LEVEL:	FRAME: SIDE:
JOB SUMMARY ID: 221A1115	TOT MAN HR.:	TOT DUR:	TOT JML COST:	PLANNING ACCEPTANCE:	

WORK CERTIFICATION SIGNATURES:	DLs														
COMPLETION OF WORK REVIEW:				BADGE NO:		SHOP/CODE:		PHONE:		DATE:					
RECORDS REVIEW:				BADGE NO:		SHOP/CODE:		PHONE:		DATE:					



WebAIM Short Form TASK GROUP INSTRUCTION

05-MAR-2025 1644

20.14.15.2.9020 (September 2024)

(Continued)

ICN: 3819P22115

KeyOp: A06

TGI NO:	COMPONENT NAME: 1B BLR FO BNR LD PPG	TYPE: AY	PHASE: A	REPEAT: 0	CHG/VER: 0/0
SHIP/HULL NO: LCC-19	SHIP/HULL NAME: USS BLUE RIDGE	PROJECT: 19P	SYSTEM:	PLANT ID:	CASREP CAT:
CU PHASE TITLE: *(K37A-02) F/O - ACCOMPLISH HYDRST TEST OF 1B BLR FO BURNER LEAD PP IN 8-76-0-E					

CU PHASE DESCRIPTION (Cont.)

1.3.2 Quantity (One AY), No. 2 FO Burner Lead Piping for 1B Boiler, from FO Manifold Root Valve No. 24 to No. 2 Burner

Size: 1/2 Inch IPS

Material: Carbon Steel

Specification: MIL-T-20157C, SCH 40

Remarks: See Sheet One (Zone 11-A and Zone 11-B) of Ref. No. 3 for detail.

1.3.3 Quantity (One AY), No. 3 FO Burner Lead Piping for 1B Boiler, from FO Manifold Root Valve No. 25 to No. 3 Burner

Size: 1/2 Inch IPS

Material: Carbon Steel

Specification: MIL-T-20157C, SCH 40

Remarks: See Sheet One (Zone 11-A and Zone 11-B) of Ref. No. 3 for detail.

1.4 Security Classification: None.

1.5 Initial Condition:

1.5.1 Potential Lead Hazard.

1.6 Contractor work start date: 7/21/2026

1.7 Contractor work completion date: 11/21/2027

2. PROCEDURE:

2.1 Disconnect and reconnect each existing FO burner lead piping listed in 1.3.1 through 1.3.3 for accomplishment of hydrostatic test, using Ref. No. 3 for guidance.

2.1.1 Accomplish the requirements of 009-71 of Ref. No. One for hydrostatic test, using clean, fresh water at 605 PSIG, for each existing FO burner lead piping listed 1.3.1 through 1.3.3.

2.1.1.1 Document shop hydrostatic test results on QA Form 28 Enclosure-01-1.

2.2 Accomplish the requirements of 009-32 of Ref. No. One for each new and disturbed surface.

2.3 Notes:

2.3.1 Planner: Code 234 T. Nagashima, 243-4527

Planner: Code 233 M. Takemura, 080-9350-1458

2.3.2 This TGI is response to Boiler Inspection and Repair Management Information System (BIRMIS) for 1B Boiler report dated 17 OCT 2024, Line Item(s) K37A-02.

2.3.3 Work Integration Manager (WIM): Code 333 T. Yaginuma, 080-5419-0598

2.3.4 JCN EM02-L192 is related to this TGI.

2.4 Government Furnished Material (GFM):

WebAIM Short Form TASK GROUP INSTRUCTION

05-MAR-2025 1644

20.14.15.2.9020 (September 2024)

(Continued)

ICN: 3819P22115

KeyOp: A06

TGI NO:	COMPONENT NAME: 1B BLR FO BNR LD PPG	TYPE: AY	PHASE: A	REPEAT: 0	CHG/VER: 0/0
SHIP/HULL NO: LCC-19	SHIP/HULL NAME: USS BLUE RIDGE	PROJECT: 19P	SYSTEM:	PLANT ID:	CASREP CAT:
CU PHASE TITLE: *(K37A-02) F/O - ACCOMPLISH HYDRST TEST OF 1B BLR FO BURNER LEAD PP IN 8-76-0-E					

CU PHASE DESCRIPTION (Cont.)

2.4.1 SRF-JRMC will provide GFM listed in Material List.

2.5 SRF-JRMC will provide the following Service Work: (TGI No. 3819P22115S07).

2.5.1 [C740] Crane and crane rigging service.

2.5.2 [X99E] Utility Service, electrical.

2.5.3 [X99M] Utility Service, including low pressure air supply, water supply, and steam supply.

2.5.4 [C106.1] Safety inspection for SRF-JRMC employees.

2.5.5 [C106.2] Gas free inspection for SRF-JRMC employees.

2.5.6 [C133] QA inspection for (G) symbols.

WebAIM Short Form TASK GROUP INSTRUCTION

05-MAR-2025 1644

20.14.15.2.9020 (September 2024)

(Continued)

ICN: 3819P22115

KeyOp: A06

TGI NO:	COMPONENT NAME: 1B BLR FO BNR LD PPG	TYPE: AY	PHASE: A	REPEAT: 0	CHG/VER: 0/0
SHIP/HULL NO: LCC-19	SHIP/HULL NAME: USS BLUE RIDGE	PROJECT: 19P	SYSTEM:	PLANT ID:	CASREP CAT:
CU PHASE TITLE: *(K37A-02) F/O - ACCOMPLISH HYDRST TEST OF 1B BLR FO BURNER LEAD PP IN 8-76-0-E					

OTHER SPECIAL REQUIREMENTS:
CLEANLINESS FOR PIPING SYSTEM/EQUIPMENT LEVEL II.

Ref. No.	Document/Drawing Number	DOCUMENT/DRAWING TITLE	REV	CHG NO.	CPY REQ	PARAGRAPH	SECT	PG	CHPT
1	NSI FY-25	NAVSEA Standard Items	-	ORG	N				
2	LI FY-25	Local Standard Items	-	ORG	N				
3	DWG 210-2492122	F.O SERV. DISCH. Piping - ARR	G		Y			ALL	

TASK NAME / TASK DESCRIPTION	SHOP/ TSD	TS	SF WC	CREW #	MHRS	RWRK
2.1 PFTR HRs, RGRS HRs, INSL HRs, ELEC HRs, QA HRs	22/KE	PC				N
2.2 PNTR HRs, QA HRs	22/KE	PC				N
Piping Work CFM sample cost for lead paint, misc such as painting material, plastic bag and tapes.	22/MQ	CS				N
Electrical Work CFM for insulation tape, plastic bags, rope, and other consumable.	22/MQ	CS				N
Process Funding Document.	10/CT	OM				N

MATERIAL REFERENCES			
REF NO.	DOCUMENT/DRAWING NUMBER	DOCUMENT/DRAWING TITLE	REV

ICN: 3819P22115	KEY OP: A06
-----------------	-------------

MATERIAL LIST												
ITEM NO.	PC NO.	REF NO.	M / C	DESCRIPTION	STOCK NUMBER	GENERIC MATL TYPE	LVL	QA	HAZ MAT	DOC NO.	QTY REQD/ UNIT	QTY USED/ UNIT
001			M	GASKET, SPIRAL WOUND, GASKET, SPIRAL WOUND, 1/2"- 600 ORDERED FOR KTR, ORG: C234, T. NAGASHIMA, TEL: 243-4527	9B 5330 013387849		NA	4	N	50435171	6/EA	
002			M	GASKET, SPIRAL WOUND, GASKET, SPIRAL WOUND, 3/4"-600 ORDERED FOR KTR, ORG: C234, T. NAGASHIMA, TEL: 243-4527	9B 5330 013387875		NA	4	N	50435166	6/EA	

ATTACHMENT LIST

TITLE	FILE NAME	SAVED DATE
ENCLOSURE-01	3819P22115A06-QA28.docx	10-FEB-2025 0000

♦1. SHIP USS BLUE RIDGE		HULL NO. LCC19		♦2. JCN EM02-L192		♦3. LWC/SHOP KTR		♦4. CWP/REC SER NO. N/A		5. SYSTEM/COMPONENT/ROTATABLE POOL SER NO. FO BURNER LEAD SYSTEM PIPING			
♦6. REFERENCES: TEST REF (E.G., MS, TECH MAN) & OTHER REFS (E.G., VLV DWG)				7. TEST GAGE RANGE /INSTRUMENT USED		SERIAL NO.		CAL DUE DATE		8. RELIEF VLV SET POINT			
A.		S9086-RK-STM-010/CH-505 Rev. 6											
B.		DWG 210-2492121 Rev. E											
C.													
D.													
9. TEST REQUIREMENTS & RESULTS													
TEST TYPE KEY		H = STRENGTH AND POROSITY/ELEVATED PRESSURE TEST				J = MECHANICAL JOINT TIGHTNESS		ST = SEAT TIGHTNESS		OP = OPERATIONAL		O = OTHER (SPECIFY):	
♦ TEST TYPE (SEE KEY)	♦ PARAGRAPH DESCRIBING VALVE POSITION AND POINT OF ENTRY	♦ REF LTR	GAGE USED (LTR FROM BLK 7)	♦ REQUIRED MEDIUM	MEDIUM USED	♦ REQUIRED PRESSURE	ACTUAL PRESSURE	♦ MINIMUM DURATION	ACTUAL DURATION	♦ ALLOWED LEAKAGE	ACTUAL LEAKAGE	SAT/UNSAT	SIGNATURE, BADGE NO. & DATE
H	2.1.1 for 1.3.1	A,B		Clean Fresh Water		605 PSIG		30 minutes		None			
H	2.1.1 for 1.3.2	A,B		Clean Fresh Water		605 PSIG		30 minutes		None			
H	2.1.1 for 1.3.3	A,B		Clean Fresh Water		605 PSIG		30 minutes		None			
10. REMARKS. (CRAFTSMAN/QAI SUBMIT A DF TO RESOLVE UNSAT DATA)													
11. QA INSPECTOR/SHOP SUPERVISOR SIGNATURE/BADGE NO. (RECORD REVIEWED FOR FINAL ACCEPTANCE)													
DATE													
12. QAS SIGNATURE/BADGE NO. (RECORD HAS BEEN REVIEWED FOR COMPLETENESS)													
DATE													