





NEW		PANEL "HA"										480 / 277 V 3 PH- 4 W 600 A- 3 P MCB 42 KAIC						
LOAD SERVED		LOAD			BKR TRIP	WIRE SIZE	CKT NO.	A B C			CKT NO.	WIRE SIZE	BKR TRIP	LOAD			LOAD SERVED	
		A	B	C				A	B	C				A	B	C		
DOAU-1		38.6			50	-	1				2	-	125	54.3			PANEL HB	
			38.6				3				4				56.5			
				38.6			5				6					53.7		
RTU-1		31.8			40	-	7				8	-	15	4.9			IDU-1	
			31.8				9				10				4.9			
				31.8			11				12					4.9		
MAU-1		68.9			100	-	13				14	-	15	4.9			IDU-2	
			68.9				15				16				4.9			
				68.9			17				18					4.9		
ODU-1		18.0			25	-	19				20	-	15	4.9			IDU-3	
			18.0				21				22				4.9			
				18.0			23				24					4.9		
ODU-2		18.0			25	-	25				26	-	15	7.6			EF-1	
			18.0				27				28				7.6			
				18.0			29				30					7.6		
ODU-3		18.0			25	-	31				32	-	-	-			SPACE	
			18.0				33				34				-			
				18.0			35				36					-		
WH-1		65.0			90	-	37				38	-	-	-			SPACE	
			65.0				39				40				-			
				65.0			41				42					-		
SQ D HCM I-LINE 72" MTG HEIGHT		258.3	258.3	258.3	TOTAL CONNECTED LOAD (AMPS)			A= 334.9A B= 337.1A C= 334.3A						16.6	18.8	16.0	MOUNTING: SURFACE ENCLOSURE: NEMA 1 FEEDER: -/PH AIC EACH CB: -,000	

NEW		PANEL "HB"					480 / 277 V 3 PH- 4 W 125 A- 3 P MLO 42 KAIC									
LOAD SERVED	LOAD			BKR TRIP	WIRE SIZE	CKT NO.	A B C			CKT NO.	WIRE SIZE	BKR TRIP	LOAD			LOAD SERVED
	A	B	C				A	B	C				A	B	C	
MIXER 40QT	16			20	#12	1				2	#12	20	11			LIGHTS – KITCHEN
		16				3				4	#12	20		13		LIGHTS – TRAINING AREA
			16			5				6	#12	20			10	LIGHTS – CONFERENCE ROOM
OVEN BAKING	20			30	#10	7				8	–	20	–			SPARE
		20				9				10	–	20		–		SPARE
			20			11				12	–	20			–	SPARE
SPARE	–			20	–	13				14	–	20	–			SPARE
SPARE		–		20	–	15				16	–	20		–		SPARE
SPARE			–	20	–	17				18	–	20			–	SPARE
SPARE	–			20	–	19				20	–	20	–			SPARE
SPARE		–		20	–	21				22	–	20		–		SPARE
SPARE			–	20	–	23				24	–	20			–	SPARE
SPARE	–			20	–	25				26	–	20	–			SPARE
SPARE		–		20	–	27				28	–	20		–		SPARE
SPARE			–	20	–	29				30	–	20			–	SPARE
SQ D NF	36.0	36.0	36.0	TOTAL CONNECTED LOAD (AMPS)			A= 47.3A B= 49.2A C= 46.4A						11.3	13.2	10.4	MOUNTING: SURFACE ENCLOSURE: NEMA 1 FEEDER: –/PH AIC EACH CB: –,000

EXISTING		PANEL "KA"										208 / 120 V 3 PH- 4 W 225 A- 3 P MLO 10 KAIC									
LOAD SERVED	LOAD			BKR TRIP	WIRE SIZE	CKT NO.	A B C			CKT NO.	WIRE SIZE	BKR TRIP	LOAD			LOAD SERVED					
	A	B	C				A	B	C				A	B	C						
EXHAUST FAN	-			20	-	1				2	-	20	-			EXISTING LOAD					
EXISTING LOAD		-		20	-	3				4	-	20		-		RITEHEN					
GRILL			-	20	-	5				6	-	20			-	HEATER					
FREEZER EVAP	-			20	-	7				8	-	20	-			SPARE					
EXISTING LOAD		-		20	-	9				10	-	20		-		SPARE					
WALK-IN COOLER FAN			-	20	-	11				12	-	20			-	SPARE					
BLUE BOX CONDENSER	-			20	-	13				14	-	20	-			SPARE					
15"		-		20	-	15				16	-	20		-		SPARE					
17"			-	20	-	17				18	-	20			-	SPARE					
RP-1	4.4			20	-	19				20	-	20	-			SPARE					
CONTROL PANEL		1.0		20	-	21				22	-	20		-		SPARE					
EMERGENCY SHUTOFF SWITCH			1.0	20	-	23				24					-						
SPARE	-			20	-	25				26			-								
TOASTER 115 VOLT		-		20	-	27				28	-	20		-		BONVEYOR					
			-			29				30	-	20			-	SPARE					
DISHWASHER	-			20	-	31				32	-	20	-			ICE MACHINE					
		-				33				34				-							
SPACE			-	-	-	35				36	-	20			10	CEILING MOUNTED TRACK (BUS DUCT)					
WATER HEATER	-			20	-	37				38			10								
		-				39				40	-	20		10		CEILING MOUNTED TRACK (BUS DUCT)					
			-			41				42					10						
--	-	-	-	TOTAL CONNECTED LOAD (AMPS)			A= -A B= -A C= -A						-	-	-	MOUNTING: SURFACE ENCLOSURE: NEMA 1 FEEDER: -/PH AIC EACH CB: -,000					

EXISTING																
PANEL "KE"																
208 / 120 V 3 PH- 4 W 225 A- 3 P MLO 10 KAIC																
LOAD SERVED	LOAD			BKR TRIP	WIRE SIZE	CKT NO.	A B C			CKT NO.	WIRE SIZE	BKR TRIP	LOAD			LOAD SERVED
	A	B	C				A	B	C				A	B	C	
RECEPTACLES	—			20	—	1				2	—	20	—			HOOD LIGHT – FIRE SUP SYS
ICE MACHINE CUBER		—		20	—	3				4	—	20		—		LIGHTS – LOCKER ROOM
ICE MACHINE FLAKER			—	20	—	5				6	—	20			—	DISHWAHER & LIGHTS
RECEPTACLES	—			20	—	7				8	—	20	—			LIGHTS
RECEPTACLES		—		20	—	9				10	—	20		—		WALK-IN FAN
MENS DRESSING ROOM			—	20	—	11				12	—	20			—	EXISTING LOADS
COOLER	—			20	—	13				14	—	30	—			CONVEYOR
		—				15				16				—		
			—			17				18					—	
CONEYOR	—			30	—	19				20	—	30	—			MAIN DISHWASHER
		—				21				22				—		
			—			23				24					—	
DISHWASHER	—			30	—	25				26	—	50	—			SPARE
		—				27				28				—		
			—			29				30					—	
EXISTING LOADS	—			20	—	31				32	—	20	—			EXISTING LOADS
BOOSTER HEATER		—		40	—	33				34	#12	20		5.6		MEAT SLICER
			—			35				36	#12	20			6.7	UNDERCOUNTER REFRIDGERATOR
	—					37				38	#12	20	6.4			UNDERCOUNTER FREEZER
HOOD,MAU1,EF1 CONTROL PNL		10		20	#12	39				40	#12	20		13.1		REEFER FREEZER COMBO
TANK FIRE SYSTEM			10	20	#12	41				42	#12	20			16	FOOD WARMER
--	—	—	—	TOTAL CONNECTED LOAD (AMPS)			A= —A B= —A C= —A						—	—	—	MOUNTING: SURFACE ENCLOSURE: NEMA 1 FEEDER: —/PH AIC EACH CB: —,000

EXISTING		EXISTING PANEL "MCP"										208 / 120 V 3 PH- 4 W 600 A- 3 P MCB 25 KAIC				
LOAD SERVED	LOAD			BKR TRIP	WIRE SIZE	CKT NO.	A B C			CKT NO.	WIRE SIZE	BKR TRIP	LOAD			LOAD SERVED
	A	B	C				A	B	C				A	B	C	
SPACE	-			--	-	1				2	-	--	-			SPACE
		-			-						-			-		
			-		-						-				-	
SPACE	-			--	-	3				4	-	--	-			SPACE
		-			-						-			-		
			-		-						-				-	
A.C.UNIT - MALL	-			250	-	5				6	-	250	-			A.C. UNIT - MALL
		-			-						-			-		
			-		-						-				-	
A.C. UNIT - MALL	-			250	-	7				8	-	250	-			A.C. UNIT - MALL
		-			-						-			-		
			-		-						-				-	
EXISTING LOAD	-			250	-	9				10	-	200	-			POWER PANEL #5
		-			-						-			-		
			-		-						-				-	
NEW TWIN TILT KETTLE	78.6			100	-	11				12	-	200	-			SANDWICH LINE
		78.6			-						-			-		
			78.6		-						-				-	
POWER PANEL	-			125	-	13				14	-	250	-			SPARE
		-			-						-			-		
			-		-						-				-	
LIGHTS	-			200	-	15				16	-	125	-			FRYER
		-			-						-			-		
			-		-						-				-	
MAIN BREAKER	-			600	-	17				18	-	--	-			NON-USABLE SPACE
		-			-						-			-		
			-		-						-				-	
--	-	-	-	TOTAL CONNECTED LOAD (AMPS)			A= -A B= -A C= -A						-	-	-	MOUNTING: RECESSED ENCLOSURE: NEMA 1 FEEDER: - AIC EACH CB: -