

RFQ IHS1524765 – Questions and Answers

Are these the only two Fire Alarm systems that are to be quoted in the solicitation?

The SOW does not list the number of fire alarms. It lists the fire risers. This work is primarily for fire sprinkler testing.

Cibecue Clinic has a fire alarm.

Hospital has a fire alarm.

Annex Building has a fire alarm.

Fire risers and Fire Sprinkler Systems are located at the following buildings:

LOCATION	# OF FIRE RISERS
Cibecue Clinic	1
Annex Building	1
Hospital	2
Special Service Building	2
Garrett Building	1
Apartment #298	1
Apartment #302	1

Is Fire Alarm testing to be quoted on a semi-annual basis?

This is work for fire sprinkler inspections. Per the statement of work. The services to be quoted are:

- Quarterly Fire Sprinkler Testing and Inspections.
- Semi-Annual Fire Sprinkler Testing and Inspections.
- Annual Fire Sprinkler Testing and Inspections.

It shows the device count for each, but it doesn't specify a brand/model of panel or quantity of power supplies, if any. Can you please provide me with that information?

Hospital has a fire alarm.

Make: Notifier

Model: NFS-3030

SLC/IDC Voltage: 13~15

Cibecue Clinic has a fire alarm.

Make: Notifier

Model: AFP-200R

SLC/IDC Voltage: 15 ~ 18

Annex Building has a fire alarm.

Make: Notifier

Model: NFS2-3030

SLC/IDC Voltage: 15 ~ 18

Lastly, since this was set to me by a third-party, will you need our submission sent to them, or can it be sent to you?

The Prime contractor needs to be submit to me.

Is it to be sent via SAM.gov, or can it be emailed to you?

Submittal instructions are in Attachment A and Attachment B.