

Vendor Questions and Answers					
Question No.	RFP Attachment No.	REFERENCE		QUESTION	Government Response
		Page	Section		
1	USHMM+Generator+Maintenance+RFP	1	Offer Due Date	Block 8. states the Offer Due Date/Local Time is 5/9/2026 5:00PM and Block 20. start 5/7/2026. Please confirm Offer Due Date/Local Time is to be Friday, 5/8/2026 5:00PM.	The proposal due date is 5/8/2026 5:00 PM. But due to clarification questions received, Amendment #1 will extend the proposal due date to 5/11/2026 5:00 PM.
2	USHMM+Generator+Maintenance+RFP & Generator+SOW+FY26	1	Period of Performance/Contract Terms & Conditions	Period of Performance in SOW is base period + 4 option periods, with USHMM having unilateral option of extending for 5 consecutive periods, we found no Option year related FAR Clauses (i.e. 52.217-8 or 52.217-9) included in Terms and Conditions of the RFP. Pricing form allows for base +4 opt yrs to be priced, however, it is unclear how to price the 5 option periods. As such, please provide the applicable FARs which apply to the additional 5 yr periods or revise the pricing form to allow bidders to price the additional 5 yr periods.	This contract will run from date of award for 60 months. There will be one base period plus four options. FAR Clauses 52.217-8 Option to Extend Services and 52.217-9 Option to Extend Term of the Contract are incorporated in Amendment #1. The bid schedule will be revised.
3	USHMM+Generator+Maintenance+RFP	4 & 6	Contract Terms and Conditions	FAR 52.204-14 Service Contract Reporting and 52.222-41 Service Contract Labor Standards as well as other Service Contract Labor standard FARs are checked for this RFP, as such, could USHMM please provide the applicable wage scale applicable to all bidders?	FAR clauses 52.204-14 and 52.222-41 are removed and substituted with 52.222-5 Davis-Bacon Act-Secondary Site of Work and 52.222-6 Davis-Bacon Act in Amendment #1. The current wage determination applies as copy will be posted with Amendment #1.
4	USHMM+Generator+Maintenance+RFP	5	Contract Terms and Conditions	Upon review of Contract Terms and Conditions, we see 52.219.8 and 52.219-9 are checked, as such is there a Small Business Subcontracting Plan required of the awarded bidder?	FAR Clauses 52.219-8 and 52.219-9 will be removed with Amendment #1. No subcontracting plan will be required due to the dollar amount.
5	USHMM+Generator+Maintenance+RFP	5	Contract Terms and Conditions	We noticed 52.225-1 Buy American is marked in list of FARs; considering OEM repair parts are not always BAA compliant despite the original system may have been sourced as BAA compliant, to avoid awarded bidder requesting BAA waivers for non-compliant OEM repair parts would USHMM consider removing this requirement or changing/adding the requirement to reflect 52.225-5 Trade Agreement Act to at least broaden the list of countries OEM repair parts may originate?	We are willing to add FAR 52.225-5 but the Trade agreement act has a cost threshold that we do not think this contract will meet. Buy American Act Clause will remain.
6	Generator+SOW+FY26	3	Equipment	The Automatic Transfer Switch (ATS) is a single point of failure during an emergency. Please confirm whether ATS maintenance should be added to the service contract. If so, provide the ATS equipment associated with each generator.	ATS maintenance is handled by the Museum.
7	Generator+SOW+FY26	2	Schedule of Quarterly Maintenance and Annual Load	Does the contractor need to provide backup power during the annual PM?	No, the Museum will provide a back up generator for the annual PM.
8	Generator+SOW+FY26			Does the contractor need to provide backup power during the load bank testing?	No, the building load is part of the load the contractor will use for the testing along with the load bank.
9	BID+SHEET	1	General	Are you able to provide a Microsoft Excel copy of this document?	Yes
10	BID+SHEET	1	Description	The USHMM and RAC generators appear on a single pricing line. Please separate them so that each generator has its own pricing line.	Please price it as listed.
11	BID+SHEET	1	Description	Please add separate pricing lines for the ATS associated with each generator.	No need for this ATS is handled by the Museum.