

Grade D Air Compressor & Regenerative Air Dryer Rental

APPENDIX "A" Interface Requirements For Rental Equipment Hook-up To NNSY Temporary Service

NOTE: All Rental Equipment received by NNSY must be supplied with proper interface connectors shown below to allow hook-up by NNSY Shop. There may be specific equipment that will require NNSY Shop evaluation to determine proper cabling and connectors.

Mechanical Service: Shall have 2" Male NPT inlet and outlet connections.

110-120 VAC Service: Material Manufactured by Duraline
20 Amp or less- 3 foot tail of 12/3 cable w/3MT20 crowsfoot plug
Over 20 Amp and up to 50 Amp : 3 foot tail of 6/3 cable w/3MT50 crowsfoot plug

440 VAC Service: Material Manufactured by Duraline
20 Amp or less- 3 foot tail of 12/4 cable w/ 4MT20 crowsfoot plug
Over 20 Amp and up to 50 Amp- 3 foot tail of 6/4 cable w/ 4MT50 crowsfoot plug Above can also be used on 220VAC Any service over 50 Amp requires box cable

440 VAC 50-100 Amp Service: *Material manufactured by Crouse Hinds*
50- 100 Amps 3-5 foot length of 2/4 cable w/male camlock twist connectors:
Part Numbers:
Brass -A200036-2
Black Sleeve- A200706-7
White Sleeve- A200706-12
Red Sleeve-A200706-9

Over 100 and up to 225 Amps: 3- 5 foot length of 3 conductor 3/0 cable with camlock connectors:
Part Numbers:
Brass - A200038-2
Black Sleeve- A2000706-13
White Sleeve-A2000706-18
Red Sleeve- A2000706-15

Over 225 and up to 400 Amps: 5-15 length of 500 MCM cable w/camlock connectors:
Part Numbers:
Brass- A20028-2
Black Sleeve-A200056-
White Sleeve-A200056-6
Red Sleeve- A200056-3