

Department of Veterans Affairs

ATTACHMENT A
Memorandum 626-01-EC5-01

INTERIM LIFE SAFETY MEASURES (ILSM) CHECK SHEET	AHU Refurbish Fan Room 15/6/12	PROJECT NO.	COTR Clint Roberts
--	--------------------------------	-------------	------------------------------

The COTR for each and every project will complete this ILSM Check Sheet prior to the start of the project. When project work makes it necessary to implement ILSM, the Safety Officer will be informed. The Safety Officer will assist in initiating those ILSM necessary to maintain life safety before the project starts. The COTR is responsible for assuring that the project does not start before ILSM are in place. The COTR is responsible for conducting daily inspections of the work site.

1.	Will any exits be obstructed during construction such that alternative exits will have to be established? If yes, then the Safety Officer must provide training to all concerned staff on alternative exiting arrangements.			Yes ☐ No ☒
	Training completed:	Date	By	
2.	Will access to emergency services be obstructed so that emergency forces cannot gain access? If yes, then alternate means of access or proper direction for emergency service personnel must be provided.			Yes ☐ No ☒
	Corrections completed:	Date	By	
3.	Will any fire alarm, detection, or suppression system be impaired during this project? If yes, then a temporary but equivalent system must be provided. The temporary system must be inspected every day.			Yes ☐ No ☒
	Temporary in place:	Date	By	
4.	Will temporary construction partitions be necessary? If yes, then the temporary partitions must be smoke tight and built of non-combustible or limited-combustible materials that will not contribute to the development or spread of fire.			Yes ☐ No ☒
5.	Will additional fire fighting equipment be necessary? If yes, then the COTR will assure that the contractor provides construction employees with adequate fire extinguishers and assure that these employees are properly trained in the use of the fire fighting equipment.			Yes ☐ No ☒
6.	Will the level of fire safety that is required by the Life Safety Code be reduced because of exiting deficiencies or other activities due to the construction? If yes then the Safety Officer will initiate a program of conducting two fire drills per shift per quarter in the areas affected by the construction for the duration of the project.			Yes ☐ No ☒
7.	Will structural or compartmentation features of fire safety be compromised? If yes, then the Safety Officer will provide training on alternate fire safety procedures to the personnel of all smoke zones that will be affected.			Yes ☐ No ☒
	Training completed:	Date	By	
8.	Will any of the above ILSM need to be implemented? If yes, then In addition to the training and education initiatives, the Safety Officer will initiate a memorandum for the Director's signature addressed to all employees that clarifies the ILSM taken to address any Life Safety Code deficiencies and/or construction hazards that will exist during this project.			Yes ☐ No ☒
	Memorandum initiated:	Date 4/29/2026	By	

Remarks: All work will be performed in the fan room inside the actual air handling unit.