

FA302925R0011 Repair Roof F542

Q1	Is it acceptable to triple-hat the SSHO, QC, and Superintendent roles on this project?
A1	Yes
Q2	Is a licensed architect or registered roof consultant required for this project in accordance with the UFC?
A2	This project should comply with all applicable UFC requirements. Reference UFC 3-110-03, Ch5
Q3	Is it acceptable to install the new lightning protection system externally and abandon the existing system in place?
A3	No, the contractor will utilize the existing system as it also bonded to the structure.
Q4	Is there an existing detail of the roof profile available? We have been unable to locate the required R-value for the new roof.
A4	Design shall comply with ASHRAE 90.1, zone 4
Q5	Should we anticipate any deck replacement as part of this project? While not specifically listed, it is commonly required. If so, would including an allowance equal to 10% of the total roof square footage be appropriate?
A5	Yes
Q6	Should we anticipate any masonry replacement or repair on this project? While exterior cleaning and localized repairs are noted, should contractors include a tuckpointing allowance of approximately 10% of the total masonry surface area?
A6	Limit masonry repairs to that as described in the statement of work.
Q7	Is a reflected ceiling plan available, and if so, can it be provided to bidders? This would be particularly helpful if the existing lightning protection system is to be fully removed.
A7	Record drawings will be provided.
Q8	Where are mentioned specifications appendix B or the as-builts appendix C
A8	Refer to addendum attachment