

**SECTION 080100
WINDOW CLEANING: INTERIOR & EXTERIOR**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Wash interior and exterior glass and frames of each window assembly identified in this contract.
- B. Window washing shall be completed after all other work is complete.

PART 2 PRODUCTS

2.01 NA

PART 3 EXECUTION

3.01 CLEANING

- A. Remove excess glazing materials from finish surfaces immediately after application using solvents or cleaners recommended by manufacturers.
- B. Remove nonpermanent labels immediately after glazing installation is complete.
- C. Clean glass and adjacent surfaces after sealants are fully cured.
- D. Wash surfaces by method recommended and acceptable to window manufacturer; rinse and wipe surfaces clean.
- E. Immediately remove stains resulting from the work of this section.
- F. Clean surrounding surfaces.

END OF SECTION

SECTION 080110 WINDOW WEATHERSTRIPPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Replacement of all existing vinyl window weatherstripping and replace in-kind.

1.02 SUBMITTALS

- A. Product Data: Vinyl weatherstripping system for windows.
- B. Warranty Documentation: Submit 5 year warranty that ensures water will not reach the interior of the building through the window assemblies.

1.03 WARRANTY

- A. Watertight Window Assembly: Provide a five (5) year warranty to include coverage for seal failure, interpane dusting or misting, including providing products to replace failed units.

PART 2 PRODUCTS

2.01 PERFORMANCE REQUIREMENTS - EXTERIOR GLAZING ASSEMBLIES

- A. Weather-Resistive Barrier Seals: Provide completed assemblies that maintain continuity of building enclosure water-resistive barrier, vapor retarder, and/or air barrier.

2.02 WEATHERSTRIPPING

- A. Vinyl weatherstripping to match existing system.
- B. Supplemental Sealants
 - 1. Type GC-2 - Butyl Sealant: Single component; ASTM C920 Grade NS, Class 12-1/2, Uses M and A, Shore A hardness of 10 to 20; black color.
 - 2. Type GC-4 - Polyurethane Sealant: Single component, chemical curing, nonstaining, nonbleeding; ASTM C920 Type S, Grade NS, Class 25, Uses M, A, and G; with cured Shore A hardness range of 20 to 35; black color.
 - 3. Type GC-5 - Silicone Sealant: Single component; neutral curing; capable of water immersion without loss of properties; nonbleeding, nonstaining; ASTM C920 Type S, Grade NS, Class 25, Uses M, A, and G; with cured Shore A hardness range of 15 to 25; color as selected.

PART 3 EXECUTION

3.01 PREPARATION

- A. Clean contact surfaces with appropriate solvent and wipe dry within maximum of 24 hours before sealing. Remove coatings that are not tightly bonded to substrates.
- B. Seal porous glazing channels or recesses with substrate compatible primer or sealer.
- C. Prime surfaces scheduled to receive sealant where required for proper sealant adhesion.

3.02 INSTALLATION, GENERAL

- A. Install weatherstripping/glazing in compliance with written instructions of glass, gaskets, and other material manufacturers, unless more stringent requirements are indicated.
- B. Install weatherstripping/glazing sealants in accordance with manufacturer's instructions.

3.03 CLEANING

- A. Remove excess glazing materials from finish surfaces immediately after application using solvents or cleaners recommended by manufacturers.

END OF SECTION

SECTION 080153 WINDOW CAULK

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Replacement of caulking/joint sealant around exterior window frames.

1.02 SUBMITTALS

- A. Product Data: Caulk/joint sealant

PART 2 PRODUCTS

2.01 CAULK (JOINT SEALANT)

- A. Several sealants have been tested by sealant manufacturers and have been found to be compatible with Dryvit products. These sealants are:
 - 1. Tremco, Inc.
 - 1) Sealant: Spectrem 1, Spectrem 3, and Spectrem 4
 - 2) Primer: TREMprime Silicone Porous Primer
 - 2. Pecora Corporation
 - 1) Sealant: Dynatrol II
 - 2) Primer: Type 75 or 150
 - 3. Pecora Corporation
 - 1) Sealant: 890 FTS or 890 NFT
 - 2) Primer: 150
 - 4. Sika Corporation
 - 1) Sealant: Sikaflex 2C
 - 2) Primer: Sikaflex 429A
- B. Use one of the above listed sealants and primers or an approved equal recognized by the Dryvit system manufacturer.
- C. To the greatest extent possible, new sealant shall match color of existing sealants.

PART 3 EXECUTION

3.01 INSTALLATION, GENERAL

- A. Remove existing deteriorated joint sealant compound from exterior window perimeters.
- B. Application of new sealant shall follow sealant manufacturer's installation instructions.
- C. Install primer, bond breaker and/or backer rod as required.
- D. Apply sealant with gun or knife as appropriate, using proper nozzle and technique. Sealant should completely fill joint cavity to backer material and be in intimate contact with the substrate.
- E. Finished sealant shape and color shall match existing

END OF SECTION

SECTION 088155 WINDOW REPLACEMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Replacement of existing damaged windows and supporting elements.
 - 1. Window casings, trim, sealants/weatherstripping, frames, etc.

1.02 SUBMITTALS

- A. Product Data: Include component dimensions, information on glass and glazing, internal drainage details, and descriptions of hardware and accessories.

1.03 FIELD CONDITIONS

- A. Do not install sealants when ambient temperature is less than 40 degrees F (5 degrees C).
- B. Maintain this minimum temperature during and 24 hours after installation of sealants.

PART 2 PRODUCTS

2.01 REPLACEMENT WINDOWS

- A. Custom-fabricate replacement windows to accurately replicate key features of existing units.
 - 1. Fabricate using same or similar materials.
 - 2. Replicate configuration of glass panes.
 - 3. Replicate glass and glazing materials.
 - 4. Replicate proportions and profiles of the frame components, sash components, and exterior trim.
 - 5. Provide weatherstripping of type that does not significantly change the original appearance of the units.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces to be cleaned and restored are ready for work of this section.

3.02 PREPARATION - IN SITU RESTORATION

- A. Install windows in accordance with manufacturer's instructions.
- B. Protect surrounding elements from damage due to restoration procedures.
- C. Remove or dismantle and store removable items located in areas to be restored including, but not limited to, fixtures, fittings, finish hardware, and accessories; reinstall upon completion of restoration work.
- D. Separate areas to be protected from restoration areas to prevent damage.

3.03 WEATHERIZATION

- A. Apply weatherstripping indicated along edge of sash in accordance with manufacturer's instructions.

3.04 CLEANING

- A. Immediately remove stains resulting from the work of this section.
- B. Clean surrounding surfaces.

END OF SECTION