

COMBINED SYNOPSIS/SOLICITATION
Fire Alarm Suppression and Testing
US Forest Service – Job Corps. - Timber Lake - Estacada, OR 97023

Description

This is a combined synopsis/solicitation for commercial items prepared in accordance with the format in FAR Part 12. This announcement constitutes the only solicitation. Quotations are being requested and a separate written solicitation will not be issued.

Solicitation 1282A726Q0022 is issued as a Request for Quotation (RFQ) for a fire alarm repair. This acquisition is set-aside for small business concerns. The applicable North American Industry Classification Standard Code is 561621 The small business size standard is \$25 million. This acquisition is a Total Small Business Set-Aside. All responsible sources may submit a quotation which will be considered by the agency.

Statement of Requirement

This project is located at the Timber Lake Job Corps Center campus located approximately 25.6 miles east of Estacada, Oregon couple blocks past mile marker 48 on the left. The address is 59868 E Highway 224, Estacada, Oregon 97023. Driving directions can be obtained by calling the Center at 503.834.3400, 503.834.3455 or 503.834.3450.

Schedule of Items:

	Description	SERIAL/PRODUCT NO.	QUANTITY	UNIT COST	AMOUNT
Base Year: 12 Months					
0001	15-Year & 1-year Annual Inspection (2026)		1		

BASE YEAR TOTAL:

	DESCRIPTION	SERIAL/PRODUCT NO.	QUANTITY	UNIT COST	AMOUNT
Option Year 1: 12 Months					
1001	15-Year & 1-year Annual Inspection (2027)		1		

OPTION YEAR 1 Total:

	DESCRIPTION	SERIAL/PRODUCT NO.	QUANTITY	UNIT COST	AMOUNT
Option Year 2: 12 Months					
2001	15-Year & 1-year Annual Inspection (2028)		1		

OPTION YEAR 2 Total:

	DESCRIPTION	SERIAL/PRODUCT NO.	QUANTITY	UNIT COST	AMOUNT
Option Year 3: 12 Months					
3001	15-Year & 1-year Annual Inspection (2029)		1		

OPTION YEAR 3 Total:

	DESCRIPTION	SERIAL/PRODUCT NO.	QUANTITY	UNIT COST	AMOUNT
Option Year 4: 12 Months					
4001	15-Year & 1-year Annual Inspection (2030)		1		

OPTION YEAR 4 Total:

GRAND TOTAL:

Signature: _____

Date: _____

See Attachment 3 – Certificate of Conformance

The contractor shall furnish a Certificate of Conformance (COC) in accordance with Federal Acquisition Regulation (FAR) clause 52.246-15. COC must be submitted in the format specified in the clause. Offerors must be able to provide necessary certification including traceability to the manufacturer, manufacturer's COC, and its own certificate of conformance. Prospective vendors who are not the OEM or an authorized distributor must provide traceability for the offered product back to the manufacturer or authorized distributor.

Vendors having the expertise and required capabilities to provide these items are invited to submit offers in accordance with the requirements stipulated in this solicitation. Alternate Parts will be authorized if they are an approved alternate part that satisfies all form, fit, and function requirements of the original parts and conform to the approved configuration. All parts shall be NEW approved parts.

Solicitation Attachments:

The following documents are included as attachments to this solicitation:

- Attachment 1 – Certificate of Conformance
- Attachment 2 – Experience Questionnaire
- Attachment 3 – Vicinity Site
- Attachment 4 – Oregon County Wage Determination

Federal Acquisition Regulation (FAR) and United States Department of Agriculture Acquisition Regulation (AGAR) Clauses and Provisions

The clauses and provisions contained herein are applicable to any order awarded as a result of this solicitation. The terms and conditions set forth herein supersede all other terms and conditions. Acceptance of the order in accordance with (IAW) FAR 12.201-1(b)(2) constitutes acceptance of all terms and conditions contained herein.

As part of the Revolutionary FAR Overhaul (RFO), system updates may lag policy updates. The System for Award Management (SAM) may continue to require entities to complete representations based on provisions that are not included in this solicitation. Contracting officers will rely on representations from offers based on provisions in the solicitation. Entities are not required to, nor are they able to, update their entity registration to remove these representations in SAM.

52.252-2 Clauses Incorporated by Reference (Feb 1998)

This solicitation incorporates one or more clauses by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. Also the full text of the clause may be accessed electronically at Internet address <https://www.acquisition.gov/far-overhaul/far-part-deviation-guide/far-overhaul-part-52>

Federal Acquisition Regulation (FAR): <https://www.acquisition.gov/browse/index/far> (Clauses are located at [FAR part 52](#) and begin with 52)

Department of Agriculture Acquisition Regulation (AGAR): <https://www.acquisition.gov/agar> (Clauses are located at [AGAR part 452](#) and begin with 452)

Deviations to clauses may be viewed at: [USDA FAR Class Deviations](#)

(End of clause)

- 52.212-4 Terms and Conditions—Commercial Products and Commercial Services (Nov 2025)
☐ Alternate I (Nov 2025) of 52.212-4
- 52.203-17 Contractor Employee Whistleblower Rights (Nov 2023)
- 52.203-19 Prohibition on Requiring Certain Internal Confidentiality Agreements or Statements (Jan 2017)
- 52.222-50 Combating Trafficking in Persons (Nov 2025)
☐ Alternate I (Nov 2025) of 52.222-50
- 52.226-8 Encouraging Contractor Policies to Ban Text Messaging While Driving (May 2024)
- 52.232-39 Unenforceability of Unauthorized Obligations (Jun 2013)
- 52.232-40 Providing Accelerated Payments to Small Business Subcontractors (Mar 2023)
- 52.233-3 Protest After Award (Sep 2025)
- 52.233-4 Applicable Law for Breach of Contract Claim (Sep 2025)
- 52.240-91 Security Prohibitions and Exclusions (Nov 2025)
☐ Alternate I (Nov 2025) of 52.240-91
- 52.244-6 Subcontracts for Commercial Products and Commercial Services (Nov 2025)

The following clauses are applicable if checked:

- ☒ 52.204-13 System for Award Management—Maintenance (Nov 2025)
- ☒ 52.209-10 Prohibition on Contracting with Inverted Domestic Corporations (Sep 2025)
- ☒ 52.217-8 Option to Extend Services (Nov 1999)
30 calendar days prior to contract expiration
- ☒ 52.217-9 Option to Extend the Term of the Contract (Mar 2000)
 (a) 30 Calendar days prior to contract expiration and 60 days
 (c) five years.
- ☒ 52.219-6 Notice of Total Small Business Aside (Nov 2025)
- ☒ 52.222-3 Convict Labor (June 2003)
- ☒ 52.222-19 Child Labor—Cooperation with Authorities and Remedies (Nov 2025)
- ☒ 52.222-36 Equal Opportunity for Workers with Disabilities (Nov 2025)
- ☒ 52.222-41 Service Contract Labor Standards (Aug 2018)
- ☒ 52.222-42 Statement of Equivalent Rates for Federal Hires (May 2014)
- ☒ 52.222-55 Minimum Wages for Contractor Workers Under Executive Order 14206 (JAN 2022)

This Statement is for Information Only:
It is not a Wage Determination

Employee Class	Monetary Wage -- Fringe Benefits
23290 Fire Alarm System Mechanic	\$37.56

- ☒ 52.222-62 Paid Sick Leave Under Executive Order 13706 (Jan 2022)
- ☒ 52.223-23 Sustainable Products and Services
- ☒ 52.225-1 Buy American-Supplies (Nov 2025)
- ☒ 52.232-33 Payment by Electronic Funds Transfer— System for Award Management (Oct 2018)
- ☒ 52.237-2 Protection of Government Buildings, Equipment, and Vegetation (Apr 1984))

Other Applicable Clauses

52.246-15 Certificate of Conformance (Apr 1984)

AGAR Clauses

452.203-71 Anti-Discrimination and Diversity, Equity, and Inclusion (DEI) Compliance (Dec 2025)

(a) By entering into this contract, the Contractor certifies that:

- (1) It is compliant with all applicable Federal anti-discrimination laws and the Equal Protection principles of the U.S. Constitution, and it will remain compliant for the duration of the contract.
- (2) Neither it nor any subcontractor or teaming partner operates or funds any program, policy, or initiative that promotes DEI in a manner that violates any applicable Federal anti-discrimination laws, including but not limited to Title VI and VII of the Civil Rights Act of 1964, or the Equal Protection principles of the U.S. Constitution, and the Contractor and any subcontractor or teaming partner will not do so for the duration of the contract.

(b) If the Contractor participates in, facilitates, or funds programs that implicate Title VI of the Civil Rights Act of 1964 or Title IX of the Education Amendments of 1972, as amended, including but not limited to grants to or for schools, colleges, universities, 4-H programs, non-governmental organization (NGO) programs, sports programs, and education-related grants to prisons or other detention facilities, the Contractor certifies that it will remain compliant with those laws, including the requirements set forth in Executive Order 14168, Defending Women from Gender Ideology Extremism and Restoring Biological Truth to the Federal Government, and Executive Order 14173, Ending Illegal Discrimination and Restoring Merit-Based Opportunity.

(c) The Contractor affirms that the above requirements are conditions of payment that go to the essence of the contract and are therefore material terms of the contract. Payments under the contract are predicated on compliance with the above requirements, and therefore the Contractor is not eligible for funding under the contract or to retain any funding under the contract absent compliance with the above requirements.

(d) This certification reflects a change in the Government's position regarding the materiality of the foregoing requirements and therefore any prior payment of similar claims does not reflect the materiality of the foregoing requirements to this contract.

(e) Submission of a knowing false statement relating to Contractor's compliance with the above requirements and/or eligibility for the contract may subject the Contractor to liability under the False Claims Act, 31 U.S.C. § 3729, and/or criminal liability, including under 18 U.S.C. §§ 287 and 1001.

(f) The Contractor must include the provisions of this clause in all subcontract solicitations.

(g) Failure on the part of the Contractor or its subcontractors to comply with the terms of this clause may be grounds for the Contracting Officer to terminate this contract for default.

(End of Clause)

452.204–70 Modification for Contract Closeout (Nov 2025)

(a) If unliquidated funds in the amount of \$1000 or less remain on the contract, the Contracting Officer (Contracting Officer) shall issue a unilateral modification for deobligation. The contractor will receive a copy of the modification but will not be required to provide a signature. The Contracting Officer shall immediately proceed with contract closeout upon completion of the period of performance, receipt and acceptance of supplies or services, and final payment.

(b) Upon contract closeout for contracts utilizing SAP: if unliquidated funds of more than \$1000 remain on the contract, the Contracting Officer shall issue a bilateral modification for deobligation. The contractor will receive a copy of the modification and will be required to provide a signature. (The Contracting Officer may also request a "Contractor Release of Claims" be completed by the contractor, although not required for contracts and orders using SAP.) If the bilateral modification and Release of Claims are not returned to the Contracting Officer within 60 days, the Contracting Officer shall release the modification as unilateral and proceed with contract close-out upon completion of the period of performance, receipt and acceptance of supplies or services, and final payment.

(c) Upon contract closeout for contracts utilizing anything other than cost reimbursement, if unliquidated funds of more than \$1000 remain on the contract, the Contracting Officer shall issue a bilateral modification for deobligation. The contractor will receive a copy of the modification and a "Contractor Release of Claims" and will be required to provide a signature on both forms. If the bilateral modification and Release of Claims are not returned to the Contracting Officer within 120 days, the Contracting Officer shall release the modification as unilateral and proceed with contract closeout upon completion of the period of performance, receipt and acceptance of supplies or services, and final payment.

(End of Clause)

NOTICE FOR FILING AGENCY PROTESTS **United States Department of Agriculture (USDA) Ombudsman Program**

The USDA is committed to issuing solicitations and awarding contracts in a fair and prompt manner. The Ombudsman Program for Agency Protests (OPAP) was established to address protest issues within the agency, providing an alternative to costly and time-consuming litigation. Operating independently, OPAP offers relief comparable to that granted by the Government Accountability Office (GAO). Interested parties are encouraged to resolve concerns through USDA's internal Alternative Dispute Resolution (ADR) process before pursuing external forums such as the GAO. Concerns may be addressed informally or through a formal agency protest filed with either the Contracting Officer or the Ombudsman.

Informal Forum with the Ombudsman

1. **Initial Point of Contact:** Interested parties who believe a specific USDA procurement is unfair or otherwise defective should first direct their concerns to the applicable Contracting Officer.

2. **Escalation:** If the Contracting Officer is unable to address their concerns, interested parties are encouraged to contact the USDA Ombudsman for Agency Protests. Under this informal process, the agency is not required to suspend contract award performance. Utilization of the informal forum does not suspend any time requirement for filing a formal protest with the agency or other forums.
3. **Required Information:** To ensure a timely response, interested parties should provide the following information to the Ombudsman: solicitation/contract number, contracting office, Contracting Officer, and solicitation closing date (if applicable).

Formal Agency Protest with the Ombudsman

1. **Effort to Resolve:** Prior to submitting a formal agency protest, protesters must first use their best efforts to resolve their concerns with the Contracting Officer through open and frank discussions.
2. **Independent Review:** If the protester's concerns remain unresolved, an Independent Review is available by the Ombudsman. The protester may file a formal agency protest with either the Contracting Officer or, alternatively, with the Ombudsman under the OPAP program. Contract awards or performance will be suspended during the protest period unless justified in writing for urgent and compelling reasons or determined in writing to be in the best interest of the Government.
3. **Resolution Timeline:** The agency's goal is to resolve protests within 35 calendar days from the date of filing.
4. **Required Information:** Protests shall include the information set forth in FAR 33.104(a)(3). Failure to submit the required information may result in a delay or dismissal of the protest.
5. **Timeliness:** Protests must be filed within the timeframes specified in FAR 33.104.
6. **Submission:** Formal protests under the OPAP program should be submitted electronically to SPE.inquiry@usda.gov and the Contracting Officer.

Election of Forum. By initiating a protest with the USDA, the protester agrees not to pursue the same matter with the Government Accountability Office (GAO) or any other external forum while the agency protest is pending. If a protest is filed externally, the agency protest will be dismissed.

Solicitation Information

Award Type

It is anticipated that a stand-alone, firm-fixed price contract will be awarded as a result of this synopsis/solicitation. It is anticipated that a firm-fixed price requirements contract consisting of one (1) one-year base period and four (4) one-year option periods shall be awarded as a result of this synopsis/solicitation. The total duration of this contract shall not exceed five (5) years.

The Government intends to make one award from this solicitation. Therefore, to be considered responsive, contractors must submit pricing for all items.

Evaluation Method and Basis for Award

The provision at FAR 52.212-2, Evaluation—Commercial Products and Commercial Services is not applicable to this solicitation. In lieu of this provision, quotes will be evaluated in accordance with FAR 12.203 based on the criteria listed below. Award will be made to the offeror representing the best value to the Government. The Government will evaluate quotations based on the lowest price technically acceptable criteria. Only the lowest priced offer will be evaluated for Technical Acceptability. Should the lowest priced offer not receive an acceptable technical or past performance rating, the process will continue in order of lowest priced offer until the lowest price, technically acceptable offer with acceptable or neutral past performance is identified.

Technical Approach:

The technical approach will evaluate the ability of the offeror to provide a sound and compliant approach that meets all requirements and shows a thorough understanding of them. It is the contractor's responsibility to ensure their quotation clearly demonstrates their capability to meet these requirements. Technical Acceptability will be evaluated to receive an overall rating of "acceptable" or "unacceptable." This will be based on the offeror's ability to provide a sound and compliant approach that meets all requirements and shows a thorough understanding of them. It is the contractor's responsibility to ensure their quotation clearly demonstrates their capability to meet these requirements. All offerors must provide the following minimum information and documentation with their quotations to be considered responsive and have their offers evaluated:

Technical Factors:

- a. *Sub-factor 1 - Narrative: Ability/capability:* The offeror shall submit a narrative response that clearly demonstrates their understanding of and the approach of accomplishing the service requirements set forth in the statement of work. The Government will evaluate the offeror's narrative statement to assess the offeror's comprehension of the technical requirements of the project and its capacity to successfully execute the specified tasks.
- b. *Sub-factor 2 - Licensing/Certifications:* Offerors must provide proof of Oregon licensing and fire alarm installation certifications.

Technical Experience and Past Performance:

- a. *Technical Experience:* The Government will evaluate the offeror's experience submission to determine if it has met all quotation submission requirements and to determine whether the offeror has sufficient experience to successfully complete the contract requirements. Offerors shall provide up to 3 projects within the last 3 years that demonstrate their experience performing fire alarm repair/support.
- b. *Past Performance:* Past performance will be assessed as part of the quotation evaluation process. Past performance will be assessed and rated as Acceptable, Neutral, or Unacceptable.
 - Acceptable: The contractor shows a demonstrated ability to meet contract requirements in prior or current contracts, including quality of work, timeliness, cost control, business relations, and adherence to contract terms.

- Neutral: Offeror does not have a past performance record.
- Unacceptable: The contractor has a documented history of failing to meet contract requirements, including poor quality, missed deadlines, cost overruns, lack of responsiveness, or unethical behavior.

Price:

The offeror shall provide pricing as requested on pages 2 and 3 - Schedule of Items of this Request for Quote. Failure to propose pricing for all individual line items (missing, incomplete, or calculations are inaccurate) may result in a quotation being excluded from further consideration/ineligible for award. The offeror's quotation will be evaluated in accordance with FAR 12.204, to determine if it is fair and reasonable.

For purposes of evaluation, the potential need to exercise the option under FAR 52.217-8 to extend a period of performance for a maximum period of six (6) months beyond any period of performance will be considered the same for all offerors. The Government will consider that if the extension of service clause (FAR 52.217-8) is exercised, it will be on the exact same rates and terms, other than length of performance, as the period of performance being extended. For purposes of evaluation only, the Government will use the rates specified in the last option period and add the cost of six months to the prices proposed for the base period and all option periods to determine total evaluated price of the contract. The Government will determine whether the price, including the options available under FAR 52.217-8, is fair and reasonable.

Evaluation Method:

The Government will evaluate quotations based on the lowest price technically acceptable criteria. Only the lowest priced offer will be evaluated for technical acceptability. Should the lowest priced offer not receive an acceptable technical or past performance rating, the process will continue in order of lowest priced offer until the lowest price, technically acceptable offer with acceptable or neutral past performance is identified.

Award will be made to the offeror whose proposal is determined to be the lowest price technically acceptable, provided that:

- The proposed price is fair and reasonable
- Salient characteristics of replacement parts are met
- Past performance is assessed as acceptable or neutral.

Notice of award. A written notice of award or acceptance of an offer furnished to the successful Offeror within the time for acceptance specified in the offer, shall result in a binding contract without further action by either party. Before the offer's specified expiration time, the Government may accept an offer (or part of an offer), whether or not there are negotiations after its receipt, unless a written notice of withdrawal is received before award.

(End of provision)

Delivery Information

Fire Alarm repair will be completed at the Timber Lake Job Corps Center, located at 59868 E Highway 224, Estacada, Oregon 97023.

Other Information - Include any other information as needed for the solicitation.

52.252-1 Solicitation Provisions Incorporated by Reference Feb 1998

This solicitation incorporates one or more solicitation provisions by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. The offeror is cautioned that the listed provisions may include blocks that must be completed by the offeror and submitted with its quotation or offer. In lieu of submitting the full text of those provisions, the offeror may identify the provision by paragraph identifier and provide the appropriate information with its quotation or offer. Also, the full text of a solicitation provision may be accessed electronically at this/these address(es): <https://www.acquisition.gov/far-overhaul/far-part-deviation-guide/far-overhaul-part-52>

52.212-1 Instructions to Offerors - Commercial Products and Commercial Services (Nov 2025)

FAR 52.212-1 is amended as follows:

Period for acceptance of offers.

The Offeror agrees to hold the prices in its offer firm for **30 calendar days** from the date specified for receipt of offers.

Quotes are Due **2 June 2026 at 1pm EST**. Quotes submitted in response to this solicitation shall include a price proposal, technical proposal, and contractor representations and certifications. Offeror must have an active entity registration in the System for Award Management (SAM) in order to submit a quote. Emails should contain 3 separate attachments (Technical Proposal (**include/attach the Experience Questionnaire-Attachment 2**), Price Proposal, and Representations and Certifications) in Microsoft Word, Microsoft Excel, or Adobe PDF format. Be aware that large attachments may increase the time required to deliver an email. It is the offerors responsibility to confirm receipts of the quote, **submit signed and dated Quotes** to Darlene.Chase@usda.gov before the exact time specified in this notice.

Options. The Government will evaluate quotations for award purposes by adding the total price for all options to the total price for the basic requirement. This includes options under FAR 52.217-8, Option to Extend Services, which applies to this solicitation. Evaluation of options under FAR 52.217-8 will be accomplished by adding six months of the quoter's price for the last potential period of performance under this contract to the quoter's total price. For example, if the contract includes option periods that are exercisable under FAR 52.217-9, the quoter's total price for the purpose of evaluation will include the base period, all option periods, and an additional six months of the last option period. Quoters must price only the base and option periods specified in the contract line-item numbers (CLINs) and shall not submit a price for the potential six-month extension of services under FAR 52.217-8. The Government reserves the right to exercise the option under FAR 52.217-8 before the end of any of the contractor's performance periods and will be exercised at the price and/or rates in effect at the time the clause is exercised. Evaluation of options shall not obligate the Government to exercise the option(s).

Site Visit:

A site visit is scheduled for May 19, 2026, at 10:00 a.m. PCD Time. Please email Loren Vanhorn at Loren.Vanhorn@usda.gov before 4:00 p.m. May 18, 2026, to be added to the visitor roster.

Questions:

Questions shall be submitted via email to Darlene.Chase@usda.gov and are due no later than May 20, 2026, before 12:00 p.m. PCD Time. This will ensure enough time to respond before the solicitation period ends. **Please include the solicitation name and number as the subject line of the email.**

- 52.203-18 Prohibition on Contracting with Entities that Require Certain Internal Confidentiality Agreements or Statements-Representation (Jan 2017)
- 52.209-2 Prohibition on Contracting with Inverted Domestic Corporations - Representation (Sep 2025)
- 52.209-11 Representation by Corporations Regarding Delinquent Tax Liability or a Felony Conviction under any Federal Law (Sep 2025)
- 52.240-90 Security Prohibitions and Exclusions Representations and Certifications (Nov 2025)

The following provisions are applicable if checked:

- ☒ 52.204-7 System for Award Management—Registration (Nov 2025)
- ☒ 52.222-18 Certification Regarding Knowledge of Child Labor for Listed End Products (Feb 2021)
- ☒ 52.225-2 Buy American Certificate (Oct 2022)

Other Applicable FAR Provisions

- 52.225-18 Place of Manufacture (Aug 2018)
- 52.237-1 Site Visits (Apr 1984)

AGAR Provisions

- 452.203-70 Anti-Discrimination and Diversity, Equity, and Inclusion (DEI) Certification (Dec 2025)

(a) By submission of its offer, the offeror certifies that:

- (3) It is compliant with all applicable Federal anti-discrimination laws and the Equal Protection principles of the U.S. Constitution.
- (4) Neither it nor any proposed subcontractor or teaming partner operates or funds any program, policy, or initiative that promotes DEI in a manner that violates any applicable Federal anti-discrimination laws, including but not limited to Title VI and VII of the Civil Rights Act of 1964, or the Equal Protection principles of the U.S. Constitution.

(b) If the offeror participates in, facilitates, or funds programs that implicate Title VI of the Civil Rights Act of 1964 or Title IX of the Education Amendments of 1972, as amended, including but not limited to grants to or for schools, colleges, universities, 4-H programs, non-governmental organization (NGO) programs, sports programs, and education-related grants to prisons or other detention facilities, by submission of its offer, the offeror certifies that it is compliant with those laws, including the requirements set forth in Executive Order 14168, Defending Women from Gender Ideology Extremism and Restoring Biological Truth to the Federal Government, and Executive Order 14173, Ending Illegal Discrimination and Restoring Merit-Based Opportunity.

(c) The offeror affirms that the above requirements are conditions of payment that go to the essence of the contract and are therefore material terms of the contract. Payments under the contract are predicated on compliance with the above requirements, and therefore the offeror will not be eligible for funding under the contract or to retain any funding under the contract absent compliance with the above requirements.

(d) This certification reflects a change in the Government's position regarding the materiality of the foregoing requirements and therefore any prior payment of similar claims does not reflect the materiality of the foregoing requirements to this contract.

(e) Submission of a knowing false statement relating to offeror's compliance with the above requirements and/or eligibility for the contract may subject the offeror to liability under the False Claims Act, 31 U.S.C. § 3729, and/or criminal liability, including under 18 U.S.C. §§ 287 and 1001.

(f) Failure on the part of the offeror or its subcontractors to comply with the terms of this clause may be grounds for the Contracting Officer to terminate the contract for default.

(End of Provision)

452.211-70 Brand Name or Equal (Sep 2025)

(a) If an item in this solicitation is identified as "brand name or equal," the purchase description reflects the characteristics and level of quality that will satisfy the Government's needs. The salient physical, functional, or performance characteristics that "equal" products must meet are specified in the solicitation.

(b) To be considered for award, offers of "equal" products, including "equal" products of the brand name manufacturer, must-

(5) Meet the salient physical, functional, or performance characteristics specified in this solicitation;

(6) Clearly identify the item by-

- i. Brand name, if any; and
- ii. Make or model number;

(7) Include descriptive literature such as illustrations, drawings, or a clear reference to previously furnished descriptive data or information available to the Contracting Officer; and

(8) Clearly describe any modifications the offeror plans to make to a product to make it conform to the solicitation requirements. Mark any descriptive material to clearly show the modifications.

(c) The Contracting Officer will evaluate "equal" products on the basis of information furnished by the offeror or identified in the offer and reasonably available to the Contracting Officer. The Contracting Officer is not responsible for locating or obtaining any information not identified in the offer.

(d) Unless the offeror clearly indicates in its offer that the product being offered is an "equal" product, the offeror shall provide the brand name product referenced in the solicitation.

(End of provision)

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

STATEMENT OF WORK

FOR

**INSPECTION AND TESTING OF FIRE
ALARM & FIRE SUPPRESSION SYSTEMS**

Timber Lake Job Corps
Job Corps National Office
MAY 2026

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

- 1. BACKGROUND** _____
- 1.1. DESCRIPTION OF SERVICES** _____
- 2. GOVERNMENT FURNISHED PROPERTY AND SERVICES** _____
- 2.1. UTILITIES** _____
- 2.2. SECURITY, FIRE AND MEDICAL SERVICES** _____
- 3. GENERAL INFORMATION** _____
- 3.1. DAMAGES TO GOVERNMENT BUILDINGS, EQUIPMENT OR VEGETATION** _____
- 3.2. PERMITS, LICENSES AND CERTIFICATIONS (RESERVED)** _____
- 3.3. HOURS OF OPERATION** _____
- 3.4. RECOGNIZED HOLIDAYS** _____
- 3.5. TRAFFIC LAWS** _____
- 3.6. WEAPONS, FIREARMS, AND AMMUNITION** _____
- 3.7. GOVERNMENT INTERFACE** _____
- 3.8. SAFETY** _____
- 3.9. WORKMANSHIP** _____
- 3.10. TOOLS** _____
- 3.11. TEST EQUIPMENT** _____
- 3.12. SANITARY FACILITIES** _____
- 3.13. PERSONNEL** _____
- 4. LIST OF APPENDICES:** _____
- APPENDIX A - FIRE DETECTION AND ALARM SYSTEM IT TASKS** _____
- APPENDIX B – FIRE SUPPRESSION EQUIPMENT SYSTEM LIST** _____
- APPENDIX C – WET PIPE SPRINKLER SYSTEMS IT TASKS** _____
- APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS IT TASKS** _____
- APPENDIX E – CLEAN AGENT IT TASKS** _____
- APPENDIX F - BUILDINGS REQUIRING FIRE ALARM / SUPPRESSION SERVICE** _____

APPENDIX D - PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

1282A726Q0022
1. BACKGROUND

Job Corps Centers serve students and thus require life safety systems to be operational at all times to ensure safety of building occupants in the event of an emergency. This effort will provide all personnel, labor, equipment, tools, materials, instruments, meters, gauges, test equipment, transportation, supervision, and other items and services necessary to perform inspection and testing (11) for the Fire Alarm Systems (FA) & Fire Suppression Systems (FS) for the Timber Lake Job Corps Center located in Estacada, Oregon. **A table showing buildings requiring FA and FS services is included in the attached sheet titled Appendix F.**

I. I. DESCRIPTION OF SERVICES**1.1.1. LOCATION OF SERVICES**

This project is located at the Timber Lake Job Corps Center campus located approximately 25.6 miles east of Estacada, Oregon couple blocks past mile marker 48 on the left. The address is 59868 E Highway 224, Estacada, Oregon 97023. Driving directions can be obtained by calling the Center at 503.834.3400, 503.834.3455 or 503.834.3450.

1.1.2. SCHEDULED FIRE ALARM SYSTEM TESTING

Timberlake Job Corps is due for annual and 5 year inspection in accordance NFPA 25 code for CY2025. See appendix F for listed buildings and appropriate inspections. Buildings 1330, 1337, 1338, 1339, 1340, 1341, 1467, 1631, 1767, 2015, 2242, 2831, 2832, 2907, 3020, & 1332/ 1333 have fire alarm systems that are in service with 11 backflow devices. Drawings are attached that show layouts of the components. The Contractor shall inspect each system and test it in accordance with the attached inspection schedule in Appendix A for Fire Alarm Guidance on the tasks in Appendix A can be found in NFPA 70B, latest edition (*Recommended Practice for Electrical Equipment Maintenance*). Fire alarm system descriptions and backflow locations are listed below.

Building:	Fire Alarm Panel:	Backflow devices:
1330-Leruning Resource Center	Auth Model I00	None Installed
1337-Dorm A	Simplex ES4700	Aines-200055
1338-Dorm B	Simplex 4010	None Installed
1339-Dorm E	Simplex 4010	Aines-Colt 200, FEBCO-860U
1340 - Recreation	Simplex 4100U	None Installed
1341-Dorm D (Vacant)	Simplex 2080-9023	None Installed
1467-Dining Hall/ Culinary Arts	FireLite MS-4424	Watts-709QT, FEBCO-806YD, FEBCO-805Y
1631 - Education	FireLite MS-4024	None Installed
1767-Health Services	Notifier SFP-4	Watts-009MIQT
2015-Administration	Notifier SGL 400	None Installed
2242- Warehouse	Silent Knight SK-4	None installed
2831 - Gymnasium	FireLite MS-2	FEBCO-805

APPENDIX D - PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

2832 - Storage (AKA ruts & craft)	Firelite MS 4024	
29007- Sewage Treatment plant2	Simplex 4010	Watts-009QT (QTY 2)
3020 - Forestry / 3030 - Automotive	FireLite MP-24	
1332 / 1333 Staff Housing Aprutments	Firelite MS-5024	

1.1.3. SCHEDULED SUPPRESSION INSPECTIONS

Inspections for Wet Pipe Automatic Sprinkler Systems, Pre-action Automatic Sprinkler Systems and CleanAgent systems will require Annual Inspections, Two-Year Inspections and Five-Year Inspections at various times during the period of performance. Inspectors must meet the qualifications listed below in order to perform the IT tasks. The Contactor shall inspect each system and test it in accordance with the inspection schedule relevant to the type of system being tested. Technical guidance for the task required to be performed can be found in NFPA 25, latest edition (*Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*). The types and locations of existing fire suppression systems are described in Appendix F.

1.1.4. WET PIPE SPRINKLER SYSTEMS

Contactor shall perform tasks outlined Appendix C & D is contained and NFPA 25. When performing inspections on wet pipe systems, the following guidance and actions must be adhered to and noted on inspection reports.

Caution: Main drain static or residual test pressures that vary more than 10 percent from the previous test readings or the original acceptance readings require immediate evaluation to determine the cause.

Warning: Main drain static or residual test pressures that vary more than 20 percent from the previous test readings or the original acceptance readings indicate an emergency situation. Immediate distribution system flow testing is indicated. Immediately conduct main drain tests on all adjacent sprinkler systems to determine the extent to which the sprinkler systems are compromised.

1.1.5. PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS

Contactor shall perform tasks outlined in Appendix C & D and NFPA 25. When performing inspections on dry pipe systems the following guidance and actions must be adhered to and noted on inspection reports.

Caution: Main drain static or residual test pressures that vary more than 10 percent from the previous test readings or the original acceptance readings require immediate evaluation to determine the cause.

Warning: Main drain static or residual test pressures that vary more than 20 percent from the previous test readings or the original acceptance readings indicate an emergency situation. Immediate distribution system flow testing is indicated. Immediately conduct main drain tests on all adjacent sprinkler systems to determine the extent to which the sprinkler systems are compromised.

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS**1.1.6. CLEAN AGENT SYSTEMS**

Contractor shall perform tasks outlined in Appendix E and NFPA 2001, latest edition (*Standard on Clean Agent Fire Extinguishing Systems*).

1.1.7. SUBMITTALS/DELIVERABLES

Contractor shall provide a separate inspection report for each system tested/inspected. Furnish reports in both hard format to the Center and electronic PDF format to the CO. Each report will include the following at a minimum:

- Job Corps Center Name
- Building Number and Name
- Item Description
- Location
- Inspection and Testing Performed in accordance with Appendices
- Indication of Pass/Fail
- Recommendations for repair in case of failed test
- Indication of System Normal, Warning or Caution Condition
- Date of Inspection
- Name of Inspector
- Signature of Inspector

Inspection reports are due within fourteen (14) days of the system inspection.

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS**2. GOVERNMENT FURNISHED PROPERTY AND SERVICES****2.1 UTILITIES**

Use of Government existing facilities will be permitted without metering and without payment of use charges, as long as facilities are cleaned and maintained in an acceptable condition. At Substantial Completion, restore these facilities to condition existing before initial use. The following are available for use by the Contractor: water, and electrical power services. The following are not available: telephone service. The Contractor is expected to provide whatever phone service he deems necessary for the duration of the project.

2.2 FIRE SERVICES

Municipal or volunteer fire protection services are not available at this site.

3. GENERAL INFORMATION**3.1 DAMAGES TO GOVERNMENT BUILDINGS, EQUIPMENT OR VEGETATION**

Damages to Government buildings, equipment, or vegetation are addressed in FAR clause 52.237-2 – Protection of Government Buildings, Equipment, and Vegetation. The Contractor shall use reasonable care to avoid damaging existing buildings, equipment, and vegetation on the Government installation. If the Contractor's failure to use reasonable care causes damage to any of this property, the Contractor shall replace or repair the damage at no expense to the Government as the Contracting Officer directs. If the Contractor fails or refuses to make such repair or replacement, the Contractor shall be liable for the cost, which may be deducted from the contract price.

3.2 PERMITS, LICENSES AND CERTIFICATIONS (RESERVED)**3.3 HOURS OF OPERATION**

The Contractor shall perform services during normal duty hours which are 0800-1630 Monday through Friday, excluding Federal Holidays. The Contractor may work weekends and holidays if approved in advance at his convenience. Work required outside of the standard work hours shall be coordinated with the Center.

3.4 RECOGNIZED HOLIDAYS

The Contractor is not required to provide service on federal holidays, except in emergency situations. The holidays are as follows:

New Year's Day - 1 January
Martin Luther King Day - 3rd Monday in January
Washington's Birthday - 3rd Monday in February
Memorial Day - last Monday in May
Juneteenth – 19 June
Independence Day - 4 July
Labor Day - 1st Monday in September
Columbus Day - 2nd Monday in October
Veteran's Day - 11 November
Thanksgiving Day - 4th Thursday in November
Christmas Day - 25 December

If a holiday falls on Saturday, the preceding Friday will be the observed holiday. If the holiday falls on Sunday, the

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

following Monday will be the observed holiday. If a holiday falls on a scheduled service day, the Contractor will be responsible for rescheduling services for the first day post the holiday observance.

3.5 TRAFFIC LAWS

The Contractor and its employees shall comply with all site traffic regulations.

3.6 WEAPONS, FIREARMS, AND AMMUNITION

Contractor employees are prohibited from possessing weapons, firearms, or ammunition, on themselves or within their Contractor-owned or privately owned vehicle while on the Center.

3.7 GOVERNMENT INTERFACE

Do not unduly interfere with regularly scheduled Government operational activities in the performance of contract requirements. In the event a Government supervisor so requests, temporarily cease work in the area and report the instructions, to include name of the Government person involved, to the CO immediately by the most expedient means. Notify the CO verbally of disputes with customers or other base Contractors and follow-up in writing.

3.8 SAFETY

The Contractor shall comply with all applicable Occupational Safety and Health Administration (OSHA) standards, federal, state, and local laws, regulations, and requirements regarding worker safety while performing work at the Center. Compliance shall also include following industry standards concerning worker safety and personal protective equipment. The Contractor shall comply with all safety and health requirements necessary for the protection of personnel, facilities and equipment.

3.8.1 WRITTEN SAFETY PROGRAM

Maintain a written Safety Program, as required by OSHA and make said plan available for review by the Government upon request by the Contracting Officer.

3.9 WORKMANSHIP

All work shall be performed by qualified, experienced Contractor personnel.

3.10 TOOLS

All tools shall be furnished by the Contractor.

3.11 TEST EQUIPMENT

The Contractor shall furnish his own test equipment.

3.12 SANITARY FACILITIES

The Contractor's workmen may use existing sanitary facilities, subject to the regulations governing their use by Government personnel in the buildings in which the work is being accomplished.

3.13 PERSONNEL

Contractor personnel shall present a neat appearance. Contractor personnel shall be easily recognizable while on the

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

installation in conjunction with this contract.

The government is authorized to restrict the employment under the contract of any Contractor employee or prospective Contractor employee, who is identified as a potential threat to the health, safety, security, general well- being, or operational mission of the installation and its population.

4. LIST OF APPENDICES:

- APPENDIX A - FIRE DETECTION AND ALARM SYSTEM ITM TASKS
- APPENDIX B – FIRE SUPPRESSION EQUIPMENT SYSTEM LIST
- APPENDIX C – WET SYSTEM ITM TASKS
- APPENDIX D – PRE-ACTION ITM TASKS
- APPENDIX E – CLEAN AGENT ITM TASKS
- APPENDIX F - BUILDINGS REQUIRING FIRE ALARM / SUPPRESSION SERVICE

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS**APPENDIX A - FIRE DETECTION AND ALARM SYSTEM INSPECTION AND TESTING TASKS**

Frequency	Component	Tasks
Monthly	1. Control Panels and Annunciator Equipment (unmonitored only)	Reserved
Annual	1. Control Panel and Annunciator Equipment (monitored)	- Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs) and operation of notification appliances and auxiliary functions (outputs). - Verify that all lamps and LEDs are illuminated. - Load test backup batteries (when provided).
	2. Initiating Devices: a. Manual Fire Alarm Stations	1. Verify station is accessible (visual).
	b. Radiant Energy Detectors (Optical Detectors)	Reserved
	Gas Detectors	Reserved
	3. Notification Appliances and Voice Communication (telephone, speakers, horns, and strobe lights)	1. Test to verify operability.
	4. Digital Alarm Transmitters and Receivers	1. Test to verify operability.

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

APPENDIX B – FIRE SUPPRESSION EQUIPMENT SYSTEM LIST

BLDG	RISER #	Riser Location	System Type	System Manufacturer	System Status
1337	1	Closet on A-side 1 st floor (north, east)	Wet		In Service
1337	2	“	Dry	Reliable Model A	In Service
1338	1	NE corner basement	Wet		In Service
1339	1	SE corner basement	Wet		In Service
1339	2	“	Dry	FireLock NXT	In Service
1467	1	NE corner basement	Wet		In Service
1467	2	“	Dry	Tyco	In Service
1467		Main Kitchen	Clean Agent		In Service
1467		Culinary	Clean Agent		In Service
2831	1	1 st Flr Mech room (west side)	Wet		In Service

APPENDIX D - PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS**APPENDIX C - WET PIPE SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS**

Frequency	Component	Tasks
Monthly	1. Control Valves (without seal, lock, or electric supervision)	2. Reserved.
Annual	1. Control Valves (sealed, locked, or electrically supervised)	1. Verify valve position.
	1. Water flow Alarm Devices	1. Operate to verify initiation and receipt of alarm. 2. Verify alarm test valve alignment and trumper switch (if sealed or electrically supervised).
	3. Alarm Valve and Trim	1. Visually check the exterior of valves, 2. gauges, trim alignment Verify valve pressure and legibility of the hydraulic nameplate.
	4. Main Drain	1. Conduct a main drain test to verify supply (valve position). 2. Document static and residual pressure readings on a 3- by 5-inch (3x5) tag and secure it to the system pressure gauge. 3. Compare results with results from previous main drain tests and original acceptance test. 4. Verify that the results are within acceptable limits or identify corrective measures.
	5. Fire Department Connection	1. Verify accessibility and condition. 2. If caps are removed or missing, check for obstructions.

APPENDIX D - PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS**APPENDIX D - PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS**

Frequency	Component	Tasks
Monthly	1. Control Valves (without seal, lock, or electric supervision)	1. Reserved.
Annual	1. Control Valves (sealed, locked, or electrically supervised)	1. Verify valve position.
	2. Water flow Alarm Devices	1. Operate to verify initiation and receipt of alarm. 2. Verify alarm test valve alignment and tamper switch (if sealed or electrically supervised).
	3. Pre-Action Valve and Trim	1. Visually inspect the exterior of valves, gauges, trim alignment. 2. Verify valve pressure and legibility of the hydraulic nameplate.
	4. Main Drain	1. Conduct main drain test to verify supply (valve position). 2. Document static and residual pressure readings on a 3x5 tag and secure it to the system pressure gauge. 3. Compare results with results from previous main drain tests and original acceptance test. 4. Verify that the results are within acceptable limits or identify corrective measures.
	5. Fire Department Connection	1. Verify accessibility and condition. 2. If caps are removed or missing, check for obstructions.
	6. Dry Pipe Alarm Valve Enclosure Heating	1. Verify operability at the beginning of the heating season (annually for constant cold areas).
	7. Low Temperature Alarm	1. Verify initiation and receipt of alarm at the beginning of the heating season.

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

5 Year inspection criteria listed Below but not limited to refer to NFPA 25 Code:

Gauge Inspection

5.3.2.1 Gauges shall be replaced or tested every five years by comparison with a calibrated gauge.

Standpipe Flow Test

6.3.1.1 * A flow test shall be conducted every 5 years on all automatic standpipe systems to verify that the required flow and pressure are available at the hydraulically most remote hose valve outlet(s) while flowing the standpipe system demand.

6.3.1.1.1 Where a flow test of the hydraulically most remote outlet(s) is not practical, the authority having jurisdiction shall be consulted for the appropriate location for the test.

6.3.1.1.2 Pressure gauges maintained in accordance with 8.3.3.5.2 shall be provided for the test.

6.3.1.2 * Class I and Class III standpipe system demand shall include 500 gpm (1892 L/min) for the most remote standpipe and 250 gpm (946 L/min) for each additional standpipe until the total system demand is simultaneously flowing.

6.3.1.2.1 * The 250 gpm (946 L/min) required from each additional Class I and Class III standpipe shall be allowed to be flowed from the most convenient hose valve on that standpipe.

6.3.1.2.2 * Where the 250 gpm (946 L/min) cannot be flowed from each additional Class I and Class III standpipe, the authority having jurisdiction shall determine where the additional flow can be taken.

6.3.1.3 Class II standpipe system demand shall include 100 gpm (379 L/min) for the most remote standpipe connection.

6.3.1.4 The standpipe system demand shall be based on the design criteria in effect at the time of the installation.

6.3.1.4.1 Where the standpipe system demand cannot be determined, the authority having jurisdiction shall determine the standpipe system demand.

6.3.1.4.2 The actual test method(s) and performance criteria shall be discussed in advance with the authority having jurisdiction.

Standpipe Hydrostatic Test

6.3.2.1 * Hydrostatic tests of not less than 200 psi (13.8 bar) pressure for 2 hours, or at 50 psi (3.4 bar) in excess of the maximum pressure, where maximum pressure is in excess of 150 psi (10.3 bar), shall be conducted every 5 years on manual standpipes.

Check Valve Inspection

13.4.2.1 Inspection. Valves shall be inspected internally every five years to verify that all components operate correctly, move freely, and are in good condition.

Internal Inspection of Piping

14.2.1 Except as discussed in 14.2.1.1 and 14.2.1.4, an inspection of piping and branch line conditions shall be conducted every five years by opening a flushing connection at the end of one main and by removing a sprinkler toward the end of one branch line to inspect for the presence of foreign organic and inorganic material.

14.2.1.1 Alternative nondestructive examination methods shall be permitted.

14.2.1.2 Tubercules or slime, if found, shall be tested for indications of microbiologically influenced corrosion (MIC).

14.2.1.3 * If the presence of sufficient foreign organic or inorganic material is found to obstruct pipe or sprinklers, an obstruction investigation shall be conducted as described in Section 14.3.

14.2.1.4 Non-metallic pipe shall not be required to be inspected internally

14.2.2 * In buildings with multiple wet pipe systems, every other system shall have an internal piping inspection every five years, as described in 14.2.1.

14.2.2.2 If the presence of foreign organic and/or inorganic material is found in any system in a building during the 5-year internal inspection of piping, all systems shall have an internal inspection.

APPENDIX D – PRE-ACTION AUTOMATIC SPRINKLER SYSTEMS INSPECTION AND TESTING TASKS

APPENDIX E – CLEAN AGENT INSPECTION AND TESTING TASKS

Frequency	Component	Tasks
Annual	1. Piping	1. Inspect piping and nozzles for condition and orientation.
	2. Flexible Hoses	1. Inspect for damage.
	3. Storage Vessels	1. Inspect the exterior of storage containers (tanks, spheres, cylinders).
	4. Agent and Propellant	1. Verify adequate quantity of agent. 2. Verify adequate pressure of agent/propellant and pressure gauge within operating range.
	5. Actuators	1. Inspect manual actuators for accessibility. 2. Test actuation without agent release.
	6. Auxiliary Equipment	1. Test to verify that interfaces (equipment shutdown, dampers, and door closures) operate properly and are activated by the system actuation.
	7. Valves	1. Verify that the valves are in proper alignment.

