

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J		PAGE 1 OF 3 PAGES	
2. AMENDMENT/MODIFICATION NUMBER 0006		3. EFFECTIVE DATE 24 APR 2025		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable) 107592	
6. ISSUED BY W2SD ENDIST NEW ENGLAND KO CONTRACTING DIVISION, 696 VIRGINIA ROAD CONCORD, MA 01742-2751 UNITED STATES ANN ADLEY, EMAIL: ANN.M.ADLEY@USACE.ARMY.MIL TELEPHONE: 978-318-8255		CODE W912WJ		7. ADMINISTERED BY (If other than Item 6) SCD: PAS:		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NUMBER W912WJ25BA001	
				(X)		9B. DATED (SEE ITEM 11) 12 MAR 2025	
				()		10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
				()		10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)
SEE SECTION G - CONTRACT ADMINISTRATION DATA

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
()	
()	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
()	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
()	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

AMENDMENT 0006 IS NECESSARY TO PROVIDE RESPONSES TO REQUEST FOR INFORMATION (RFIS). ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) ERIN E. BRADLEY	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA 	16C. DATE SIGNED 24 APR 2025
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Section 01 00 00 - General Requirements

The Requirements text has been modified to:

Amendment 0006 is necessary to provide responses to Request for Information (RFIs).

QUESTION 1: Does everything need to be rated for damp/wet location?

RESPONSE 1: Per NFPA 70, a damp location is a location protected from weather and not subject to saturation with water or other liquids but subject to other moderated degrees of moisture. These restrooms fall within this category (outside of the shower areas which are wet locations); however, restroom interiors are regularly cleaned by hosing them down, so these spaces need to be treated as a wet location.

QUESTION 2: What are the specifications for the new fans?

RESPONSE 2: Amend Technical Requirements, Part 2 Products as follows:

A. Insert subparagraph 2.35 titled PROPELLER TYPE OVERHEAD FANS:

Provide propeller blade, overhead type fans, installed with appropriate clearance for temporary personnel passage. Refer to electrical guidelines, specifications, and plans for electrical maximum connection capacity. Refer to manufactures recommendations for installation and coordination guidelines with all other trades. Final finish size, color, and equipment shall be by coordinated with COR and Operations Project Manager.

Fans shall have occupancy sensor control with automatic shut off of fifteen (15) minute runtime intervals. (See electrical specifications for further information). Fan shall have singular speed and be sized for no more than seven (7) air changes per hour for each structure. Equipment shall be residential type in style, performance, and connections to the structure in all manners per manufactures recommendations. Low profile design may be required in certain areas.

QUESTION 3: Is the electric water shutdown valve part of the scope?

RESPONSE 3: Specifications include power requirements for automatic flush valves throughout the restrooms electrically but not an electric water shutdown valve.

QUESTION 4: Will subcontractors be required to be licensed in the state of Vermont or just the state they are incorporated in since this is a federal project?

RESPONSE 4: USACE does not require a Vermont license, however, contractor is responsible to comply with state and local regulations.

QUESTION 5: Have you conducted an asbestos survey report? If so, can you please provide us with the report? If not, do you intend to conduct one before the bid date or the period of performance?

RESPONSE 5: Refer to Specifications, Section 01 11 00, Part 1 General, 1.2 Work Covered by Contract Documents, that states, The existing facilities have been sampled and tested for the presence of lead and asbestos. There are no asbestos-containing materials present in the restroom structures. Lead has been found in the paint coatings applied to two items at the restrooms, the water well pipes and privacy fence

brackets, however these items are not involved in the renovation work and the Contractor shall not disturb them.