

656-22-341 Transformer Outage Table By Building/Location	
General comments:	
<i>All outages must be coordinated based on building use and requirements at the time of the outage.</i>	
<i>The table below is a summary of the allowable outage timing based on current facility needs.</i>	
<i>A schedule for the work shall be submitted by the Contractor as approved by VA so that arrangements can be made for all outages.</i>	
<i>Many transformers will affect chillers, so temperatures are a consideration.</i>	
<i>Buildings 2, 5, 48, 50, and 51 - outages exceeding 8 hours will require temporary power provided by the Contractor.</i>	
Transformer	Allowable Outage Timing Per Current Building Usage
ALTERNATE	Provide adequate notice for surgery schedule - 60 day advanced notice with schedule approval.
PRIMARY	Provide adequate notice for surgery schedule - 60 day advanced notice with schedule approval.
TX1	Must take place outside normal business hours including urgent care hours, before 8 a.m. or after 5:00 p.m. 7 days a week. This will also take down Transformer 1C.
TX1C	Must take place outside normal business hours including urgent care hours, before 8 a.m. or after 5:00 p.m. 7 days a week.
TX2	This outage can be during normal business hours. If exceeding 8 hours of outage, provide temporary power for the building.
TX2A	This outage can be completed during normal business hours.
TX4	Must take place outside normal business hours.
TX5	This outage must be outside normal business hours. If exceeding 8 hours of outage, provide temporary power for the building.
TX8	Advanced notice (30 days minimum) required for shutdown that can be during normal business hours. Some flexibility needed to schedule a day without other uses.
TX9 (HPU)	Must take place outside normal business hours. Disconnection from S&C switch required prior to working on this transformer in order to return power to B111.
TX10	Must take place outside normal business hours
TX48	This outage must be outside normal business hours. If exceeding 8 hours of outage, provide temporary power for the building.
TX50 (deduct alternate)	This outage must be outside normal business hours. If exceeding 8 hours of outage, provide temporary power for the building.
TX51A	This outage must be outside normal business hours. If exceeding 8 hours of outage, provide temporary power for the building.
TX57	Must take place outside normal business hours
TX59	Laundry is closed on Wednesdays. This outage must be completed outside business hours for Laundry
TX88	30 days advanced notice minimum and can work during business hours.
TX94	Can be scheduled without restrictions.