

ELECTRICAL CONNECTION SCHEDULE FOR BMS PANELS										
BUILDING	BMS PANEL NAME	BMS PANEL ROOM#	NORMAL POWER SOURCE			EMERGENCY POWER SOURCE			MECHANICAL REFERENCE DRAWING#	PANEL NAMES AND LOCATION NOTES FROM UTILITIES SHOP
			PANEL SOURCE	CIRCUIT#	PANEL LOCATION RM#	PANEL SOURCE	CIRCUIT#	PANEL LOCATION RM#		
1	B1.P0	G44A	2N1C	10	G29	2QI	36	G30	01-M-401	ALLERTON
1	B1.P1	ATTIC	2LCIY	9	TBD	QI-4-INA	TBD	ATTIC	01-M-401	B1.P1 FAN ROOM 5 NODE 1, AHU 1 &2 MEC W/EXPANSION
1	B1.P2	G44A	2N1C	10	G29	2QI	36	G30	01-M-401	B1.P2 FAN ROOM 6 MBC BEHIND G44A NODE 2 NUCMED DENTAL
1	B1.P3	G29	TBD	TBD	TBD	SPDI	2	G30	01-M-401	B1.P3 G30 NODE 32 MBC
1	B1.P4	4TH FLR	2N1FF	TBD	406A	2QI	40	G30	01-M-141	B1.P4 AHU2 :7172 BACKNET PXC 36 W/EXPANSION 4TH FLOOR FAN ROOM 2
1	B1.P5	4TH FLR	2N1FF	TBD	406A	2QI	42	G30	01-M-141	B1.P5 AHU1: 7171 BACKNET PXC36 W/EXPANSION 4TH FLOOR FAN ROOM 1
1	B1.P6	G44A	2N1C	10	G29	2QI	36	G30	01-M-401	B1.P6 ALLERTON
1	B1.P7	G41	2N1C	TBD	G29	2QI	38	G30	01-M-401	B1.P7 ALLERTON
2	B2.P0	G25A	TBD	TBD	G22	2Q2A	13	TBD	02-M-401	ALLERTON
2	B2.P1	G25A	TBD	TBD	G22	2Q2A	13	TBD	02-M-401	B2.P1 ALLERTON
2	B2.P2	FAN RM2	TBD	TBD	TBD	2Q2A	13	TBD	02-M-401	B2.P2 FAN ROOM (G25) NODE 4 MBC HAS POINTS FOR AL5, AHU 10, 11, 30, 33, 5W, E6, AL9
2	B2.P3	10	TBD	TBD	TBD	2Q2D	35	102J	02-M-401	B2.P3 - 105J - MEDIA HALLWAY NODE 3 AHU10 POINTS
2	B2.P4	G24	TBD	TBD	G22	2Q2A	TBD	TBD	02-M-401	B2.P4 - 102J ELECTRICAL ROOM IN KITCHEN NODE 33 MEC W/EXPANSIONS AHU30
2	B2.P5	ROOF	TBD	TBD	TBD	202D	37	102J	02-M-111	B2.P5 AHU - 08 NODE 34 MEC
2	B2.P6	ROOF	TBD	TBD	TBD	2Q2D	39	102J	02-M-111	B2.P6 AHU - 09 NODE 39 PXC 36 W/EXPANSIONS AHU9
2	B2.P7	G21	TBD	TBD	G22	2Q2A	TBD	TBD	02-M-401	B2.P5 AHU - 09 NODE 36 MEC AHU 9T
3	B3.P0	BASEMEN	TBD	TBD	TBD	TBD	TBD	TBD	03-M-401	
3	B3.P2	ATTIC	TBD	TBD	TBD	TBD	TBD	TBD	03-M-401	B3.P2 FAN ROOM 11 NORTH NODE 7 MEC W/2 EXPANSIONS AHU 16
3	B3.P3	ATTIC	TBD	TBD	TBD	TBD	TBD	TBD	03-M-401	B3.P3 FAN ROOM 11 NORTH NODE 8 MEC W/2 EXPANSIONS AHU 17
3	B3.P4	ATTIC	TBD	TBD	TBD	TBD	TBD	TBD	03-M-401	B3.P4 FAN ROOM 11 NORTH NODE 70 MEC W/EXPANSION ISO FANS
	B5.P0	BASEMEN	TBD	TBD	TBD	TBD	TBD	TBD	05-M-401	
5	B5.P1	ATTIC	TBD	TBD	TBD	2Q5	7	TBD	05-M-401	B5.P1 NODE 10 FAN ROOM 15 MEC W/EXPANSION - SVC ROOM FUNCTIONS
5	B5.P2	BASEMEN	TBD	TBD	TBD	2Q55R	2	BASEMENT	05-M-401	B5.P2 NODE 11 FAN ROOM 14 PXC 36 W/CONTROL FRONT AHU 19 + AHU 15 HUMIDITY FUNCTION
5	B5.P4	ATTIC	TBD	TBD	TBD	2Q5	7	TBD	05-M-401	B5.P4 NODE 71 FAN ROOM 14 MEC MONITORS LIBERT , COMPUTER ROOMS, AND EX FANS
7	B7.P0	G25	TBD	TBD	TBD	TBD	TBD	TBD	07-M-401	ALLERTON? THERE IS NO 4TH PANEL FOR SIEMENS LISTED IN BLDG 7
7	B7.P1	G50	2N7B	TBD	G50B	2Q7B	TBD	G50B	07-M-401	B7.P1 NODE 16 MBC G50 AHU 7C+AHU 7D+PUMPS
7	B7.P2	G51	2N7A	TBD	G51B	2Q7A	TBD	G51B	07-M-401	B7.P2 NODE 17 MBC G51 AHU 7A+7B
7	B7.P3	G25	TBD	TBD	TBD	TBD	TBD	TBD	07-M-401	B7.P3 NODE 18 MEC G25 BLDG 7 HW SYSTEM
8	B8.P0	G25	TBD	TBD	TBD	TBD	TBD	TBD	08-M-401	THERE IS NO 4TH PANEL FOR SIEMENS LISTED IN BLDG 8
8	B8.P1	G33	TBD	TBD	G33A	TBD	TBD	G33A	08-M-401	B8.P1 NODE 19 MBC G33 AHU 8C+AHU 8D+PUMPS
8	B8.P2	G34	2N8A	1	G34B	2LBA	8	G34B	08-M-401	B8.P2 NODE 20 MBC G34 AHU 8A+AHU 8B
8	B8.P3	G13	TBD	TBD	TBD	TBD	TBD	TBD	08-M-401	B8.P3 NODE 21 MEC PUMPS FOR DOMESTIC HOT WATER SYSTEM EXCHANGER
9	B9.P0	BASEMEN	TBD	TBD	TBD	TBD	TBD	TBD	09-M-401	
9	B9.P1	ATTIC	TBD	TBD	TBD	TBD	TBD	TBD	09-M-401	B9.P1 NODE 23 MEC FAN ROOM 21 SVC FUNCTIONS
9	B9.P2	ATTIC	TBD	TBD	TBD	TBD	TBD	TBD	09-M-401	B9.P2 NODE 25 MEC FAN ROOM 20 AHU 25+AHU 26
9	B9.P4	ATTIC	TBD	TBD	TBD	TBD	TBD	TBD	09-M-401	B9.P4 NODE 67 MEC FAN ROOM 20 EXHAUST FANS
10	B10.P0	G15	TBD	TBD	TBD	TBD	TBD	TBD	10-M-101	
10	B10.P1	G15	TBD	TBD	TBD	TBD	TBD	TBD	10-M-101	B10.P1 NODE 26 MEC FAN ROOM 22
11	B11.P0	G04	TBD	TBD	TBD	TBD	TBD	TBD	11-M-101	
11	B11.P1	G04	TBD	TBD	TBD	TBD	TBD	TBD	11-M-101	B11.P1 NODE 27 MEC FAN ROOM 24
16	B16.P0	CTRL RM	TBD	TBD	TBD	TBD	TBD	TBD	16-M-101	B16.P1 BOILER MAU 1&2 NODE 22 B16.P2 BOILER PUMPS NODE 24
116	B116.P1	A114A	A3	5	A114A	EA	25	A114A	116-M-401	B116.P1 NODE 78 MEC G114C SVC ROOM FUNCTIONS
116	B116.P2	A114C	A3	5	A114A	EA	25	A114A	116-M-401	B116.P2 NODE 79 MBC A114C AHU 40
117	B117.P0	100	TBD	TBD	TBD	TBD	TBD	TBD	117-M-401	ALLERTON?
117	B117.P1	FAN RM8	TBD	TBD	TBD	2Q7E	27	FAN RMB	117-M-401	B117.P1 NODE 76 MBC FAN ROOM 9 W/EXPANSION BUS AHU 13+AHU 14
117	B117.P2	FAN RM9	N7G	TBD	FAN RM9	2Q7G	25	FAN RM9	117-M-401	B117.P2 NODE 77 MBC FAN ROOM 9 ISO FANS AL1 + AL2
120	B120.P1	FAN RM 10	2N20B	31	FAN RM 10	2Q20B	19	FAN RM 10	120-M-401	B120.P2 NODE 81 FAN ROOM 10 PXC
120	B120.P2	FAN RM 10	2N20B	31	FAN RM 10	2Q20B	TBD	FAN RM 10	120-M-401	
120	B120.P3	FAN RM 10	2N20B	31	FAN RM 10	2Q20B	TBD	FAN RM 10	120-M-401	
120	B120.P4	FAN RM 10	2N20B	31	FAN RM 10	2Q20B	19	FAN RM 10	120-M-401	B120.P4 NODE 84 MEC RADIOLOGY