

Salient Characteristics, v1 (Dated 04 April 2026)

One brand-name Trane Chiller with the highlighted specifications:

Model Number Descriptions

Digit 1, 2, 3, 4 — Unit Model

ACSA = Air-Cooled Scroll Chiller

ACXA = Air-Cooled Scroll Heat Pump Chiller

Digit 5, 6, 7 — Nominal Tonnage

140 = 140 Tons

160 = 160 Tons

180 = 180 Tons

200 = 200 Tons

215 = 215 Tons

230 = 230 Tons

Digit 8 — Compressor Type

2 = Scroll with Variable Volume Ratio

Digit 9 — Unit Voltage

A = 200V/60Hz/3 phase

B = 230V/60Hz/3 phase

C = 380V/60Hz/3 phase

D = 400V/60Hz/3 phase

E = 460V/60Hz/3 phase

F = 575V/60Hz/3 phase

Digit 10 — Manufacturing Location

U = Trane Commercial Systems, Pueblo, CO USA

Digits 11, 12 — Design Sequence

****** = Factory assigned

Digit 13 — Unit Sound Package

X = Standard Unit

L = Superior

R = Standard with Noise Reduction Request

Q = Superior with Noise Reduction Request

Digit 14 — Agency Listing

U = UL/cUL Listing

E = UL Listed to U.S. and Canadian Safety Std via ETL-2019

C = No Agency Listing

Digit 15 — Pressure Vessel Code

X = Not Applicable

C = CRN or Canada Equivalent

Digit 16 — Factory Charge

L = Refrigerant Charge R-454B

M = Nitrogen Charge (R-454B Field Supplied)

Digit 17 — Auxiliary Items

X = No Auxiliary Items

D = Condenser Drain Pan - HP Units Only

Digit 18 — Evaporator Application

N = Standard Cooling

P = Low Temp Process Cooling

F = Lower Temp Process Cooling

C = Ice Making

Digit 19, 20 — Evaporator Type

B2 = Brazed Plate Heat Exchanger (Standard)

Digit 21 — Water Connection

X = Grooved Pipe

A = Grooved Pipe + Flange Adapter

Digit 22 — Flow Switch Set Point

C = Flow Switch Setpoint 15

F = Flow Switch Setpoint 35

H = Flow Switch Setpoint 45

L = Flow Switch Setpoint 60

Digit 23 — Insulation

N = Standard 0.75 inch

H = Evaporator-Only 1.25 inch humidity/low evap

Digit 24 — Unit Application

X = Standard Ambient

L = Low Ambient

H = High Ambient

W = Wide Ambient

Digit 25 — Condenser Length

S = Standard

Digit 26 — Condenser Fin Options

M = Aluminum Microchannel

C = CompleteCoat™ Microchannel

R = Copper Round Tube, Aluminum Plate Fin

K = Coated Copper Round Tube, Aluminum Plate Fin

Digit 27 — Fan Type

E = EC Condenser Fan Motors

F = Fixed Speed Fans

Digit 28 — Compressor Starter

X = Across-the-Line Starter

Digit 29 — Incoming Unit Power Line Connection

1 = Single Point Unit Power Connection

Digit 30 — Power Line Connection Type

T = Terminal Block

C = Circuit Breaker

M = High Fault Rated Circuit Breaker with Energy Meter

H = High Fault Rated Circuit Breaker

Digit 31 — Short Circuit Current Rating

A = Default Short Circuit Rating

B = High Short Circuit Rating

Digit 32 — Electrical Accessories

X = None

U = Under/Over Voltage Protection

N = 20A - 115V Convenience Outlet

B = Convenience Outlet and Under/Over Voltage Protection

Digit 33 — Remote Communications Options

X = None

B = BACnet® Interface (MS/TP)

p = BACnet® Interface (IP)

M = Modbus™ Interface

L = LonTalk® Interface

Digit 34 — Hard Wire Communication

X = None

A = Hard Wired Bundle — All

Digit 35 — Smart Flow Control

X = None

T = Variable Primary Flow (Constant Delta T)

Digit 36 — Structural Options

A = Standard Unit Structure

Digit 37 — Appearance Options

X = No Appearance Options

A = Architectural Louvered Panels

Digit 38 — Unit Isolation

X = None

1 = Elastomeric Isolators

Digit 39 — Shipping Package

X = No Shipping Package

F = Shipped with Fork Pocket

T = Tarp Covering Full Unit

Digit 40 — Pump Package

X = No Pump Option

2 = Single Pump, High Pressure, Single VFD

4 = Dual Pump, High Pressure, Dual VFD

Digit 41 — Not Used

Digit 42 — Not Used

X = Selection1

Digit 43 — Special Requirement

0 = None

S = Special Requirement

F = Ship to Final Finisher

Digit 44 — Harmonic Filter

N = No Harmonic Filter

Digit 45 — Wireless Connectivity

X = None

A = Wi-Fi

B = LTE Modem

C = Air-Fi

D = Wi-Fi and LTE Modem

E = Wi-Fi and Air-Fi

F = LTE Modem and Air-Fi

G = Wi-Fi, LTE Modem, and Air-Fi