



DEFENSE LOGISTICS AGENCY
DLA DISTRIBUTION WARNER ROBINS
455 BYRON STREET BLDG 385
ROBINS A F B GA 31098-1887

May 6, 2026

MEMORANDUM FOR RECORD

SUBJECT: STATEMENT OF WORK

REFERENCES: DDWG – UPS Battery Replacement

1. Name of site where work is to be performed:

Site 1: Defense Logistics Agency 455 Byron Street Bldg. 385

2. Description of Requirement

DDWG is requesting labor and replacement batteries to support the Eaton UPS system. CSB HRL1234WF2FR batteries or equivalent shall be provided to install in the UPS System.

Vendor will need to remove old batteries and install new batteries. All removed batteries shall be placed to the side in building 385 on a commercial pallet for pick up.

The service will be performed during standard business hours between 830 am – 4:00 pm.

3. Description of Quantity of item needed

Quantity: 40

Description: Battery, 12v Quick Connect 12V Quick Connect, Lead Acid Battery; 9Ah Capacity; 98.3 mm H x 64mm D x 151mm W; UL94-HB and UL94V-0 Flammability rating; 130A at 5sec Maximum discharge current; 6 Cells per unit; 4W at 15 Minutes rate to 1.67V per cell at 25°C (77°F) capacity; 3.4A Recommended maximum charging current limit; HRL Series; Similar or equal to CSB Battery of America Part Number HRL1234WF2FR

