

N4523A26Q5705 Solicitation Questions-100kW EDG

1. Question: Whether this requirement is a new requirement or a follow-on/replacement to an existing generator rental/lease.

- **Answer:** This is a replacement contract to N4523A22D1304.

2. Question: Does the Government have an estimated average daily runtime (hours/day or year) for the generator?

- **Answer:** Please refer to Section 1.2 of the PWS, which states “Expected run time for the rented DG is less than 20 hours in a calendar year”.

3. Question: We would like to know if this is a brand new contract OR if there is (was) an incumbent performing these services. If not brand new, could you please provide the current / previous contract number?

- **Answer:** This is a replacement contract to N4523A22D1304.

4. Question: What is the exact address for delivery of generator?

- **Answer:** PSNS & IMF in Bremerton, WA. See Section 1.7.18 of the PWS.

5. Question: Will the Government Personnel refill the fuel if needed?

- **Answer:** Yes.

6. Question: I am requesting clarification on the required contents and submission format for the CLIN pricing and supporting documentation. Could you please specify exactly what needs to be included with the quote in relation to the completed CLIN pricing structure? Should the pricing be submitted based on a monthly rental basis or an annual rental basis?

- **Answer:** Please refer to document “C8 26Q5705 Combined Synopsis Solicitation”, Section 7 (Pages 1 and 2), which highlights and breaks down how to provide pricing. Based on the structure of Section 7 of the Combined Synopsis Solicitation, the Unit of Measure is “Months”. Please provide pricing in accordance with Section 7 of the Combined Synopsis Solicitation.