

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 3 PAGES		
2. AMENDMENT/MODIFICATION NUMBER 0002		3. EFFECTIVE DATE 04/08/2026		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable)	
6. ISSUED BY CODE LCA BLM CA-STATE OFC BUS SVC BR (CA944) 2800 COTTAGE WAY, SUITE W-1834 SACRAMENTO CA 95825				7. ADMINISTERED BY (If other than Item 6) CODE			
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				9A. AMENDMENT OF SOLICITATION NUMBER (X) 140L1226Q0011			
				9B. DATED (SEE ITEM 11) (X) 04/08/2026			
				10A. MODIFICATION OF CONTRACT/ORDER NUMBER			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended. ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Laurie Ehlinger	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Previous edition unusable

CONTINUATION SHEET	REFERENCE NO. OF DOCUMENT BEING CONTINUED	PAGES
	140L1226Q0011/0002	PAGE 2 OF 3

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	The purpose of this amendment 00002 is to answer vendor questions and extend the deadline for quotation submissions to 5/05/2026 5:00pm PDT. SUMMARY: Potable Water Delivery & Testing ----- SUBMIT QUOTES TO: michael_anson@ios.doi.gov ----- All responses to this notice must be In Accordance With (IAW) the attached Solicitation, Contract Clauses, Specifications, Requirements, Provisions, Terms, and Conditions. ----- This will be a firm fixed purchase order. Include all Shipping and/or Travel costs in the current line items. ----- F.O.B DESTINATION 1. "Water analysis samples must be collected by a technician approved by California Department of Health." Question: The subcontractor is a professional water delivery service provider who routinely collects the samples at the site and submits them to a separate laboratory for analysis. Will this be acceptable or will I be required to contract a second vendor from the laboratory to collect the samples? Answer: As long as the sample is collected properly and submitted to a certified laboratory the contractor can collect the sample. 2. "Potable water tanks and collection points may be in areas in which a 4-wheel drive or off-road vehicle is needed." Question: It was noted that the sites appear to be on compacted dirt roads; do you know if they have historically been able to safely sustain the tonnage of the water delivery vehicles? Answer: Access roads historically have been able to sustain the tonnage of all water Continued...				

CONTINUATION SHEET	REFERENCE NO. OF DOCUMENT BEING CONTINUED	PAGES
	140L1226Q0011/0002	PAGE 3 OF 3
NAME OF OFFEROR OR CONTRACTOR		

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	delivery vehicles. 3. "Task 5: Provide results of water testing and analysis along with chain of custody documentation to the BLM COR within 24 hours of receipt" Question: Standard bacteriological test for total coliform/e. Coli usually receives a "pass/fail" determination from the laboratory. Is this acceptable or will the government require a more comprehensive test and if so could you provide what they would like see? Answer: Pass/Fail for total coliform/e from a certified/licensed laboratory is acceptable. We will require more comprehensive testing once a year which is required by the California department of public health. Period of Performance: 05/15/2026 to 05/14/2030				