



DEPARTMENT OF THE AIR FORCE
HEADQUARTERS 88TH AIR BASE WING (AFLCMC)
WRIGHT-PATTERSON AIR FORCE BASE OHIO

5 May 2026

Questions and Answers Document

CONTRACTING ACTIVITY/AGENCY: Operational Contracting Division, Directorate of Contracting, Air Force Life Cycle Management Center (AFLCMC), Air Force Material Command (AFMC), Department of the Air Force.

AFLCMC/PZIBB
2275 D Street, Area B, Bldg. 16 Room 150
Wright-Patterson AFB, OH 45433

QUESTIONS

Inquiry One (1): *Following our review of the PWS for the PDU relocation in Building 10271, we have the following technical inquiries to ensure an accurate quote: (ANSWERS IN RED)*

- **Documentation:** Can you please provide floor plans or photos of Rooms 134 and 128A available for logistical planning? **-ATTACHED.**
- **Path of Travel:** Are there specific weight restrictions for the raised floor tiles along the move path? **The flooring system can support the rolling load of the PDU.**
- **Work Hours:** Is the final power cutover required after-hours/weekends, or during standard business hours? **During business hours**
- **Equipment:** If the existing stand in 128A is incompatible with PDU 9, is the contractor responsible for procurement or will the government provide a new one? **The existing stand where PDU 9 currently sits will be reused in the new location. PDU 28 and its stand will be removed and placed in storage.**
- **Access:** Will the crew have a full-time security escort, or is unescorted base-level badging required? **Vendor will be escorted for the duration of the work.**
- **Cabling:** Is the contractor responsible for new cabling/terminations if existing tails are insufficient? **Existing power tails will be uninstalled from PDU 28, then terminated in PDU 9. It's unclear how material at the site would be insufficient.**
- **Disposal:** Is the contractor responsible for off-site disposal of old wiring and debris? **No. All wiring /metal will be collected by base personnel and turned in to recycling center.**

Curtis V. Thomas III
Contracting Officer
AFLCMC/PZIBB