

SECTION J  
DOCUMENTS, EXHIBITS, AND OTHER ATTACHMENTS  
TABLE OF CONTENTS

| ATTACHMENT<br>NUMBER | ATTACHMENT TITLE                            |
|----------------------|---------------------------------------------|
| J-1604000-01         | Definitions and Acronyms                    |
| J-1604000-02         | References and Technical Documents          |
| J-1604000-03         | Wastewater System Description and Inventory |
| J-1604000-04         | Historical Critical Spare Parts Inventory   |

ATTACHMENT J-1604000-01  
DEFINITIONS AND ACRONYMS

| Definition/Acronym                | Description                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
|-----------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Equipment, Collateral             | Encompasses built-in and large substantially affixed equipment/property that is normally acquired and installed as part of a facility project.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| Equipment, Installed              | Encompasses building-type equipment, built-in equipment, and large, substantially affixed equipment/property, and is normally acquired and installed as part of a facility project. Installed equipment is normally required to make a facility useful and operable. Removing such equipment would impair the usefulness, safety, or environment of the facility or the facility restoration work required after its removal, is substantial.                                                                                                                                                                                      |
| Equipment, Personal Property      | Personal property equipment includes all equipment other than collateral equipment. Such equipment, when acquired and used in a facility or a test apparatus, can be severed and removed after erection or installation without substantial loss of value or damage thereto or to the premises where installed.                                                                                                                                                                                                                                                                                                                    |
| Facilities Life Cycle             | A facilities life cycle is divided into four stages, requirements (planning and design), acquisition (construction and acceptance), stewardship (operations, maintenance and repair), and disposal.                                                                                                                                                                                                                                                                                                                                                                                                                                |
| Facilities Maintenance Management | The planning, prioritizing, organizing, controlling, reporting, evaluating, and adjusting of facilities maintenance operations to support the CNO/NAVFAC facilities policy and objectives and satisfy customers' facility needs. Defined by the International Facility Management Association as "the practice of coordinating the physical workplace with the people and work of the organization."                                                                                                                                                                                                                               |
| Facility Related Control System   | Facility-related control systems are a subset of control systems that are used to monitor and control equipment and systems related to DoD real property facilities (e.g., building control systems, utility control systems, electronic security systems, and fire and life safety systems).                                                                                                                                                                                                                                                                                                                                      |
| Industrial Control System         | Most specifically a control system which controls an industrial process. Sometimes also used to refer to other types of control systems, particularly utility control systems such as electrical, gas, or water distribution systems. ICS includes PLCs, field sensors, field actuators, meters, transducers, relays, protection relays, contactors, electrical current, potential transformers, etc.                                                                                                                                                                                                                              |
| Integrated Maintenance Plan       | IMP is a recurring state-of-the-art, reliability-centered inspection, testing, maintenance and repair program that determines best practices for managing the functions and consequences of failures of facilities equipment and system components. IMP encompasses accepted commercial practices, including reactive, preventive, predictive and proactive maintenance, into one optimal program. The IMP approach gives the Contractor full responsibility to maintain systems and equipment and perform repairs whenever necessary to ensure equipment and systems are operational and remain in a constant state of readiness. |
| Life-Cycle Costs                  | A form of economic analysis that considers the total cost of owning, operating, and maintaining a building or system over its useful life.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| Repair                            | Repair is the restoration of facilities or equipment to such a condition that it may be effectively utilized for its designated purposes by overhaul, reconstruction, or replacement of constituent parts or materials which have deteriorated by action of the elements or usage, and which have not been corrected through maintenance. This term also applies to replacement of the entire unit or system if beyond economical repair. The intent of repair is to have the equipment at normal working condition.                                                                                                               |

| <b>Definition/Acronym</b> | <b>Description</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
|---------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Replacement               | Replacement, as a distinct work element, is confined to a program of planned replacement of a facility or its components. It may be further limited to major components such as air conditioning compressors, furnaces or hot water heaters. Replacement is performed when the equipment has reached the end of its useful life; when it no longer can perform due to degradation of its internal components and repair is no longer cost effective. Included under the replacement would be the major rebuilding of any component, since rebuilding also restores performance. |
| Restoration               | Restoration of real property to such a condition that it can be used for its intended purpose. Includes repair or replacement work to restore facilities damaged by inadequate sustainment, excessive age, natural disaster, fire, accident or other causes.                                                                                                                                                                                                                                                                                                                    |
| Sustainment               | Maintenance and repair activities necessary to keep a typical inventory of facilities in “normal working condition”. Sustainment includes regularly scheduled maintenance as well as cyclical major repairs or replacement of components that occur periodically over the expected service life of the facilities.                                                                                                                                                                                                                                                              |
| SCADA                     | A version of telemetry commonly used in wide-area industrial applications, such as electrical power generation and distribution and water distribution, which includes supervisory control of remote stations as well as data acquisition from those stations over a bidirectional communications link.                                                                                                                                                                                                                                                                         |
| ANSI                      | American National Standards Institute                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| ASHRAE                    | American Society of Heating, Refrigerating and Air-Conditioning Engineers                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| ASME                      | American Society of Mechanical Engineers                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| MACP                      | Manhole Assessment and Certification Program                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
| MBR                       | Membrane Bioreactor                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |
| NASSCO                    | National Association of Sewer Service Companies                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| NPDES                     | National Pollutant Discharge Elimination System                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| PACP                      | Pipeline Assessment and Certification Program                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| SCADA                     | Supervisory Control and Data Acquisition                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| SRM                       | Sustainment, Restoration and Modernization                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
| UFC                       | Unified Facilities Criteria                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| WEF                       | Water Environmental Federation                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |

ATTACHMENT J-1604000-02  
REFERENCES AND TECHNICAL DOCUMENTS

| Reference                                                 | Title                                                                           |
|-----------------------------------------------------------|---------------------------------------------------------------------------------|
| EI 11C201                                                 | Wastewater Collection and Pumping                                               |
| MO-209                                                    | Engineering Criteria                                                            |
| MIL-HDBK-1005/9                                           | Industrial and Oily Wastewater Control                                          |
| NAVFAC P-603                                              | Utilities Infrastructure Management Manual                                      |
| OEBGD                                                     | Overseas Environmental Baseline Guidance Document                               |
| UFC 3-240-02N                                             | Wastewater Treatment Systems                                                    |
| UFC 3-240-04A                                             | Wastewater Collection                                                           |
| UFC 3-240-07FA                                            | Sanitary and Industrial Wastewater Collection: Gravity Sewers and Appurtenances |
| UFC 3-240-09FA                                            | Domestic Wastewater Treatment                                                   |
| UFC 3-240-13FN                                            | Industrial Water Treatment Operation and Maintenance                            |
| UFC 4-832-01N                                             | Design: Industrial and Oily Wastewater Control                                  |
| <b>Non-Government Publications</b>                        |                                                                                 |
| National Association of Sewer Service Companies, (NASSCO) |                                                                                 |
| 11521 Cronridge Drive, Suite J, Owings, MD 21117          |                                                                                 |
|                                                           |                                                                                 |
| American National Standards Institute, Inc. (ANSI)        |                                                                                 |
| 11 West 42nd Street, New York, NY 10036                   |                                                                                 |

**WASTEWATER TREATMENT PLANT AND COLLECTION SYSTEM DESCRIPTION****Collection System Description:**

NAVFAC's Sanitary Sewer system collect wastewater from buildings either to a centralized treatment plant on site or at a municipal treatment facility. The system contains laterals that connect buildings to a main sewer pipeline. The sewer system is a conveying system that includes pump stations, force mains, manholes, storage facilities and other components. Most systems are designed to take advantage of gravity flow; however, in areas lacking adequate depths, pump or lift stations move wastewater into a new pipe section (force main) to continue the transfer. The collection piping systems may include combinations of differing materials and sizes.

**Wastewater Treatment Plant Description:**

A facility where the wastewater is treated to remove as much pollution in order to comply with the FGS regulation.

NAS Sigonella wastewater treatment plant is composed as follows:

- Pre-treatment
- Equalization
- Biological plant + MBR plant
- Disinfection

The wastewater produced by the activities carried out within the base is pre-treated with the removal of big and fine solids by means of existing pre-treatment. The wastewater are collected into equalization tank and mixed by two submersible mixers. From the equalization basin, three submersible pumps transfer the mixed wastewater to the biological treatment. The biological process takes place in the bioreactor tank and into membrane tank for the degradation of pollutants. The treated effluent is finally disinfected and discharged.

**Wastewater Treatment Plant And Collection System Inventory and Minimum Frequencies of Services**

| NAS I - Lift Stations Inventory |          |                              |      |                              |                   |                                                                            |                    |                                    |
|---------------------------------|----------|------------------------------|------|------------------------------|-------------------|----------------------------------------------------------------------------|--------------------|------------------------------------|
| Site                            | Bldg No. | Facility Description         | Mfr  | Model No.                    | Level Sensor      | Remarks                                                                    | Cleaning Frequency | Level Sensor Calibration Frequency |
| NAS I                           | 231      | WWTP Lift Station Tripolare  | DAB  | VS 1000T-NA                  | Float switch      | 2 pumps; 1 electrical panel; 1 level sensor                                | Not required       | 1 per year                         |
| NAS I                           | 157      | Lift Station (Ex Galley)     | Wilo | Rexa UNIV06/T 15-540         | Wilo-Control EC-L | 2 pumps; 2 check valves; 2 gate valves; 1 electrical panel; 1 level sensor | Not required       |                                    |
| NAS I                           | 234      | Sewage Lift Station Near CDC | KSB  | Amarex N F65-170/042 ULG-152 | AquaRanger 5L     | 2 pumps; 2 check valves; 2 gate valves; 1 electrical panel; 1 level sensor | 2 per year         |                                    |

**NAS I - Lift Stations Inventory**

| Site  | Bldg No. | Facility Description     | Mfr   | Model No.   | Level Sensor  | Remarks                                                                    | Cleaning Frequency | Level Sensor Calibration Frequency |
|-------|----------|--------------------------|-------|-------------|---------------|----------------------------------------------------------------------------|--------------------|------------------------------------|
| NAS I | 229      | WWTP Lift Station Office | Flygt | NP 3085.160 | AquaRanger 5L | 2 pumps; 2 check valves; 2 gate valves; 1 electrical panel; 1 level sensor | 1 per year         |                                    |

**NAS I - WWTP inventory**

| Site  | Bldg No. | Facility Description | Mfr    | Model No.                   | Remarks                                                                   | Cleaning Frequency            |
|-------|----------|----------------------|--------|-----------------------------|---------------------------------------------------------------------------|-------------------------------|
| NAS I | 229      | Pre-treatment        | NA     | NA                          | Inlet channel cleaning and sludge disposal + 3 Bins solid sludge disposal | 1 per year                    |
| NAS I | 229      | EQ pit pumps         | Flygt  | NP 3085.160                 | 3 pumps; 1 electrical panel; 1 sensor level                               | 1 per year                    |
| NAS I | 229      | Equalization Tank    | Flygt  | SR 4640                     | tank with 2 mixers; 1 electrical panel                                    | 1 per year                    |
| NAS I | 229      | MBR Tank             | NA     | NA                          | tank                                                                      | 1 per year                    |
| NAS I | 229      | MBR                  | Sulzer | XFP100C-CB1.4-PE22/4-D14*10 | 2 pumps; 1 electrical panel                                               | NA                            |
| NAS I | 229      | MBR Tank             | Sulzer | XRW 3031 PA29/6-EC-10-BO    | 2 mixer; 1 electrical panel                                               | NA                            |
| NAS I | 229      | 4 Dry beds           | NA     | NA                          | NA                                                                        | 2 per year (per each dry bed) |

**NAS I - WWTP Tools Inventory**

| Site  | Bldg No. | Facility Description | Mfr            | Model No.                       | Asset                                                                  | Calibration Frequency |
|-------|----------|----------------------|----------------|---------------------------------|------------------------------------------------------------------------|-----------------------|
| NAS I | 229      | Influent channel     | Endress+Hauser | Prosonic S FDU91                | 1 flow meter                                                           | 1 per year            |
| NAS I | 229      | Equalization Tank    | Siemens        | Sitrans LUT420                  | 1 level transmitter                                                    |                       |
| NAS I | 229      | MBR Tank             | Endress+Hauser | controller probes CM444-13R1/0  | 1 pH sensor; 1 suspended solid sensor; 1 oxygen sensor; 1 Redox sensor |                       |
|       |          |                      |                | 2 controllers level transmitter | 1 level transmitter MBR tank ; 1 level                                 |                       |

| NAS I - WWTP Tools Inventory |          |                      |                |                            |                                                                                 |                       |
|------------------------------|----------|----------------------|----------------|----------------------------|---------------------------------------------------------------------------------|-----------------------|
| Site                         | Bldg No. | Facility Description | Mfr            | Model No.                  | Asset                                                                           | Calibration Frequency |
| NAS I                        | 229      | Effluent Channel     |                | RIA46-13L9/0               | transmitter permeate tank                                                       |                       |
|                              |          |                      |                | PMC51-JT20/295             | 2 pressure meter blower; 1 pressure meter permeate pump                         |                       |
|                              |          |                      |                | 6BABL1-7J27/115            | 2 flow transmitters blower                                                      |                       |
|                              |          |                      |                | 10L1Z-16C0/101             | 1 flow meter permeate pump; 1 flow meter backwash pump                          |                       |
|                              |          |                      | Hach Lange     | SC200 Universal Controller | 1 pH sensor; 1 suspended solid sensor; 1 conductivity sensor; 1 Chlorine sensor |                       |
|                              |          |                      | Endress+Hauser | Prosonic S FDU91           | 1 flow meter                                                                    |                       |

| NAS II - Lift Stations Inventory |          |                      |            |                      |                    |                                                            |                                 |                                    |
|----------------------------------|----------|----------------------|------------|----------------------|--------------------|------------------------------------------------------------|---------------------------------|------------------------------------|
| Site                             | Bldg No. | Facility Description | Mfr Pumps  | Model Pumps          | Level Sensor       | Remarks                                                    | Cleaning Frequency Lift Station | Level Sensor Calibration Frequency |
| NAS II                           | 402.1    | WWTP Lift Station    | Flygt      | NP 3085.160          | 4 Float switches   | 3 pumps; 3 check valves; 3 gate valves                     | 3 per year                      | 1 per year                         |
| NAS II                           | 431      | PWD Lift Station     | Flygt      | NP 3069              | AquaRanger 3       | 2 pumps; 2 check valves; 2 gate valves; 1 electrical panel | 2 per year                      |                                    |
| NAS II                           | 565      | Subway Lift Station  | KBS        | AMAREX N F80-220/034 | Ultra Ranger MUR 1 | 2 pumps; 2 check valves; 2 gate valves; 1 electrical panel | 2 per year                      |                                    |
| NAS II                           | 820      | Weapons Lift Station | Faggiolati | G409J6V1-M64AA0      | AquaRanger 5       | 2 pumps; 2 check valves; 2 gate valves; 1 electrical panel | NA                              |                                    |
| NAS II                           | 1023     | Hazmat Lift Station  | Lowara     | 1320H-80x.253.V92    | AquaRanger 5       | 2 pumps; 2 check valves; 1 electrical panel                | NA                              |                                    |

| NAS II - WWTP Inventory |          |                      |       |           |                                                                           |                    |
|-------------------------|----------|----------------------|-------|-----------|---------------------------------------------------------------------------|--------------------|
| Site                    | Bldg No. | Facility Description | Mfr   | Model No. | Remarks                                                                   | Cleaning Frequency |
| NAS I                   | 402      | Pre-treatment        | NA    | NA        | Inlet channel cleaning and sludge disposal + 5 Bins solid sludge disposal | 1 per year         |
| NAS II                  | 402      | EQ pit pumps         | Flygt | CP3085MT  | 3 pumps; 3 check valves; 3 gate valves                                    | 1 per year         |

| NAS II - WWTP Inventory |          |                      |           |                             |                                                |                    |
|-------------------------|----------|----------------------|-----------|-----------------------------|------------------------------------------------|--------------------|
| Site                    | Bldg No. | Facility Description | Mfr       | Model No.                   | Remarks                                        | Cleaning Frequency |
| NAS II                  | 402      | Equalization Basin   | Flygt     | SR-4640                     | tank with 2 mixers                             | 1 per year         |
| NAS II                  | 402      | AST Tank             | Flygt     | NP 3085.160                 | 1 sludge recycle pump                          | NA                 |
| NAS II                  | 402      | AST Tank             | Flygt     | SR-4640                     | 2 mixers                                       | NA                 |
| NAS II                  | 402      | MBR Tank             | NA        | NA                          | Tank                                           | 1 per year         |
| NAS II                  | 402      | MBR Tank             | Sulzer    | XFP100C-CB1.4-PE22/4-D14*10 | 2 pumps; 1 electrical panel                    | NA                 |
| NAS II                  | 402      | MBR Tank             | Sulzer    | XRW 3031 PA29/6-EC-10-BO    | 2 mixer; 1 electrical panel                    | NA                 |
| NAS II                  | 402      | UV System            | Prominent | 2 Dulcodes 4 x 350 LP       | 1 UV disinfection electrical panel, 8 UV lamps | NA                 |
| NAS II                  | 402      | 1 Dry beds           | NA        | NA                          | NA                                             | 3 per year         |

| NAS II - WWTP Tools Inventory |          |                      |                |                                                |                                                                        |                       |
|-------------------------------|----------|----------------------|----------------|------------------------------------------------|------------------------------------------------------------------------|-----------------------|
| Site                          | Bldg No. | Facility Description | Mfr            | Model No.                                      | Asset                                                                  | Calibration Frequency |
| NAS II                        | 402      | Influent channel     | Endress+Hauser | Prosonic flow 91                               | 1 flow meter                                                           | 1 per year            |
| NAS II                        | 402      | Equalization Tank    | Endress+Hauser | controllers level transmitter prosonic FMU 860 | 1 level transmitter                                                    |                       |
| NAS II                        | 402      | MBR Plant            | Endress+Hauser | controller probes CM444-13R1/0                 | 1 pH sensor; 1 suspended solid sensor; 1 oxygen sensor; 1 Redox sensor |                       |
|                               |          |                      |                | 2 controllers level transmitter RIA46-13L9/0   | 1 level transmitter MBR tank ; 1 level transmitter permeate tank       |                       |
|                               |          |                      |                | PMC51-JT20/295                                 | 2 pressure meter blower; 1 pressure meter permeate pump                |                       |
|                               |          |                      |                | 6BABL1-7J27/115                                | 2 flow transmitters blower                                             |                       |
|                               |          |                      |                | 10L1Z-16C0/101                                 | 1 flow meter permeate pump; 1 flow meter backwash pump                 |                       |
| NAS II                        | 402      | AST Tank             | Hach Lange     | SC1000 Universal Controller                    | 1 pH sensor; 1 oxygen sensor; 1 Redox sensor                           |                       |



| NAS II - WWTP Tools Inventory |          |                      |                |                            |                                                                                 |                       |
|-------------------------------|----------|----------------------|----------------|----------------------------|---------------------------------------------------------------------------------|-----------------------|
| Site                          | Bldg No. | Facility Description | Mfr            | Model No.                  | Asset                                                                           | Calibration Frequency |
| NAS II                        | 402      | Effluent Channel     | Hach Lange     | SC200 Universal Controller | 1 pH sensor; 1 suspended solid sensor; 1 conductivity sensor; 1 Chlorine sensor |                       |
|                               |          |                      | Endress+Hauser | Promag 400                 | 1 flow meter                                                                    |                       |

| NAS I - Irrigation Plant Inventory |          |                                     |                         |               |                         |
|------------------------------------|----------|-------------------------------------|-------------------------|---------------|-------------------------|
| Site                               | Bldg No. | Facility Description                | Asset Name / Mfr        | Remarks       | PM                      |
| NAS I                              | NA       | Irrigation tank (Behind WWTP NAS 1) | Tank / NA               | NA            | cleaning 1 per year     |
| NAS I                              | NA       |                                     | FM-1, FM-2 / Hach lange | 2 flow meters | calibration: 1 per year |

| NAS II - Irrigation Plant Inventory |          |                                        |                         |               |                         |
|-------------------------------------|----------|----------------------------------------|-------------------------|---------------|-------------------------|
| Site                                | Bldg No. | Facility Description                   | Asset Name / Mfr        | Remarks       | PM                      |
| NAS II                              | NA       | Irrigation tank (near to Building 442) | Tank / NA               | NA            | cleaning 1 per year     |
| NAS II                              | NA       |                                        | FM-1, FM-2 / Hach Lange | 2 flow meters | calibration: 1 per year |

| NAS 1 - Irrigation System Distribution Inventory |                                     |                                                                                                                                                                                                                                    |                                                                                                                                       |
|--------------------------------------------------|-------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------|
| Site                                             | Zone / Delivery Point               | Remarks / Service Point                                                                                                                                                                                                            | PM Frequency / Remarks                                                                                                                |
| NAS I                                            | N1C-102 / A4 - Sport field area CP4 | manholes including: valves, water meter, filter, programming irrigation controller, irrigation zone controller valves, type connection, piping, motorized valves, control wire to zone controller, and all component not specified | The Contractor shall operate and maintain irrigation systems to provide the appropriate amount of water to lawns and other vegetation |

| NAS II - Irrigation System Distribution Inventory |                                        |                |                                                                                                                                                                                                                                    |                                                                                                                                               |
|---------------------------------------------------|----------------------------------------|----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------|
| Site                                              | Zone / Description                     | Delivery Point | Remarks / Service point                                                                                                                                                                                                            | PM frequency / Remarks                                                                                                                        |
| NAS II                                            | N2C-104 / Gallery areas and Nassig/PWD | CP1            | manholes including: valves, water meter, filter, programming irrigation controller, irrigation zone controller valves, type connection, piping, motorized valves, control wire to zone controller, and all component not specified | Daily / The Contractor shall operate and maintain irrigation systems to provide the appropriate amount of water to lawns and other vegetation |
|                                                   | N2C-106 / Gallery areas and Nassig/PWD | CP5            |                                                                                                                                                                                                                                    |                                                                                                                                               |
|                                                   | N2C-101 / new Entry Control Point      | CP6            |                                                                                                                                                                                                                                    |                                                                                                                                               |

| NAS II - Irrigation System Distribution Inventory |                                   |                |                         |                        |
|---------------------------------------------------|-----------------------------------|----------------|-------------------------|------------------------|
| Site                                              | Zone / Description                | Delivery Point | Remarks / Service point | PM frequency / Remarks |
|                                                   | N2C-105 / New Entry Control Point | CP7            |                         |                        |
|                                                   | NA / New Entry Control Point      | CP8            |                         |                        |

ATTACHMENT J-1604000-04  
HISTORICAL CRITICAL SPARE PARTS INVENTORY

Historical critical spare parts inventory is included for reference only. The Contractor shall develop a separate critical spare parts inventory for submittal to the KO, per section F.

| Description                                 | Manufacturer | Part Number/Model             | Qty. |
|---------------------------------------------|--------------|-------------------------------|------|
| NAS II - WWTP Lift Station (B402)           | Flygt        | NP 3085                       | 1    |
| NAS II - PWD Lift Station (B431)            | Flygt        | NP 3069                       | 1    |
| NAS II - AST Tank, sludge pump (B402)       | Flygt        | NP 3085                       | 1    |
| NAS II - Subway Lift Station (B565)         | KBS          | AMAREX N F80-20/034           | 1    |
| AST Tank                                    | Flygt        | SR-4640                       | 1    |
| NAS I - Sewage Lift Station Near CDC (B234) | KSB          | Amarex N F65- 170/042 ULG-152 | 1    |