

Addendum 01 to

STATEMENT of WORK

For

VGLZ 242015

Repair HVAC B105

Selfridge Air National Guard Base, Michigan

By: Tom Resh

23 July 2025

STATEMENT OF WORK

For

Repair HVAC B105

Selfridge Air National Guard Base, Michigan

Updated Note 14 on the Tasks of the SOW as follows in RED

1. The tasks of this SOW are:

14. The contractor will install new isolation valves and unions at inlets/outlets of all pumps and boilers for ease of replacement. **The contractor will install new flanged stainless steel flex connectors for all pump connections on inlet and outlet sides.**

End of Addendum 01