

REQUEST FOR INFORMATION GOVERNMENT RESPONSE

Page	Section	Paragraph	Questions
			We were not able to see inside the trench at the site visit. Please provide quantities for bidding purposes. Cracks --- m Spalls --- m², or -- % of quantity in trench Government Response: Crack-Minimum 150LF, Spall-Minimum 90 SY
			Please consider extending the bid proposal date for us to submit an accurate estimate. — Government Response: Follow the 18CONS schedule.
			Is our understanding correct that the pit angles will be replaced, and the grating will be reused?- Government Response: Yes.
			Please provide the area/range for LBP removal. Government Response: Drain pit border marking.
			Please provide details of duct cleaning. Government Response: Cleanings means cleaning up, to remove dirt and debris.
			Is it safe to assume that it will be completely unoccupied during construction? Government Response: Yes, the hangar would not be able to be occupied by aircraft during the repair of the floor. Ideally, the building occupants would still use the office space if that's possible.
			Is it permitted to use high-pressure water at the site? Government Response: Yes, the high-pressure water can be used for cleaning etc.

			Are we required to paint the grating? Government Response: Yes, the grating requires the paint.
			For the drainage system, what type of chemical agents are typically discharged? Government Response: Typically jet fuel (JP-8). It's also possible for hydraulic oil to be discharged in small quantities from aircraft or support equipment.
			when we should anticipate the release of the Past Performance Fact Sheet Attachment 9 and Past Performance Questionnaires (PPQs) Attachment 10 that are required to respond to this solicitation Please check SAM for these attachment, let us know if you're not able to pull we will send via email
			In accordance with Section L, proposals are to be submitted through PIEE, however, Offerors are unable to do so because the solicitation is now closed in PIEE. Will the solicitation be reopened in PIEE for Offerors to submit their proposals? Section L will be updated to state proposal shall be submitted via email to both POCs (via Solicitation Amend03): POC 1: SrA Rubino, Emily @ emily.rubino@us.af.mil POC 2: Rosita Crawford @ rosita.crawford@us.af.mil We will extend Solicitation due date thru 27 June 2025 1630 JST.